

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONTINO BLOCK: 1

01 CITMNS 27 00-00000-0000 3411114

CONT REPORT SOURCE L 60 5 0 0 0 3 3 5 71 1 0 6 7 8 81 2 0 6 7 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
 (02) CEA No. 63 in regulating group No. 3 reed switch position indicator channel was
 (03) declared inoperable due to erratic indication. In accordance with Technical Specifici-
 (04) cation Section 3.1.3.3, action statement C.1, the position of CEA No. 63 was verified
 (05) by its full out limit switch once per 8 hours. There are no probable consequences
 (06) of this event as the plant was operated in accordance with Technical Specifications
 (07) Section 3.1.3.3.

09 SYSTEM CODE I F (11) CAUSE CODE E (17) CAUSE SUBCODE A (13) COMPONENT CODE INSTR U (14) COMP. SUBCODE E (15) VALVE SUBCODE (16)

(12) LEAD REPORT NUMBER 17 8 EVENT YEAR 7 8 SEQUENTIAL REPORT NO. J 3 0 OCCURRENCE CODE 0 3 REPORT TYPE L (15) REVISION NO. 0

ACTION TAKEN A (18) A (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS 0 0 0 0 ATTACHMENT SUBMITTED N (23) NRC FORM SUP. Y (24) PRIME COMP. SUPPLIER N (25) COMPONENT MANUFACTURER E 1 4 6 (47)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
 (12) An intermittent open in the reed switch assembly power supply lead produced the
 (11) erratic indication. A temporary indicating system was installed, restoring position
 (13) indication. At the next cold shutdown the reed switch assembly will be repaired and
 (14) position indication restored to normal.

15 FACILITY STATUS E (28) % POWER 1 0 0 (29) OTHER STATUS NA (30) METHOD OF DISCOVERY A (31) DISCOVERY DESCRIPTION: Operator observation (32)

16 ACTIVITY CONTENT Z (33) Z (34) AMOUNT OF ACTIVITY NA (35) LOCATION OF RELEASE NA (36)

17 PERSONNEL EXPOSURES NUMBER 0 (37) TYPE Z (38) DESCRIPTION NA (39)

18 PERSONNEL INJURIES NUMBER 0 (40) DESCRIPTION NA (41)

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) DESCRIPTION NA (43)

20 PUBLICITY DESCRIPTION NA (45)

21 PRIORITY DESCRIPTION NA (46)

781220113 NAME OF PREPARER R. W. Bates PHONE 203-447-1791