

Central Files

DEC 4 1978

DISTRIBUTION:  
 OLB Reading File ~~XXXXXX~~  
 OLB Facility File VBenaroya  
 PDR  
 Central Files ✓  
 PFCollins  
 BABoger  
 DRoss  
 JJBuzy  
 EBrooks

Docket Nos. 50-369  
and 50-370

MEMORANDUM FOR: Robert L. Baer, Chief, Light Water Reactors Branch No. 2,  
DPM

FROM: Paul F. Collins, Chief, Operator Licensing Branch, DPM

SUBJECT: REVIEW OF CONDUCT OF OPERATIONS, SECTIONS 13.2 and 13.5

Plant Name: McGuire Units 1 and 2  
 Licensing Stage: OL Complete, SER Supplement  
 Branch and Project Manager  
 Requesting Assistance: LWR No. 2, R. A. Birkel  
 Review Branch Involved: PM:OLB

We have completed our review of Sections 13.2 and 13.5 of the FSAR. Additional information on fire protection training was provided in Revision 31 to the FSAR. Based on our review, summarized in the attachment, we have concluded that the information submitted meets the requirements for approval.

Paul F. Collins, Chief  
 Operator Licensing Branch  
 Division of Project Management

Enclosure:  
 Supplement to Safety Evaluation  
 Report

cc: D. J. Skovholt  
 W. P. Haass  
 D. B. Vassallo  
 R. A. Birkel  
 N. Haller

7812130089 F

|          |              |           |  |  |  |
|----------|--------------|-----------|--|--|--|
| OFFICE   | PM:OLB       | PM:OLB    |  |  |  |
| SURNAMES | BABoger: jll | PFCollins |  |  |  |
| DATE     | 11/29/78     | 12/11/78  |  |  |  |

Supplement to the Safety Evaluation Report  
McGuire Nuclear Station, Units 1 & 2  
Operator Licensing Branch

13.2  
and  
13.5

Subsequent to our review of the McGuire FSAR, requirements for fire protection training were issued. We have reviewed the latest revisions to Sections 13.2 and 13.5 of the FSAR and conclude the following:

Plans for fire protection training and retraining of the fire protection staff, the fire brigade personnel and other staff personnel and plans for periodic drills provide reasonable assurance that the plant staff will be adequately trained to cope with fire related emergencies. Construction workers and temporarily assigned personnel will be sufficiently indoctrinated so that they will contribute to the overall fire protection program.