

**STEAM GENERATOR
PROGRESS REPORT
REVISION 9**

EPRI

August 1993

Prepared by

*Energy Management Services, Inc.
Little Rock, Arkansas*

Steam Generator Strategic Management Project

STEAM GENERATOR
PROGRESS REPORT
REVISION 9

Research Project S 405-3
August, 1993

Prepared by

ENERGY MANAGEMENT SERVICES, INC.
P. O. Box 5493 Little Rock, Arkansas 72215

Principal Investigator
B. L. Dow, Jr.

Prepared for

Electric Power Research Institute
3412 Hillview Avenue Palo Alto, California 94304

EPRI Project Manager
Chuck Welty

NOTICE

This report was prepared by the organization named below as an account of work sponsored by the Electric Power Research Institute, Inc. (EPRI). Neither EPRI, members of EPRI, the organization named below, nor any person acting on their behalf: (a) makes any warranty, express or implied, with respect to the use of any information, apparatus, method, or process disclosed in this report or that such use may not infringe privately owned rights; or (b) assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

Prepared by:
Energy Management Services, Inc.
Little Rock, Arkansas

ABSTRACT

The status of steam generator problems is presented through December 1992. Older problems such as wastage and denting are reasonably under control. Newer problems include SCC/IGA in tubesheet crevices, at the tube support plates, and under tubescale in the freespan region. Additional damage mechanisms include primary side cracking in high stress regions, pitting and tube fretting. Lost generation due to steam generator outages is presented along with steam generator problems reported at operating plants, the number of steam generator tubes plugged and sleeved, the number of forced outages caused by tube leaks, and the plants which have replaced steam generators.

ACKNOWLEDGEMENTS

Grateful appreciation is extended to the many utility organizations, vendors and individuals who supplied data used in this report.

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1.0 Introduction	1 - 1
2.0 Current Status	2 - 1
3.0 Lost Generation	3 - 1
4.0 Forced Outages	4 - 1
5.0 Plants Reporting Problems	5 - 1
6.0 Tube Fretting and Wear	6 - 1
7.0 Steam Generator Tube Sleeving	7 - 1
8.0 Steam Generator Replacement	8 - 1
Appendix	
A Historical Tube Plugging Data	

LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
1	World Wide Percentage of Plants Plugging Steam Generator Tubes	2 - 5
2	World Wide Percentage of Steam Generator Tubes Plugged	2 - 6
3	World Wide Number of Steam Generator Tubes Plugged	2 - 7
4	World Wide Causes of Steam Generator Tube Plugging	2 - 8
5	U.S. Capacity Factor Loss Due to Steam Generator Problems	3 - 3
6	U. S. PWR Capacity Factor Components (1980-84)	3 - 4
7	U. S. PWR Capacity Factor Components (1992)	3 - 5
8	U. S. Steam Generator Tube Leak Forced Outages	4 - 3
9	U. S. Steam Generator Tube Leak Forced Outage Rate	4 - 4

LIST OF TABLES

<u>Table</u>	<u>Page</u>
1 Steam Generator Program Goals	3 - 6
2 U. S. Tube Leak Forced Outages (1992)	4 - 2
3 Status of Units Reporting Problems (Dec. 1992)	5 - 2
4 Units Reporting Steam Generator Problems	5 - 10
5 Status of U. S. Steam Generators (Dec. 1992)	5 - 11
6 Tube Fretting and Wear	6 - 2
7 Sleeving Experience	7 - 2
8 Major Sleeving Operations	7 - 7
9 Replacement Steam Generators	8 - 3
10 Planned Steam Generator Replacements (Orders Placed)	8 - 4

Section 1

INTRODUCTION

This report is intended to provide EPRI members with the status of operating PWR steam generators. Considerable progress has been made since the formation of the EPRI Steam Generator Owners Group (SGOG I) in early 1977. At that time the industry was beginning to recover from wide scale steam generator tube wastage but was plagued by even wider scale tube denting. In addition to denting, stress corrosion cracking and apparent fatigue cracking were reported at a number of operating units. By the end of the SGOG I effort in December 1982, the causes and remedies for denting were much better understood and the occurrences of denting had dramatically decreased.

As these older problems were brought under control, newer problems were emerging. These problems included tube cracking and intergranular attack in the open tube sheet crevices, primary side tube cracking at high stress locations, pitting between the tube sheet and first support plate, and tube fretting in preheater sections and at antivibration bar locations. SGOG II followed SGOG I and focused on these newer problem areas.

Together utility members in SGOG I and SGOG II pledged more than 65 million dollars to help understand and resolve steam generator problems. The SGOG II project formally ended December 30, 1986. The work started by SGOG I and SGOG II has been continued in the EPRI base program. A five year Steam Generator Reliability Project (SGRP) began January 1, 1987 and was extended through December 1992. EPRI steam generator activities are now managed by the Steam Generator Strategic Management Project. Steam generator performance goals will be set and monitored to ensure that the Steam Generator Strategic Management Project addresses the most significant problems facing nuclear utilities. Although significant progress has been made in resolving steam generator problems, considerable work still remains. Steam generator forced outages and tube degradation are still occurring. This report is an updated status of the progress that has been made through December 31, 1992. It is intended that this report be updated annually through the duration of the Steam Generator Strategic Management Project.

A report such as this is only as good as the data from which it is generated. Data for 1992 was collected directly from U.S. and foreign utilities. Individual data sheets for each plant were sent to the Technical Advisory Group members for confirmation. It is hoped that this process will provide the most accurate data possible. If you have any corrections or suggestions, please send them to the author at the address listed on the front cover. This report contains the best available data at the time of printing and includes information from the EPRI Steam Generator Data Base, the Atomic Energy of Canada Limited, the Nuclear Regulatory Commission and individual utilities. Data trending is used to illustrate the progress that has been made and the problems that still exist. Appendix A provides a history of tube plugging and sleeving at each plant.

Section 2 CURRENT STATUS

The Atomic Energy of Canada Limited (AECL) has been keeping track of the causes of tube plugging since 1971 (References 1 and 2). Much of the early information presented in this section is from data collected by AECL. The data for 1992 was collected directly from the U.S. and foreign utilities whose plants are listed.

Figure 1 shows the percentage of reactors in the surveys which plugged tubes from 1976 through 1992. During the last 10 years the average percentage of reactors plugging steam generator tubes has been 45%. Figure 1 shows that this trend has not changed significantly. In 1992, 50% of the operating units were required to plug steam generator tubes.

Figure 2 shows the tubes plugged per year as a percentage of the total number of steam generator tubes in service. The number of tubes in service has risen from less than 200,000 in 1971 to more than 3.0 million in 1992. The percentage of tubes plugged per year over the last ten years has averaged .23 percent. This trend has decreased from an average of .39% for 1971 through 1979, to .23% for 1983 through 1992. Steam generator degradation is still widely occurring, however, and utilities are required to take expensive remedial action. Although the ten year average of .23 percent may not appear significant, over a 30 or 40 year steam generator life this amounts to plugging 6.9% to 9.2% of the available tubes. Even though this average value might be acceptable, not all steam generators are degrading equally. Extensive plugging efforts over the last few years have occurred at the following units:

- o 661 tubes in 1985 at Ohi 1 due to SCC/IGA
- o 330 tubes in 1985 at San Onofre 2 due to potential AVB fretting and other causes
- o 353 tubes in 1987 at Connecticut Yankee due to pitting and to ID SCC at the roll transition region
- o 559 tubes in 1987 at North Anna due to secondary side IGA and primary side SCC

- o 401 tubes in 1988 at Millstone 2 due to pitting and secondary side IGA
- o 336 tubes in 1988 at Salem 2 due to primary side SCC
- o 556 tubes in 1988 at V. C. Summer due to primary side SCC
- o 518 tubes in 1988 at Ringhals 2 due to secondary side IGA and other causes
- o 649 tubes in 1989 at Millstone 2 due to pitting and secondary side IGA
- o 386 tubes in 1989 at Palisades due to secondary side IGA and other causes
- o 363 tubes in 1989 at Salem 1 due to primary side cracking at the U bends
- o 327 tubes in 1989 at Ohi 1 due to secondary side IGA and primary side cracking in the roll transition region
- o 548 tubes in 1990 at Farley 2 due to primary side SCC and secondary side IGA
- o 617 tubes preventively plugged in 1990 at Palisades due to AVB fretting concerns
- o 624 tubes in 1990 at ASCO 1 due to primary side SCC and secondary side IGA
- o 468 tubes in 1991 at St. Lucie 1 due to secondary side SCC/IGA
- o 1580 tubes in 1991 at Trojan due to secondary side SCC/IGA
- o 600 tubes in 1991 at North Anna 1 due to secondary side IGA and primary side SCC
- o 760 tubes in 1991 at Beaver Valley 1 due to secondary side SCC/IGA

- o 331 tubes in 1991 at Bugey 5 due to primary side SCC
- o 400 tubes in 1991 at Angra 1 due to secondary side SCC/IGA
- o 306 tubes in 1992 at ANO-1 due to secondary side SCC/IGA
- o 354 tubes in 1992 at D.C. Cook 1 due to secondary side SCC/IGA
- o 527 tubes in 1992 at North Anna 2 due to secondary side SCC/IGA
- o 612 tubes in 1992 at Oconee 1 due to secondary side erosion/corrosion
- o 353 tubes in 1992 at ASCO 1 due to secondary side SCC/IGA

Degradation rates at these units are higher than the average rate. Tube degradation has already caused the steam generators to be replaced at thirteen nuclear units.

Figure 3 shows the total number of tubes plugged per year. In 1985 over 6000 tubes were plugged. This was due in part to the 1880 tubes plugged in French steam generators due to actual or anticipated SCC in the U-bend region and 1081 tubes plugged in U. S. steam generators due to actual or anticipated AVB wear. In 1986 a total of 3669 tubes were plugged. This reduction was due in part to less preventive plugging and an increase in the number of tubes sleeved. In 1987 a total of 4822 tubes were plugged. This increase from 1986 was due in part to fewer tubes being sleeved and an increase in primary side SCC and secondary side IGA at a number of U. S. plants. In 1988 a total of 6309 tubes were plugged. This increase from 1987 was due in part to a larger number of tubes plugged in the U.S. and Spain due to primary side stress corrosion cracking and a larger number of tubes plugged in Sweden and Japan due to secondary side IGA. In 1989 a total of 6106 tubes were plugged. Compared to 1988, the number of tubes plugged due to I.D. SCC decreased slightly while the number of tubes plugged due to O.D. SCC/IGA increased slightly. In addition, almost seven hundred tubes

were plugged in the French 1300 MW units due to denting caused by debris located on top of the tubesheet. In 1990, 7412 tubes were plugged. Compared to 1989, the number of plants plugging tubes increased, and the number of tubes plugged due to primary side SCC and fretting increased. In 1991, 9550 tubes were plugged. A small part of this increase was due to adding the PWR units from Germany and Korea to the report. Looking at the same units for each year, approximately 30% more tubes were plugged in 1991 compared to 1990. The largest increases in plugged tubes were due to secondary side SCC/IGA, especially at support plate intersections. In 1992 a total of 7860 tubes were plugged. This is approximately 20% fewer than were plugged in 1991. The reduction in tube plugging was almost equally divided between U.S. and non-U.S. plants.

Figure 4 shows the causes of steam generator plugging on a world wide basis from 1973 to 1992. When the SGOG I was formed in early 1977, denting was responsible for almost 90% of the tube plugging. By the end of SGOG I in 1982, this figure was less than 2%. During the existence of SGOG II, SCC/IGA in the tubesheet, primary side SCC, pitting, and fretting surfaced as the primary causes of plugging. Although significant progress has been made with wastage and denting, the data in this section shows that the percentage of reactors plugging tubes and the percentage of tubes being plugged each year has remained relatively constant. In 1992 I.D. stress corrosion cracking (20.8%), O.D. stress corrosion cracking and intergranular attack (37.6%), and fretting (7.4%) accounted for over 65% of all the tubes plugged. Figures 4-1 and 4-2 show the causes of steam generator tube plugging separated into U.S. and non-U.S. plants. Pitting and fretting have been slightly more of a problem for U.S. plants while primary side stress corrosion cracking, SCC(ID), has been more of a problem for non-U.S. plants. The diversity of these damage mechanisms means that no one solution is likely to resolve all problems. The task of maintaining steam generator integrity continues to remain formidable and challenging. The Steam Generator Strategic Management Project will utilize the results of earlier programs to focus on the resolution of current damage mechanisms.

FIGURE 1

World Wide Percentage of Plants Plugging Steam Generator Tubes




FIGURE 2

World Wide Percentage of Steam Generator Tubes Plugged




FIGURE 2

World Wide Number of Steam Generator Tubes Plugged




Figure 4
World Wide Causes of Steam Generator Plugging




Figure 4-1

United States Causes of Steam Generator Plugging





Figure 4-2

Non-U.S. Causes of Steam Generator Plugging



Section 3 LOST GENERATION

One of the real incentives for improving steam generator integrity is the increased electrical generation due to improved capacity factors. In fact, over the last ten years, steam generator problems in the United States rank second behind refueling outages as the most significant contributor to lost generation.

During the last ten years, the capacity factor loss for U.S. PWR's due to steam generator problems has averaged 3.0%. In 1992 the capacity factor loss was 3.3% (see Figure 5). From 1980 to 1984 the average U.S. PWR capacity factor was 57.2%. During this time steam generator problems resulted in a reduction in the average U.S. PWR capacity factor of 5.7 percent. Of this amount, Figure 6 shows that 1.5 % was due to steam generator replacement and 4.2 % due to steam generator tube problems. Figure 7 shows the improvement in U.S. PWR capacity factors (73.9%) in 1992. Figure 7 also shows the reduction in lost generation (.6%) due to steam generator replacement and in lost generation (2.7%) due to steam generator tube problems.

Using the 1980 - 1984 average values for tube plugging, sleeving, radiation exposure, and lost generation due to steam generator outages and replacement, the EPRI Steam Generator Project Office initially established steam generator performance goals for the period 1986 through 1990 and then extended these goals through 1991. Revised performance goals are now being established. Table 1 shows that steam generator performance in 1992 relative to lost generation was ahead of previous target goals and resulted in a conservatively estimated savings of \$83 million. The number of tubes plugged and sleeved in 1992 exceeded (was worse than) previous target goals. As a result of this, the estimated radiation exposure also exceeded the target goal. The expenditures for these three items result in an estimated expenditure of an additional \$15 million. Combining the tube plugging and sleeving results with the improvements in electrical generation results in a savings of approximately \$68 million when compared with the average annual expenditures in the 1980 to 1984 time frame. These savings are conservatively estimated and indicate that utilities are making progress in managing steam generator degradation. However, a

number of utilities are planning steam generator replacements and this needs to be factored into new target goals.

FIGURE 5




FIGURE 6

U. S. PWR Capacity Factor Components (1980-1984)




FIGURE 7

U. S. PWR Capacity Factor Components (1992)




TABLE 1 STEAM GENERATOR PROGRAM GOALS

	U. S. YEARLY AVERAGES						SAVINGS	
	ACTUAL 1980-1984		TARGET 1986-1991		ACTUAL 1992		TARGET 1986-1991	ACTUAL 1992
	NO.	COST (MILLION \$)	NO.	COST (MILLION \$)	NO.	COST (MILLION \$)	SAVINGS (MILLION \$)	SAVINGS (MILLION \$)
LOST CAPACITY								
S/G REPLACEMENT	1.5%	\$51	.5%	\$17	.6%	\$20	\$34	\$31
FORCED & EXTENDED OUTAGES	4.2%	\$145	2.5%	\$86	2.7%	\$93	\$59	\$52
REPAIR & MAINTENANCE								
TUBE PLUGGING	2242	\$5	2000	\$4	4407	\$9	\$1	(\$4)
TUBE SLEEVING	3181	\$32	3000	\$30	4160	\$42	\$2	(\$10)
RAD. EXPOSURE	4670 mr	\$5	4000 mr	\$4	6000* mr	\$6	\$1	(\$1)

3-6

*Estimated

Section 4 FORCED OUTAGES

Another indication of the ability of utilities to successfully manage steam generator issues is the number of forced outages caused by steam generator tube leaks. Forced outages not only cause a loss of production, but are expensive because repair teams have to be mobilized on short notice. In 1992 there were four forced outages in the U.S. due to steam generator tube leaks (Table 2). This compares with an average of 10 forced outages per year from 1976 to 1992 (Figure 8). By dividing the number of forced outages per year by the number of operating PWR's, a tube leak forced outage rate can be determined. In 1992 the forced outage rate was .06 which means there was one tube leak outage for every seventeen generating PWR's. The average tube leak forced outage rate per year in the U.S. from 1976 to 1992 was .23 or one tube leak outage per year for every four operating PWR's (Figure 9). Although Figure 9 shows an improving trend, the long range goal of utilities is to have no forced outages due to steam generator tube leaks. The verdict is still out on whether or not this goal is achievable.

TABLE 2 U. S. TUBE LEAK FORCED OUTAGES (1992)

Plant	Date	Leak Rate	Outage Duration	Probable Cause
Mc Guire 1	1/92	250 gpd	34 days	Freespan crack
ANO 2	3/92	360 gpd	54 days	SCC(TS)
Prairie Island 1	3/92	144 gpd	12 days	Axial crack (roll transition region)
Trojan	11/92	200 gpd	indefinite	Circumferential fault at sleeve weld

FIGURE 8

U. S. Steam Generator Tube Leak Forced Outages





FIGURE 91

U. S. Steam Generator Tube Leak Forced Outage Rate



Section 5 PLANTS REPORTING PROBLEMS

EPRI has been tracking reported plant problems since early 1977. Table 3 shows the status of reported problems as of December 1992. Table 4 compares the 1992 results with those from 1977 and 1982. The largest increases in reported problems are I.D. initiated cracking, O.D. initiated SCC/IGA, and tube fretting. Over fifty percent of the operating units covered in this report indicate some occurrence of tube fretting and wear. The Steam Generator Strategic Management Project is focused on addressing these problems. Although the type of information provided in Tables 3 and 4 is useful for general trending of reported problems, the criteria for reporting is not always consistent and the data is difficult to verify. A more definitive method at looking at problem areas is to review the number of tubes plugged at each unit and the reported damage mechanism causing the tube to be removed from service. Appendix A provides this information on a yearly basis for each plant. A summary of the number of tubes plugged and sleeved at U.S. plants is provided in Table 5.

Table 3 Status of Units Reporting Problems (Dec. 1992)

Plant	Date	NSSS	Com'l	REPORTED PROBLEMS											
				Wastage	Denting Sup Plate	Denting Tubesheet	Pitting	SCC (OD)	SCC (ID)	IGA (OD)	IGA (ID)	Fretting	High Cy Fatigue	Erosion	Water- Hammer
Almaraz 1	Dec-81	W						O	O	O	O	O	O	O	
Almaraz 2	Sep-83	W						O	O	O	O	O	O	O	
Angra 1	Dec-84	W						O	O	O	O	O	O	O	
ANG 1	Dec-74	B						O	O	O	O	O	O	O	
ANO 2	Nov-80	B						O	O	O	O	O	O	O	
Asco 1	Dec-84	W						O	O	O	O	O	O	O	
Asco 2	Mar-86	W						O	O	O	O	O	O	O	
Atucha 1	Mar-74	KWU						O	O	O	O	O	O	O	
Beaver Valley 1	Oct-76	W						O	O	O	O	O	O	O	
Beaver Valley 2	Nov-87	W						O	O	O	O	O	O	O	
Belleville 2	Jan-89	F						O	O	O	O	O	O	O	
Belleville 1	Jur-88	F						O	O	O	O	O	O	O	
Biblis A	Aug-74	KWU						O	O	O	O	O	O	O	
Biblis B	Apr-76	KWU						O	O	O	O	O	O	O	
Blayais 1	Dec-81	F						O	O	O	O	O	O	O	
Blayais 2	Feb-83	F						O	O	O	O	O	O	O	
Blayais 3	Nov-83	F						O	O	O	O	O	O	O	
Blayais 4	Oct-83	F						O	O	O	O	O	O	O	
Borsigela	Jul-73	KWU						O	O	O	O	O	O	O	
Braidwood 1	Jul-88	W						O	O	O	O	O	O	O	
Braidwood 2	Oct-88	W						O	O	O	O	O	O	O	
Brokdorf	Oct-86	KWU						O	O	O	O	O	O	O	
Bugey 2	Feb-79	F						O	O	O	O	O	O	O	
Bugey 3	Feb-79	F						O	O	O	O	O	O	O	
Bugey 4	Jul-79	F						O	O	O	O	O	O	O	
Bugey 5	Jan-80	F						O	O	O	O	O	O	O	
Byron 1	Sep-85	W						O	O	O	O	O	O	O	
Byron 2	Aug-87	W						O	O	O	O	O	O	O	

Table 3 Status of Units Reporting Problems (Dec. 1992) cont.

5-3

Plant	Date Com'l	NSSS	REPORTED PROBLEMS												
			Wastage	Denting Sup Plate	Denting Tubesheet	Pitting	SCC (OD)	SCC (ID)	IGA (OD)	IGA (ID)	Fretting	High Cy Fatigue	Erosion	Water-hammer	Moisture Carryover
Callaway	Apr-85	W									0				
Calvert Cliffs 1	May-75	C		0					0		0		0	0	
Calvert Cliffs 2	Apr-77	C		0					0		0		0	0	
Catawba 1	Jun-85	W							0		0				
Catawba 2	Aug-86	W									0				
Cattenom 1	Apr-87	F													
Cattenom 2	Feb-88	F			0						0				
Cattenom 3	Jul-90	F			0										
Cattenom 4	May-91	F													
Chinon B1	Feb-84	F							0						
Chinon B2	Aug-84	F							0						0
Chinon B3	Mar-87	F													
Chinon B4	Apr-88	F													
Comanche Peak 1	Aug-90	W													
Conn. Yankee	Jan-68	W	0	0	0	0					0				
Cook 1	Aug-75	W	0	0	0	0	0	0	0	0	0		0		
Cook 2 (Org)	Jul-78	W	0		0		0	0	0	0	0		0		
Cook 2 (Rpl)	Mar-89	W													
Cruas 1	Apr-84	F			0			0							
Cruas 2	Apr-85	F						0			0				
Cruas 3	Sep-84	F													
Cruas 4	Feb-85	F													
Crystal River 3	Mar-77	B													
Dampierre 1 (Org)	Sep-80	F						0	0		0	0	0		
Dampierre 1 (Rpl)	Jun-90	F					0	0			0				
Dampierre 2	Feb-81	F					0	0			0				
Dampierre 3	May-81	F			0		0	0			0				
Dampierre 4	Nov-81	F			0		0	0			0				

Table 3 Status of Units Reporting Problems (Dec. 1992) cont.

Plant	Date Com'l	NSSS	REPORTED PROBLEMS												
			Wastage	Denting Sup Plate	Denting Tubesheet	Pitting	SCC (OD)	SCC (ID)	IGA (OD)	IGA (ID)	Fretting	High Cy Fatigue	Erosion	Water- hammer	Moisture Carryover
Davis Besse 1	Jul-78	B				O			O						
Diablo Canyon 1	May-85	W		O				O			O				
Diablo Canyon 2	Mar-86	W		O				O			O				
Doel 1	Feb-75	W		O	O		O	O	O		O				
Doel 2	Nov-75	W		O	O		O	O	O		O				
Doel 3	Oct-82	FC		O			O	O	O		O				
Doel 4	Jul-86	ACW				O	O	O			O				
Emsland	Apr-88	KWU	O												
Farley 1	Dec-77	W					O	O	O		O				
Farley 2	Jul-81	W					O	O	O		O				
Fessenheim 1	Jan-78	F					O	O	O		O				
Fessenheim 2	Apr-78	F					O	O	O	O	O				O
Flamanville 1	Dec-76	F													
Flamanville 2	Mar-87	F													
Ft. Calhoun	Sep-73	C		O	O		O				O				
Genkai 2	Mar-81	M													
Genkai 1	Oct-75	M							O						
Ginna	Jul-70	W	O				O	O	O		O				
Coesgen	Feb-79	KWU	O								O				
Grohnde	Aug-74	KWU									O				
Gol'ech 1	Jun-80	F													
Grafenrheinfeld	Dec-81	KWU													
Gravelines 1	Nov-86	F			O		O	O			O				
Gravelines 2	Dec-80	F			O		O	O			O				
Gravelines 3	Jun-81	F			O			O			O				
Gravelines 4	Oct-81	F			O			O			O				
Gravelines 5	Jan-85	F			O						O				
Gravelines 6	Nov-85	F									O				

Table 3 Status of Units Reporting Problems (Dec. 1992) cont.

Plant	Date Com'l	NSSS	REPORTED PROBLEMS											
			Wastage	Denting Sup Plate	Denting Tubesheet	Pitting	SCC (OD)	SCC (ID)	IGA (OD)	IGA (ID)	Fretting	High Cy Fatigue	Erosion	Water- hammer
Obringheim (Rpl)	Aug-83	KWU												
Oconee 1	Jul-73	B										o	o	
Oconee 2	Sep-74	B										o	o	
Oconee 3	Dec-74	B										o	o	
Ohi 1	Mar-79	W												
Ohi 2	Dec-79	M												
Ohi 3	Dec-91	M												
Palisades (Org)	Dec-71	C	o	o			o	o	o					o
Palisades (Rpl)	Mar-91	C												
Palo Verde 1	Jan-86	C										o		
Palo Verde 2	Sep-86	C										o		
Palo Verde 3	Jan-88	C												
Paluel 1	Dec-85	F				o						o		
Paluel 2	Dec-85	F				o						o		
Paluel 3	Feb 86	F				o						o		
Paluel 4	Jun-86	F				o						o		
Penly 1	Dec-90	F												
Penly 2	Feb-92	F												
Philipsburg 2	Dec-84	KWU												
Point Beach 1 (Org)	Dec-70	W	o	o			o	o	o	o				
Point Beach 1 (Rpl)	Apr-84	W												
Point Beach 2	Oct-72	W	o	o			o	o	o	o				
Prairie Island 1	Dec-73	W	o				o	o	o	o		o		
Prairie Island 2	Dec-74	W	o				o	o	o	o		o		
Rancho Seco	Apr-75	B					o	o	o	o		o		o
Ringhals 2 (Org)	May-75	W					o	o	o	o		o		o
Ringhals 2 (Rpl)	Aug-89	W					o	o	o	o				
Ringhals 3	Apr-81	W					o	o	o	o				o

Table 3 Status of Units Reporting Problems (Dec. 1992) cont.

Table 3 Status of Units Reporting Problems (Dec. 1992) cont.

Table 3 Status of Units Reporting Problems (Dec. 1992) cont.

TABLE 4 UNITS REPORTING STEAM GENERATOR PROBLEMS

<u>DATE</u>	3/77	8/82	12/92
NO. UNITS:	52	99	205
REPORTED PROBLEMS:			
Denting			
-Tube Support Corrosion	15	30	34
-Tube Sheet Corrosion	6	12	50
Tubing Corrosion			
-Wastage	19	28	39
-Pitting	0	3	14
-ID Cracking	1	22	90
-OD SCC/IGA	6	22	74
Mechanical Damage			
-Fretting	9	15	117
-Fatigue Cracking	3	4	10
-Impingement	0	2	9
No Problems	26	32	33
No problems after 5 years ops (no. of units / no. > 5 yrs. ops) .	1/14	4/57	13/168
Units reporting no problems after five years of operation	Trino Neckarwestheim Davis Besse	Kewaunee Mihama 3 Cruas 3 Cruas 3 Cruas 4 Genkai 2 Grehnde Loviisa 1 Loviisa 2 Obrigheim Rep. Philippensburg 2 Robinson 2 Rep. Surry 2 Rep. Unterwesser	Brokdorf Chinon B3 Cruas 3 Cruas 4 Genkai 2 Grehnde Loviisa 1 Loviisa 2 Obrigheim Rep. Philippensburg 2 Robinson 2 Rep. Surry 2 Rep. Unterwesser

Table 5

Status of U.S. Steam Generators (Dec. 1992)

	COMM. OPS.	NO. OF LOOPS	SG MODEL	NO. OF TUBES PER S.G.	TUBE MATERIAL	NO. OF TUBES PLUGGED	NO. OF SLEEVES
BABCOCK & WILCOX							
Arkansas Nuclear One 1	Dec-74	2	OTSG	15531	Inc-600S	642	902
Crystal River 3	Mar-77	2	OTSG	15531	Inc-600S	162	0
Davis Besse	Jul-78	2	OTSG	15547	Inc-600S	74	0
Oconee 1	Jul-73	2	OTSG	15531	Inc-600S	1266	475
Oconee 2	Sep-74	2	OTSG	15531	Inc-600S	180	0
Oconee 3	Dec-74	2	OTSG	15531	Inc-600S	376	247
Rancho Seco	Apr-75	2	OTSG	15547	Inc-600TT	221	508
Three Mile Island 1	Sep-74	2	OTSG	15531	Inc-600S	1640	250
COMBUSTION ENG.							
Arkansas Nuclear One 2	Mar-80	2	2815	8411	Inc-600MA	367	444
Calvert Cliffs 1	May-75	2	67	8519	Inc-600MA	195	0
Calvert Cliffs 2	Apr-77	2	67	8519	Inc-600MA	113	0
Fort Calhoun	Sep-73	2	71	5005	Inc-600MA	109	0
Maine Yankee	Dec-72	3	67	5703	Inc-600MA	210	0
Millstone 2 (Repl.)	Dec-75	2	BWC	-	Inc-690TT	0	0
Palisades (Repl.)	Dec-71	2	N/A	8219	Inc-600MA	617	0
Palo Verde 1	Jan-86	2	80	11012	Inc-600MA	140	0
Palo Verde 2	Sep-86	2	80	11012	Inc-600MA	310	0
Palo Verde 3	Jan-88	2	80	11012	Inc-600MA	199	0
San Onofre 2	Aug-83	2	3410	9350	Inc-600MA	64	0
San Onofre 3	Apr-84	2	3410	9350	Inc-600MA	554	0
St. Lucie 1	Dec-76	2	67	8519	Inc-600MA	1688	0
St. Lucie 2	Aug-83	2	3410	8411	Inc-600MA	458	0
Waterford 3	Sep-85	2	3410	8485	Inc-600MA	518	0

Table 5

Status of U.S. Steam Generators (cont.)

	COMM. OPS.	NO. OF LOOPS	SG MODEL	NO. OF TUBES PER S.G.	TUBE MATERIAL	NO. OF TUBES PLUGGED	NO. OF SLEEVES
WESTINGHOUSE							
Beaver Valley 1	Oct-76	3	51	3388	Inc-600MA	1054	0
Beaver Valley 2	Nov-87	3	51M	3376	Inc-600MA	33	0
Braidwood 1	Jul-88	4	D4	4578	Inc-600MA	216	0
Braidwood 2	Oct-88	4	D5	4530	Inc-600TT	2	0
Byron 1	Sep-85	4	D4	4578	Inc-600MA	239	0
Byron 2	Aug-87	4	D5	4530	Inc-600TT	72	0
Callaway	Dec-84	4	F	5626	Inc-600MA	104	0
Catawba 1	Jun-85	4	D3	4674	Inc-600MA	740	183
Catawba 2	Aug-86	4	D5	4530	Inc-600TT	60	0
Comanche Peak 1	Aug-90	4	D4	4578	Inc-600MA	0	0
Connecticut Yankee	Jan-68	4	27	3794	Inc-600MA	1189	0
Cook 1	Aug-75	4	51	3388	Inc-600MA	952	1840
Cook 2 (Repl.)	Jul-78	4	54F	3592	Inc-690TT	0	0
Diablo Canyon 1	May-85	4	51	3388	Inc-600MA	40	0
Diablo Canyon 2	Mar-86	4	51	3388	Inc-600MA	15	0
Farley 1	Dec-77	3	51	3388	Inc-600MA	358	136
Farley 2	Jul-81	3	51	3388	Inc-600MA	817	29
Ginna	Jul-70	2	44	3260	Inc-600MA	504	1687
Indian Point 2	Aug-74	4	44	3262	Inc-600MA	1072	0
Indian Point 3 (Repl.)	Aug-76	4	44F	3214	Inc-690TT	0	0
Kewaunee	Jun-74	2	51	3388	Inc-600MA	496	4344
McGuire 1	Dec-81	4	D2	4674	Inc-600MA	1492	855
McGuire 2	Mar-84	4	D3	4674	Inc-600MA	1099	615
Millstone 3	Apr-86	4	F	5626	Inc-600TT	21	0
North Anna 1	Jun-78	3	51	3388	Inc-600MA	2065	0

Table 5

Status of U.S. Steam Generators (cont.)

	COMM. OPS.	NO. OF LOOPS	SG MODEL	NO. OF TUBES PER S.G.	TUBE MATERIAL	NO. OF TUBES PLUGGED	NO. OF SLEEVES
WESTINGHOUSE							
North Anna 2	Dec-80	3	51	3388	Inc-600MA	712	0
Point Beach 1 (Repl.)	Dec-70	2	44F	3260	Inc-600TT	5	0
Point Beach 2	Oct-72	2	44	3260	Inc-600MA	589	3597
Prairie Island 1	Dec-73	2	51	3388	Inc-600MA	194	319
Prairie Island 2	Dec-74	2	51	3388	Inc-600MA	237	0
Robinson 2 (Repl.)	Mar-71	3	44F	3214	Inc-600TT	3	0
Salem 1	Jun-77	4	51	3388	Inc-600MA	480	0
Salem 2	Jul-81	4	51	3388	Inc-600MA	440	0
San Onofre 1	Jan-68	3	27	3794	Inc-600MA	1456	6929
Seabrook	Jul-90	4	F	5626	Inc-600TT	13	0
Sequoyah 1	Jul-81	4	51	3388	Inc-600MA	144	0
Sequoyah 2	Jun-82	4	51	3388	Inc-600MA	434	0
Shearon Harris	May-87	3	D4	4578	Inc-600MA	32	0
South Texas 1	Aug-88	4	E	4850	Inc-600MA	15	0
South Texas 2	Jun-89	4	E	4850	Inc-600MA	15	0
Summer	Jan-84	3	D3	4674	Inc-600MA	1573	735
Surry 1 (Repl.)	Dec-72	3	51F	3342	Inc-600TT	14	0
Surry 2 (Repl.)	May-73	3	51F	3342	Inc-600TT	3	0
Trojan	May-76	4	51	3388	Inc-600MA	2442	1063
Turkey Point 3 (Repl.)	Dec-72	3	44F	3214	Inc-600TT	62	0
Turkey Point 4 (Repl.)	Sep-73	3	44F	3214	Inc-600TT	33	0
Vogtle 1	May-87	4	F	5626	Inc-600TT	11	0
Vogtle 2	May-89	4	F	5626	Inc-600TT	15	0
Wolf Creek	Sep-85	4	F	5626	Inc-600TT	39	0
Yankee Rowe	Jul-61	4	13	1620	304 SS	334	0

Table 5

Status of U.S. Steam Generators (cont.)

	COMM. OPS.	NO. OF LOOPS	SG MODEL	NO. OF TUBES PER S.G.	TUBE MATERIAL	NO. OF TUBES PLUGGED	NO. OF SLEEVES PLUGGED
WESTINGHOUSE							
Zion 1		Dec-73	4	51	3388	Inc-600MA	907
Zion 2		Sep-74	4	51	3388	Inc-600MA	525

Section 6 TUBE FRETTING AND WEAR

The Steam Generator Strategic Management Project has also been studying steam generator vibration induced tube wear. This wear is caused by relative movement between the tube and support structure and is enhanced by clearances provided for ease of manufacturing. Depending on the tube dynamics, tube leaks due to fretting and wear can be produced within a relatively short period of time. Fifty-seven percent of the nuclear units covered in this survey report some type of fretting and wear problem. In 1992, 579 steam generator tubes were plugged due to fretting and wear.

In order to better understand the magnitude and severity of this problem, additional information on the number of indications, general location and wear rate (mils/year) was requested from TAG members. Table 6 summarizes the information received. As expected, the majority of fretting and wear indications reported are in the preheater areas and at the AVE intersections. The reported wear rates ranged from .3 to 3.4 mils per year with a maximum wear rate reported by the Japanese of 12.1 mils per year. It is realized that Table 6 represents only a limited amount of industry data and it is hoped that additional information on the number of indications and wear rates can be obtained and reported in future publications.

TABLE 6 TUBE FRETTING AND WEAR

PLANT	GENERAL AREA	NO. OF INDICATIONS(1)	NO. OF TUBES PLUGGED(1)	WEAR RATE (mils/year)
Almaraz 1	Preheater (<1992)	180	25	0.6
	Preheater (1992)	228	16	1.1
	AVB (<1992)	278	12	1.5
	AVB (1992)	378	0	1.1
Almaraz 2	Preheater (<1992)	130	17	1.3
	Preheater (1992)	144	24	1.7
	AVB (<1992)	192	4	1.6
	AVB (1992)	205	2	0.5
ANO-2	Batwing	332	60	-
ASCO 1	Preheater (<1992)	79	4	2.8
	Preheater (1992)	105	6	2.2
	AVB (<1992)	221	13	2
	AVB (1992)	254	5	1.3
ASCO 2	AVB (<1992)	52	2	-
	AVB (1992)	67	0	0.6
Beaver Valley 1	AVB	10	10	-
	Cold Leg	88	0	<3.0
Beaver Valley 2	AVB	13	0	-
Connecticut Yankee	AVB	191	14	-
Diablo Canyon 1	AVB	54	0	-
Diablo Canyon 2	AVB	28	0	-
Jose Cabrera	AVB (<1992)	135	19	0.3
	AVB (1992)	147	2	0.5
Millstone 3	AVB	61	10	-
St. Lucie 2	Diagonal & Vertical Straps	478	347	-
Sequoayah 1	AVB	37	2	2.8

TABLE 6 TUBE FRETTING AND WEAR (cont.)

PLANT	GENERAL AREA	NO. OF INDICATIONS(1)	NO. OF TUBES PLUGGED(1)	WEAR RATE (mils/year)
Sequoyah 2	AVB	125	14	2.8
Turkey Point 3	AVB	95	10	<2.0
Turkey Point 4	AVB	2	0	<2.0
Vandellos 2	AVB (<1992) AVB (1992)	733 1529	172 30	2.5 3.4

Section 7

STEAM GENERATOR TUBE SLEEVING

Steam generator tube sleeving has been used as an effective alternative to plugging. Sleeving consists of installing a smaller diameter tube (sleeve) into a damaged tube. The sleeve ends are expanded and sealed to provide both a seal and redundant load carrying path. Although sleeving is generally more expensive than plugging, it has the advantage of leaving the tube in service and providing additional tube strength. Most sleeves to date have been installed in the tube sheet region. A few sleeves have been installed at other locations in the steam generator and have been used to improve structural support and provide vibration damping. Table 7 is a listing of the number of tubes sleeved at each plant. To date over 48,000 tubes have been sleeved. Table 8 (Reference 6) gives additional information on sleeving times and radiation exposure for selected sleeving campaigns. As more automated techniques have been developed, the installation time and exposure per sleeve have been dramatically reduced. Sleeving will undoubtedly play an increasing role in maintaining steam generator tube integrity. A number of utilities are using sleeving as a preventative measure to reduce the number of forced outages caused by steam generator tube leaks.

TABLE 7 SLEEVING EXPERIENCE

PLANT	YEAR	TUBES SLEEVED	REPORTED CAUSE
ALMARAZ 1	89	3	SCC(ID)
	90	100	SCC(ID)
ANO 1	84	10	SCC/IGA
	86	40	SCC/IGA
	88	174	SCC/IGA
	90	106	SCC/IGA
	92	572	SCC/IGA
ANO 2	92	444	SCC/IGA
ASCO 1	91	115	SCC/IGA
BEZNAU 1	81	3	SCC(OD)
	82	24	SCC(OD)
	83	37	SCC/IGA
	84	35	SCC/IGA
	86	174	SCC/IGA
BEZNAU 2	83	17	SCC/IGA
	84	17	SCC/IGA
	86	86	SCC/IGA
BUGEY 5	89	76	SCC(ID)
CATAWBA 1	91	75	SCC(ID), SCC/IGA
	92	108	SCC(ID), SCC/IGA
D.C. COOK 1	92	1840	SCC/IGA
DOEL 2	82-83	187	SCC(ID)
	85	10	SCC(ID)
	86	81	SCC(ID)
DOEL 3	88	55	SCC(ID)
FARLEY 1	92	136	SCC(ID), SCC(OD-TSP)

TABLE 7 (cont') SLEEVING EXPERIENCE

<u>PLANT</u>	<u>YEAR</u>	<u>TUBES SLEEVED</u>	<u>REPORTED CAUSE</u>
FARLEY 2	92	29	SCC(ID), SCC (OD-TSP)
FESSENHEIM 1	84	10	SCC(ID)
GENKAI 1	85	147	SCC/IGA
	86	342	SCC/IGA
	87	384	SCC/IGA
	89	870	SCC/IGA
	90	805	SCC/IGA
	91	447	SCC/IGA
GINNA	80	5	SCC/IGA
	81	16	SCC/IGA
	83	77	SCC/IGA
	84	8	SCC/IGA
	85	69	SCC/IGA
	86	39	SCC/IGA
	87	101	SCC/IGA
	89	502	SCC/IGA
	90	241	SCC/IGA
	91	207	SCC/IGA
	92	425	SCC/IGA
IKATA 1	84	14	SCC(ID)
INDIAN POINT 3	82	2971	PITTING
	85	635	PITTING
KEWAUNEE	88	1940	SCC/IGA
	89	1698	SCC/IGA
	91	690	SCC/IGA
	92	16	SCC/IGA
KORI 1	88	558	PITTING
	89	178	PITTING
	90	415	PITTING/SCC(ID)
	92	330	PITTING/SCC(ID)

TABLE 7 (cont') SLEEVING EXPERIENCE

<u>PLANT</u>	<u>YEAR</u>	<u>TUBES SLEEVED</u>	<u>REPORTED CAUSE</u>
MC GUIRE 1	90	397	SCC(ID)
	91	458	SCC(ID)
MC GUIRE 2	90	478	SCC(ID)
	92	137	SCC(ID)
MIHAMA 2	82	3	SCC(OD)
	83	14	SCC(OD)
	84	25	SCC(OD)
MILLSTONE 2	83	2022	PITTING
	85	2917	PITTING, WASTAGE
	86	225	PITTING, WASTAGE
OCONEE 1	78	6	FATIGUE
	87	469	FATIGUE
OCONEE 3	88	247	FATIGUE
OHI 1	84	81	SCC(ID)
	85	443	SCC(ID)
	86	650	SCC(ID)
	87	743	SCC(ID), SCC/IGA
	88	162	SCC(ID)
	89	1122	SCC(ID)
	90	863	SCC(ID)
	91	877	SCC(ID)
OHI 2	84	8	SCC(ID)
PALISADES	76	10	WASTAGE
	78	23	WASTAGE
POINT BEACH 1	81	13	SCC/IGA

TABLE 7 (cont') SLEEVING EXPERIENCE

<u>PLANT</u>	<u>YEAR</u>	<u>TUBES SLEEVED</u>	<u>REPORTED CAUSE</u>
POINT BEACH 2	83	3001	SCC/IGA, WASTAGE
	87	87	SCC/IGA, WASTAGE
	88	509	SCC/IGA, WASTAGE
PRAIRIE ISLD 1	87	26	SCC/IGA
	88	73	SCC/IGA
	90	62	SCC/IGA
	92	158	SCC/IGA
RANCHO SEC()	86	508	FATIGUE
RINGHALS 2	84	35	SCC/IGA
	85	50	SCC/IGA
	86	596	SCC/IGA
	87	554	SCC/IGA
RINGHALS 3	91	57	SCC/IGA
SAN ONOFRE 1	81	6929	WASTAGE, SCC/IGA
SUMMER	90	125	SCC(ID)
	91	610	SCC(ID)
TAKAHAMA 1	80	2	SCC(OD)
	81	4	SCC(OD)
	82	32	SCC(ID), SCC(OD)
	84	59	SCC(OD)
	88	6	SCC/IGA

TABLE 7 (cont') SLEEVING EXPERIENCE

<u>PLANT</u>	<u>YEAR</u>	<u>TUBES SLEEVED</u>	<u>REPORTED CAUSE</u>
TAKAHAMA 2	84	231	SCC/IGA
	86	330	SCC/IGA
	87	466	SCC/IGA
	88	1007	SCC/IGA
	90	1139	SCC/IGA
	91	675	SCC/IGA
	92	644	SCC/IGA
TMI	91	250	FATIGUE
TRICASTIN 2	85	14	SCC/IGA
TROJAN	90	2	SCC/IGA(TSP)
	91	1061	SCC/IGA(TSP)
ZION-1	86	128	SCC/IGA
	88	47	SCC/IGA
	89	445	SCC/IGA
	92	125	SCC/IGA
ZION-2	90	82	SCC/IGA
	92	170	SCC/IGA

TABLE 8 MAJOR SLEEVING OPERATIONS

	San Onofre 1	Point Beach 2	Indian Point 3	Millstone 2	DoeI 2	DoeI 3
Sleeving Dates	9/80 - 6/81	4/83 - 6/83	10/82 - 1/83	7/83 - 9/83	9/82 - 9/83	1988
Number of Sleeves Installed	6929	3000	2971	2022	185	55
Damage Type	IGA	IGA	Pitting	Pitting	IGSCC	PWSCC
Location	Top of TS	TS Crevice	Sludge Pile	Sludge Pile	TS Roll Trans	Top of TS
Sleeving Contractor	W	W	W	W	B&W	W
Sleeve Length (in)	27-30-36	36	36-40-44	40	1.5	36
Sleeve Base Material	Alloy 600-TT	Alloy 600-TT	Alloy 600-TT	Alloy 690	Alloy 600-TT	Alloy 600-TT
OD Clad Materail	None	None	None	Alloy 625	None	None
Expansion Material	Hydraulic	Hydraulic	Hydraulic	Hydraulic	Explosive	Laser
Total Installation Time (weeks)	30	10	14	8	-	-
Installation per Sleeve (hrs)	0.94	0.53	0.74	0.6	-	-
Exposure Total (man-rem)	3496	660	860	385	-	-
Exposure per Sleeve	0.5	0.22	0.29	0.19	-	-

TABLE 8 MAJOR SLEEVING OPERATIONS (cont.)

	R.E. Ginna			Palisades		Ringhals 2		Ringhals 3
Sleeving Dates	11/80	5/81	5/83	3/76	3/78	5/84	5/84	6/91
Number of Sleeves Installed	5	16	78	14	23	18	17	68
Damage Type		IAG/IGSCC			Wastage	IAG/IGSCC	IAG/IGSCC	PWSCC/ODSCC
Location		Tubesheet Crevice			TSP Intersections	TS Crevice	TS Crevice	TS/RTZ
Sleeving Contractor		B&W and RGE			CE	CE	W	CE
Sleeve Length (in)		20-36			12 (nominal)	30	30	TSP/TS
Sleeve Base Material		Alloy 600-TT			Alloy 600	Alloy 600-TT	Alloy 600-TT	690TT
OD Clad Material		Nickel			None	None	None	-
Expansion Material		Hydraulic Explosive			Hydraulic	Elastomeric	Hydraulic	Weld
Total Installation Time (weeks)	-	-	-	8	-	-	-	-
Installation per Sleeve (hrs)	8	2	0.33	-	-	-	3.5	.9 - 1.5
Exposure Total (man-rem)	-	-	-	15	-	4	3.4	3.4
Exposure per Sleeve		Ave. 0.4 - 0.5		-	-	0.22	0.17	0.13

TABLE 8 MAJOR SLEEVING OPERATIONS (cont.)

	Point Beach 1	Kewaunee			
Sleeving Dates	8 81	3 88	3 89	3 91	3 92
Number of Sleeves Installed	13	1940	1698	690	16
Damage Type	IGA	IGA/IGSCC	IGA/IGSCC	IGA/IGSCC	IGA/IGSCC
Location	TS Crevice	TS Crevice	TS Crevice	TS Crevice	TS Crevice
Sleeving Contractor	W	W	W	W	ABB/CE
Sleeve Length (in)	36	30-36	30-36	27-30-36	27
Sleeve Base Material	Alloy 600-TT	Alloy 600-TT	Alloy 600-TT	Alloy 600-TT	Alloy 690-TT
OD Clad Materail	None	None	None	None	None
Expansion Material	Hydraulic	HEJ	HEJ	HEJ	Welded
Total Installation Time (weeks)	2	2.4	2.2	-	-
Installation per Sleeve (hrs)	-	0.21	0.21	-	-
Exposure Total (man-rem)	-	66.8	41.2	-	-
Exposure per Sleeve	-	0.034	0.024	-	-

Section 8

STEAM GENERATOR REPLACEMENT

Steam generators were replaced at Millstone 2 during 1992 (Table 9). Replacement steam generators have been ordered for over 30 plants. The activity (and lost generation) associated with steam generator replacement will increase substantially during the next few years. To date eight United States, one German, one French and one Swedish utility have replaced a total of 37 steam generators at 13 nuclear units. (Reference 5). Several techniques have been utilized to replace steam generators. These techniques include the pipe cut and channel head cut methods. In the pipe cut method, the steam generators are removed from the reactor coolant system by cutting the hot and cold leg primary piping adjacent to the primary channel head of the steam generator. Replacement steam generators or replacement portions are installed by reconnection to the primary piping to complete the repair operation. In initial replacements the upper steam dome was cut from the lower portion of the steam generator and refurbished inside the containment building. Because of sufficient containment hatch size at Obrigheim, Cook 2, Indian Point 3, and Ringhals 2, the entire steam generator assemblies were removed and replaced.

In the channel cut technique the steam generator is separated by cutting the channel head just below the tubesheet. This leaves the lower primary piping in place and simplifies the fit up operation. The upper portion of the steam generator can be replaced in its entirety or the upper steam dome can be cut and refurbished in the containment building. Operation before steam generator replacement has ranged from 7 to 19 years. However, effective full years of operation (EFPY) has ranged from 3.6 to 11.2 EFPY. The steam generators replaced at Indian Point 3 had 6.4 EFPY which was about the same as the Turkey Point 3 generators which were replaced in 1982. The impact to a utility of having to replace steam generators is substantial. Table 9 shows that replacement durations have ranged from 70 days up to 260 days. Total doses received by personnel performing the changeout have ranged from 220 to 2141 man rems. Replacement costs have ranged from 37 to 190 million dollars excluding replacement power costs. An encouraging trend is that while the costs for replacement have continued to increase, both the replacement duration and man rem exposure have been decreasing. The replacements at Ringhals 2, Dampierre 1, Palisades,

and Millstone 2 required on the average only 44% of the time and 20% of the exposure as the first replacement at Surry 2.

Replacement steam generators have been ordered for over 30 plants. Table 10 shows the steam generator replacement orders that have been announced to date. These orders indicate that steam generator replacement activity will continue to increase over the next few years.

TABLE 9 REPLACEMENT STEAM GENERATORS

UNIT	NO. SG.	REPL. METHOD	REPL. S.G.	TUBE MATERIAL	COMM. OPER.	COMP. DATE	OPER. (YEARS)	EFPY OPER.	REPL. DURATION (DAYS)	EXPOSURE (MAN-REM)	REPL. COSTS (1) (MILLIONS)
Surry 2	3	Pipe Cut (Lower Shell)	W	I-600TT	May-74	Sep-80	7	3.6	260	2141	\$94
Surry 1	3	Pipe Cut (Lower Shell)	W	I-600TT	Dec-72	Jul-81	8	4.4	200	1759	\$94
Turkey Point 3	3	Channel Head cut	W	I-600TT	Dec-72	Apr-82	10	6.2	217	2152	\$90
Turkey Point 4	3	Channel Head Cut	W	I-600TT	Sep-73	May-83	9	5.3	150	1305	\$90
Obrigheim	2	Pipe Cut (Entire SG)	KWU	I-800	Mar-69	Sep-83	14	11.2	72 (2)	690	\$37 (3)
Point Beach 1	2	Pipe cut	W	I-600TT	Dec-70	Mar-84	13	9.2	118 (2)	575	\$77
H B Robinson	3	Channel Head cut	W	I-600TT	Mar-71	Oct-84	13	8.5	130	1207	\$85
D C Cook 2	4	Pipe Cut (Entire SG)	W	I-690TT	Jun-78	Mar-89	11	6.6	175	561	\$112
Indian Pt. 3	4	Pipe Cut (Entire SG)	W	I-690TT	Aug-76	Jun-89	13	6.4	140	541	\$120
Ringhals 2	3	Pipe Cut (Entire SG)	KWU	I-690TT	May-76	Aug-89	14	8.1	72 (2)	290	\$130
Dampierre 1	3	Pipe Cut (Entire SG)	FRA	I-690TT	Sep-80	Jun-90	10	6.7	70	220	\$104
Palisades	2	Pipe Cut (Entire SG)	CE	I-600MA	Dec-71	Mar-91	19	8.3	121	487	\$100
Millstone 2	2	Pipe Cut (Partial SG)	BWC	I-690TT	Dec-75	Jan-93	17	10.9	192	697	\$190

(1) Excluding replacement power costs

(2) Shutdown until start of hydro

(3) Partial warranty provision

TABLE 10 PLANNED STEAM GENERATOR REPLACEMENTS (Orders Placed)

Plant	Number of Steam Generator Units	Net Capacity (MWe)	Replacement Supplier	Tube Material	Projected Year of Replacement
DoeI 3	3	900	S-F	I-800	1993
DoeI 4	3	1010	S-F	I-690TT	1996
Tihange 1	3	870	MHI	I-690TT	1995
Beznau 1	2	350	Fra	I-690TT	1993
Almaraz 1&2	6	900	S-F	I-800	1996/97
Asco 1&2	6	887	S-F	I-800	1995/96
Bugey 5	3	900	Fra	I-690TT	1993
Gravelines 1	3	910	Fra	I-690TT	1994/95
Genkai 1	2	529	Fra	I-690TT	1994
Mihama 1	2	320	MHI	I-690TT	1996
Mihama 2	2	470	MHI	I-690TT	1995
Mihama 3	3	780	MHI	I-690TT	1996
Ohi 1	4	1120	MHI	I-690TT	1994/95
Ohi 2	4	1120	MHI	I-690TT	1998/99
Takahama 1	3	780	MHI	I-690TT	1996
Takahama 2	3	780	MHI	I-690TT	1994
Ringhals 3	3	915	S-F	I-690TT	1995
Catawba 1	4	1129	BWC	I-690TT	1996/97
Farley 2	3	872	W	I-690TT	2005
Farley 1	3	873	W	I-690TT	After 2005
Ginna	2	470	BWC	I-690TT	1996
McGuire 1	4	1129	BWC	I-690TT	1996/97
McGuire 2	4	1129	BWC	I-690TT	1996/97
North Anna 2	3	907	W	I-690TT	Not specified
Point Beach 2	2	485	W	I-690TT	1996/7
St. Lucie 1	2	839	BWC	I-690TT	1996
Summer	3	895	W	I-690TT	1994
Zion 1	4	1040	BWC	I-690TT	1996
Zion 2	4	1040	BWC	I-690TT	2001

W=Westinghouse

Fra=Framatome

S-F=Siemens/Framatome

MHI=Mitsubishi Heavy Industries

BWC=B&W Canada

REFERENCES

1. O. S. Tatone and R. S. Pathania, "Steam Generator Tube Performance: Experience with Water-Cooled Nuclear Power Reactors During 1982," Report AECL 8268, October 1984.
2. Personal communication with O. S. Tatone, July 1985.
3. J. Payne, "Japan: Aiming for Excellence," Nuclear News", August 1985.
4. F. Calori, R. Skjoldebrand, D. White, "The IAEA Power Reactor Information System (PRIS)," Proceedings of an International Symposium on Nuclear Plant Outage Experience, June 1984.
5. P. DeLozier, J. Scarborough, W. Greenaway, P. Pettit, "Environmental, Regulatory, and Occupational Constraints on Steam Generator Replacement, Repair, and Maintenance." AIF/NESP 029, October 1984.
6. E. S. Hunt and J. A. Gorman, "Design Review Checklist: Steam Generator Sleeving," EPRI Report NP-4296 LD, November 1985.

APPENDIX A

HISTORICAL TUBE PLUGGING DATA

Appendix A Abbreviations

<u>Abbreviation</u>	<u>Includes</u>
Wastage	Wastage and thinning
Denting S P	Denting at support plate intersections
Denting T S	Denting at and above the tubesheet
Pitting	Pitting
OD S/IGA SP	Secondary side stress corrosion and/or intergranular attack (support plate)
OD S/IGA TS	Secondary side stress corrosion and/or intergranular attack (tubesheet)
ID SCC TS	Primary side stress corrosion cracking (tubesheet locations)
ID SCC UB	Primary side stress corrosion cracking (U-bend locations)
FRET (PREH)	Tube fretting and wear (preheater locations)
FRET (AVB)	Tube fretting and wear (AVB locations)
FRET (LP)	Tube fretting and wear caused by a loose part or foreign object
HC FATIGUE	High cycle fatigue
ERR/COR	Erosion and/or corrosion
OTHER	Unknown cause or a cause other than above
TOT PLUGGED	Total number of tubes plugged
TOT SLEEVED	Total number of tubes sleeved
T.L. OUTAGE	Number of forced outages caused by steam generator tube leaks

UTILITY : CSES

TOTAL TUBES : 14,022

PLANT : ALMARAZ 1

TUBE MATERIAL : I-600 MA

PLUGGED: 887

SG MODEL : W-D3

EFPY : 8.3

H. L. TEMP (F) : 616

C.L. TEMP (F) : 553

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP														371	47	2	18	438	
OD S/IGA TS																			0
ID SCC TS										74	32		223	6	3	27	365		
ID SCC UB																			0
FRET (PREH)							4	2		14						5	16	41	
FRET (AVB)														3	3	6	15	27	
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER						2					1			5	2	5	1	15	
TOT PLUGGED	0	0	0	0	0	2	4	2	0	14	75	32	0	602	58	21	0	77	887
TOT SLEEVED															3100*				103
T. L. OUTAGE														1					*

UTILITY CONTACT: Gustavo Bollini

* Six sleeves plugged after installation

PHONE NUMBER: 34-1-6516700

UTILITY : CSES

TOTAL TUBES : 14,022

PLANT : ALMARAZ 2

TUBE MATERIAL : I-600 MA

PLUGGED: 779

SG MODEL : W-D3

EFPV : 7.8

H. L. TEMP (F) : 616

C.L. TEMP (F) : 553

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL		
WASTAGE																			0		
DENTING SP																			0		
DENTING TS																			0		
PITTING																			0		
OD S/IGA SP															2	39	87	101	157	386	
OD S/IGA TS																	21	12	33		
ID SCC TS															10	22	27	46	131	66	302
ID SCC UB																1				1	
FRET (PREH)																	7	10	24	41	
FRET (AVB)																	2	2	2	6	
FRET (LP)																				0	
HC FATIGUE																				0	
ERR/CORR																				0	
OTHER										5					1		2		2	10	
TOT PLUGGED	0	0	0	0	0	0	0	0	5	0	0	1	10	27	66	144	0	265	261	779	
TOT SLEEVED																				0	
T. L. OUTAGE																				0	

UTILITY CONTACT: Gustavo BolliniPHONE NUMBER: 34-1-6516700

UTILITY : FURNAS CENTRAIS

TOTAL TUBES : 8,918

PLANT : ANGRA 1

TUBE MATERIAL : I-600 MA

PLUGGED : 447

SG MODEL : W-D3

EFPY : 2.0

H. L. TEMP (F) : 620

C.L. TEMP (F) : 549

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																20	7		27
OD S/IGA SP																2		364	366
OD S/IGA TS																8	15		23
ID SCC TS																6		14	20
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER										4						7			11
TOT PLUGGED	0	0	0	0	0	0	0	0	4	0	0	0	7	6	30	0	400	0	447
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: _____

PHONE NUMBER: _____

UTILITY : ENTERGY OPERATIONS, INC.

TOTAL TUBES : 31062

PLANT : ANO-1

TUBE MATERIAL : I-600

PLUGGED : 642

SG MODEL : OTSG

EFPY : 11.4

H. L. TEMP (F) : 602

C.L. TEMP (F) : 556

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP							2		26	2	9				4				43	
OD S/IGA TS					1		9		116	37	101					9		196	469	
ID SCC TS																			0	
ID SCC UB																			0	
FRET (PREH)																			0	
FRET (AVB)																			0	
FRET (LP)																			0	
HC FATIGUE														1					1	
ERR/CORR										1									1	
OTHER									3	1		5		9			110		128	
TOT PLUGGED	0	0	0	1	0	11	0	142	43	111	0	5	1	13	0	9	0	306	642	
TOT SLEEVED											10		40		174		106		572	902
T. L. OUTAGE							2		1	1				1					5	

UTILITY CONTACT: Darol HarrisonPHONE NUMBER: (501) 964-8909

UTILITY : ENTERGY OPERATIONS, INC.

TOTAL TUBES : 16822

PLANT : ANO-2

TUBE MATERIAL : I-600 MA

PLUGGED : 367

SG MODEL : CE-2815

EFPY : 8.9

H. L. TEMP (F) : 600

C.L TEMP (F) : 544

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																52	129	181	
OD S/IGA TS																5	76	81	
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)															6		16	38	60
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER				44						1									45
TOT PLUGGED	0	0	0	44	0	0	0	1	0	0	0	0	0	6	0	0	73	243	367
TOT SLEEVED																			
T. L OUTAGE																		1	1

UTILITY CONTACT: Darol HarrisonPHONE NUMBER: (501) 964-8909

UTILITY : ANA

TOTAL TUBES : 14,022

PLANT : ASCO 1

TUBE MATERIAL : I-600 MA

PLUGGED : 1351

SG MODEL : W-D3

EFPY : 7.0

H. L TEMP (F) : 620

C.L TEMP (F) : 556

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP													14	132	385	120**	334	985		
OD S/IGA TS																	1	3	4	
ID SCC TS											6	15	21	28	15	231	1	2	319	
ID SCC UB																			0	
FRET (PREH)																1	3	6	10	
FRET (AVB)																6	7	5	18	
FRET (LP)																			0	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER										7		1	2				1	1	3	15
TOT PLUGGED	0	0	0	0	0	0	0	0	7	0	7	17	21	42	147	624	133	353	1351	
TOT SLEEVED																	115***	4#	111***	
T. L. OUTAGE																			0	

UTILITY CONTACT: Gustavo Bollini

* 20 tubes plugged by C. L. Indications

PHONE NUMBER: 34-1-6516700

** 30 tubes plugged by C. L. Indications

***1 tube sleeved for ODSCC indication
in the free span region of the tube

4 tubes sleeved in 1991 were plugged in 1992

UTILITY : ANA

TOTAL TUBES : 14,022

PLANT : ASCO 2

TUBE MATERIAL : I-600 MA

PLUGGED : 442

SG MODEL : W-D3

EFPY : 5.8

H. L. TEMP (F) : 620

C. L. TEMP (F) : 556

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP															2	36	105	126**	98	367
OD S/IGA TS																	9	2	11	
ID SCC TS															4	32	10	3	49	
ID SCC UB																			0	
FRET (PREH)																			0	
FRET (AVB)																	2		2	
FRET (LP)																			0	
HC FATIGUE															1 *				1	
ERR/CORR																			0	
OTHER										4					1		7		12	
TOT PLUGGED	0	0	0	0	0	0	0	4	0	0	0	0	0	7	37	144	147	103	442	
TOT SLEEVED																			0	
T. L. OUTAGE																			0	

UTILITY CONTACT: Gustavo Bollini

* Plugged after evaluation for tube
vibration induced fatigue

PHONE NUMBER: 34-1-6516700

** 3 tubes plugged for ODSCC in free span
tube and 5 tubes plugged for C. L. indications

UTILITY : CNEA

TOTAL TUBES : 7,890

PLANT : ATUCHA-1

TUBE MATERIAL : I-800

PLUGGED : 89

SG MODEL : KWU

EFFY : 11.9

H. L. TEMP (F) : 582

C.L. TEMP (F) : 521

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE									1					2					3
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)										1			2	74			2	79	
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER														* 7					7
TOT PLUGGED	0	0	0	0	0	0	0	1	1	0	0	2	83	0	0	0	0	2	89
TOT SLEEVED																			0
T. L. OUTAGE										1			2	2					5

UTILITY CONTACT: S. Odar / R. Bouecke

* Plugged preventively

PHONE NUMBER: 49-9131-18-2077 / 49-9131-18-9410

UTILITY	DUQUESNE LIGHT CO.												TOTAL TUBES : 10,164						
PLANT	BEAVER VALLEY 1												TUBE MATERIAL : I-600 MA						
PLUGGED	1054												SG MODEL : W-51						
EFPY	9.1												H. L. TEMP (F) : 607						
													C.L. TEMP (F) : 542						
DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE									2	15		27	15		11		17		87
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP											8		117		735		860		
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC JB											42		9						51
FRET (PREH)																			0
FRET (AVB)									3		4			2		1		10	
FRET (LP)														12					12
HC FATIGUE																			0
ERR/CORR																			0
OTHER									1	6	6		7	7			7		34
TOT PLUGGED	0	0	0	0	0	0	0	1	8	24	0	38	72	0	151	0	760	0	1054
TOT SLEEVED																			0
T. L. OUTAGE											1								1

UTILITY CONTACT: Greg Kammerdeiner

PHONE NUMBER: 412-393-5677

UTILITY : DUQUESNA LIGHT CO.	TOTAL TUBES : 10,128
PLANT : BEAVER VALLEY 2	TUBE MATERIAL : I-600 MA
PLUGGED : 33	SG MODEL : W-51M
EFPY : 3.9	H. L. TEMP (F) : 607
	C.L. TEMP (F) : 542

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																		8	8
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			J
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																	2	2	
FRET (LP)																4			4
HC FATIGUE															2	2			4
ERR/CORR																			0
OTHER														14			1	15	
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	14	0	6	2	0	11	33
TOT SLEEVED																			0
T. L. OUTAGE																1	1		2

UTILITY CONTACT: Greg Kammerdeiner

PHONE NUMBER: 412-393-5677

UTILITY : EDF

TOTAL TUBES : 21,368

PLANT : BELLEVILLE 1

TUBE MATERIAL : I-600 TT

PLUGGED: 29

SG MODEL : FRAM-68/19

EFPY : 3.3

H. L. TEMP (F) : 616

C.L. TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																		0	
DENTING SP																		0	
DENTING TS																2	10	12	
PITTING																		0	
OD S/IGA SP																		0	
OD S/IGA TS																		0	
ID SCC TS																		0	
ID SCC UB																		0	
FRET (PREH)																		0	
FRET (AVB)																		0	
FRET (LP)															2			2	
HC FATIGUE																		0	
ERR/CORR																		0	
OTHER															1	11	3	15	
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3	13	0	13	29
TOT SLEEVED																		0	
T. L. OUTAGE																		0	

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 21,368

PLANT : BELLEVILLE 2

TUBE MATERIAL : I-600 TT

PLUGGED : 58

SG MODEL : FRAM-68/19

EFPY : 3.0

H. L. TEMP (F) : 616

C.L. TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																	2	3	5	
PITTING																			0	
OD S/IGA SP																			0	
OD S/IGA TS																			0	
ID SCC TS																			0	
ID SCC UB																			0	
FRET (PREH)																			0	
FRET (AVB)																			0	
FRET (LP)																8			8	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER																9	31	5	45	
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	8	9	33	8	58
TOT SLEEVED																				0
T. L. OUTAGE																				0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : RHEINISCH-WESTFALISCHES TOTAL TUBES : 16,240
ELEKTRIZITATSWERK AG

PLANT : BIBLIS-A TUBE MATERIAL : I-800

PLUGGED : 604 SG MODEL : KWU

EFPY : 12.2 H. L. TEMP (F) : 596

C.L. TEMP (F) : 543

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE					1	10*	1	2		101	140	179	19	2	3	6	4	12	480
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)										37	2	4	5				1	49	
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER			2**							66***				2***	4***	1***			75
TOT PLUGGED	0	0	2	0	0	1	10	1	2	204	142	179	23	9	7	7	4	13	604
TOT SLEEVED																			0
T. L. OUTAGE										1									1

UTILITY CONTACT: S. Odar / R. Bouecke

* 3 tubes out of 10 were pulled for investigation

** 2 tubes were pulled for investigation

*** Total of 73 tubes were plugged preventively

(63 due to AVB repair,

10 due to uninspectability of the tubes)

PHONE NUMBER: 49-9131-18-2077 /

49-9131-18-9410

UTILITY : RHEINISCH-WESTFALISCHES TOTAL TUBES : 16,084

ELEKTRIZITATSWERK AG

PLANT : BIBLIS-B

TUBE MATERIAL : I- 800

PLUGGED: 61

SG MODEL : KWU

EFPY : 10.3

H. L. TEMP (F) : 607

C.L. TEMP (F) : 551

DEFECTS	<76	76	77	78	79	80	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE					*	3	1**		1				2					7
DENTING SP																		0
DENTING TS																		0
PITTING																		0
OD S/IGA SP																		0
OD S/IGA TS																		0
ID SCC TS																		0
ID SCC UB																		0
FRET (PREH)																		0
FRET (AVB)							6		22	1	1	1	7		5	7	50	
FRET (LP)																		0
HC FATIGUE																		0
ERR/CORR																		0
OTHER				3												1	4	
TOT PLUGGED	0	0	0	3	0	3	1	0	7	0	22	1	3	1	7	0	5	61
TOT SLEEVED																		0
T. L. OUTAGE																		0

UTILITY CONTACT: S. Odar / R. Bouecke

PHONE NUMBER: 49-9131-18-2077 / 49-9131-18-9410

* 2 tubes out of 3 were pulled because of uninterpretable ECT-signals

Result: Wastage + Pitting

** Tube was pulled because of uninterpretable ECT-signals. Result: Wastage + ODSCC

UTILITY : EDF

TOTAL TUBES : 10,083

PLANT : BLAYAIS 1

TUBE MATERIAL : I-600 MA

PLUGGED: 170

SG MODEL : FRAM-51M

EFPY : 8.1

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																	27	4	31
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS										1	16	1		5		11	13	8	85
ID SCC UB																	2		2
FRET (PREH)																			0
FRET (AVB)																1	1	2	4
FRET (LP)											2	1			3	2			8
HC FATIGUE																			0
ERR/CORR																			0
OTHER								18									1	21	40
TOT PLUGGED	0	0	0	0	0	0	0	18	1	18	2	0	5	0	17	43	30	36	170
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 9,987

PLANT : BLAYAIS 2

TUBE MATERIAL : I-600 MA

PLUGGED : 84

SG MODEL : FRAM-51B1

EFPY : 7.4

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																54	2		56	
PITTING																			0	
OD S/IGA SP																			0	
OD S/IGA TS																			0	
ID SCC TS											2	1	2			2	1		8	
ID SCC UB																1			1	
FRET (PREH)																			0	
FRET (AV8)																1	1	1	4	
FRET (LP)											3	2	1						6	
HC FATIGUE																			0	
ERR/CORR																1			1	
OTHER										4							1	1	2	8
TOT PLUGGED	0	0	0	0	0	0	0	0	0	4	2	4	4	1	0	5	56	5	3	84
TOT SLEEVED																				0
T. L. OUTAGE																				0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 9,987

PLANT : BLAYAIS 3

TUBE MATERIAL : I-600 MA

PLUGGED: 104

SG MODEL : FRAM-51B1

EFFY : 6.8

H. L. TEMP (F) : 613

C. L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			C
DENTING SP																			C
DENTING TS																62	20		82
PITTING																			C
OD S/IGA SP																			C
OD S/IGA TS																			C
ID SCC TS														1	1		5	3	10
ID SCC UB																			C
FRET (PREH)																			C
FRET (AVB)																1	1	1	3
FRET (LP)																			C
HC FATIGUE																			C
ERR/CORR																			C
OTHER										6						1	2		3
TOT PLUGGED	0	0	0	0	0	0	0	0	0	6	1	1	0	0	1	1	70	23	104
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 9,990

PLANT : BLAYAIS 4

TUBE MATERIAL : I-600 MA (SG1,SG2)
: I-600 TT (SG3)

PLUGGED: 211

SG MODEL : FRAM-51B

EFFY : 6.9

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																53	2	4	59
PITTING																			0
OD S/GA SP																			0
OD S/GA TS																			0
ID SCC TS																6			6
ID SCC UB																1			1
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)													4	1	0	3	3		16
HC FATIGUE																			0
ERR/CORR																			0
OTHER							3			8	1		1	4		106	6		129
TOT PLUGGED	0	0	0	0	0	0	3	0	0	8	5	1	1	16	3	162	8	4	211
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : EPZ

TOTAL TUBES : 8,468

PLANT : BORSSELE

TUBE MATERIAL : I-800

PLUGGED : 123

SG MODEL : KWU

EFPY : 15.1

H. L. TEMP (F) : 606

C.L. TEMP (F) : 558

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE					49		41	1		3		3		3		13	1		114
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																	9		9
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	49	0	41	1	0	3	0	3	0	3	0	13	10	0	123
TOT SLEEVED																			0
T. L. OUTAGE																		1	1

UTILITY CONTACT: S. Odar / R. BoueckePHONE NUMBER: 49-9131-18-2077 / 49-9131-18-9410

UTILITY : COMMONWEALTH EDISON TOTAL TUBES : 18,696
 PLANT : BRAIDWOOD 1 TUBE MATERIAL : I-600 MA
 PLUGGED: 216 SG MODEL : W-D4
 EFPY : 3.2 H. L. TEMP (F) : 608
 C.L. TEMP (F) : 557

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																30	166	196	
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)															2	4	6	12	
FRET (LP)																			0
HC FATIGUE																	1	1	
ERR/CORR																			0
OTHER															4	1	2	7	
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	6	0	36	174	216
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: John Blomgren

PHONE NUMBER: 708-515-7215

UTILITY : COMMONWEALTH EDISON

TOTAL TUBES : 18,696

PLANT : BRAIDWOOD 2

TUBE MATERIAL : I-600 TT

PLUGGED : 2

SG MODEL : W-D5

EFPY : 3.2

H. L. TEMP (F) : 608

C. L. TEMP (F) : 552

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																	2		2
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0	0	2
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: John BlomgrenPHONE NUMBER: 708-515-7215

UTILITY : KERNKRAFTWERK TOTAL TUBE'S : 16,344
 BROKDORF GmbH
 PLANT : BROKDORF TUBE MATERIAL : I-800
 PLUGGED : 0 SG MODEL : KWU-54GS
 EFPY : 4.9 H. L. TEMP (F) : 618
 C. L. TEMP (F) : 558

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: S. Odar / R. Bouecke

PHONE NUMBER: 49-9131-18-2077 / 49-9131-18-9410

UTILITY : EDF

TOTAL TUBES : 10,164

PLANT : BUGEY 2

TUBE MATERIAL : 1-600 MA

PLUGGED : 342

SG MODEL : FRAM-51A

EFPY : 8.6

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP																			0	
OD S/IGA TS															2	1	26	4	33	
ID SCC TS															1	7	13	3	24	
ID SCC UR								10	84	94						1			189	
FRET (PREH)																			0	
FRET (AVB)															10	2	3	4	23	
FRET (LP)											1	4				12	3	8	28	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER												4					29	10	2	45
TOT PLUGGED	0	0	0	0	0	0	0	0	10	89	98	10	2	0	18	38	56	21	342	
TOT SLEEVED																			0	
T. L. OUTAGE																			0	

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 10,164

PLANT : BUGEY 3

TUBE MATERIAL : I-600 MA

PLUGGED: 157

SG MODEL : FRAM-51A

EFPY : 8.5

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP															10				10
OD S/IGA TS																2	6		8
ID SCC TS										1		1	3	2			1	13	21
ID SCC UB											1				2				3
FRET (PREH)																			0
FRET (AVB)														34	7	3	28	8	80
FRET (LP)							1									11		9	21
HC FATIGUE																			0
ERR/CORR																			0
OTHER									11		1				1		1		14
TOT PLUGGED	0	0	0	0	0	12	0	0	3	0	1	37	9	27	0	31	37	0	157
TOT SLEEVED																			0
T. L. OUTAGE													1						1

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 10,164

PLANT : BUGEY 4

TUBE MATERIAL : I-600 MA

PLUGGED : 426

SG MODEL : FRAM-51A

EFPY : 8.6

H. L TEMP (F) : 613

C.L TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
OENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																		2	2
OD S/IGA TS																2	53	27	82
ID SCC TS												3	1	2	1	2		6	15
ID SCC UB										94	186				3		4	287	
FRET (PREH)																			0
FRET (AVB)													5	2	4		1	12	
FRET (LP)															9		9	18	
HC FATIGUE																			0
ERR/CORR																			0
OTHER									6						1	2		1	10
TOT PLUGGED	0	0	0	0	0	0	0	0	6	97	186	6	0	5	21	57	0	48	426
TOT SLEEVED																			0
T. L OUTAGE																			0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 10,164

PLANT : BUGEY 5

TUBE MATERIAL : I-600 MA

PLUGGED: 1064

SG MODEL : FRAM-51A

EFPY : 9.0

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP																1	3	2	6	
OD S/IGA TS																	2	1	3	
ID SCC TS							9	3	62	12	19	61		53	215	312	203	949		
ID SCC IB										1		3	6		3				13	
FRET (PREH)																			0	
FRET (AVB)							1				6	8			4	7	7		33	
FRET (LP)							4								1		11	16		
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER				6						4					9	2	7	16	44	
TOT PLUGGED	0	0	0	6	0	0	5	9	3	67	18	30	67	0	71	224	331	233	1064	
TOT SLEEVED																76			76	
T. L. OUTAGE															1	1			1	3

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : COMMONWEALTH EDISON

TOTAL TUBES : 18,696

PLANT : BYRON 1

TUBE MATERIAL : 1-600 MA

PLUGGED: 239

SG MODEL : W-D4

EFPY : 5.5

H. L. TEMP (F) : 608

C.L. TEMP (F) : 557

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE													4	5					9
DENTING SP																			0
DENTING TS																			0
PITTING																		11	11
OD S/IGA SP																13	135		148
OD S/IGA TS																			0
ID SCC TS													2	1		1	2		6
ID SCC UB													1	39					40
FRET (PREH)																			0
FRET (AV8)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR														1					1
OTHER										19				2	1	2			24
TOT PLUGGED	0	0	0	0	0	0	0	0	19	0	0	0	10	46	0	16	148	0	239
TOT SLEEVED																			0
T. L. OUTAGE															2				2

UTILITY CONTACT: John Blomgren

PHONE NUMBER: 708-515-7215

UTILITY : COMMONWEALTH EDISON

TOTAL TUBES : 18,696

PLANT : BYRON 2

TUBE MATERIAL : I-600 TT

PLUGGED: 72

SG MODEL : W-D5

EFPY : 4.0

H. L TEMP (F) : 608

C.L. TEMP (F) : 557

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																	24	24	
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER															11		32	5	48
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	11	0	0	32	0	29	72
TOT SLEEVED																			0
T. L OUTAGE																			0

UTILITY CONTACT: John BlomgrenPHONE NUMBER: 708-515-7215

UTILITY : UNION ELECTRIC COMPANY

TOTAL TUBES : 22504

PLANT : CALLAWAY

TUBE MATERIAL : I-600MA

PLUGGED : 104

SG MODEL : W-F

EFPY : 6.6

H. L. TEMP (F) : 618

C.L. TEMP (F) : 558

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																10	12	22	73
FRET (LP)																			0
HQ FATIGUE																			0
ERR/CORR																			0
OTHER										25				3			1		31
TOT PLUGGED	0	0	0	0	0	0	0	0	25	0	0	0	13	0	12	23	0	31	104
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: Ron AffolterPHONE NUMBER: (314) 676-8240

UTILITY : BALTIMORE GAS & ELECTRIC

TOTAL TUBES : 17038

PLANT : CALVERT CLIFFS 1

TUBE MATERIAL : I-600 MA

PLUGGED: 195

SG MODEL : CE-67

EFPY : 11.5

H. L. TEMP (F) : 595

C.L. TEMP (F) : 548

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS													14	20	63	2	11	10	120
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)													2	9	1			8	20
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER					3					26	5		6	10		4		1	55
TOT PLUGGED	0	0	0	3	0	0	0	26	5	0	22	39	0	68	2	12	0	18	195
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: KEITH HOFFMAN/ PAUL KLEINPHONE NUMBER: (301) 260-4850/ 260-3871

UTILITY : BALTIMORE GAS & ELECTRIC

TOTAL TUBES : 17038

PLANT : CALVERT CLIFFS 2

TUBE MATERIAL : I-600 MA

PLUGGED: 113

SG MODEL : CE-67

EFPY : 11.0

H. L. TEMP (F) : 595

C.L. TEMP (F) : 547

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS												3	7	36	13				59
ID SCC TS																			0
ID SCC UB																			0
FRET (PTEH)																			0
FRET (AVB)												1	2	9	7				19
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER					9					2		2	4	16	2				35
TOT PLUGGED	0	0	0	9	0	0	0	2	0	6	13	0	61	0	22	0	0	0	113
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: KEITH HOFFMAN/ PAUL KLEINPHONE NUMBER: (301) 260-4850/ 260-3871

UTILITY : DUKE POWER CO.

TOTAL TUBES : 18,696

PLANT : CATAWBA 1

TUBE MATERIAL : I-600 MA

PLUGGED: 740

SG MODEL : W-D3

EFPY : 5.2

H. L. TEMP (F) : 617

C.L. TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																	17		17
OD S/IGA TS																	158	89	247
ID SCC TS															53	140	45	41	279
ID SCC UB															1		15	5	21
FRET (PREH)															3	1	6	10	
FRET (AVB)																		1	1
FRET (LP)																	7		7
HC FATIGUE																			0
ERR/CORR																			0
OTHER														12	8	22	4	112	158
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	12	0	62	0	182	230	254	740	
TOT SLEEVED																	75	108	183
T. L. OUTAGE															1				1

UTILITY CONTACT: Dan MayesPHONE NUMBER: 704-382-4211

UTILITY : DUKE POWER CO.

TOTAL TUBES : 18,696

PLANT : CATAWBA 2

TUBE MATERIAL : 1-600 TT

PLUGGED : 60

SG MODEL : W-D5

EFPY : 4.5

H. L. TEMP (F) : 618

C.L. TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL		
WASTAGE																			0		
DENTING SP																			0		
DENTING TS																			0		
PITTING																			0		
OD S/IGA SP																			0		
OD S/IGA TS																			0		
ID SCC TS																			0		
ID SCC UB																			0		
FRET (PREH)																			0		
FRET (AVB)																14	6		20		
FRET (LP)																3	4	3	5	15	
HC FATIGUE																				0	
ERR/CORR																				0	
OTHER																14	4	4	2	1	25
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	14	0	7	8	19	12	0	60		
TOT SLEEVED																				0	
T L OUTAGE																				0	

UTILITY CONTACT: Dan MayesPHONE NUMBER: 704-382-4211

UTILITY : EDF	TOTAL TUBES : 21,368																		
PLANT : CATTENOM 1	TUBE MATERIAL : I-600 TT																		
PLUGGED : 51	SG MODEL : FRAM-68/19																		
EFPY : 3.3	H. L. TEMP (F) : 616																		
	C.L. TEMP (F) : 559																		
DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																	21	3	24
PITTING																			0
OD S/IGA SP																			0
ID S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																	12	12	
HC FATIGUE																			0
ERR/CORR																			0
OTHER																	15	15	15
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	21	15	15	51
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 21,368

PLANT : CATTENOM 2

TUBE MATERIAL : I-600 TT

PLUGGED: 160

SG MODEL : FRAM-68/19

EFPY : 3.2

H. L. TEMP (F) : 616

C.L. TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																72	1		73	
PITTING																			0	
OD S/IGA SP																			0	
OD S/IGA TS																			0	
ID SCC TS																			0	
ID SCC UB																			0	
FRET (PREH)																			0	
FRET (AVB)																			0	
FRET (LP)																4		5	9	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER																	2	74	2	78
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	76	2	75	7	160
TOT SLEEVED																				0
T. L. OUTAGE																				0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 21,368

PLANT : CATTENOM 3

TUBE MATERIAL : I-600 TT

PLUGGED : 9

SG MODEL : FRAM-68/19

EFPY : 1.2

H. L. TEMP (F) : 616

C.L. TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HG FATIGUE																			0
ERR/CORR																			0
OTHER																	9	9	
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	9	9
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. Comby _____

PHONE NUMBER: 1-49-22-86-78 _____

UTILITY : EDF	TOTAL TUBES : 21,368																		
PLANT : CATTENOM 4	TUBE MATERIAL : 1-600 TT																		
PLUGGED : 15	SG MODEL : FRAM-68/19																		
EFPY : 0.8	H. L. TEMP (F) : 616																		
	C.L. TEMP (F) : 559																		
DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																		0	
DENTING SP																		0	
DENTING TS																		0	
PITTING																		0	
OD S/IGA SP																		0	
OD S/IGA TS																		0	
ID SCC TS																		0	
ID SCC UB																		0	
FRET (PREH)																		0	
FRET (AVB)																		0	
FRET (LP)																		0	
HC FATIGUE																		0	
ERR/CORR																		0	
OTHER															15			15	
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	15	0	0	15	
TOT SLEEVED																		0	
T. L. CUTAGE																		0	

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF	TOTAL TUBES : 9,987
PLANT : CHINON B1	TUBE MATERIAL : I-600 MA
PLUGGED : 6	SG MODEL : FRAM-51B1
EFPY : 6.9	H. L. TEMP (F) : 613
	C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																	2		2
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER										2						2			4
TOT PLUGGED	0	0	0	0	0	0	0	2	0	0	0	0	0	0	2	2	0	0	6
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 9,990

PLANT : CHINON B2

TUBE MATERIAL : I-600 MA

PLUGGED : 42

SG MODEL : FRAM-51B

EFPY : 6.2

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP																			0	
OD S/IGA TS																			0	
ID SCC TS																1	9	3	32	
ID SCC UB																			0	
FRET (PREH)																			0	
FRET (AVB)																			0	
FRET (LP)																			0	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER								7									3		10	
TOT PLUGGED	0	0	0	0	0	0	0	7	0	0	0	0	0	0	0	0	9	6	20	42
TOT SLEEVED																				0
T. L. OUTAGE																				0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF	TOTAL TUBES : 9,987																		
PLANT : CHINON B3	TUBE MATERIAL : I-600 TT																		
PLUGGED: 10	SG MODEL : FRAM-51B																		
EFPY : 4.3	H. L TEMP (F) : 613																		
	C.L TEMP (F) : 546																		
DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER														10					10
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	10	0	0	0	0	0	0	10	
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 9,987

PLANT : CHINON B4

TUBE MATERIAL : 1-600 TT

PLUGGED : 13

SG MODEL : FRAM-51B

EFPY : 3.7

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																		5	5
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																	5	5	
HC FATIGUE																			0
ERR/CORR																			0
OTHER													2				1		3
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	2	0	0	0	5	1	51	13
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : TEXAS UTILITIES ELECTRIC

TOTAL TUBES : 18,696

PLANT : COMANCHE PEAK 1

TUBE MATERIAL : I-600 MA

PLUGGED : 0

SG MODEL : W-D4

EFPY : 1.6

H. L. TEMP (F) : 622

C.L. TEMP (F) : 558

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			C
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: James HossPHONE NUMBER: 817-897-5210

UTILITY : NORTHEAST UTILITYIES

TOTAL TUBES : 15,176

PLANT : CONNECTICUT YANKEE (HADDAM NECK) TUBE MATERIAL : I-600 MA

PLUGGED : 1189

SG MODEL : W-27

EFPY : 17.7

H. L TEMP (F) : 585

C.L TEMP (F) : 534

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE	30	1	1														4		36
DENTING SP							3		200	20		6					1	1	231
DENTING TS									12										12
PITTING		1					12		7	32		51	50		18		16		187
OD S/IGA SP																			0
OD S/IGA TS																	4		4
ID SCC TS	2										119	289		141		104			655
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)	2	2	1		1		2					2	4						14
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER	4					2	8		1	15		9	10				1		50
TOT PLUGGED	38	4	2	0	1	2	25	0	220	67	0	187	353	0	159	1	130	0	1189
TOT SLEEVED																			0
T. L. OUTAGE	1																		1

UTILITY CONTACT: John KliesiewiczPHONE NUMBER: 203-665-3969

UTILITY : AMERICAN ELECTRIC POWER

TOTAL TUBES : 13,552

PLANT : D. C. COOK 1

TUBE MATERIAL : I-600

PLUGGED : 952

SG MODEL : W-51

EFPY : 10.9

H. L TEMP (F) : 599

C.L TEMP (F) : 536

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE										1		9		14	10		20	54	
DENTING SP																		0	
DENTING TS																		0	
PITTING																		0	
OD S/IGA SP											1		2			45	48		
OD S/IGA TS									6	23	255	131	104			284	803		
ID SCC TS											4	133	51					188	
ID SCC UB									3								1	4	
FRET (PREH)																		0	
FRET (AVB)									5	4			1	5				15	
FRET (LP)																		0	
HC FATIGUE																		0	
ERR/CORR									1									1	
OTHER	1	0	0	0	0	20	20	3								4	48		
TOT PLUGGED	1	0	0	0	0	20	0	20	18	0	28	0	269	0	281	170	0** 354	952	
TOT SLEEVED																	1840**	1840	
T. L OUTAGE																		0	

UTILITY CONTACT: John Jensen

* Does not include 4 good tubes plugged
with sentinel plugs.

PHONE NUMBER: 614-223-1975

** 209 previously plugged tubes were
sleeved and returned to service.

UTILITY : AMERICAN ELECTRIC POWER TOTAL TUBES : 13,552

PLANT : D. C. COOK 2 (ORIGINAL S. G.) TUBE MATERIAL : I-600

PLUGGED: 951 SG MODEL : W-51

EFPY : 6.6 H. L. TEMP (F) : 606

C.L. TEMP (F) : 541

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE										3	1	1							5
DENTING SP																			0
DENTING TS																			0
PITTING													R						0
OD S/IGA SP										16	20	34	E						70
OD S/IGA TS									3	68	125	129	133	P					458
ID SCC TS								3	5	6			19	L					19
ID SCC UB							3						A						14
FRET (PREH)													C						0
FRET (AVB)								3		1			E						4
FRET (LP)													D						0
HC FATIGUE																			0
ERR/CORR										2	1								3
OTHER			1			6	14	22		328	4	1	2						378
TOT PLUGGED	0	0	1	0	0	6	17	30	9	402	147	151	188	0	0	0	0	0	951
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: John Jensen

PHONE NUMBER: 614-223-1975

UTILITY : AMERICAN ELECTRIC POWER TOTAL TUBES : 14,368
 PLANT : D. C. COOK 2 (REPLACEMENT S. G.) TUBE MATERIAL : I-690 TT
 PLUGGED : 0 SG MODEL : W-54F
 EFPY : 2.2 H. L. TEMP (F) : 606
 C.L. TEMP (F) : 541

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC US																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: John Jensen

PHONE NUMBER: 614-223-1975

UTILITY : EDF

TOTAL TUBES : 9,990

PLANT : CRUAS 1

TUBE MATERIAL : I-600 TT

PLUGGED : 48

SG MODEL : FRAM-51B

EFPY : 6.2

H. L TEMP (F) : 613

C.L TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																	18	2	20
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																1	2		3
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																	17	17	
HC FATIGUE																			0
ERR/CORR																			0
OTHER									8										8
TOT PLUGGED	0	0	0	0	0	0	0	8	0	0	0	0	0	0	1	20	0	19	48
TOT SLEEVED																			0
T. L OUTAGE																			0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 9,990

PLANT : CRUAS 2

TUBE MATERIAL : I-600 TT

PLUGGED : 10

SG MODEL : FRAM-51B

EFPY : 5.6

H. L. TEMP (F) : 613

C.L. TEMP (F) : 549

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																	4	4	
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																2		2	
HC FATIGUE																			0
ERR/CORR																			0
OTHER															2		2		4
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	2	0	0	0	4	4	0	10
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 9,990

PLANT : CRUAS 3

TUBE MATERIAL : I-600 TT

PLUGGED : 10

SG MODEL : FRAM-51B

EFPY : 6.1

H. L. TEMP (F) : 613

C.L. TEMP (F) : 547

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			10
TOT PLUGGED	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	3	4	2	10
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. COMBYPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 9,990

PLANT : CRUAS 4

TUBE MATERIAL : I-600 TT

PLUGGED : 30

SG MODEL : FRAM-51B

EFPY : 5.5

H. L. TEMP (F) : 613

C.L. TEMP (F) : 547

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DEFNTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																1	1	2	
HC FATIGUE																			0
ERR/CORR																			0
OTHER										3				4		3	18		28
TOT PLUGGED	0	0	0	0	0	0	0	0	3	0	0	0	4	0	4	0	18	1	30
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : FLORIDA POWER CORP. TOTAL TUBES : 31,062
 PLANT : CRYSTAL RIVER 3 TUBE MATERIAL : I-600
 PLUGGED: 162 SG MODEL : OTSG
 EFPY : 9.1 H. L. TEMP (F) : 603
 C.L. TEMP (F) : 554

DEFECTS	476	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																2			2
ERR/CORR																			0
OTHER	3	3		8	17	1	1							3	1	31	92	160	
TOT PLUGGED	3	3	0	8	17	1	1	0	0	0	0	0	0	3	0	1	33	0	92
																			162
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: Rocky Thompson

PHONE NUMBER: (904) 563-4548

UTILITY : EDF

TOTAL TUBES : 10,083

PLANT : DAMPIERRE 1 (ORIGINAL S. G.)

TUBE MATERIAL : I-600 MA

PLUGGED : 714

SG MODEL : FRAM-51M

EFPY : 6.7

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																		0	
DENTING SP																		0	
DENTING TS															R			0	
PITTING														E				0	
OD S/IGA SP														P				0	
OD S/IGA TS													L					0	
ID SCC TS										22	89	53	57	931	A			314	
ID SCC UB										90	172	85			C			347	
FRET (PREH)														E				0	
FRET (AVB)													2	D				2	
FRET (LP)									2				1					3	
HC FATIGUE																		0	
ERR/CORR																		0	
OTHER				14						1	12	14		7				48	
TOT PLUGGED	0	0	0	14	0	0	0	0	2	23	191	239	143	102	0	0	0	714	
TOT SLEEVED																		0	
T. L. OUTAGE									1		1		1					3	

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 10,083

PLANT : DAMPIERRE 1 REPLACEMENT S. G.

TUBE MATERIAL : I-690 TT

PLUGGED : 0

SG MODEL : FRAM-51B

EFPY : 1.6

H. L TEMP (F) : 613

C.L TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			2
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. Comby _____

PHONE NUMBER: 1-49-22-86-78 _____

UTILITY : EDF

TOTAL TUBES : 10,083

PLANT : DAMPIERRE 2

TUBE MATERIAL : I-600 MA

PLUGGED: 396

SG MODEL : FRAM-51M

EFFY : 7.9

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																		1	1
OD S/IGA TS																	23	23	
ID SCC TS								2	1	14	7	30		39	13	42	15	163	
ID SCC UB										180							6	186	
FRET (PREH)																			0
FRET (AVB)													1		7		2	10	
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER					11					1			1						13
TOT PLUGGED	0	0	0	0	11	0	0	0	2	2	194	7	32	0	39	20	55	24	396
TOT SLEEVED																			0
T. L. OUTAGE													1						1

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF	TOTAL TUBES : 10,083
PLANT : DAMPIERRE 3	TUBE MATERIAL : I-600 MA
PLUGGED: 762	SG MODEL : FRAM-51M
EFPY : 8.4	H. L. TEMP (F) : 613
	C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			88	
PITTING																			0	
OD S/IGA SP																			14	
OD S/IGA TS																			4	
ID SCC TS										12	15		7	93	38	36	24	44	269	
ID SCC UB																1	163	83	247	
FRET (PREH)																			0	
FRET (AVB)																1	1	4	2	
FRET (LP)											2	2		1	2	2	6		15	
HC FATIGUE																			0	
ERR/CORR																2			2	
OTHER							7				1	2				2	1	37	65	115
TOT PLUGGED	0	0	0	0	0	7	0	0	0	15	19	0	9	98	43	131	231	209	762	
TOT SLEEVED																			0	
T. L. OUTAGE													1						1	

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF TOTAL TUBES : 10,083
 PLANT : DAMPIERRE 4 TUBE MATERIAL : I-600 MA
 PLUGGED: 353 SG MODEL : FRAM-51M
 EFPY : 7.9 H. L. TEMP (F) : 613
 C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																10	7	17	
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																	13	13	
ID SCC TS										30				3	1		1	35	
ID SCC UB										90	88								178
FRET (PREH)																			0
FRET (AVB)																1	4	5	
FRET (LP)																1	4	5	
HC FATIGUE																			0
ERR/CORR																			0
OTHER						10				1	3				1		63	22	100
TOT PLUGGED	0	0	0	0	0	10	0	0	0	121	91	0	0	4	1	75	0	51	353
TOT SLEEVED																			0
T. L. OUTAGE														1					1

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : TOLEDO EDISON

TOTAL TUBES : 30,914

PLANT : DAVIS BESSE

TUBE MATERIAL : I-600

PLUGGED : 74

SG MODEL : OTSG

EFPY : 7.6

H. L. TEMP (F) : 608

C.L. TEMP (F) : 557

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																	10		10
OD S/IGA SP																			0
OD S/IGA TS																2			2
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER			18					2	7	1		19		2		10	3		52
TOT PLUGGED	0	0	18	0	0	0	2	7	0	1	0	19	0	2	0	12	13	0	74
TOT SLEEVED																			0
T. L. OUTAGE										1									1

UTILITY CONTACT: Gene Matranga

PHONE NUMBER: 419-321-8369

UTILITY : PACIFIC GAS & ELECTRIC

TOTAL TUBES : 13,552

PLANT : DIABLO CANYON 1

TUBE MATERIAL : I-600 MA

PLUGGED : 40

SG MODEL : W-51

EFPY : 5.9

H. L. TEMP (F) : 603

C. L. TEMP (F) : 545

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																	1 1/4 *	17	18
FRET (PREH)																	1	1	2
FRET (AVB)																		12	12
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER														1			7		8
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	1	0	0	1	11	1	0	29	40
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: David Hampshire

* One tube unplugged and returned to service in 1989

PHONE NUMBER: 415-972-6568

UTILITY : PACIFIC ELECTRIC & GAS

TOTAL TUBES : 13,552

PL:NT : DIABLO CANYON 2

TUBE MATERIAL : I-600 MA

PLUGGED : 15

SG MODEL : W-51

EFPY : 5.4

H. L TEMP (F) : 603

C.L TEMP (F) : 545

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																7			7
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CCRR																			0
OTHER														2	24	(19)*		1	8
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	2	31	-19	0	1	0	15
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: David Hampshire

* 19 Tubes unplugged and returned to service in 1989

PHONE NUMBER: 415-972-6568

UTILITY : EBES

TOTAL TUBES : 6520

PLANT : DOEL 1

TUBE MATERIAL : I-600

PLUGGED: 111

SG MODEL : ACE-44

EFPY : 15.0

H. L. TEMP (F) : 598

C. L. TEMP (F) : 544

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																	5		5
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																32	19		51
FRET (LP)	1	8	13												3		2		27
HC FATIGUE																			0
ERR/CORR																			0
OTHER	3	1	1				11					2	1				4	5	28
TOT PLUGGED	3	2	9	13	0	11	0	0	0	5	1	0	0	2	32	4	24	5	111
TOT SLEEVED																			0
T. L. OUTAGE				3															3

UTILITY CONTACT: Paul HernaisteenPHONE NUMBER: (02) 3820551

UTILITY : EBES

TOTAL TUBES : 6520

PLANT : DOEL 2

TUBE MATERIAL : I-600

PLUGGED : 663

SG MODEL : ACE-44

EFPY : 13.2

H. L. TEMP (F) : 598

C.L. TEMP (F) : 544

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP								1			1		3	4				4	13	
OD S/IGA TS																	8	3	11	
ID SCC TS	1		2	25	34	6	7		10	18	43	149	40				57	5	397	
ID SCC UB							1					107							108	
FRET (PREH)																			0	
FRET (AVB)																8	2		10	
FRET (LP)																			0	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER	3			3	77	1						1	2	22		8	1		6	124
TOT PLUGGED	4	0	2	28	112	8	7		10	19	43	260	46	22	0	16	60	13	13	663 *
MINI SLEEVE								133**	54**										187**	
KISS SLEEVE												10	81						91#	
NICKEL PLATE																	348		348	
T. L. OUTAGE								1	1							1			3	

UTILITY CONTACT: Paul Hernaisteen

* 175 of the 663 plugs removed for repair

PHONE NUMBER: (02) 3820551

** 186 of the 187 sleeved tubes subsequently plugged

10 of the kiss sleeves subsequently removed

UTILITY : EBES

TOTAL TUBES : 10,083

PLANT : DOEL 3

TUBE MATERIAL : I-600

PLUGGED : 555

SG MODEL : FRAM-51M

EFFY : 8.8

H. L TEMP (F) : 617

C. L TEMP (F) : 547

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																	35	17	52
OD S/IGA TS																			0
ID CCC TS									5	3	1	2	51	16	16	28	42	35	199
ID SCC UB																			0
FRET (PREH)																			0
FRET (AV8)																14			14
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER								23		1			266*						24
TOT PLUGGED	0	0	0	0	0	0	0	23	5	4	1	2	317	16	30	28	77	52	555
TOT SLEEVED															55				55
T. L OUTAGE														3				1	4

UTILITY CONTACT: Paul Hernalsteen

* 264 preventive row 1 plugging

PHONE NUMBER: (02) 3820551

UTILITY : EBES TOTAL TUBES : 14,592
 PLANT : DOEL 4 TUBE MATERIAL : I-600
 PLUGGED: 310 SG MODEL : ACE-E
 EFPY : 6.5 H. L. TEMP (F) : 616
 C.L. TEMP (F) : 560

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																3	50	24	77
OD S/IGA TS																		43	43
ID SCC TS															3	17	5	25	
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																2			2
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER										19							8	136	163
TOT PLUGGED	0	0	0	0	0	0	0	0	0	19	0	0	0	0	0	6	77	208	310
TOT SLEEVED																			0
T. L. OUTAGE																		1	1

UTILITY CONTACT: Paul Hernalsteen

PHONE NUMBER: (02) 3820551

UTILITY : KERNKRAFTWERKE TOTAL TUBES : 16,472
 LIPPE-EMS GmbH
 PLANT : Emsland TUBE MATERIAL : I-800
 PLUGGED : 0 SG MODEL : KWU-54SK
 EFPY : 4.2 H. L. TEMP (F) : 616
 C.L. TEMP (F) : 557

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: S. Odar / R. Bouecke

PHONE NUMBER: 49-9131-18-2077 / 49-9131-18-9410

UTILITY : ALABAMA POWER COMPANY

TOTAL TUBES : 10,164

PLANT : FARLEY 1

TUBE MATERIAL : I-600 MA

PLUGGED : 358

SG MODEL : W-51

EFPY : 11.3

H. L. TEMP (F) : 607

C.L. TEMP (F) : 543

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP											3		2		95	22	122			
OD S/IGA TS											1	3	16	22		42	9	93		
ID SCC TS													1			75	2	78		
ID SCC UB					1	4	277	**							(226) #			56		
FRET (PREH)																			0	
FRET (AVB)										9									9	
FRET (LP)																			0	
HC FATIGUE																			0	
ERR/CCRR																			0	
OTHER																			0	
TOT PLUGGED	0	0	0	0	1	4	277		0	0	9	1	6	0	17	24	0	-14	33	358
TOT SLEEVED																			136	136
T. L. OUTAGE									1											1

UTILITY CONTACT: Forrest Hundley

* ODSOC above tubesheet (full depth exansion)

(some pitting associated with these indications)

PHONE NUMBER: 205-870-6998

** 274 Row 1 tubes preventively plugged

226 tube returned to service

UTILITY : ALABAMA POWER COMPANY TOTAL TUBES : 10,164

PLANT : FARLEY 2 TUBE MATERIAL : I-600 MA

PLUGGED : 817 SG MODEL : W-51

EFPY : 9.4 H. L. TEMP (F) : 607

C.L. TEMP (F) : 543

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP										1	2	28	76		10	238		19	374
OD S/IGA TS											1								1
ID SCC TS												40	30		16	310		22	418
ID SCC UB							*280								**279				1
FRET (PREH)																			0
FRET (AVB)											6	2	2		1				11
FRET (LP)							3		2										5
HC FATIGUE																			0
ERR/CCRR																			0
OTHER						1	1				5		1			.1			7
TOT PLUGGED	0	0	0	0	1	0	1	283	0	3	14	70	109	0	27	268	0	41	817
TOT SLEEVED																			29
T. L. OUTAGE																			1

UTILITY CONTACT: Forrest Hundley

* Row 1 preventively plugged

PHONE NUMBER: 205-870-6998

** One recovered F* tube was replugged

UTILITY : EDF

TOTAL TUBES : 10,164

PLANT : FESSENHEIM 1

TUBE MATERIAL : I-600 MA

PLUGGED : 492

SG MODEL : FRAM-51A

EFPY : 9.6

H. L. TEMP (F) : 611

C.L. TEMP (F) : 543

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP													20						20	
OD S/IGA TS																1	3	1	5	
ID SCC TS							26	2	45	1	9	1				5		2	91	
ID SCC UB										2	15	89	171			2	3	3	10	295
FRET (PREH)																			0	
FRET (AVB)										1	6	1	5			1	1	1	16	
FRET (LP)																	3		3	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER	6									1	12	11	3	5		7	3	2	12	62
TOT PLUGGED	6	0	0	0	0	0	26	3	60	33	102	202	0	9	13	9	29	0	492	
TOT SLEEVED										10*									10	
T. L. OUTAGE																			0	

UTILITY CONTACT: R. Comby

* Subsequently Plugged

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF	TOTAL TUBES : 10,164																			
PLANT : FESSENHEIM 2	TUBE MATERIAL : I-600 MA																			
PLUGGED: 104	SG MODEL : FRAM-51A																			
" : 10.0	H. L. TEMP (F) : 611																			
	C.L. TEMP (F) : 543																			
DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP																		1	1	
OD S/IGA TS																	31	27	7	65
ID SCC TS																		6	6	
ID SCC UB																			0	
FRET (PREH)																			0	
FRET (AVB)																	1	4	1	6
FRET (LP)								1											1	
HC FATIGUE																			0	
ERR/ CORR																			0	
OTHER	12									4			1	1				4	3	25
TOT PLUGGED	0	12	0	0	0	0	1	0	4	0	0	2	1	0	0	35	39	10	104	
TOT SLEEVED																			0	
T. L. OUTAGE																			0	

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF	TOTAL TUBES : 21,368																		
PLANT : FLAMANVILLE 1	TUBE MATERIAL : I-600 TT																		
PLUGGED : 56	SG MODEL : FRAM-68/19																		
EFPY : 4.4	H. L TEMP (F) : 616																		
	C.L TEMP (F) : 559																		
DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			4
ID SCC UB																			4
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CCRR																			0
OTHER										11				7	2		3	29	52
TOT PLUGGED	0	0	0	0	0	0	0	0	0	11	0	0	7	2	0	3	29	4	56
TOT SLEEVED																			0
T. L OUTAGE																			0

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF	TOTAL TUBES : 21,368																		
PLANT : FLAMANVILLE 2	TUBE MATERIAL : I-600 TT																		
PLUGGED : 57	SG MODEL : FRAM-68/19																		
EFPY : 4.1	H. L TEMP (F) : 616																		
	C.L TEMP (F) : 559																		
DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			5
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			2 1 3
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			18 25 6 49
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	20	5	0	25	7	57
TOT SLEEVED																			0
T. L OUTAGE																			0

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : OMAHA PUBLIC POWER DISTRICT TOTAL TUBES : 10,010

PLANT : FORT CALHOUN TUBE MATERIAL : I-600 MA

PLUGGED : 109 SG MODEL : CE-71

EFPY : 13.0 H. L TEMP (F) : 594

C.L TEMP (F) : 543

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WA STAGE										1									1
DENTING SP										9	28								37
DENTING TS																			0
PITTING																			0
OD S/IGA SP										8	2								10
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR							1				1								2
OTHER	49						3				4	3							59
TOT PLUGGED	49	0	0	4	0	0	0	0	0	23	33	0	0	0	0	0	0	0	109
TOT SLEEVED																			0
T. L OUTAGE											1								1

UTILITY CONTACT: J.M. Cate

PHONE NUMBER: (402) 533-6834

UTILITY : KYUSHU ELECTRIC POWER COMPANY TOTAL TUBES : 6,776

PLANT : GENKAI 1

TUBE MATERIAL : I-600 MA

PLUGGED: 649

SG MODEL : MHI-51

EFPY : 11.8

H. L. TEMP (F) : 601

C.L. TEMP (F) : 551

DEFECTS	<75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL		
WASTAGE																			0		
DENTING SP																			0		
DENTING T ₃																			0		
PITTIN'																			0		
OD S/IGA SP						233	167			105	17	38	-106		-7	-40	26/11*		422		
OD S/IGA TS									9		15	124	62	90		20	-27	14/89*		218	
ID SCC TS																			0		
ID SCC UB																			0		
FRET (PREH)																			0		
FRET (AVB)																			0		
FRET (LP)	1																		1		
HC FATIGUE																			0		
ERR/CORR																			0		
OTHER	4	2										1		1					8		
TOT PLUGGED	5	2	0	0	0	0	233	176	0	120	142	100	-15		13	-67	40/100*	0	649		
TOT SLEEVED													147	342	384		870	805	447		2995
T. L. OUTAGE	1																			1	

UTILITY CONTACT: H. Takamatsu

PHONE NUMBER: 06-441-8821

* Plugged 26 tubes, removed 11 plugs

* Plugged 14 tubes, removed 89 plugs

* Plugged 40 tubes, removed 100 plugs

UTILITY : KYUSHU ELECTRIC POWER COMPANY TOTAL TUBES : 6,764

PLANT : GENKAI 2

TUBE MATERIAL : I-600 MA

PLUGGED : 1

SG MODEL : MHI-51M

EFPY : 9.8

H. L. TEMP (F) : 599

C.L. TEMP (F) : 551

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			1
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	1
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: H. Takamatsu

PHONE NUMBER: 06-441-8821

UTILITY : ROCHESTER GAS & ELECTRIC

TOTAL TUBES : 6520

PLANT : GINNA

TUBE MATERIAL : I-600 MA

PLUGGED: 504

SG MODEL : W-44

EFPY : 17.1

H. L. TEMP (F) : 601

C.L. TEMP (F) : 552

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE	32	19		1		1				1					4				58
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS	46	39	13		13	34	7	49	5	2	6	24	85	59	14	10		37/49*	394
ID SCC TS																6			6
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)									1										1
HC FATIGUE															25				25
ERR/CORR																			0
OTHER	1		6	23	6				3						2		-8	-13	20
TOT PLUGGED	79	58	19	24	19	35	7	53	5	3	6	24	85	86	18	8	-13	-12	504
TOT SLEEVED						5	16		77	8	69	39	101	-3	502	241	207	425	1687
T. L. OUTAGE	1	1	1	1	1			1							1				7

UTILITY CONTACT: John Smith* 37 tubes plugged and
49 returned to service.PHONE NUMBER: (716) 724 8363

UTILITY : EDF

TOTAL TUBES : 21,368

PLANT : GOLFECH 1

TUBE MATERIAL : I-600 TT

PLUGGED: 14

SG MODEL : FRAM-68/19

EFPY : 0.9

H. L TEMP (F) : 616

C.L TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																10		4	14
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	10	0	0	0	4	14
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : KERNKRAFTWERK
GÖSGEN-DANIKEN
PLANT : GÖSGEN

TOTAL TUBES : 12,318
TUBE MATERIAL : 1-800

PLUGGED: 12

SG MODEL : KWU

EFPY : 11.5

H. L. TEMP (F) : 610

C.L. TEMP (F) : 558

DEFECTS	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE								*	1										1
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)															1	4	5	10	
HC FATIGUE																			0
ERR/CORR																			0
OTHER							*	1											1
TOT PLUGGED	0	0	0	0	0	0	1	1	0	0	0	0		1		4	0	5	12
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: S. Odar / R. Bouecke

* Tube pulled for investigation

PHONE NUMBER: 49-9131-18-2077 / 49-9131-18-9410

UTILITY : BAYERNWERK AG TOTAL TUBES : 16,344
 PLANT : GRAFENRHEINFELD TUBE MATERIAL : I-800
 PLUGGED : 0 SG MODEL : KWU-54GS
 EFPY : 9.2 H. L. TEMP (F) : 618
 C.L. TEMP (F) : 555

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	C	0	0	0	0	0	0	0	0	0
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: S. Odar / R. Bouecke

PHONE NUMBER: 49-9131-18-2077 / 49-9131-18-9410

UTILITY : EDF	TOTAL TUBES : 10,083																		
PLANT : GRAVELINES 1	TUBE MATERIAL : I-600 MA																		
PLUGGED : 662	SG MODEL : FRAM-51M																		
EFPY : 8.0	H. L. TEMP (F) : 613																		
	C.L. TEMP (F) : 546																		
DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			4
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			20
ID SCC TS										2	12	18	10	25	38	203	11		319
ID SCC UB												179							179
FRET (PREH)																			0
FRET (AVB)																			2
FRET (LP)																			1
HC FATIGUE																			0
ERR/CORR																			0
OTHER				10			2		1		2					86	36		137
TOT PLUGGED	0	0	0	10	0	0	2	0	1	2	193	18	10	25	38	295	68	0	662
TOT SLEEVED																			0
T. L. OUTAGE																			1

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 10,083

PLANT : GRAVELINES 2

TUBE MATERIAL : I-600

PLUGGED : 707

SG MODEL : FRAM-51M

EFPY : 8.6

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			19	
PITTING																			0	
OD S/IGA SP																			0	
OD S/IGA TS																			50	
ID SCC TS												7		11	15	16	25	72	7	153
ID SCC UB												179						5	2	186
FRET (PREH)																			0	
FRET (AVB)																			0	
FRET (LP)																			20	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER						4						2					176	81	5	268
TOT PLUGGED	0	0	0	0	4	0	0	0	0	0	188	0	11	27	24	224	210	19	707	
TOT SLEEVED																			0	
T. L. OUTAGE																			1	

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 10,083

PLANT : GRAVELINES 3

TUBE MATERIAL : I-600 MA

PLUGGED: 308

SG MODEL : FRAM-51M

EFPY : 8.5

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																		6	6
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS										2	4		11		1	10	8	30	66
ID SCC UB											90							4	94
FRET (PREH)																			0
FRET (AVB)												9		24	8	3	5	49	
FRET (LP)											4		1		15	4	4		29
HC FATIGUE																			0
ERR/CORR																			0
OTHER					8						3				11	38	4	64	
TOT PLUGGED	0	0	0	0	8	0	0	0	0	2	101	0	21	0	41	39	53	43	308
TOT SLEEVED																			0
T. L. OUTAGE												1	1						2

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF	TOTAL TUBES : 10,083
PLANT : GRAVELINES 4	TUBE MATERIAL : 1-600 MA
PLUGGED: 379	SG MODEL : FRAM-51M
EFPY : 8.3	H. L. TEMP (F) : 613
	C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																	22	9	31
PITTING																			0
OD S/IGA SP																			0
CD S/IGA TS																	4	4	
ID SCC TS										15				1	4	11	18	49	
ID SCC UB											180			10					190
FRET (PREH)																			0
FRET (AVB)															2		1	3	
FRET (LP)										2				2	3	9			16
HC FATIGUE																			0
ERR/CORR																			0
OTHER						6					1			2		1	52	24	36
TOT PLUGGED	0	0	0	0	0	6	0	0	2	16	180	0	2	13	10	94	0	56	379
TOT SLEEVED																			0
T. L. OUTAGE											1	1	1						3

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF	TOTAL TUBES : 9,990
PLANT : GRAVELINES 5	TUBE MATERIAL : I-600 TT
PLUGGED : 16	SG MODEL : FRAM-51B
EFPY : 5.8	H. L. TEMP (F) : 613
	C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																		9	9
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)															1		2	1	4
HC FATIGUE																			0
ERR/CORR																			0
OTHER												2			1				3
TOT PLUGGED	0	0	0	0	0	0	0	0	2	0	0	2	0	0	0	2	10	0	16
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 9,990

PLANT : GRAVELINES 6

TUBE MATERIAL : I-600 TT

PLUGGED : 31

SG MODEL : FRAM-51B

EFPY : 5.3

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)															6	10	1	8	25
HC FATIGUE																			0
ERR/CORR																			0
OTHER											5	1							6
TOT PLUGGED	0	0	0	0	0	0	0	0	0	5	0	1	6	0	10	0	1	8	31
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : GEMEINSCHAFTSKERN-
 KRAFTWERK GROHnde GmbH
 PLANT : GROHnde
 PLUGGED : 1
 EFPY : 7.2
 TOTAL TUBES : 16,344
 TUBE MATERIAL : I-800
 SG MODEL : KWU-54GS
 H. L TEMP (F) : 620
 C. L TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																* 1		1	
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	1	
TOT SLEEVED																			0
T. L OUTAGE																			0

UTILITY CONTACT: S. Odar / R. Bouecke

* Probably FRET (AVB)

PHONE NUMBER: 49-9131-18-2077 / 49-9131-18-9410

UTILITY : SHIKOKU ELECTRIC POWER

TOTAL TUBES : 6,776

PLANT : IKATA 1

TUBE MATERIAL : I-600 MA

PLUGGED: 272

SG MODEL : MHI-51

EFPY : 11.9

H. L. TEMP (F) : 603

C. L. TEMP (F) : 550

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP																			0	
OD S/IGA TS																			0	
ID SCC TS										134		18	6	12			12	14	55	251
ID SCC UB																			0	
FRET (PREH)																			0	
FRET (AVB)								9											9	
FRET (LP)																			0	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER									12										12	
TOT PLUGGED	0	0	0	0	0	0	9	146	0	18	6	12	0	0	12	14	55	0	272	
TOT SLEEVED											14								14	
T. L. OUTAGE																			0	

UTILITY CONTACT: H. TakamatsuPHONE NUMBER: 06-441-8821

UTILITY : SHIKOKU ELECTRIC POWER

TOTAL TUBES : 6,764

PLANT : IKATA 2

TUBE MATERIAL : I-600 MA

PLUGGED : 4

SG MODEL : MHI-51M

EFPY : 9.0

H. L. TEMP (F) : 604

C.L. TEMP (F) : 550

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																	4	4	
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	4	4	
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: H. TakamatsuPHONE NUMBER: 06-441-8821

UTILITY : CONSOLIDATED EDISON TOTAL TUBES : 13,040
 PLANT : INDIAN POINT 2 TUBE MATERIAL : I-600 MA
 PLUGGED : 1072 SG MODEL : W-44
 EFPY : 12 H. L. TEMP (F) : 589
 C.L. TEMP (F) : 530

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP		3		8	26	16	10	20		84		33	19		55		1		275
DENTING TS																			0
PITTING										79		76	90		76		27		348
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)													3						3
HC FATIGUE																			0
ERR/CORR																			0
OTHER	394	3		14				2		6			2		13		12		446
TOT PLUGGED	394	6	0	22	26	16	10	22	0	169	0	112	111	0	144	0	40	0	1072
TOT SLEEVED																			0
T. L. OUTAGE			1					1			1				1				4

UTILITY CONTACT: Jimmy Mark

PHONE NUMBER: 212-460-3599

UTILITY : NEW YORK POWER AUTHORITY TOTAL TUBES : 13,040
 PLANT : INDIAN POINT 3 (ORIGIONAL S. G.) TUBE MATERIAL : 1-600
 PLUGGED : 1828 SG MODEL : W-44
 EFPY : 6.4 H. L TEMP (F) : 595
 C.L. TEMP (F) : 543

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE										2									2
DENTING SP				4	69	9		19		5			6						112
DENTING TS																			0
PITTING						367	377		23	246	94	176	7						1290
OD S/IGA SP														R					0
OD S/IGA TS														E					0
ID SCC TS														P					0
ID SCC UB														L					0
FRET (PREH)														A					0
FRET (AVB)														C					0
FRET (LP)														E					0
HC FATIGUE														D					0
ERR/ CORR																			0
OTHER					379					32	1	1		11					424
TOT PLUGGED	0	0	0	4	448	9	367	396	0	60	249	95	182	18	0	0	0	0	1828
TOT SLEEVED							2971				635								* 3606
T. L. OUTAGE					1	1		1	1					1	1				6

UTILITY CONTACT: Jim Gillen

* Total of 3606 tubes sleeved.

PHONE NUMBER: 914-736-8450

Of these, 155 have subsequently been plugged, leaving 3451 tubes previously sleeved.

UTILITY : NEW YORK POWER AUTHORITY

TOTAL TUBES

PLANT : INDIAN POINT 3 (REPLACEMENT S. G.) TUBE MATERIAL : 1-690 TT

PLUGGED : 0

SG MODEL : W-44F

EFPY : 2.5

H. L. TEMP (F) :

C.L. TEMP (F) :

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: Jim GillenPHONE NUMBER: 914-736-8450

UTILITY : GEMEINSCHAFTSKERN-
 KRAFTWERK ISAR 2 GmbH
 PLANT : ISAR-2
 PLUGGED : 0
 EFPY : 3.8
 TOTAL TUBES : 16,472
 TUBE MATERIAL : I-800
 SG MODEL : KWU-54SK
 H. L. TEMP (F) : 615
 C.L. TEMP (F) : 558

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: S. Odar / R. Bouecke

PHONE NUMBER: 49-9131-18-2077 / 49-9131-18-9410

UTILITY : UNION ELECTRICA FENOSA

TOTAL TUBES : 2,604

PLANT : JOSE CABERA (ZORITA)

TUBE MATERIAL : I-600 MA

PLUGGED: 147

SG MODEL : W-24

EFPY : 17.1

H. L. TEMP (F) : 584

C.L. TEMP (F) : 537

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE	3				1	4	2						7	2					19
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS													1		2	1	1	5	
ID SCC TS							7	51			4	5	5	4	2	3			81
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)	1			1	2	1	1	2			1		1		3	5	1	2	21
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER	5			7	1		1	1			2	1	2			1			21
TOT PLUGGED	9	0	0	8	4	5	11	54	0	0	7	6	15	7	5	10	3	3	147
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: Gustavo BolliniPHONE NUMBER: 34-1-6516700

UTILITY : WISCONSIN PUBLIC SERVICE CORP. TOTAL TUBES : 6,776

PLANT : KEWAUNEE TUBE MATERIAL : I-600

PLUGGED: 496 SG MODEL : W-51

EFPY : 14.8 H. L. TEMP (F) : 599

C.L. TEMP (F) : 536

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP											6	1	6	10	12	43	66	56	200	
OD S/IGA TS									63	25	43	71	116	29	36	185	91	8	667	
ID SCC TS																4			4	
ID SCC UB												2	1	1				1	5	
FRET (PREH)																			0	
FRET (AVB)									9										9	
FRET (LP)																			0	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER															3		3 *-395		389	
TOT PLUGGED	0	0	0	0	0	0	0	0	72	25	49	74	123	43	52	231	-238	65	496	
TOT SLEEVED															1940	1698		690	16	4344
T. L. OUTAGE																1			1	

UTILITY CONTACT: Chuck Smoker

* 395 tubes unplugged, sleeved
and returned to service.

PHONE NUMBER: 414-388-2560 EXT. 2608

UTILITY : KOREA ELECTRIC POWER CO.

TOTAL TUBES : 6,776

PLANT : KORI 1

TUBE MATERIAL : 1-600 MA

PLUGGED: 754

SG MODEL : W-51

EFPY : 10.0

H. L. TEMP (F) : 607

C.L. TEMP (F) : 541

DEFECTS	<75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING										419	175		54	15	25				688
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																1			1
ID SCC UB																2	3	5	
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER															14	25	21	60	
TOT PLUGGED	0	0	0	0	0	0	0	0	0	419	175	0	54	29	53	0	241	754	
TOT SLEEVED															558	178	415		330 1481
T. L. OUTAGE													1				1		2

UTILITY CONTACT: YANG UOO CHOE

PHONE NUMBER:

UTILITY : KOREA ELECTRIC POWER CO.

TOTAL TUBES : 11,252

PLANT : KORI 2

TUBE MATERIAL : I-600 TT

PLUGGED: 178

SG MODEL : W-F

EFPY : 7.7

H. L. TEMP (F) : 616

C.L. TEMP (F) : 550

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS															7	116		2	125
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)															14	10	1		49
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER															2	1	1		4
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	23	127	2	0	8	4	14	178
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: YANG UOO CHOE

PHONE NUMBER: _____

UTILITY : KOREA ELECTRIC POWER CO.

TOTAL TUBES : 16,878

PLANT : KORI 3

TUBE MATERIAL : I-600 TT

PLUGGED : 30

SG MODEL : W-F

EFPY : 5.9

H. L. TEMP (F) : 619

C.L. TEMP (F) : 556

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)														7	6	4	3	9	29
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER														1					1
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	8	6	4	3	9	30
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: YANG UO CHO

PHONE NUMBER: _____

UTILITY : KOREA ELECTRIC POWER CO.

TOTAL TUBES : 16,878

PLANT : KORI 4

TUBE MATERIAL : I-600 TT

PLUGGED: 32

SG MODEL : W-5

EFPY : 5.4

H. L. TEMP (F) : 619

C.L. TEMP (F) : 556

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL		
WASTAGE																			0		
DENTING SP																			0		
DENTING TS																			0		
PITTING																			0		
OD S/IGA SP																			3		
OD S/IGA TS																			0		
ID SCC TS																			0		
ID SCC UB																			0		
FRET (PREH)																			0		
FRET (AVB)																5	3	2	9	13	32
FRET (LP)																					0
HC FATIGUE																					0
ERR/CORR																					0
OTHER																					0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	5	3	2	9	13	32	
TOT SLEEVED																					0
T. L. OUTAGE																					0

UTILITY CONTACT: YANG UOO CHOE

PHONE NUMBER: _____

UTILITY : IMATRAN VOIMA OY

TOTAL TUBES : 33216

PLANT : LOVIISA 1

TUBE MATERIAL : AISI 321

PLUGGED : 0

SG MODEL : AEE-B-213

EFPY : 12.3

H. L. TEMP (F) : 567

C.L. TEMP (F) : 505

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER							1*												0
TOT PLUGGED	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: THOMAS BUDDAS

* Defect in manufacture

PHONE NUMBER: 358 15 5501

UTILITY : IMATRAN VOIMA OY

TOTAL TUBES : 33216

PLANT : LOVIISA 2

TUBE MATERIAL : AISI 321

PLUGGED : 1

SG MODEL : AEE-B-213

EFPY : 10.4

H. L. TEMP (F) : 567

C.L. TEMP (F) : 505

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA 3P																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			1
TOT PLUGGED	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: THOMAS BUDDAS

* Defect in manufacture

PHONE NUMBER: 358 15 5501

UTILITY : MAINE YANKEE ATOMIC POWER CO. TOTAL TUBES : 17109
 PLANT : MAINE YANKEE TUBE MATERIAL : I-600 MA
 PLUGGED : 210 SG MODEL : CE-67
 EFPY : 14.0 H. L. TEMP (F) : 602
 C.L. TEMP (F) : 550

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE								12			11								23
DENTING SP															5		25	30	
DENTING TS													1					1	
PITTING										20			1	6		17	12	56	
OD S/IGA SP															1			1	
OD S/IGA TS																		0	
ID SCC TS														31		21	52		
ID SCC UB														10		4	14		
FRET (PREH)											2							2	
FRET (AVB)																		0	
FRET (LP)													2					2	
HC FATIGUE																		0	
ERR/CORR																		0	
OTHER	6			15				1			3				3		1	29	
TOT PLUGGED	6	0	0	15	0	0	0	13	0	0	36	0	2	13	0	62	0	63	210
TOT SLEEVED																		0	
T. L. OUTAGE															1			1	

UTILITY CONTACT: LINCOLN SPEED

PHONE NUMBER: (207) 882-5182

UTILITY : DUKE POWER CO.

TOTAL TUBES : 18,696

PLANT : McGuire 1

TUBE MATERIAL : I-600 MA

PLUGGED : 1492

SG MODEL : W-D2

EFPY : 6.8

H. L. TEMP (F) : 618

C.L. TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP															7	21	17	45	
OD S/IGA TS															1	8		9	
ID SCC TS										4	37	152	113	58	166	41	6	577	
ID SCC UB											383		2			4		389	
FRET (PREH)								7	2					7	1	1	1	19	
FRET (AVB)																7	4	11	
FRET (LP)															1	4	1	6	
HC FATIGUE																		0	
ERR/CORR																		0	
OTHER						80		2						1	3	6	6	330	436
TOT PLUGGED	0	0	0	0	0	80	0	9	2	0	4	420	153	125	74	185	82	358	1492
TOT SLEEVED																397	458		855
T. L. OUTAGE														1		1		1	3

UTILITY CONTACT: Dan MayesPHONE NUMBER: 704-382-4211

UTILITY : DUKE POWER CO.

TOTAL TUBES : 18,696

PLANT : McGuire 2

TUBE MATERIAL : I-600 MA

PLUGGED : 1099

SG MODEL : W-D3

EFPY : 6.5

H. L. TEMP (F) : 618

C.L. TEMP (F) : 558

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																		6	6
OD S/IGA TS																	4	4	
ID SCC TS										5	141	152	139	4					441
ID SCC UB										50	406								456
FRET (PREH)															3		3	6	
FRET (AVB)																1	4	5	
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER									1						31	12	137	181	
TOT PLUGGED	0	0	0	0	0	0	0	1	0	0	50	411	141	152	173	17	0	154	1099
TOT SLEEVED																	478		137
T. L. OUTAGE															1				1

UTILITY CONTACT: Dan Mayes

PHONE NUMBER: 704-382-4211

UTILITY : KANSAI ELECTRIC POWER TOTAL TUBES : 8,852

PLANT : MIHAMA 1 TUBE MATERIAL: I-600 MA

PLUGGED: 1875 SG MODEL : CE

EPPY : 9.4 H. L. TEMP (F) : 599

C.L. TEMP (F) : 553

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE	1149	180																	1329
DENTING SP																			0
DENTING TS																			0
PITTING																6		243	249
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER	870	15					13								-47	-320	-235	1	297
TOT PLUGGED	2019	195	0	0	0	0	13	0	0	0	0	0	0	-47	-314	-235	0	244	1875
TOT SLEEVED																			0
T. L. OUTAGE		2																1	3

UTILITY CONTACT: H. Takamatsu

PHONE NUMBER: 06-441-8821

UTILITY : KANSAI ELECTRIC POWER

TOTAL TUBES : 6,520

PLANT : MIHAMA 2

TUBE MATERIAL : I-600 MA

PLUGGED : 412

SG MODEL : MHI-44

EFPY : 11.5

H. L. TEMP (F) : 59 $\frac{1}{2}$

C.L. TEMP (F) : 653

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE	266															11		277	
DENTING SP																		0	
DENTING TS																		0	
PITTING																		0	
OD S/IGA SP										13								13	
OD S/IGA TS						25	17			7	6			2	1			58	
ID SCC TS										36						5		41	
ID SCC UB												1						1	
FRET (PREH)																		0	
FRET (AVB)												1	4					5	
FRET (LP)																		0	
HC FATIGUE																1		1	
ERR/CORR																		0	
OTHER		4		8		1						1		2				16	
TOT PLUGGED	266	4	0	8	25	18	0	13	43	6	0	3	6	3	0	16	1	0	412
<hr/>																			
TOT SLEEVED									3	14	25		-1						41
T. L. OUTAGE	1					1				1						* 1		4	

UTILITY CONTACT: akamatsu

* Longterm outage due to tube break
by highcycle fretting fatigue

PHONE NUMBER: 06-441-8821

UTILITY : KANSAI ELECTRIC POWER

TOTAL TUBES : 10,164

PLANT : MIHAMA 3

TUBE MATERIAL : I-600 MA

PLUGGED: 535

SG MODEL : MHI-51

EFPY : 11.5

H. L. TEMP (F) : 608

C. L. TEMP (F) : 551

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP																51	61	112		
OD S/IGA TS																			0	
ID SCC TS										108	3	17		12	22	60		108	88	418
ID SCC UB																			0	
FRET (PREH)																			0	
FRET (AVB)													2						2	
FRET (LP)																			0	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER	2															1			3	
TOT PLUGGED	2	0	0	0	0	0	0	0	108	3	19	0	12	23	60	0	159	149	535	
TOT SLEEVED																			0	
T. L. OUTAGE																			0	

UTILITY CONTACT: H. TakamatsuPHONE NUMBER: 06-441-8821

UTILITY : NORTHEAST UTILITIES

TOTAL TUBES : 17,038

PLANT : MILLSTONE 2 (ORIGINAL S. G.)

TUBE MATERIAL : I-600 MA

PLUGGED: 3080

SG MODEL : CE-67

EFPY : 10.9

H. L. TEMP (F) : 604

C.L. TEMP (F) : 550

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP		763		4	1						3		6		6	13			796
DENTING TS						4			11		3								18
PITTING					704		180			56	22	36	366	236	54	1			1655
OD S/IGA SP																	2		2
OD S/IGA TS												1	26	413	30	34			504
ID SCC TS																	R		0
ID SCC UB																	E		0
FRET (PREH)																	P		0
FRET (AVB)																	L		0
FRET (LP)																	A		0
HC FATIGUE																	C		0
ERR/CORR																	E		0
OTHER	30				1		1		1		4	3	44	3		4	14	D	105
TOT PLUGGED	30	0	763	0	5	1	709	0	192	0	63	28	81	401	649	94	64		3080
TOT SLEEVED									2022		2917	225							*5164
T. L. OUTAGE									1				1				1		3

UTILITY CONTACT: John Kliesiewick* Approximately 535 sleeved tubes
have been plugged.PHONE NUMBER: 203-665-3969

UTILITY : NORTHEAST UTILITIES

TOTAL TUBES :

PLANT : MILLSTONE 2 (REPLACEMENT S. G.)

TUBE MATERIAL : I-690 TT

PLUGGED: 3080

SG MODEL : B&W CANADA

EPPY : 0.0

H. L. TEMP (F) :

C.L. TEMP (F) :

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			C
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	C
TOT SLEEVED																			0
T. L. OUTAGE																			C

UTILITY CONTACT: John KliesiewickPHONE NUMBER: 203-665-3969

UTILITY : NORTHEAST UTILITIES

TOTAL TUBES : 22054

PLANT : MILLSTONE 3

TUBE MATERIAL : I-600 TT

PLUGGED : 21

SG MODEL : W-F

EFPY : 4.5

H. L. TEMP (F) : 621

C.L. TEMP (F) : 558

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)															2	3	5		10
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER													5	5			1		11
TOT PLUGGED	0	0	0	0	0	0	0	0	0	5	5	0	2	0	4	0	5	0	21
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: John Klesiewicz

PHONE NUMBER: 203-665-3969

UTILITY : GEMEINSCHAFTSKERN-
KRAFTWERK NECKAR GmbH
PLANT : NECKARWESTHEIM-1

TOTAL TUBES : 12,063
TUBE MATERIAL : I-800

PLUGGED : 18

SG MODEL : KWU

EFPY : 12.6

H. L. TEMP (F) : 612

C.L. TEMP (F) : 560

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE						3		1	1				1	5		1			12
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																3			3
HC FATIGUE																			0
ERR/CORR																			0
OTHER						*	3												3
TOT PLUGGED	0	0	0	0	0	6	0	1	1	0	0	0	1	5	0	1	3	0	18
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: S. Odar / R. Bouecke

* 3 Tubes pulled for investigation

PHONE NUMBER: 49-9131-18-2077 / 49-9131-18-9410

UTILITY : GEMEINSCHAFTSKERN-	TOTAL TUBES : 16,472
KRAFTWERK NECKAR GmbH	
PLANT : NECKARWESTHEIM-2	TUBE MATERIAL : I-800
PLUGGED : 0	SG MODEL : KWU-54SK
EFPY : 3.4	H. L. TEMP (F) : 616
	C.L. TEMP (F) : 558

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: S. Odar / R. Bouecke

PHONE NUMBER: 49-9131-18-2077 / 49-9131-18-9410

UTILITY : EDF

TOTAL TUBES : 21,368

PLANT : NOGENT / SEINE 1

TUBE MATERIAL : I-600 TT

PLUGGED : 279

SG MODEL : FRAM-68/19

EFPY : 3.0

H. L. TEMP (F) : 616

C.L. TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																246	8	3	259
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																1	1		1
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)															6				6
HC FATIGUE																			0
ERR/CORR																			0
OTHER																1	11	1	13
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	252	10	14	3	279
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 21,368

PLANT : NOGENT / SEINE 2

TUBE MATERIAL : I-600 TT

PLUGGED : 57

SG MODEL : FRAM-68/19

EFFY : 2.8

H. L. TEMP (F) : 616

C.L. TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																	1	1	10	12
PITTING																			0	
OD S/IGA SP																			0	
OD S/IGA TS																			0	
ID SCC TS																			0	
ID SCC UB																			0	
FRET (PREH)																			0	
FRET (AVB)																	4	4		
FRET (LP)																15			15	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER															3		21	2	26	
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	3	0	15	1	22	16	57
TOT SLEEVED																				0
T. L. OUTAGE																	1			1

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : Virginia Power

TOTAL TUBES : 10164

PLANT : North Anna 1

TUBE MATERIAL : I-600 MA

PLUGGED : 2065

SG MODEL : W-51

EFPY : 9.5

H. L. TEMP (F) : 614

C.L. TEMP (F) : 547

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE													1						1
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP													2			92	470	564	
OD S/IGA TS											1	2	45	3		49		100	
ID SCC TS													45	28		198	36	307	
ID SCC UB				279*		3							1	2					285
FRET (PREH)																			0
FRET (AVB)														3					3
FRET (LP)																			0
HC FATIGUE													1						1
ERR/CORR																			0
OTHER					2					24	84	423^		118		268/136#	21	804	
TOT PLUGGED	0	0	0	0	281	0	3	0	0	25	86	0	516	0	156	0	471	527	2065
TOT SLEEVED																			0
T. L. OUTAGE										1	1		1		1				4

UTILITY CONTACT: Joe Eastwood

* 279 preventively plugged

PHONE NUMBER: (804) 273-2730^ 245 plugged to IDSCC at tube support plate
178 plugged due to 7th support plate fatigue issue.

136 previously plugged tubes returned to service

UTILITY : Virginia Power

TOTAL TUBES : 10164

PLANT : North Anna 2

TUBE MATERIAL : I-600 MA

PLUGGED: 712

SG MODEL : W-51

EFPY : 9.3

H. L. TEMP (F) : 614

C.L. TEMP (F) : 547

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE										1		1	16						18
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP															8	30	204	242	
OD S/IGA TS															1	30	9	40	
ID SCC TS												2	5		7		13	45	
ID SCC UB					282*							6	5		6	2			301
FRET (PREH)																			0
FRET (AVB)														7		6	11	9	33
FRET (LP)												2		2					4
HC FATIGUE																			0
ERR/CORR																			0
OTHER													120^		19/116#		15	29	
TOT PLUGGED	0	0	0	0	282	0	0	0	0	3	0	9	155	0	29	-16	0	250	712
TOT SLEEVED																			0
T. L. OUTAGE												1	1		1		1		4

UTILITY CONTACT: Joe Eastwood

* 282 preventively plugged (Row 1)

PHONE NUMBER: (804) 273-2730

^ 118 preventively plugged due to
7th support plate fatigue issue# 116 previously plugged tubes returned to service
(7th support plate fatigue issue)

UTILITY : KERNKRAFTWERK TOTAL TUBES : 5,210
 OBRIGHEIM GmbH
 PLANT : OBRIGHEIM (ORIGINAL S. G.) TUBE MATERIAL : I-600 MA
 PLUGGED : 461 SG MODEL : KWU
 EFPY : 11.2 H. L. TEMP (F) : 589
 C.L. TEMP (F) : 541

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS										R									0
PITTING										E									0
OD S/IGA SP										P									0
OD S/IGA TS	26		1			3	2		L										32
ID SCC TS					5	16	29	88	A										138
ID SCC UB	12					1	2			C									15
FRET (PREH)										E									0
FRET (AVB)										D									0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER *	160	8	23	32	9	28	14	2											276
TOT PLUGGED	198	8	24	32	15	49	45	90	0	0	0	0	0	0	0	0	0	0	461
<hr/>																			
TOT SLEEVED																			0
T. L. OUTAGE	6	1	2																9

UTILITY CONTACT: S. Odar / R. Bouecke

* Probably SCC

PHONE NUMBER: 49-9131-18-2077 / 49-9131-18-9410

UTILITY : KERNKRAFTWERK TOTAL TUBES : 6,020
 OBRIGHEIM GmbH
 PLANT : OBRIGHEIM (REPLACEMENT S. G.) TUBE MATERIAL : I-800
 PLUGGED : 0 SG MODEL : KWU
 EFPY : 6.9 H. L. TEMP (F) : 589
 C. L. TEMP (F) : 534

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: S. Odar / R. Bouecke

PHONE NUMBER: 49-9131-18-2077 / 49-9131-18-9410

UTILITY : DUKE POWER

TOTAL TUBES : 31602

PLANT : OCONEE 1

TUBE MATERIAL : I-600 MA

PLUGGED : 1266

SG MODEL : OTSG

EFPY : 13.6

H. L. TEMP (F) : 604

C. L. TEMP (F) : 554

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
H.C FATIGUE	6	2				1							20				2	31	
ERR/CORR		45		75		41		24	48				59		50	50	49	550	991
OTHER	2		8	47	9		3	2		8	3	81			11	10	50	244	
TOT PLUGGED	2	6	55	47	84	0	45	2	24	56	3	81	79	0	61	60	49	62	1266
TOT SLEEVED				6									469						475
T. L. OUTAGE		2	4	1	1		1	2				1	2						14

UTILITY CONTACT: Dan MayesPHONE NUMBER: (704) 382-4211

UTILITY : DUKE POWER

TOTAL TUBES : 31602

PLANT : OCONEE 2

TUBE MATERIAL : I-600 MA

PLUGGED : 180

SG MODEL : OTSG

EFPY : 13.1

H. L. TEMP (F) : 604

C.L. TEMP (F) : 554

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP																			0	
OD S/IGA TS																			0	
ID SCC TS																			0	
ID SCC UB																			0	
FRET (PREH)																			0	
FRET (AVB)																			0	
FRET (LP)																			0	
HC FATIGUE	1			5			1							12	1				20	
ERR/CORR		1								8					16	5			70	100
OTHER	10	3		8		1		9			9			9	3	1		7	60	
TOT PLUGGED	11	4	0	13	0	1	1	9	8	0	9	0	0	37	9	1	0	77	180	
TOT SLEEVED																			0	
T. L. OUTAGE			1		1			1							1		1		5	

UTILITY CONTACT: Dan MayesPHONE NUMBER: (704) 382-4211

UTILITY : DUKE POWER

TOTAL TUBES : 31602

PLANT : OCONEE 3

TUBE MATERIAL : I-600 MA

PLUGGED: 376

SG MODEL : OTSG

EFPY : 12.8

H. L. TEMP (F) : 604

C.L. TEMP (F) : 554

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
OENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE		3	3			5							18	8					37
ERR/CORR											13			55	41				114 223
OTHER			12	1	2			22			16	7		23	21				12 116
TOT PLUGGED	0	3	15	1	2	5	0	22	0	13	16	7	73	72	21	0	0	126	376
TOT SLEEVED														247					247
T. L. OUTAGE			1	3			1		2		1	2	1	1	1				13

UTILITY CONTACT: Dan MayesPHONE NUMBER: (704) 382-4211

UTILITY : KANSAI ELECTRIC POWER

TOTAL TUBES : 13,552

PLANT : OHI 1

TUBE MATERIAL : I-600 MA

PLUGGED : 2018

SG MODEL : W-51A

EFPY : 7.6

H. L. TEMP (F) : 613

C.L. TEMP (F) : 552

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP						26	285		475	-60	31	89	-57	-10	150/94				835
OD S/IGA TS																			0
ID SCC TS						46	105		185	42	25	121	-59	-48	76/66				427
ID SCC UB						31													31
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER						723					1			1					725
TOT PLUGGED	0	0	0	0	0	0	754	72	390	0	661	-18	56	211	-116	-58	226/160	0	2018
TOT SLEEVED										81	443	650	743	162	1122	863		877	4941
T. L. OUTAGE							1												1

* Plugged 150 tubes, removed 94 plugs

* Plugged 76 tubes, removed 66 plugs

* Plugged 226 tubes, removed 160 plugs

UTILITY CONTACT: H. Takamatsu

PHONE NUMBER: 06-441-8821

UTILITY : KANSAI ELECTRIC POWER

TOTAL TUBES : 13,552

PLANT : OHI 2

TUBE MATERIAL : I-600 MA

PLUGGED : 485

SG MODEL : MHI-51A

EFPY : 9.3

H. L. TEMP (F) : 613

C.L. TEMP (F) : 552

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL		
WASTAGE																			0		
DENTING SP																			0		
DENTING TS																			0		
PITTING																			0		
OD S/IGA SP																			0		
OD S/IGA TS																			0		
ID SCC TS										63		19	8		3	14		34	32	286	485
ID SCC US																				0	
FRET (PREH)																				0	
FRET (AVB)															1	7		5	4	17	
FRET (LP)																				0	
HC FATIGUE																				0	
ERR/CORR																				0	
OTHER									3											3	
TOT PLUGGED	0	0	0	0	0	0	3	63	0	19	8	0	10	21	0	39	36	286	485		
TOT SLEEVED											8				-1				-3	4	
T. L. OUTAGE																				0	

UTILITY CONTACT: H. TakamatsuPHONE NUMBER: 06-441-8821

UTILITY : KANSAI ELECTRIC POWER

TOTAL TUBES : 13,528

PLANT : OHI 3

TUBE MATERIAL : I-690 TT

PLUGGED : 0

SG MODEL : MHI-52FA

EFPY : 1.0

H. L. TEMP (F) : 617

C.L. TEMP (F) : 553

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: H. Takamatsu

PHONE NUMBER: 06-441-8821

UTILITY : CONSUMERS POWER CO.

TOTAL TUBES : 17,038

PLANT : PALISADES (ORIGINAL S. G.)

TUBE MATERIAL : I-600

PLUGGED : 4486

SG MODEL : CE

EFPY : 8.3

H. L. TEMP (F) : 599

C.L. TEMP (F) : 548

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE	2951	711		12	14		44			3									3735
DENTING SP				4	6		5			6	8		3	19					51
DENTING TS																			0
PITTING															R				0
OD S/IGA SP										27			15	18	96	E			156
OD S/IGA TS															P				0
ID SCC TS															L				0
ID SCC US															A				0
FRET (PREH)															C				0
FRET (AVB)															E				0
FRET (LP)															D				0
HC FATIGUE																			0
ERR/CORR														2	4				6
OTHER									2	244				5	287				538
TOT PLUGGED	2951	711	0	16	20	0	49	2	0	280	8	0	20	46	383	0	0	0	4486
TOT SLEEVED			10		23														33
T. L. OUTAGE	2								1				1	2	2				8

UTILITY CONTACT: Ron HiltzmanPHONE NUMBER: 616-764-8913 ext. 0318

UTILITY : CONSUMERS POWER CO.

TOTAL TUBES

PLANT : PALISADES (REPLACEMENT S. G.)

TUBE MATERIAL : I-600 MA

PLUGGED : 617

SG MODEL : CE

EFPY : 1.8

H. L. TEMP (F) : 591

C.L. TEMP (F) : 545

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE															R				0
DENTING SP															E				0
DENTING TS															P				0
PITTING															L				0
OD S/IGA SP															A				0
OD S/IGA TS															C				0
ID SCC TS															E				0
ID SCC UB															D				0
FRET (PREH)																			0
FRET (AVB)															* 617				617
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	617
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: Ron Hilterman

* Preventively plugged

PHONE NUMBER: 616-764-8913 ext. 0318

UTILITY : ARIZONA PUBLIC SERVICE CO. TOTAL TUBES : 22,024

PLANT : PALO VERDE 1 TUBE MATERIAL : I-600 MA

PLUGGED : 140 SG MODEL : CE-80

EFPY : 3.9 H. L. TEMP (F) : 621

C.L. TEMP (F) : 565

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																		8	8
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)													29		6				35
FRET (AVB)														6		7		13	
FRET (LP)													9	2					11
HC FATIGUE																			0
ERR/CORR																			0
OTHER										* 34			6		8		25		73
TOT PLUGGED	0	0	0	0	0	0	0	0	0	34	0	0	44	0	22	0	0	40	140
TOT SLEEVED																			0
T. L. OUTAGE														1					1

UTILITY CONTACT: Kevin Sweeney

* Baseline

PHONE NUMBER: 602-340-4809

UTILITY : ARIZONA PUBLIC SERVICE CO.

TOTAL TUBES : 22,024

PLANT : PALO VERDE 2

TUBE MATERIAL : I-600 MA

PLUGGED: 310

SG MODEL : CE-80

EFFY : 3.9

H. L. TEMP (F) : 621

C.L. TEMP (F) : 565

DEFECTS	<70	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																	6	6	
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)													51	12		2	8		73
FRET (AVB)													44		100	18			162
FRET (LP)													1			7			8
HC FATIGUE																			0
ERR/CORR																			0
OTHER													* 47			4	8	2	61
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	47	0	51	61	0	110	41	0	310
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: Kevin Sweeney

* Baseline

PHONE NUMBER: 602-340-4809

UTILITY : ARIZONA PUBLIC SERVICE CO. TOTAL TUBES : 22,024

PLANT : PALO VERDE 3 TUBE MATERIAL: I-600 MA

PLUGGED: 199 SG MODEL : CE-80

EFPY : 4.4 H. L. TEMP (F) : 621

C.L. TEMP (F) : 565

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)														**120					120
FRET (AVB)																4	2	11	17
FRET (LP)																9			9
HC FATIGUE																			0
ERR/CORR																			0
OTHER													*36			4	1	12	53
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	36	120	0	17	0	3	23	199
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: Kevin Sweeney

* Baseline

PHONE NUMBER: 602-340-4809

** Preventively plugged

UTILITY : EDF

TOTAL TUBES : 21,368

PLANT : PALUEL 1

TUBE MATERIAL : I-600 TT

PLUGGED : 139

SG MODEL : FRAM-68/19

EFPY . 5.4

H. L. TEMP (F) : 616

C.L. TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																	13	1	22	
PITTING																			0	
OD S/IGA SP																			0	
OD S/IGA TS																			0	
ID SCC TS																1	1		2	
ID SCC UB																			0	
FRET (PREH)																			0	
FRET (AVB)																			0	
FRET (LP)																4	2	15	21	
HC FATIGUE																			0	
ERR/CORR																	2		2	
OTHER									32					22	1		13	5	19	92
TOT PLUGGED	0	0	0	0	0	0	0	32	0	0	0	22	1	0	20	21	27	16	139	
TOT SLEEVED																			0	
T. L. OUTAGE																			0	

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF	TOTAL TUBES : 21,368																				
PLANT : PALUEL 2	TUBE MATERIAL : I-600 TT																				
PLUGGED : 130	SG MODEL : FRAM-68/19																				
EFPY : 5.2	H. L. TEMP (F) : 616																				
	C.L. TEMP (F) : 559																				
DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL		
WASTAGE																			0		
DENTING SP																			0		
DENTING TS																		40	40		
PITTING																			0		
OD S/IGA SP																			0		
OD S/IGA TS																			0		
ID SCC TS																2	47	1	50		
ID SCC UB																			0		
FRET (PREH)																			0		
FRET (AVB)																			0		
FRET (LP)															1		2	1	4		
HC FATIGUE																			0		
ERR/CORR																			0		
OTHER									9					3	3	1		5	4	11	36
TOT PLUGGED	0	0	0	0	0	0	0	0	9	0	0	4	3	3	0	94	5	12	130		
TOT SLEEVED																			0		
T. L. OUTAGE																			0		

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 21,368

PLANT : PALUEL 3

TUBE MATERIAL : I-600 TT

PLUGGED : 132

SG MODEL : FRAM-68/19

EFPY : 5.0

H. L. TEMP (F) : 616

C.L. TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																	48	2	50
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)													4		6	29			39
HC FATIGUE																			0
ERF/CORR																1			1
OTHER									25								15	2	42
TOT PLUGGED	0	0	0	0	0	0	0	0	25	0	0	4	0	6	78	17	0	2	132
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. ComblyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF	TOTAL TUBES : 21,368																			
PLANT : PALUEL 4	TUBE MATERIAL : I-600 TT																			
PLUGGED : 144	SG MODEL : FRAM-68/19																			
EFPY : 4.5	H. L. TEMP (F) : 616																			
	C.L. TEMP (F) : 559																			
DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																68	1	6	2	77
PITTING																			0	
OD S/IGA SP																			0	
OD S/IGA TS																			0	
ID SCC TS																2	1		3	
ID SCC UB																			0	
FRET (PREH)																			0	
FRET (AVB)																	1	1		
FRET (LP)																1	26		27	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER										16				1	2		4	13	36	
TOT PLUGGED	0	0	0	0	0	0	0	0	0	16	0	0	1	3	94	7	20	3	144	
TOT SLEEVED																			0	
T. L. OUTAGE																			0	

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF	TOTAL TUBES : 21,368																		
PLANT : PENLY 1	TUBE MATERIAL : I-600 TT																		
PLUGGED : 37	SG MODEL : FRAM-68/19																		
EFPY : 1.4	H. L TEMP (F) : 616																		
	C.L TEMP (F) : 559																		
DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																		0	
DENTING SP																		0	
DENTING TS																		0	
PITTING																		0	
OD S/IGA SP																		0	
OD S/IGA TS																		0	
ID SCC TS																		0	
ID SCC UB																		0	
FRET (PREH)																		0	
FRET (AVB)																		0	
FRET (LP)															17			17	
HC FATIGUE																		0	
ERR/CORR																		0	
OTHER														16		4		20	
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	16	0	17	4	0	37
TOT SLEEVED																		0	
T. L. OUTAGE																1		1	

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 21,368

PLANT : PENLY 2

TUBE MATERIAL : I-690 TT

PLUGGED : 4

SG MODEL : FRAM-68/19

EFPY : 0.4

H. L TEMP (F) : 616

C. L TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																4			4
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	4	0	0	4
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : KERNKRAFTWERK
PHILIPPSBURG GmbH
PLANT : PHILIPPSBURG-2

TOTAL TUBES : 16,424

PLUGGED : 0

TUBE MATERIAL : I-800

EFPY : 6.6

SG MODEL : KWU-54S

H. L. TEMP (F) : 622

C.L. TEMP (F) : 557

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: S. Odar / R. Bouecke

PHONE NUMBER: 49-9131-18-2077 / 49-9131-18-9410

UTILITY : WISCONSIN ELECTRIC POWER

TOTAL TUBES : 6,520

PLANT : POINT BEACH 1 (ORIGINAL S. G.)

TUBE MATERIAL : I-600 MA

PLUGGED: 905

SG MODEL : W-44

EFPY : 9.2

H. L. TEMP (F) : 597

C.L. TEMP (F) : 545

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE	167		1			1	1	6											176
DENTING SP			10	1															11
DENTING TS																			0
PITTING										R									0
OD S/IGA SP	180				5					E									185
OD S/IGA TS			3	10	271	110	20	59		P									473
ID SCC TS										L									0
ID SCC UB										A									0
FRET (PREH)										C									0
FRET (AVB)										E									0
FRET (LP)				2				11		D									13
HC FATIGUE																			0
ERR/CORR																			0
OTHER	18				14	12		3											47
TOT PLUGGED	365	0	14	13	290	123	21	79	0	0	0	0	0	0	0	0	0	0	905
TOT SLEEVED							13												13
T. L OUTAGE	1		1	3	4														9

UTILITY CONTACT: Gary FrieslingPHONE NUMBER: 414-221-2017

UTILITY : WISCONSIN ELECTRIC POWER TOTAL TUBES : 6,520
 PLANT : POINT BEACH 1 (REPAACEMENT S. G.) TUBE MATERIAL : I-600 TT
 PLUGGED : 5 SG MODEL : W-44F
 EFPY : 7.1 H. L. TEMP (F) : 597
 C.L. TEMP (F) : 545

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP																			0	
OD S/IGA TS																			0	
ID SCC TS																			0	
ID SCC UB																			0	
FRET (PREH)																			0	
FRET (AVB)																	2	2		
FRET (LP)																			0	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER															2		1		3	
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	2	0	0	0	1	0	0	2	0	5
TOT SLEEVED																				0
T. L. OUTAGE																				0

UTILITY CONTACT: Gary Frielng

PHONE NUMBER: 414-221-2017

UTILITY : WISCONSIN ELECTRIC POWER

TOTAL TUBES : 6,520

PLANT : POINT BEACH 2

TUBE MATERIAL : I-600 MA

PLUGGED : 589

SG MODEL : W-44

EFPY : 16.3

H. L. TEMP (F) : 597

C.L. TEMP (F) : 545

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE	3	16	5		1	35	39	7	2	1	43	55		3	4			214	
DENTING SP			2										1					3	
DENTING TS														2				2	
PITTING																		0	
OD S/IGA SP	7												2	1		7		17	
OD S/IGA TS					1	2	9	8	14	11	17	41	21	27	109	85	345		
ID SCC TS																		0	
ID SCC UB																		0	
FRET (PREH)																		0	
FRET (AVB)																		0	
FRET (LP)																		0	
HC FATIGUE																		0	
ERR/CORR																		0	
OTHER	1									2			4			1		8	
TOT PLUGGED	11	16	7	0	1	36	41	16	10	17	54	72	48	25	33	117	0	85	589
<hr/>																			
TOT SLEEVED										3001				87	509			*3597	
T. L. OUTAGE	1					1												2	

UTILITY CONTACT: Gary Frieling

* 2310 tubes with one hot leg sleeve

596 tubes sleeved in hot and cold legs

PHONE NUMBER 414-221-2017

UTILITY : NORTHERN STATE POWER CO.

TOTAL TUBES : 6,776

PLANT : PRAIRIE ISLAND 1

TUBE MATERIAL : I-600 MA

PLUGGED : 194

SG MODEL : W-51

EFPY : 15.3

H. L. TEMP (F) : 590

C.L. TEMP (F) : 530

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE							4		4	3	4	5	7	4		10	1	2	44
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																1			1
OD S/IGA TS						1			9	5	6	6	22	9		*4/26	14	46	97
ID SCC TS																			0
ID SCC U8																	1		1
FRET (PREH)																			0
FRET (AVB)							18		5		5								28
FRET (LP)						6							1						7
HC FATIGUE																			0
ERR/CORR																			0
OTHER							4			1	1	3	2	4		*0/1	1	1	16
TOT PLUGGED	0	0	0	0	6	1	26	0	18	9	16	15	31	17	0	*15/27	17	49	194
TOT SLEEVED															26	73		62	
T. L. OUTAGE						1	1			1	2			1				1	7

UTILITY CONTACT: Richard Pearson

* Total of 27 tubes returned to service

PHONE NUMBER: (612) 388-1121

UTILITY : NORTHERN STATE POWER CO.

TOTAL TUBES : 6,776

PLANT : PRAIRIE ISLAND 2

TUBE MATERIAL : I-600 MA

PLUGGED: 237

SG MODEL : W-51

EFPY : 15.1

H. L. TEMP (F) : 590

C.L. TEMP (F) : 530

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE					13	18	18	19	27	12	24		5	7	29		13	182	
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IG4 SP																			0
OD S/IGA TS																			0
ID SCC TS																1			1
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)						23	6			6	4								39
FRET (LP)						4													4
HC FATIGUE																			0
ERR/CORR							1												1
OTHER			1			1		3	1			3					1	10	
TOT PLUGGED	0	0	1	0	0	18	42	27	20	33	19	24	0	5	8	29	0	11	237
TOT SLEEVED																			0
T. L. OUTAGE							1												1

UTILITY CONTACT: Richard PearsonPHONE NUMBER: (612) 388-1121

UTILITY : SACRAMENTO MUNICIPAL UTIL. DIST. TOTAL TUBES : 15547

PLANT : RANCHO SECO

TUBE MATERIAL : I-600 TT

PLUGGED : 221

SG MODEL : OTSG

EFPY :

H. L. TEMP (F) : 604

C.L. TEMP (F) : 554

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																S			0
OD S/IGA SP								4								H			4
OD S/IGA TS									9							U			9
ID SCC TS																T			0
ID SCC UB																D			0
FRET (PREH)																O			0
FRET (AVB)																W			0
FRET (LP)																N			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER			24			3		12		3	29	38	83	16					208
TOT PLUGGED	0	0	24	0	0	3	4	21	0	3	29	38	83	16	0	0	0	0	221
TOT SLEEVED															508				508
T. L. OUTAGE									1	1	1	3							6

UTILITY CONTACT: Jim Field

PHONE NUMBER: (209) 333-2935

UTILITY : SWEDISH STATE POWER BOARD

TOTAL TUBES : 10,164

PLANT : RINGHALS 2 (ORIGINAL S. G.)

TUBE MATERIAL : I-600

PLUGGED : 1752

SG MODEL : W-51

EFPY :

H. L. TEMP (F) : 609

C.L. TEMP (F) : 556

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP				1	1	1		1											4	
DENTING TS																			0	
PITTING														R					0	
OD S/IGA SP													E						0	
OD S/IGA TS						3	53	71	309	248	108	59	510	P					1361	
ID SCC TS								10		1	2	11	15	1	L				40	
ID SCC UB					2					3				1	A				6	
FRET (PREH)														C					0	
FRET (AVB)										1	1	1	1	1	E				5	
FRET (LP)													D						0	
HC FATIGUE																			0	
ERR/CCRR																			0	
OTHER		230	1	64	1				12	10	3	2	8	5					336	
TOT PLUGGED	0	0	230	2	67	2	3	64	83	324	254	122	83	518	0	0	0	0	1752	
TOT SLEEVED										35	50	596	554							1235
T. L. OUTAGE					2		2	3	2		1								10	

UTILITY CONTACT: Jan EngstromPHONE NUMBER: (08) 739-5000

UTILITY : SWEDISH STATE POWER BOARD TOTAL TUBES : 15,390
 PLANT : RINGHALS 2 (REPLACEMENT S. G.) TUBE MATERIAL : I-690 TT
 PLUGGED : 0 SG MODEL : KWU
 EFPY : 2.5 H. L. TEMP (F) : 613
 C.L. TEMP (F) : 548

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: Jan Engstrom

PHONE NUMBER: (08) 739-5000

UTILITY : SWEDISH STATE POWER BOARD TOTAL TUBES : 14,022

PLANT : RINGHALS 3 TUBE MATERIAL : I-600

PLUGGED: 249 SG MODEL : W-D3

EFPY : 7.6 H. L. TEMP (F) : 610

C.L. TEMP (F) : 543

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP													1	1	16	3			21
OD S/IGA TS																			0
ID SCC TS											6	3	27	42	22	4	6	110	
ID SCC UB												4				13	11		28
FRET (PREH)					2	23	8										1		34
FRET (AVB)													3			2			6
FRET (LP)										1	2	6							9
HC FATIGUE																			0
ERR/CORR																			0
OTHER										1		7	1	2	11	8	4	7	41
TOT PLUGGED	0	0	0	0	0	0	2	23	8	2	2	19	9	33	69	47	22	13	249
TOT SLEEVED																	57		57
T. L. OUTAGE									1										1

UTILITY CONTACT: Jan Engstrom

PHONE NUMBER: (08) 739-5000

UTILITY : SWEDISH STATE POWER BOARD

TOTAL TUBES : 14,022

PLANT : RINGHALS 4

TUBE MATERIAL : I-600

PLUGGED : 173

SG MODEL : W-E

EFPY : 7.2

H. L. TEMP (F) : 610

C.L. TEMP (F) : 543

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS									1	2	2	5	5	9	5	26	37	92	
ID SCC UB											3	16	4	7		1	1		32
FRET (PREH)																			2 2
FRET (AVB)																			5 9
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER									1	3				11	12	10		1	38
TOT PLUGGED	0	0	0	0	0	0	0	0	1	4	2	5	21	20	30	17	27	46	173
TOT SLEEVED																			0
T. L. OUTAGE														1					1

UTILITY CONTACT: Jan EngstromPHONE NUMBER: (08) 739-5000

UTILITY : CAROLINA POWER & LIGHT CO.

TOTAL TUBES : 9,642

PLANT : H. B. ROBINSON (ORIGINAL S. G.)

TUBE MATERIAL : I-600 MA

PLUGGED : 2290

SG MODEL : W-44

EFPY : 8.5

H. L. TEMP (F) : 601

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE	14	12	19	21	23	211	102	100	69										571
DENTING SP																			0
DENTING TS																			0
PITTING										R									0
OD S/IGA SP										66	E								66
OD S/IGA TS	70				11		300	87	800	P									1268
ID SCC TS										L									0
ID SCC UB										A									0
FRET (PREH)										C									0
FRET (AVB)										E									0
FRET (LP)										D									0
HC FATIGUE																			0
ERR/CORR																			C
OTHER	377				5				3										385
TOT PLUGGED	461	12	19	21	39	211	402	187	938	0	0	0	0	0	0	0	0	0	2290
TOT SLEEVED																			C
T. L. OUTAGE	1				1	2	1	2		2	1								10

UTILITY CONTACT: Jerry WaldorfPHONE NUMBER: 919-546-4141

UTILITY : CAROLINA POWER & LIGHT

TOTAL TUBES : 9,642

PLANT : H. B. ROBINSON (REPLACEMENT S. G.) TUBE MATERIAL : I-600 TT

PLUGGED : 3

SG MODEL : W-44F

EFPY : 5.5

H. L TEMP (F) : 604

C.L TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																1	1		2
HC FATIGUE																			0
ERR/CORR																			0
OTHER																	1	1	
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	1	0	1	3
<hr/>																			
TOT SLEEVED																			0
T. L OUTAGE																			0

UTILITY CONTACT: Jerry WaldorfPHONE NUMBER: 919-546-4141

UTILITY : EDF

TOTAL TUBES : 21,368

PLANT : SAINT-ALBAN 1

TUBE MATERIAL : I-600 TT

PLUGGED: 45

SG MODEL : FRAM-68/19

EFPY : 4.1

H. L. TEMP (F) : 616

C.L. TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE	-																		0
DENTING SP																			0
DENTING TS																	9	14	23
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																	3	3	
HC FATIGUE																			0
ERR/CORR																			0
OTHER													7	1			1	10	19
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	7	0	1	0	0	0	10	27	45
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF	TOTAL TUBES : 21,368																					
PLANT : SAINT-ALBAN 2	TUBE MATERIAL : I-600 TT																					
PLUGGED: 299	SG MODEL : FRAM-68/19																					
EFPY : 3.5	H. L. TEMP (F) : 616																					
	C.L. TEMP (F) : 559																					
DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL			
WASTAGE																			0			
DENTING SP																			0			
DENTING TS																		260	260			
PITTING																			0			
OD S/IGA SP																			0			
OD S/IGA TS																			0			
ID SCC TS																		1	5	6		
ID SCC UB																			0			
FRET (PREH)																			0			
FRET (AVB)																			0			
FRET (LP)																		1	2	3		
HC FATIGUE																			0			
ERR/CORR																		5		5		
OTHER																		9	1	10	5	25
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	10	0	267	5	10	7	299			
TOT SLEEVED																				0		
T. L. OUTAGE																				0		

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 10,083

PLANT : SAINT-LAURENT-DES EAUX B1

TUBE MATERIAL : I-600 MA

PLUGGED : 274

SG MODEL : FRAM-51M

EFFY : 7.0

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																		1	1	
PITTING																			0	
OD S/IGA SP															1		33	77	111	
OD S/IGA TS																			0	
ID SCC TS															1		4	3	8	
ID SCC UB														90	2			3	95	
FRET (PREH)																			0	
FRET (AVB)																			0	
FRET (LP)																	2	3	10	15
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER					6									1				1	36	44
TOT PLUGGED	0	0	0	0	6	0	0	0	0	0	91	0	4	0	0	6	37	130	274	
TOT SLEEVED																			0	
T. L. OUTAGE																			0	

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF	TOTAL TUBES : 10,083																		
PLANT : SAINT-LAURENT-DES EAUX B2	TUBE MATERIAL : I-600 MA																		
PLUGGED : 197	SG MODEL : FRAM-51M																		
EFPY : 7.1	H. L. TEMP (F) : 613																		
	C.L. TEMP (F) : 546																		
DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS															2		1	2	5
ID SCC UB														180					180
FRET (PREH)																			0
FRET (AVB)																	2		2
FRET (LP)																			0
HC FATIGUE																			0
ERR/CCORR																			0
OTHER							10												10
TOT PLUGGED	0	0	0	0	0	10	0	0	0	0	182	0	0	1	0	4	0	0	197
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : PUBLIC SERVICE ELECTRIC & GAS TOTAL TUBES : 13,552

PLANT : SALEM 1 TUBE MATERIAL : I-600 MA

PLUGGED : 480 SG MODEL : W-51

EFPY : 9.3 H. L. TEMP (F) : 602

C.L. TEMP (F) : 544

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE							29					1		18			2	50		
DENTING SP																		0		
DENTING TS																		0		
PITTING																		0		
OD S/IGA SP																		0		
OD S/IGA TS																		0		
ID SCC TS																4	1	5		
ID SCC UB															1 * 335			336		
FRET (PREH)																		0		
FRET (AVB)								4							7	13		24		
FRET (LP)															1			1		
HC FATIGUE																		0		
ERR/CORR									1									1		
OTHER	1	30							13						2	2	12	3	63	
TOT PLUGGED	1	0	30	0	0	0	0	47	0	0	0	0	0	3	1	363	0	29	6	480
TOT SLEEVED																			0	
T. L. OUTAGE															1				1	

UTILITY CONTACT: Mahesh Danak

* Preventively plugged

PHONE NUMBER: 609-339-1872

UTILITY : PUBLIC SERVICE ELECTRIC & GAS TOTAL TUBES : 13,552

PLANT : SALEM 2 TUBE MATERIAL : I-600 MA

PLUGGED: 440 SG MODEL : W-51

EFPY : 6.7 H. L. TEMP (F) : 604

C.L. TEMP (F) : 545

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																12			12	
DENTING SP																			0	
DENTING TS																			0	
PITTING													1						1	
OD S/IGA SP																			0	
OD S/IGA TS																5			5	
ID SCC TS																	1		1	
ID SCC UB														2	*334				336	
FRET (PREH)																			0	
FRET (AVB)														3		22	7		32	
FRET (LF)													1						1	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER										1	41				2		8		52	
TOT PLUGGED	0	0	0	0	0	0	0	0	0	2	42	0	0	5	336	0	39	16	0	440
TOT SLEEVED																				0
T. L. OUTAGE																				0

UTILITY CONTACT: Mahesh Danak

* Preventively plugged

PHONE NUMBER: 609-339-1872

UTILITY : SOUTHERN CALIFORNIA EDISON TOTAL TUBES : 11,382

PLANT : SAN ONOFRE 1 TUBE MATERIAL : I-600 MA

PLUGGED: 1456 SG MODEL : W-27

EFPY : 13.4 H. L. TEMP (F) : 572

C.L. TEMP (F) : 528

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE		12	6	5				1			40			2		6	17		89
DENTING SP	31	3	9	11		3		6		4						1			68
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS					21	213		21						2		3			260
ID SCC TS								5						147		4	1		157
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)	37	87	26	3		13					23								189
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER	9	1	3	1		450		3		1				188		15	22		693
TOT PLUGGED	77	103	44	20	21	679	0	36	0	5	63	0	0	339	0	29	40	0	1456
TOT SLEEVED						6929													6929
T. L. OUTAGE	3	1			1														5

UTILITY CONTACT: Al Matheny

PHONE NUMBER: 714-368-9011

UTILITY : SOUTHERN CALIFORNIA EDISON

TOTAL TUBES : 18,700

PLANT : SAN ONOFRE 2

TUBE MATERIAL : I-600 MA

PLUGGED : 614

SG MODEL : CE-3410

EFPY : 6.9

H. L. TEMP (F) : 607

C.L. TEMP (F) : 554

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																	18	15	33
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)										249	17	136		44		23			469
FRET (LP)											2		1						3
HC FATIGUE																			0
ERR/CORR																			0
OTHER									21		1	79		5				3	109
TOT PLUGGED	0	0	0	0	0	0	0	21	0	1	330	17	142	0	62	0	4	0	614
TOT SLEEVED																			0
T. L. OUTAGE												1				1	1		3

UTILITY CONTACT: Al MathenyPHONE NUMBER: 714-368-9011

UTILITY : SOUTHERN CALIFORNIA EDISON

TOTAL TUBES : 18,700

PLANT : SAN ONOFRE 3

TUBE MATERIAL : I-600 MA

PLUGGED : 554

SG MODEL : CE-3410

EFPY : 6.5

H. L. TEMP (F) : 607

C.L. TEMP (F) : 554

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																	1	5	6
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)										234	19	177		17		21	468		
FRET (LP)																15		15	
HC FATIGUE																			0
ERR/CORR																			0
OTHER									34	2	24	1				1	3	65	
TOT PLUGGED	0	0	0	0	0	0	0	0	34	2	258	20	0	177	0	34	0	29	554
TOT SLEEVED																			0
T. L. OUTAGE										2									2

UTILITY CONTACT: Al MathenyPHONE NUMBER: 714-368-9011

UTILITY : NORTHEAST UTILITIES

TOTAL TUBES : 22,054

PLANT : SEABROOK

TUBE MATERIAL : I-600 TT

PLUGGED: 13

SG MODEL : W-F

EFPY : 1.9

H. L TEMP (F) : 618

C.L TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																13*			13
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	13	0	0	0	13
TOT SLEEVED																			0
T. L OUTAGE																			0

UTILITY CONTACT: John Klesiewicz

* Baseline

PHONE NUMBER: 203-665-3969

UTILITY : KYUSHU ELECTRIC POWER

TOTAL TUBES : 10,146

PLANT : SENDAI 1

TUBE MATERIAL : I-600 TT

PLUGGED : 17

SG MODEL : MHI-51M

EFPY : 7.0

H. L. TEMP (F) : 610

C.L. TEMP (F) : 544

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																	17		17
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	17	0	17
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: H. TakamatsuPHONE NUMBER: 06-441-8821

UTILITY : KYUSHU ELECTRIC POWER

TOTAL TUBES : 10,146

PLANT : SENDAI 2

TUBE MATERIAL : I-600 TT

PLUGGED : 19

SG MODEL : MHI-51F

EFPY : 5.9

H. L. TEMP (F) : 610

C.L. TEMP (F) : 543

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																	19		19
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	19	0	19
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: H. TakamatsuPHONE NUMBER: 06-441-8821

UTILITY : TENNESSEE VALLEY AUTHORITY

TOTAL TUBES

PLANT : SEQUOYAH 1

TUBE MATERIAL : I-600 MA

PLUGGED: 144

SG MODEL : W-51

EFPY : 6.0

H. L. TEMP (F) : 610

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																	1		1	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP																			0	
OD S/IGA TS																2	2		4	
ID SCC TS																2	68		70	
ID SCC UB																376	364*	50		63
FRET (PREH)																			0	
FRET (AVB)																	1	1	2	
FRET (LP)																		3	3	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER																	1		1	
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	376	0	364*	51	0	5	76	0	144	
TOT SLEEVED																			0	
T. L. OUTAGE																			0	

UTILITY CONTACT: David Goetchius

* 376 row 1 u-bend tubes were unplugged,
heat treated, and inspected; 12 tubes
were replugged.

PHONE NUMBER: 615-751-7652

UTILITY : TENNESSE VALLEY AUTHORITY

TOTAL TUBES : 13,552

PLANT : SEQUOYAH 2

TUBE MATERIAL : I-600 MA

PLUGGED: 434

SG MODEL : W-51

EFPY : 5.8

H. L. TEMP (F) : 610

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																3	12	15	
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																	1		1
OD S/IGA TS																1			1
ID SCC TS																4	19	23	
ID SCC UB														24	352*				376
FRET (PREH)																			0
FRET (AVB)																	8	6	14
FRET (LP)													1						1
HC FATIGUE																			0
ERR/CORR																			0
OTHER	1																2		3
TOT PLUGGED	1	0	0	0	0	0	0	0	1	0	0	24	0	352	0	18	0	38	434
TOT SLEEVED																			0
T. L. CUTAGE														1			1		2

UTILITY CONTACT: David Goetcheus* The remainder of row 1 tubes were
preventively plugged.PHONE NUMBER: 615-751-7652

UTILITY : CAROLINA POWER & LIGHT

TOTAL TUBES : 13,734

PLANT : SHEARON HARRIS

TUBE MATERIAL : I-600 MA

PLUGGED : 32

SG MODEL : W-D4

EFFY : 4.3

H. L. TEMP (F) : 619

C.L. TEMP (F) : 557

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			2	
DENTING TS																			4	
PITTING																			0	
OD S/IGA SP																			2	
OD S/IGA TS																			0	
ID SCC TS																			4	
ID SCC UB																			0	
FRET (PREH)																			0	
FRET (AVB)																			8	
FRET (LP)																			2	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER																			10	
TOT PLUGGED	0	0	0	0	0	0	0	0	0	7	0	0	0	4	10	3	2	4	2	32
TOT SLEEVED																				0
T. L. OUTAGE																				0

UTILITY CONTACT: Jerry WaldorfPHONE NUMBER: 919-546-4141

UTILITY : HOUSTON LIGHTING & POWER

TOTAL TUBES : 19,456

PLANT : SOUTH TEXAS PROJECT 1

TUBE MATERIAL : I-600 MA

PLUGGED: 15

SG MODEL : W-E

EFPY : 2.8

H. L. TEMP (F) : 624

C.L. TEMP (F) : 560

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER									* 6		4		5						15
TOT PLUGGED	0	0	0	0	0	0	0	6	0	4	0	5	0	0	0	0	0	0	15
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: Fawaz Jabali

* Shop plugged

PHONE NUMBER: 512-972-8623

UTILITY : HOUSTON LIGHTING & POWER

TOTAL TUBES : 19,404

PLANT : SOUTH TEXAS PROJECT 2

TUBE MATERIAL : I-600 MA

PLUGGED : 15

SG MODEL : W-E

EFFY : 2.5

H. L. TEMP (F) : 624

C.L. TEMP (F) : 560

DEFECTS	<78	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																	1		1
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER									*13							1			14
TOT PLUGGED	0	0	0	0	0	0	0	13	0	0	0	0	0	1	0	0	0	1	15
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: Fawaz Jabali

* Shop plugged

PHONE NUMBER: 512-972-8623

UTILITY : KERNKRAFTWERK

TOTAL TUBES : 11,972

STADE GmbH

PLANT : STADE

TUBE MATERIAL : I-800

PLUGGED : 325

SG MODEL : KWU

EFPY : 16.7

H. L. TEMP (F) : 597

C.L. TEMP (F) : 544

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE					1	45	118	43	9	24	1	18	25	11	14	4	4	317	
DENTING SP																		0	
DENTING TS																		0	
PITTING																		0	
OD S/IGA SP																		0	
OD S/IGA TS																		0	
ID SCC TS																		0	
ID SCC UB																		0	
FRET (PREH)																		0	
FRET (AVB)																		0	
FRET (LP)																		0	
HC FATIGUE																		0	
ERR/CORR																		0	
OTHER *	3				2		1								1		1	8	
TOT PLUGGED	3	0	0	0	3	45	119	43	9	24	1	18	25	12	14	4	4	325	
TOT SLEEVED																		0	
T. L. OUTAGE									1									1	

UTILITY CONTACT: S. Odar / R Bouecke

* 2 Tubes plugged preventively

6 Tubes pulled for investigation

PHONE NUMBER: 49-9131-18-2077 / 49-9131-18-9410

UTILITY : FLORIDA POWER & LIGHT

TOTAL TUBES : 17,038

PLANT : ST LUCIE 1

TUBE MATERIAL : I-600 MA

PLUGGED : 1688

SG MODEL : CE-67

EFPY : 12.3

H. L. TEMP (F) : 601

C.L. TEMP (F) : 549

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP											23		109		138	297			567
OD S/IGA TS														43	152				195
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER		23			22		103				507	66		76	129				926
TOT PLUGGED	0	23	0	0	22	0	103	0	0	507	66	23	76	238	0	181	449	0	1688
TOT SLEEVED																			0
T. L. OUTAGE																	1		1

UTILITY CONTACT: G. L. BoyersPHONE NUMBER: 407-694-4909

UTILITY : FLORIDA POWER & LIGHT

TOTAL TUBES : 16,882

PLANT : ST. LUCIE 2

TUBE MATERIAL : I-600 MA

PLUGGED : 458

SG MODEL : CE-3410

EFPY : 8.5

H. L. TEMP (F) : 601

C.L. TEMP (F) : 549

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																		8	8
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)											264	15	17	20	31	36	383		
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER										47		19	1						67
TOT PLUGGED	0	0	0	0	0	0	0	0	47	0	264	34	18	0	20	39	0	36	458
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: G. L. BoyersPHONE NUMBER: 407-694-4909

UTILITY : SOUTH CAROLINA ELECTRIC & GAS TOTAL TUBES : 14,022

PLANT : V. C. SUMMER TUBE MATERIAL : I-600 MA

PLUGGED: 1573 SG MODEL : W-D3

EFPY : 7.0 H. L. TEMP (F) : 619

C.L. TEMP (F) : 556

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																	51		51
OD S/IGA TS																			0
ID SCC TS											164		236	556		279	150		1385
ID SCC UB											4	3							7
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER							7	3			110		8				2		130
TOT PLUGGED	0	0	0	0	0	0	7	3	0	4	277	0	244	556	0	279	203	0	1573
TOT SLEEVED																	125	610	
T. L. OUTAGE												1	1						2

UTILITY CONTACT: John Frick / Rollin Kelso

PHONE NUMBER: 803-345-4379 / 4065

UTILITY : Virginia Power

TOTAL TUBES : 10164

PLANT : Surry 1 (Original SG)

TUBE MATERIAL : I-600 MA

PLUGGED : 2594

SG MODEL : W-51

EFPY : 4.4

H. L TEMP (F) : 605

C.L TEMP (F) : 536

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE	502			2		90													594
DENTING SP		963	640	364	29														1996
DENTING TS					2														2
PITTING							R												0
OD S/IGA SP							E												0
OD S/IGA TS							P												0
ID SCC TS							L												0
ID SCC UB							A												0
FRET (PREH)							C												0
FRET (AVB)							E												0
FRET (LP)							D												0
HC FATIGUE																			0
ERR/CORR																			0
OTHER	2																		2
TOT PLUGGED	504	963	640	366	31	90	0	0	0	0	0	0	0	0	0	0	0	0	2594
<hr/>																			
TOT SLEEVED																			0
T. L. OUTAGE	2	6				1													9

UTILITY CONTACT: Joe EastwoodPHONE NUMBER: (804) 273-2730

UTILITY : Virginia Power

TOTAL TUBES : 10026

PLANT : Surry 1 (Replacement SG)

TUBE MATERIAL : I-600 TT

PLUGGED: 14

SG MODEL : W-51F

EFPY : 7.6

H. L TEMP (F) : 605

C.L TEMP (F) : 543

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																	2	2	
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER								2						4				2	12
TOT PLUGGED	0	0	0	0	0	0	0	2	0	0	4	0	4	0	0	0	2	0	14
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: Joe EastwoodPHONE NUMBER: (804) 273-2730

UTILITY : Virginia Power

TOTAL TUBES : 10164

PLANT : Surry 2 (Original SG)

TUBE MATERIAL : I-600 MA

PLUGGED : 2154

SG MODEL : W-51

EFPY : 3.6

H. L. TEMP (F) : 605

C.L. TEMP (F) : 543

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE	190																		190
DENTING SP		797	899	268															1964
DENTING TS																			0
PITTING							R												0
OD S/IGA SP							E												0
OD S/IGA TS							P												0
ID SCC TS							L												0
ID SCC UB							A												0
FRET (PREH)							C												0
FRET (AVB)							E												0
FRET (LP)							D												0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	190	797	899	268	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2154
TOT SLEEVED																			0
T. L. OUTAGE			4	3															7

UTILITY CONTACT: Joe Eastwood

PHONE NUMBER: (804) 273-2730

UTILITY : Virginia Power

TOTAL TUBES : 10026

PLANT : Surry 2 (Replacement SG)

TUBE MATERIAL : I-600 TT

PLUGGED : 3

SG MODEL : W-51F

EFPY : 8.4

H. L. TEMP (F) : 605

C.L. TEMP (F) : 543

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AV8)																			0
FRET (LP)																			1
HC FATIGUE																			0
ERR/CORR																			0
OTHER								2										-1	2
TOT PLUGGED	0	0	0	0	0	0	2	0	0	0	0	0	2	0	0	0	-1	0	3
TOT SLEEVED																			0
T. L. OUTAGE																			1

UTILITY CONTACT: Joe Eastwood* Tube misplugged in 1986;
plug removed in 1991PHONE NUMBER: (804) 273-2730

UTILITY : KANSAI ELECTRIC POWER

TOTAL TUBES : 10,164

PLANT : TAKAHAMA 1

TUBE MATERIAL : I-600 MA

PLUGGED : 763

SG MODEL : W-51

EFPY : 10.7

H. L TEMP (F) : 608

C.L TEMP (F) : 551

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE	98																		98	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP										1	7	3		2	6	7		31	57	
OD S/IGA TS		32	25		12		9		40	6	7		7	8	4				150	
ID SCC TS							1				5			20	45	61	122			
ID SCC UB		31	10		55		1		1	2	1		1	6	13	17	138			
FRET (PREH)																			0	
FRET (AVB)																			0	
FRET (LP)																			0	
HC FATIGUE																			0	
ERR/CORR																			0	
OTHER					186						1			1					188	
TOT PLUGGED	98	0	63	35	0	253	0	11	0	42	16	16	0	11	40	69	0	109	763	
TOT SLEEVED							2	4	32		59	-6	-1		6		-3		-4	89
T. L OUTAGE							1												1	

UTILITY CONTACT: H. TakamatsuPHONE NUMBER: 06-441-8821

UTILITY : KANSAI ELECTRIC POWER

TOTAL TUBES : 10,164

PLANT : TAKAHAMA 2

TUBE MATERIAL : I-600 MA

PLUGGED: 1610

SG MODEL : MHI-51

EFFY : 9.8

H. L. TEMP (F) : 608

C.L. TEMP (F) : 551

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP						143		219	30		-30	-57	-56		55	*19/12	*73/11	373	
OD S/IGA TS						53		183	246	456	110	121	32		-118	*11/43	*14/37	1028	
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER	1													192			16		209
TOT PLUGGED	0	1	0	0	0	0	196	0	402	276	456	80	64	168	0	-63	-9	39	1610
TOT SLEEVED									231	-67	330	466	1007		1139		675	644	4425
T. L. OUTAGE										1			1						2

UTILITY CONTACT: H. Takamatsu

* Plugged 19 tubes, removed 12 plugs

PHONE NUMBER: 06-441-8821

* Plugged 11 tubes, removed 43 plugs

* Plugged 73 tubes, removed 11 plugs

* Plugged 14 tubes, removed 37 plugs

UTILITY : KANSAI ELECTRIC POWER

TOTAL TUBES : 10,146

PLANT : TAKAHAMA 3

TUBE MATERIAL : I-600 TT

PLUGGED : 26

SG MODEL : MHI-51F

EFPY : 6.7

H. L. TEMP (F) : 610

C.L. TEMP (F) : 543

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																23	2		25
FRET (LP)																			0
HC FATIGUE																			0
ERR/CCORR																			0
OTHER														1					1
TOT PLUGGED	0	0	0	0	0	0	0	0	0	1	0	0	0	0	23	2	0	0	26
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: H. Takamatsu

PHONE NUMBER: 06-441-8821

UTILITY : KANSAI ELECTRIC POWER

TOTAL TUBES : 10,146

PLANT : TAKAHAMA 4

TUBE MATERIAL : I-600 TT

PLUGGED : 21

SG MODEL : MHI-51F

EFPY : 6.3

H. L. TEMP (F) : 610

C.L. TEMP (F) : 543

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																21			21
FRET (LP)																			0
HC FATIGUE																			0
ERRVCORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	21	0	0	21
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: H. TakamatsuPHONE NUMBER: 06-441-8821

UTILITY : SEMO

TOTAL TUBES : 10,164

PLANT : TIHANGE 1

TUBE MATERIAL : I-600

PLUGGED : 371

SG MODEL : ACLF-51

EFPY : 13.8

H. L. TEMP (F) : 611

C.L. TEMP (F) : 547

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																		11	11
DENTING TS																			0
PITTING																			0
OD S/IGA SP																		17	17
OD S/IGA TS																		181	181
ID SCC TS																		7	7
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			54
FRET (LP)																			6
HC FATIGUE																			0
ERR/CORR																			1
OTHER	3	13	2	13	27	1		1	26				2		3	2	1		94
TOT PLUGGED	3	13	2	13	27	1	0	6	29	52	0	2	0	3	1	2	217	0	371
TOT SLEEVED																			0
T. L. OUTAGE																			3

UTILITY CONTACT: Paul HernalsteenPHONE NUMBER: (02) 3820551

UTILITY : INTERCOM

TOTAL TUBES : 10,083

PLANT : TIHANGE 2

TUBE MATERIAL : I-600

PLUGGED: 232

SG MODEL : FRAM-51M

EFPY : 8.5

H. L. TEMP (F) : 617

C.L. TEMP (F) : 547

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS										7	20	1	30	21	39	32	11	161	
ID SCC UB													1						1
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)													1						1
HC FATIGUE																			0
ERR/CORR																	1		1
OTHER								2									2	64	68
TOT PLUGGED	0	0	0	0	0	0	0	2	0	7	20	0	3	30	21	39	35	75	232
TOT SLEEVED																			0
NICKEL PLATE																		601	601
T. L. OUTAGE																	1		1

UTILITY CONTACT: Paul HernaisteenPHONE NUMBER: (02) 3820551

UTILITY : INTERCOM

TOTAL TUBES : 14,532

PLANT : TIHANGE 3

TUBE MATERIAL : I-600

PLUGGED: 61

SG MODEL : ACE-E

EFPY : 6.6

H. L. TEMP (F) : 626

C.L. TEMP (F) : 560

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																4	12		16
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																22	3		25
FRET (LP)																6			6
HC FATIGUE																			0
ERR/CORR															2				2
OTHER										3			4			1		4	12
TOT PLUGGED	0	0	0	0	0	0	0	0	3	0	0	6	0	0	7	26	19	0	61
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: Paul hernalsteenPHONE NUMBER: (02) 3820551

UTILITY : HOKKAIDO ELECTRIC POWER

TOTAL TUBES : 6,764

PLANT : TOMARI 1

TUBE MATERIAL : I-600 TT

PLUGGED : 0

SG MODEL : MHI-51F

EPPY : 2.8

H. L. TEMP (F) : 613

C.L. TEMP (F) : 550

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: H. TakamatsuPHONE NUMBER: 06-441-8821

UTILITY : HOKKAIDO ELECTRIC POWER

TOTAL TUBES : 6,764

PLANT : TOMARI 2

TUBE MATERIAL : I-600 TT

PLUGGED : 0

SG MODEL : MHI-51F

EFFY : 1.3

H. L. TEMP (F) : 613

C. L. TEMP (F) : 550

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UE																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: H. TakamatsuPHONE NUMBER: 06-441-8821

UTILITY : GENERAL PUBLIC UTILITIES

TOTAL TUBES : 31,062

PLANT : TMI-1

TUBE MATERIAL : I-600 MA

PLUGGED: 1640

SG MODEL : OTSG

EFPY : 9.3

H. L TEMP (F) : 601

C.L TEMP (F) : 557

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/GA SP																			4
OD S/GA TS																			0
ID SCC TS									331	856	3	336	64		171		8	3	1618
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			1
ERR/CORR																			0
OTHER	2		9	1	3	1											1		17
TOT PLUGGED	2	0	9	1	3	1	0	331	856	3	336	64	0	21	0	10	3	0	1640
TOT SLEEVED																	250		250
T. L. OUTAGE																	1		1

UTILITY CONTACT: Julien AbramoviciPHONE NUMBER: 201-316-7038

UTILITY : EDF

TOTAL TUBES : 10,083

PLANT : TRICASTIN 1

TUBE MATERIAL : I-600 MA

PLUGGED : 571

SG MODEL : FRAM-51M

EFPY : 8.9

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																	1		1
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																65		65	
ID SCC TS										2	17	32	10	26	20	8	18		133
ID SCC UB													1						1
FRET (PREH)																			0
FRET (AVB)													4	5	6	3	4		22
FRET (LP)						3					3	58	54	39	10	1	7		175
HC FATIGUE																			0
ERR/CORR																			0
OTHER				7						1	2	1	1		3	141	17	1	174
TOT PLUGGED	0	0	0	7	0	0	3	0	1	2	3	21	91	71	70	177	95	30	571
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 10,083

PLANT : TRICASTIN 2

TUBE MATERIAL : I-600 MA

PLUGGED: 307

SG MODEL : FRAM-51M

EFFY : 8.5

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																	9	12	21
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																	3	1	4
ID SCC TS										1		16	28	21		15	23	19	123
ID SCC UB										3	85		1						89
FRET (PREH)																			0
FRET (AVB)																	1	1	
FRET (LP)										2							3		5
HC FATIGUE																			0
ERR/CORR																			0
OTHER				15						2	3	3	1				40		64
TOT PLUGGED	0	0	0	15	0	0	0	0	0	8	88	19	30	21	0	24	30	72	307
TOT SLEEVED											14*								14
T. L. OUTAGE										1	1								2

UTILITY CONTACT: R. Comby

* 8 tubes subsequently plugged

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 10,083

PLANT : TRICASTIN 3

TUBE MATERIAL : I-600 MA

PLUGGED : 603

SG MODEL : FRAM-51M

EFPY : 9.9

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																	12		12
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																133			133
ID SCC TS										2		7	4	16	4	7	4	32	76
ID SCC UB										89	89					2		3	183
FRET (PREH)																			0
FRET (AVB)																	1		1
FRET (LP)														1				2	3
HC FATIGUE																			0
ERR/CORR																			0
OTHER					6											188	1		195
TOT PLUGGED	0	0	0	0	6	0	0	0	0	91	89	7	4	17	4	197	151	37	603
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. Comby

PHONE NUMBER: 1-49-22-86-78

UTILITY : EDF

TOTAL TUBES : 10,083

PLANT : TRICASTIN 4

TUBE MATERIAL : I-600 MA

PLUGGED: 200

SG MODEL : FRAM-51M

EFPY : 8.0

H. L. TEMP (F) : 613

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																7	2		9
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																53			53
ID SCC TS										3	2	1	7	14	1	2	6		36
ID SCC UB														7	3				10
FRET (PREH)																			0
FRET (AVB)														7	4	1	2		14
FRET (LP)																	1		1
HC FATIGUE																			0
ERR/CORR																			0
OTHER					6						1				1	63	6		77
TOT PLUGGED	0	0	0	0	6	0	0	0	0	4	2	1	7	28	9	73	70	0	200
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: R. CombyPHONE NUMBER: 1-49-22-86-78

UTILITY : A. N. TRILLO 1

TOTAL TUBES : 12,258

PLANT : TRILLO 1

TUBE MATERIAL : I-800

PLUGGED : 9

SG MODEL : KWU-54GT

EFFY : 3.5

H. L TEMP (F) : 619

C.L TEMP (F) : 561

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/GA SP																			0
OD S/GA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																4			4
HC FATIGUE																			0
ERR/CORR																			0
OTHER														4			4	1**/-4**	5
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	4	0	0	0	8	-3	0	9
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: Gustavo Bollini

* This tube was pulled
and four plugs were also removed.

PHONE NUMBER: 34-1-6516700

** Four plugs removed in 1991

UTILITY : PORTLAND GENERAL ELECTRIC TOTAL TUBES : 13,552
 PLANT : TROJAN TUBE MATERIAL : I-600 MA
 PLUGGED: 2442 SG MODEL : W-51
 EFPY : 8.2 H. L TEMP (F) : 615
 C.L TEMP (F) : 552

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																	S		0
PITTING										3	3	3			3		H		12
OD S/IGA SP															146	123	1542	U	1811
OD S/IGA TS											2		7	40	22	14	T		85
ID SCC TS														56	2	13	D		71
ID SCC UB					9	10	333			1		36	1	7			10	O	407
FRET (PREH)																	W		0
FRET (AVB)																	N		0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER					1		53				3						1		58
TOT PLUGGED	0	0	0	1	9	63	333	0	0	7	3	41	1	14	245	147*	1580		2442
TOT SLEEVED																2	1061		1063
T. L. OUTAGE						1	1	1											3

UTILITY CONTACT: Greg Kent

PHONE NUMBER: 503-556-7716

* Two tubes, previously plugged,
were restored to service via sleeving
in 1990.

UTILITY : JAPAN ELECTRIC POWER COMPANY TOTAL TUBES : 13,528
 PLANT : TSURUGA 2 TUBE MATERIAL : I-600 TT
 PLUGGED : 2 SG MODEL : M41-51FA
 EFPY : 5.2 H. L. TEMP (F) : 612
 C.L. TEMP (F) : 552

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																	2		2
FRET (LP)																			0
HC FATIGUE																			0
ERR/ CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0	0	2
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: H. Takamatsu

PHONE NUMBER: 03-441-8821

UTILITY : FLORIDA POWER & LIGHT

TOTAL TUBES : 9780

PLANT : TURKEY POINT 3 (ORIGINAL S. G.)

TUBE MATERIAL : I-600 MA

PLUGGED : 1986

SG MODEL : W-44

EFFY : 5.2

H. L. TEMP (F) : 602

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE		51			40	21													112
DENTING SP		136	604	1	690	259	59												1749
DENTING TS																			0
PITTING								R											0
OD S/IGA SP							E												0
OD S/IGA TS	34						P												34
ID SCC TS							L												0
ID SCC UB		88					A												88
FRET (PREH)							C												0
FRET (AVB)							E												0
FRET (LP)							D												0
HC FATIGUE																			0
ERR/CORR				1															1
OTHER							2												2
TOT PLUGGED	34	275	604	2	730	280	61	0	0	0	0	0	0	0	0	0	0	0	1986
TOT SLEEVED																			0
T. L. OUTAGE	1		5		1		1												8

UTILITY CONTACT: G. L. BOYERSPHONE NUMBER: 407-694-4909

UTILITY : FLORIDA POWER & LIGHT

TOTAL TUBES : 9642 (REPLACEMENT)

PLANT : TURKEY POINT 3 REPLACEMENT S. G. TUBE MATERIAL : I-600 TT

PLUGGED : 62

SG MODEL : W-44F

EFPY : 6.3

H. L. TEMP (F) : 602

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																7	3	10	
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER									39				4		1		4		52
TOT PLUGGED	0	0	0	0	0	0	0	39	0	0	4	0	1	0	0	11	0	7	62
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: G. L. BoyersPHONE NUMBER: 407-694-4909

UTILITY : FLORIDA POWER & LIGHT

TOTAL TUBES : 9780

PLANT : TURKEY POINT 4 (ORIGINAL S. G.)

TUBE MATERIAL : I-600 MA

PLUGGED : 2351

SG MODEL : W-44

EFPY : 4.0

H. L. TEMP (F) : 602

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE		5		21	6	39													71
DENTING SP	5	52	629	510	179	267	93												1735
DENTING TS																			0
PITTING									R										0
OD S/IGA SP									E										0
OD S/IGA TS	159								P										159
ID SCC TS									L										0
ID SCC UB		294							A										294
FRET (PREH)									C										0
FRET (AVB)									E										0
FRET (LP)									D										0
HC FATIGUE																			0
ERR/CORR																			0
OTHER							2	11	79										92
TOT PLUGGED	164	351	629	531	185	308	104	79	0	0	0	0	0	0	0	0	0	0	2351
TOT SLEEVED																			0
T. L. OUTAGE	3	6	5	1				1											16

UTILITY CONTACT: G. L. BoyersPHONE NUMBER: 407-694-4909

UTILITY : FLORIDA POWER & LIGHT

TOTAL TUBES : 9,642

PLANT : TURKEY POINT 4 (REPLACEMENT S. G.) TUBE MATERIAL : I-600 TT

PLUGGED : 33

SG MODEL : W-44F

EFPY : 5.3

H. L. TEMP (F) : 602

C.L. TEMP (F) : 546

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																		1	1
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																	1		32
TOT PLUGGED	0	0	0	0	0	0	0	0	31	0	0	0	0	1	0	0	1	0	33
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: G. L. BoyersPHONE NUMBER: 407-694-4909

UTILITY : KERNKRAFTWERK
UNTERWESER GmbH
PLANT : UNTERWESER

TOTAL TUBES : 16,084

PLUGGED : 0

SG MODEL : KWU

EFPY : 11.2

H. L. TEMP (F) : 604

C.L. TEMP (F) : 548

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERRVCORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: S. Odar / R. Bouecke

PHONE NUMBER: 49-9131-18-2077 / 49-9131-18-9410

UTILITY : A. N. V.

TOTAL TUBES : 16,878

PLANT : VANELLOS 2

TUBE MATERIAL I-600 TT

PLUGGED: 216

SG MODEL : W-F

EFPY : 3.8

H. L. TEMP (F) : 620

C.L. TEMP (F) : 557

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL	
WASTAGE																			0	
DENTING SP																			0	
DENTING TS																			0	
PITTING																			0	
OD S/IGA SP																			0	
OD S/IGA TS																			0	
ID SCC TS																			0	
ID SCC UB																			0	
FRET (PREH)																			0	
FRET (AVB)																30	54	88	30	202
FRET (LP)																				0
HC FATIGUE																				0
ERR CORR																				0
OTHER														11		1		2		14
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	11	0	0	31	54	90	30	216	
TOT SLEEVED																				0
T. L. OUTAGE																				0

UTILITY CONTACT: Gustavo BolliniPHONE NUMBER: 34-1-6516700

UTILITY : GEORGIA POWER

TOTAL TUBES : 22,504

PLANT : VOGTLE 1

TUBE MATERIAL : I-600 TT

PLUGGED : 11

SG MODEL : W-F

EFPY : 4.5

H. L. TEMP (F) : 618

C.L. TEMP (F) : 557

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			3
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			11
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	6	0	0	1	0	4	0		11
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: FORREST HUNDLEY

* Shop Plugged

PHONE NUMBER: 205-870-6998

UTILITY : GEORGIA POWER

TOTAL TUBES : 22,504

PLANT : VOGTLE 2

TUBE MATERIAL : I-600 TT

PLUGGED : 15

SG MODEL : W-F

EFPY : 3.0

H. L. TEMP (F) : 618

C.L. TEMP (F) : 557

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER															* 13	2			15
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	13	2	0	0	0	0	15
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: FORREST HUNDLEY

* Shop plugged

PHONE NUMBER: 205-870-6998

UTILITY : ENTERGY OPERATIONS TOTAL TUBES : 18,700
 PLANT : WATERFORD 3 TUBE MATERIAL : I-600 MA
 PLUGGED: 518 SG MODEL : CE-3410
 EFPY : 5.5 H. L. TEMP (F) : 607
 C.L. TEMP (F) : 552

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)													298*	1	3	19	156*	7	484
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER										25							9		34
TOT PLUGGED	0	0	0	0	0	0	0	0	25	0	298	0	1	3	19	0	165	7	518
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: Mike Layton

* Preventively plugged

PHONE NUMBER: 504-464-3454

UTILITY : TENNESSE VALLEY AUTHORITY

TOTAL TUBES : 18,696

PLANT : WATTS BAR 1

TUBE MATERIAL : I-600 MA

PLUGGED : 8

SG MODEL : W-D3

EFPY : 0.0

H. L. TEMP (F) : 617

C.L. TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER											3			4			1		8
TOT PLUGGED	0	0	0	0	0	0	0	0	0	3	0	0	4	0	0	0	1	0	8
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: David GoetcheusPHONE NUMBER: 615-751-7652

UTILITY : TENNESSEE VALLEY AUTHORITY

TOTAL TUBES : 18,696

PLANT : WATTS BAR 2

TUBE MATERIAL : I-600 MA

PLUGGED: 5

SG MODEL : W-D3

EFPY : 0.0

H. L. TEMP (F) : 617

C.L. TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)																			0
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER											3				2				5
TOT PLUGGED	0	0	0	0	0	0	0	0	0	3	0	0	0	2	0	0	0	0	5
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: David GoetcheusPHONE NUMBER: 615-751-7652

UTILITY : KANSAS GAS & ELECTRIC

TOTAL TUBES : 22,504

PLANT : WOLF CREEK

TUBE MATERIAL : 1-600 TT

PLUGGED : 39

SG MODEL : W-F

EFPY : 4.8

H. L. TEMP (F) : 618

C.L. TEMP (F) : 559

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)															19	2			21
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER												15				3			18
TOT PLUGGED	0	0	0	0	0	0	0	0	0	15	0	0	0	22	0	2	0	39	
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: Mark Covey / Tim CardPHONE NUMBER: 316-364-8831

UTILITY : YANKEE ATOMIC	TOTAL TUBES : 6,480
PLANT : YANKEE ROWE	TUBE MATERIAL : 304 SS
PLUGGED: 334	SG MODEL : W-13
EFPY : 22.0	H. L. TEMP (F) : 553
	C.L. TEMP (F) : 496
DEFECTS	<76 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 TOTAL
WASTAGE	0
DENTING SP	0
DENTING TS	0
PITTING	66 2 15 30 3 9 123 1 58 8 17 332
OD S/IGA SP	0
OD S/IGA TS	0
ID SCC TS	0
ID SCC UB	2
FRET (PREH)	0
FRET (AVB)	0
FRET (LP)	0
HC FATIGUE	0
ERR/CORR	0
OTHER	0
TOT PLUGGED	66 2 15 30 0 0 3 9 0 123 1 0 60 8 0 17 0 0 334
TOT SLEEVED	0
T. L. OUTAGE	0

UTILITY CONTACT: J. K. Thayer

PHONE NUMBER: 508-779-6711

UTILITY : KOREA ELECTRIC POWER CO.

TOTAL TUBES : 16,878

PLANT : YOUNGKWANG 1

TUBE MATERIAL : I-600 TT

PLUGGED : 17

SG MODEL : W-F

EFPY : 5.3

H. L. TEMP (F) : 619

C.L. TEMP (F) : 556

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL		
WASTAGE																			0		
DENTING SP																			0		
DENTING TS																			0		
PITTING																			0		
OD S/IGA SP																			0		
OD S/IGA TS																			0		
ID SCC TS																			0		
ID SCC UB																			0		
FRET (PREH)																			0		
FRET (AVB)															2	1	4	1	5	2	15
FRET (LP)																					0
HC FATIGUE																					0
ERR/CORR																					0
OTHER																	2				2
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	2	1	6	1	5	2	17	
TOT SLEEVED																					0
T. L. OUTAGE																					0

UTILITY CONTACT: YANG UOO CHOE

PHONE NUMBER: _____

UTILITY : KOREA ELECTRIC POWER CO.

TOTAL TUBES : 16,878

PLANT : YOUNGKWANG 2

TUBE MATERIAL : 1-600 TT

PLUGGED : 27

SG MODEL : W-F

EFPY : 4.5

H. L. TEMP (F) : 619

C.L. TEMP (F) : 556

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE																			0
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																			0
OD S/IGA TS																			0
ID SCC TS																			0
ID SCC UB																			0
FRET (PREH)																			0
FRET (AVB)															6	11	2	8	27
FRET (LP)																			0
HC FATIGUE																			0
ERR/CORR																			0
OTHER																			0
TOT PLUGGED	0	0	0	0	0	0	0	0	0	0	0	0	0	0	6	11	2	8	27
TOT SLEEVED																			0
T. L. OUTAGE																			0

UTILITY CONTACT: YANG UOO CHOE

PHONE NUMBER: _____

UTILITY : COMMONWEALTH EDISON

TOTAL TUBES : 13,552

PLANT : ZION 1

TUBE MATERIAL : I-600 MA

PLUGGED : 907

SG MODEL : W-51

EFPY : 10.9

H. L. TEMP (F) : 594

C.L. TEMP (F) : 530

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE							2	24	3	2	9	7		12			4	63	
DENTING SP																		0	
DENTING TS																		0	
PITTING																		0	
OD S/IGA SP															11			11	
OD S/IGA TS								12	19	37	64	75			69		29	305	
ID SCU TS																	18	18	
ID SCC UB							19	377										396	
FRET (PREH)																		0	
FRET (AVB)							4	53					1		1		2	61	
FRET (LP)																		0	
HC FATIGUE																		0	
ERR/CORR																		0	
OTHER							2	7	6		1			13	24			53	
TOT PLUGGED	0	0	0	0	0	0	27	473	28	39	74	83	0	36	94	0	0	53	907
TOT SLEEVED													128		47	445		125	745
T. L. OUTAGE											1							1	

UTILITY CONTACT: John BlomgrenPHONE NUMBER: 312-294-2838

UTILITY : COMMONWEALTH EDISON

TOTAL TUBES : 13,552

PLANT : ZION 2

TUBE MATERIAL : I-600 MA

PLUGGED : 525

SG MODEL : W-51

EFPY : 11.2

H. L. TEMP (F) : 594

C.L. TEMP (F) : 530

DEFECTS	<76	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	TOTAL
WASTAGE							2		1		1		2	8				2	16
DENTING SP																			0
DENTING TS																			0
PITTING																			0
OD S/IGA SP																	1		1
OD S/IGA TS									7				3	7				1	18
ID SCC TS													16	249	1	17	101	384	
ID SCC UB										2	1		3	2	6	28	29	71	
FRET (PREH)																			0
FRET (AVB)							11		7	4	2		3						27
FRET (LP)															6				6
HC FATIGUE																			0
ERR/CORR																			0
OTHER																1	1	1	2
TOT PLUGGED	0	0	0	0	0	0	13	0	15	6	4	0	27	272	7	47	0	134	525
TOT SLEEVED																	82	170	252
T. L. OUTAGE																1			1

UTILITY CONTACT: John BlomgrenPHONE NUMBER: 312-294-2828