



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

December 1, 1978

Docket No. 50-155

Consumers Power Company  
ATTN: Mr. David Bixel  
Nuclear Licensing Administrator  
212 West Michigan Avenue  
Jackson, Michigan 49201

Gentlemen:

We have reviewed your response dated March 7, 1978 to our letter dated February 1, 1978 regarding the need for a feedwater pump trip on reactor high water level. Based upon our review of your submittal we have determined that a feedwater trip on high reactor level is not necessary to assure safe operation of the Big Rock Point plant.

Our Safety Evaluation containing the details of the Regulatory Staff's review is enclosed.

Sincerely,

A handwritten signature in cursive script that reads "Dennis L. Ziemann".

Dennis L. Ziemann, Chief  
Operating Reactors Branch #2  
Division of Operating Reactors

Enclosure:  
As stated

cc:  
See next page

7812130281

NRC PDR  
50-155  
P

P

Consumers Power Company

- 2 -

December 1, 1978

cc  
Mr. Paul A. Perry, Secretary  
Consumers Power Company  
212 West Michigan Avenue  
Jackson, Michigan 49201

Judd L. Bacon, Esquire  
Consumers Power Company  
212 West Michigan Avenue  
Jackson, Michigan 49201

Hunton & Williams  
George C. Freeman, Jr., Esquire  
P. O. Box 1535  
Richmond, Virginia 23212

Peter W. Steketee, Esquire  
505 Peoples Building  
Grand Rapids, Michigan 49503

Charlevoix Public Library  
107 Clinton Street  
Charlevoix, Michigan 49720