



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

~~100-100~~
50-155
P

December 8, 1978

Docket Nos. 50-155
and 50-255

Mr. David Bixel
Nuclear Licensing Administrator
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Dear Mr. Bixel:

We have completed our search of the docket for the SEP Plants for information relative to Topic VIII-4, "Electrical Penetrations of Reactor Containments." The results of this effort has revealed the need for additional information to complete our evaluation of this topic.

Please provide the information identified in the enclosure within ninety (90) days.

Sincerely,

Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors

Enclosure:
Request for Additional
Information

cc:
See next page

781215005

~~51218~~

P

Consumers Power Company

- 2 -

December 8, 1978

cc
Mr. Paul A. Perry, Secretary
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Judd L. Bacon, Esquire
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Hunton & Williams
George C. Freeman, Jr., Esquire
P. O. Box 1535
Richmond, Virginia 23212

Peter W. Steketee, Esquire
505 Peoples Building
Grand Rapids, Michigan 49503

Charlevoix Public Library
107 Clinton Street
Charlevoix, Michigan 49720

M. I. Miller, Esquire
Isham, Lincoln & Beale
Suite 4200
One First National Plaza
Chicago, Illinois 60670

Myron M. Cherry, Esquire
Suite 4501
One IBM Plaza
Chicago, Illinois 60611

Kalamazoo Public Library
315 South Rose Street
Kalamazoo, Michigan 49006

ENCLOSURE

REQUEST FOR INFORMATION FROM SEP LICENSEES

Topic VIII-4 - Electrical Penetrations of Reactor Containment

We have performed a review of the information contained in your docket concerning electrical penetrations of reactor containment. The objective of this SEP topic is to determine the capability of penetrations to maintain containment integrity during short-circuit current conditions and the worst expected transient fault current resulting from single random failures of circuit overload protection devices. Based on information contained on your docket concerning electrical penetrations we have determined that additional information is necessary to confirm that this objective is satisfied. In this regard, we request that you provide the following information for a typical low-voltage penetration circuit (150-1000 Vac); a typical medium voltage penetration circuit (greater than 1000 Vac); and a typical direct current power penetration circuit (if any).

A. Circuit Information

1. Identify each typical circuit which has been selected.
2. Provide the trip curves (current versus time) for the primary and the secondary protection devices.
3. State the maximum short circuit current available to the selected penetration circuit (the short-circuit current for AC circuits should be expressed in rms symmetrical amperes with the symmetrical current being initially offset by a DC component. The short circuit current for direct current circuits should be based on the current having a constant DC value).
4. State the size of the conductor(s) for the selected circuit (that is, conductor size external to the electrical penetration).

B. Electric Penetration Information

1. State the manufacturer's electrical penetration identification number and provide the size of the conductor(s) in the penetration. Also provide the rated continuous current for each conductor.
2. State the rated short-circuit overload current and the duration of this current.
3. Provide a description of all electrical tests for these penetrations and state the results of these tests.

References:

1. Regulatory Guide 1.63, Revision 2, "Electrical Penetrations in Containment Structures for Water Cooled Nuclear Water Plants."
2. IEEE Standard 317-1976 - "IEEE Standard for Electrical Penetration Assemblies in Containment Structures for Nuclear Power Generating Stations."