

APPENDIX A

NOTICE OF VIOLATION

Nebraska Public Power District  
Cooper Nuclear Station

Docket: 50-298  
License: DPR-46

During an NRC inspection conducted on January 31 through February 4, 1994, one violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violation is listed below:

Technical Specification 6.2.1.A.4.d. requires the Station Operations Review Committee to review proposed modifications to station systems or equipment as discussed in the Updated Safety Analysis Report.

Contrary to the above, Conduct of Operations Procedure 2.0.7, "Plant Temporary Modifications Control", Revision 17, dated July 22, 1993, did not require that the Station Operations Review Committee review all proposed plant temporary modifications to station systems or equipment as described in the Updated Safety Analysis Report.

This is a Severity Level IV Violation 298/9406-01 (Supplement I).

During this inspection, it was determined that a written response to the violation discussed above is not required. This determination was based on the actions taken by the licensee to determine the root cause and implement the appropriate corrective actions.

Dated at Arlington, Texas  
this 4<sup>th</sup> day of March, 1994