

ENCLOSURE 1

Arkansas Power and Light Company  
Arkansas Nuclear One, Unit 2  
Docket No. 50-368

NOTICE OF VIOLATION

Based on the results of an NRC inspection conducted September 18-21, 25-28 and October 2-6, 1978, it appears that certain of your activities were not conducted in full compliance with conditions of your Operating License No. NFP-6 as indicated below:

Technical Specification 6.8.1.c requires that written procedures shall be established, implemented and maintained covering surveillance and test activities of safety-related equipment.

Contrary to the above, written procedures for the surveillance and test activities related to the "noninterruptable" power supplies 2Y11, 2Y13, 2Y22 and 2Y24 (120 V AC inverters) were not found to have been established.

This is an infraction.

78122101624