

Alabama Power Company
500 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291
Telephone 205 323-5341

F. L. CLAYTON, JR.
Senior Vice President



December 13, 1978

Docket Nos. 50-348
50-364

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attn: Mr. Albert Schwencer

Dear Mr. Schwencer:

RE: JOSEPH M. FARLEY NUCLEAR PLANT
Fire Protection Program Review

Alabama Power Company has conducted a detailed review of cables passing through the component cooling water pump room. It was determined that only one exists (power cable for auxiliary feedwater pump room cooler) where redundant cables for hot shutdown equipment run through the area with less than twenty foot separation that do not terminate in the room. While the subject cables do not carry power to the auxiliary feedwater pumps they are required for long term cooling of the pump rooms. Due to the congestion of cables in this area, Alabama Power Company plans to remove the "B" train auxiliary feedwater pump room cooler cable from the room as discussed with Mr. Ed Reeves by phone on December 12, 1978.

It is our understanding that no other outstanding items exist in review of our fire protection program at Farley Nuclear Plant Units 1 and 2.

If you have questions, please advise.

Yours very truly,

F. L. Clayton, Jr.

FLCJr/TNE:bjj

cc: Mr. G. F. Trowbridge
Mr. R. A. Thomas

7812270169

Handwritten notes: "A006 5/10" and a large "F" mark.