

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION
P.O. BOX 128
SAN CLEMENTE, CALIFORNIA 92672

RECEIVED
MRC
SCE
1983 JAN -3 PM 1:14
REGIONAL TELEPHONE
(714) 492-7700

H. B. RAY
STATION MANAGER

December 28, 1982

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket No. 50-361
30-Day Follow-Up Report
Licensee Event Report No. 82-159
San Onofre Nuclear Generating Station, Unit 2

This submittal is in accordance with the reporting requirements of Section 6.9.1.13b of Appendix A to Facility Operating License NPF-10. It describes a reportable occurrence involving Limiting Condition for Operation (LCO) 3.3.3.5 associated with Remote Shutdown Instrumentation. A completed copy of LER 82-159 is enclosed.

While in Mode 3 at 0420 on November 28, 1982, the monthly channel check surveillance in accordance with procedure S023-3-3.28 was in progress. Pressure indicator 2PI-8300 for Steam Generator E-088 located on the Remote Shutdown Panel was observed to be reading more than 120 psia greater than a similar indicator located in the Control Room on panel CR-52. Consequently, 2PI-8300 was declared inoperable and LCO 3.3.3.5 Action statement 'a' was invoked.

The indicator was replaced, calibrated, and returned to service on November 29, 1982. The cause of the indicator failure is under investigation. A revised LER identifying the cause and any further corrective action will be submitted by January 31, 1983.

8301170487 821228
PDR ADOCK 05000361
S PDR

IE-22
82-473

Since the redundant indicator on Control Room Evacuation Shutdown panel 2L-042 remained operable and the inoperable indicator was returned to service within the allowable time constraints, there was no impact on plant operation or the health and safety of plant personnel or the public.

If there are any questions regarding the above, please contact me.

Sincerely,

HB Ruy / NCM

Enclosure: LER 82-159

cc: A.E. Chaffee (USNRC Resident Inspector, San Onofre, Units 2 and 3)

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U.S. Nuclear Regulatory Commission
Office of Management Information & Program Control (MIPC)

Institute of Nuclear Power Operations (INPO)