

LICENSE TERMINATION REPORT

USNRC LICENSE NO. SNM-951

PRELIMINARY SURVEY OF SELECTED SITE BUILDINGS

DECEMBER 7, 1992

WESTINGHOUSE ELECTRIC CORPORATION

LARGE, PA

9403210075 921207  
PDR ADOCK 07000997  
B PDR

Report #006

"OFFICIAL RECORD COPY"

M. 10

# 117646

PRELIMINARY SURVEY OF SELECTED SITE BUILDINGS

TABLE OF CONTENTS

	<u>Page Number</u>
Purpose	1
Scope	1
Selection of Building Areas	1
Description of Surveys	1
Conclusions	2
Appendix A - Building 4, Basement	
Appendix B - Building 5, First Floor	
Appendix C - Building 5, Second Floor	
Appendix D - Building 5, Third Floor	
Appendix E - Building 6, First Floor	
Appendix F - Building 6, Second Floor	
Appendix G - Building 6A, First Floor	
Appendix H - Building 7, First Floor	
Appendix I - Building 8A, First Floor	
Appendix J - Building 9, Basement	
Appendix K - Building 9, First Floor	
Appendix L - Hydrogen Building	

090169

(i)

Report #006

"OFFICIAL RECORD COPY" ML 10

# 117646

## PRELIMINARY SURVEY OF SELECTED SITE BUILDINGS

### Scope

The Westinghouse Electric Corporation is preparing to request the termination of USNRC License Number SNM-951 for the site located in Large, PA. This report is one of a series of reports that presents the necessary information to establish that the site meets all applicable regulatory requirements so that the license can be terminated by the United States Nuclear Regulatory Commission.

### Scope

This report documents information collected during a preliminary survey of selected building areas on the site. The intention of the survey was to collect preliminary information on building areas that had the highest potential for contamination based on the history of prior use. Such preliminary information was to serve as the basis for establishing a site survey plan. No detailed statistical analysis is present in the report. It is not intended that this information serve as documentation that the acceptance criteria for termination of the license have been met. No preliminary survey information is presented on the Monitored Drain Line system. A separate report has been issued on the removal and survey of that system.

### Selection of Building Areas

In the early stages of the project a group of individuals, who had long term knowledge of the activities that had been conducted on the site including the current and past Safety Officers, was convened. This group reviewed each building and identified an appropriate classification based on the history of prior use. The classification system used is presented in Table 1 and the resulting ranking of buildings is presented in Table 2. Figure 1 presents an overall plot plan for the site. Based on this ranking, a preliminary survey program was undertaken, which covered all areas that had been classified as either Group II, III or IV. No effort was made to include the Group I areas in the preliminary survey. In some areas, ductwork for the ventilation systems was included in the survey.

### Description of Surveys

The preliminary survey program was limited towards surveys of accessible surfaces for removable and total contamination, both alpha and beta/gamma activity, in units of dpm/100 cm<sup>2</sup>. Gamma dose rate measurements were made using TLD badges placed throughout the site and those results are described in a separate report (Report #001). The instruments used are identified on each survey sheet as appropriate. In general, the portable survey instruments are the ratemeter type so the recorded values are based on the meter output rather than an integrated value over a specific time period. The smears were counted in standard laboratory bench top units.

## PRELIMINARY SURVEY OF SELECTED SITE BUILDINGS

### Purpose

The Westinghouse Electric Corporation is preparing to request the termination of USNRC License Number SNM-951 for the site located in Large, PA. This report is one of a series of reports that presents the necessary information to establish that the site meets all applicable regulatory requirements so that the license can be terminated by the United States Nuclear Regulatory Commission.

### Scope

This report documents information collected during a preliminary survey of selected building areas on the site. The intention of the survey was to collect preliminary information on building areas that had the highest potential for contamination based on the history of prior use. Such preliminary information was to serve as the basis for establishing a site survey plan. No detailed statistical analysis is present in the report. It is not intended that this information serve as documentation that the acceptance criteria for termination of the license have been met. No preliminary survey information is presented on the Monitored Drain Line system. A separate report has been issued on the removal and survey of that system.

### Selection of Building Areas

In the early stages of the project a group of individuals, who had long term knowledge of the activities that had been conducted on the site including the current and past Safety Officers, was convened. This group reviewed each building and identified an appropriate classification based on the history of prior use. The classification system used is presented in Table 1 and the resulting ranking of buildings is presented in Table 2. Figure 1 presents an overall plot plan for the site. Based on this ranking, a preliminary survey program was undertaken, which covered all areas that had been classified as either Group II, III or IV. No effort was made to include the Group I areas in the preliminary survey. In some areas, ductwork for the ventilation systems was included in the survey.

### Description of Surveys

The preliminary survey program was limited towards surveys of accessible surfaces for removable and total contamination, both alpha and beta/gamma activity, in units of dpm/100 cm<sup>2</sup>. Gamma dose rate measurements were made using TLD badges placed throughout the site and those results are described in a separate report (Report #001). The instruments used are identified on each survey sheet as appropriate. In general, the portable survey instruments are the ratemeter type so the recorded values are based on the meter output rather than an integrated value over a specific time period. The smears were counted in standard laboratory bench top units.


### Survey Results

The survey results for each selected building area are presented in the appendices to this report. A brief summary of this information is presented in Table 3. No statistical evaluation was prepared on this data. With the exception of the Building 9 basement areas, no significant contamination and/or radiation levels were found. The basement area of Building 9 is a large pit which housed the three large collection tanks for the Monitored Drain Line system. These tanks and the associated pumps, filters and piping were used to collect, sample and treat as appropriate, all suspect water prior to discharge. While detectable, the results for this area meet the acceptance criteria.

### Conclusions

The preliminary survey data indicates that all buildings on the site meet the acceptance criteria without any cleanup action. With the exception of the basement in Building 9, no area was identified as having a high potential for contamination. The results for the basement in Building 9 indicated activity above background in area of the floor. Therefore, the survey plan for this area will reflect this information.

FIGURE 1



ITEM CODE	NAME	DESCRIPTION	QUANTITY ON DRAWING	PART OR ASSEMBLY NO.	REVISION	SPECIFICATION	PARTS LIST			
							ITEM NO.	NAME	DESCRIPTION	QUANTITY ON DRAWING
		WALLS OTHER THAN SPECIFIED		CONTRACT NO.						
		STRUCTURE 200 FT. FROM ROAD		ITEM NO.	PRICE OF ITEM					
		NO. 10 SHEET PLATE 1/2 IN.		00000000	100.00					
		HOLDINGS - DO NOT SCALE								
		SPL. SEC. SPL. SEC. ANGLES								
		0 0 0								
		INSTRUCTIONS								
		TYPE								
		DRW. CODE NO.								

Westinghouse Advanced Energy Systems Division  
Pittsburgh, Pennsylvania

WAESD LARGE, PA

DATE DRAWN BY	DATE REC'D BY
D	JN030
SCALE	1/4 IN.=1'-0"
WT. ACTL.	WT. CALC.
BLDG.	BLDG.

FIGURE 1  
SITE PLOT PLAN

TABLE 1

CLASSIFICATION SYSTEM

GROUP DESIGNATION	DESCRIPTION	COLOR CODE
I	Offices, Administrative Areas and Plant Areas where historical information indicates that no radioactive material had ever been used or stored	Green
II	Offices, Administrative Areas and Plant Areas where historical information is uncertain, but does not indicate that any radioactive material had been used or stored.	Yellow
III	Areas where historical information indicates only encapsulated material or sealed sources were used or stored.	Blue
IV	Areas where historical information indicates that unencapsulated radioactive material may have been used or stored.	Red

TABLE 2  
HISTORICAL REVIEW OF RADIOACTIVE MATERIAL USE

The following locations were identified by selected Westinghouse employees based on personal knowledge and recollection of the Large activities from 1961 to 1992.

Location Floor(s)	Type Of RAM Activities			Group ID	Comments
	Unencap	Sealed	Incidental		
4 Basement		X		II	1977 HPO
First			X	I	ADMIN OFFICES
Second			X	I	ADMIN OFFICES
Third		X		II	1989 HPO
5 First	X			IV	ENR U/IRRAD U
Second	X			IV	ENR U/IRRAD U
Third	X			IV	ENR U/IRRAD U
Fourth			X	I	
5A First			X	I	STOREROOM
6 First	X			IV	RX ASSEMBLY
Second	X			IV	QA AREA
6A First	X			IV	FUEL ASSEMBLY
7 First	X			IV	
Second			X	I	TRUCKLOCK/VAULT
8 First			X	I	
Second			X	I	
8A First	X			IV	OLD HPO/PU/CO
Second			X	I	
9 Basement		X	X	IV	
First	X			IV	MDL TANKS
Second			X	I	MET LAB/MFP/ACT
10 First			X	I	
Second			X	I	LIBRARY
11 First			X	I	ADMIN OFFICES
Second			X	I	ADMIN OFFICES
Third			X	I	ADMIN OFFICES
12 First		X		II	DEP U CASK
Hyd Fac First	X			IV	FUEL FLOW
Firehall			X	I	FIRETRUCK
Backlot		X		III	LLRW STORAGE
Centerlot			X	III	INHOUSE XFER
Frontlot			X	I	PARKING

TABLE 3

Page 1

## SUMMARY OF PRELIMINARY SURVEY RESULTS

Building Location	Appendix	Number of Survey Points	Removable Activity (dpm/100cm <sup>2</sup> )		Total Activity (dpm/100cm <sup>2</sup> )		Comments
			Alpha	Beta	Alpha	Beta	
(1)		(2)	(3)	(4)	(5)		
Building 4, Basement	A	86	<MDA	<MDA	<MDA	<MDA	
Building 5, First Floor, Plant Area	B	116	<MDA	<MDA	<MDA	<MDA	
Building 5 First Floor Office Area	B	22	<MDA	<MDA	<MDA	<MDA	
Building 5, First Floor, Areas where floor tile was removed.	B	5	--	--	<MDA	<MDA	One higher beta/gamma reading was later found to be due to small piece of Co-60 in buried drain line.
Building 5, Second Floor	C	55	<MDA	<MDA	<MDA	<MDA	
Building 5, Third Floor	D	27	<MDA	<MDA	<MDA	<MDA	
Building 6, First Floor North Section	E	42	<MDA	<MDA	<MDA	<MDA	
Building 6, First Floor, Center Section	E	26	<MDA	<MDA	<MDA	<MDA	
Building 6, First Floor South Section	E	41	<MDA	<MDA	<MDA	<MDA	
Building 6, First Floor Inside Ventilation Ductwork	E	2	<MDA	<MDA	<MDA	<MDA	

TABLE 3 - Continued

Page Two

## SUMMARY OF PRELIMINARY SURVEY RESULTS

Building Location	Appendix	Number of Survey Points	Removable Activity (dpm/100cm <sup>2</sup> )		Total Activity (dpm/100cm <sup>2</sup> )		Comments
			Alpha	Beta	Alpha	Beta	
	(1)	(2)	(3)	(4)	(5)		
Building 6, Second Floor	F	40	<MDA	<MDA	<MDA	<MDA	
Building 6A, First Floor,	G	54	<MDA	<MDA	<MDA	<MDA	
Building 6A, First Floor Inside Ventilation Ductwork	G	4	<MDA	<MDA	<MDA	<MDA	
Building 7, First Floor,	H	80	<MDA	<MDA	<MDA	<MDA	One beta smear and 5 beta survey points appeared to be detectable above background.
Building 8A, First Floor, Center Section where MDL was to be removed.	I	27	<MDA	<MDA	<MDA	<MDA	
Building 8A First Floor North and South Sections where MDL was to be removed.	I	66	<MDA	<MDA	<MDA	<MDA	
Building 9, Basement Floor	J	57	<34	<MDA	<2640	<425	Four survey points showed detectable activity.
Building 9, Basement, Floor above floor drain line.	J	10	---	---	<MDA	<MDA	

TABLE 3 - Continued

Page Three

## SUMMARY OF PRELIMINARY SURVEY RESULTS

Building Location	Appendix	Number of Survey Points	Removable Activity (dpm/100cm <sup>2</sup> )		Total Activity (dpm/100cm <sup>2</sup> )		Comments
			Alpha	Beta	Alpha	Beta	
		(1)	(2)	(3)	(4)	(5)	
Building 9, Basement North Wall	J	15	---	---	<MDA	<MDA	
Building 9, Basement East Wall	J	54	---	---	<MDA	<MDA	
Building 9, Basement West Wall	J	54	---	---	<MDA	<MDA	
Building 9, Basement, South Wall	J	15	---	---	<MDA	<MDA	
Building 9, First Floor, East Section	K	69	<MDA	<MDA	<MDA	<MDA	
Building 9 First Floor West Section	K	54	<MDA	<MDA	<MDA	<MDA	
Building 9, First Floor Inside Ventilation Ductwork.	K	2	<MDA	<MDA	<MDA	<MDA	
Hydrogen Facility (Paint Spray Facility)	L	21	<MDA	<MDA	<MDA	<MDA	

TABLE 3 - Continued

Page Four

SUMMARY OF PRELIMINARY SURVEY RESULTS

NOTES:

- 1) The survey data sheets are located in the referenced Appendix to the report.
- 2) The minimum detectable activity is approximately 15 to 20 dpm/100 cm<sup>2</sup>.
- 3) The minimum detectable activity is approximately 100 to 150 dpm/100 cm<sup>2</sup>.
- 4) The minimum detectable activity is approximately 50 to 100 dpm/100cm<sup>2</sup>/
- 5) The minimum detectable activity is approximately 250 to 1200 dpm/100 cm<sup>2</sup>.

APPENDIX A

BUILDING 4, BASEMENT

SURVEYOR: Larry Smith	SIGNATURE: <i>Larry Smith</i>	DATE: 4-14-92	FORM SERIAL NUMBER: Preliminary
-----------------------	-------------------------------	---------------	---------------------------------

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA			ALPHA
	Canberra	RS-2	Canberra	SAC-4		PAC-4G			
BACKGROUND	1.80 CPM	CPM	.20 CPM	CPH	SERIAL NO.	4478			ASP-1
EFFICIENCY	17.1 %	%	32.6 %	%	PROBE	AC-21B			1891
									AC-3

BUILDING/AREA	FLOOR	GRID	SHEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
4	Basement	N/A	1 0	20	N/A	N/A	≤ Bkg. Unless	≤ Bkg. Unless
			2 0	0			specified	specified
			3 0	0				
			4 0	0			Efficiency: 63.4%	Efficiency: 20.2%
			5 0	8			Avg. Bkg: 1104 DPM	Avg. Bkg: 74.3 DPM
			6 0	0			2 Per 100 cm	2 Per 100 cm
			7 0	0				
			8 0	31				
			9 0	0				
			10 6	0				
			11 0	20				
			12 0	8				
			13 0	0				
			14 0	0				
			15 0	0				
			16 0	8				
			17 0	0				
			18 0	0				
			19 0	20				

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

SURVEYOR: Larry Smith	SIGNATURE: <i>Larry Stt</i>	DATE: 4-14-92	FORM SERIAL NUMBER: Preliminary
-----------------------	-----------------------------	---------------	---------------------------------

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA			ALPHA
	Canberra	MS-2	Canberra	SAC-4		PAC-4G			
BACKGROUND	1.80 CPM	CPM	.20 CPM	CPM	CPM	SERIAL NO.	4478		ASP-1
EFFICIENCY	17.1 %	%	32.6 %	%	%	PROBE	AC-21B		1891 AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
4	Basement	N/A	20	0	0	N/A	N/A	≤ Bkg. Unless
			21	0	20			≤ Bkg. Unless
			22	0	0			specified
			23	0	8			Efficiency: 63.4% Efficiency: 20.2%
			24	0	8			Avg. Bkg: 1104 DPM Avg. Bkg: 74.3 DPM
			25	0	0			Per 100 cm <sup>2</sup> Per 100 cm <sup>2</sup>
			26	0	8			
			27	0	0			
			28	0	0			
			29	0	0			
			30	6	0			
			31	6	20			
			32	0	0			
			33	6	8			
			34	6	0			
			35	0	8			
			36	0	8			
			37	0	0			
			38	0	8			

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

SURVEYOR: Larry Smith	SIGNATURE: <i>Larry S. S.</i>	DATE: 4/14/92	FORM SERIAL NUMBER: Preliminary
-----------------------	-------------------------------	---------------	---------------------------------

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA			ALPHA
	Canberra	MS-2	Canberra	SAC-4		PAC-4G	ASP-1		
BACKGROUND	1.80 CPM	CPM	.20 CPM	CPM	SERIAL NO.	4478			1891
EFFICIENCY	17.1 %	%	32.6 %	%	PROBE	AC-21B			AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
4	Basement	N/A	39 0	0	N/A	N/A	≤ Bkg. Unless specified	≤ Bkg. Unless specified
			40 0	0				
			41 0	8				
			42 0	20			Efficiency: 63.4%	Efficiency: 20.2%
			43 0	0			Avg. Bkg: 1104 DPM	Avg. Bkg: 74.3 DPM
			44 6	20			Per 100 cm <sup>2</sup>	Per 100 cm <sup>2</sup>
			45 0	0				
			46 0	8				
			47 0	8				
			48 0	0				
			49 0	20				
			50 0	0				
			51 0	0				
			52 0	0				
			53 6	0				
			54 0	0				
			55 0	8				
			56 0	8				
			57 6	8				

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

SURVEYOR: Larry Smith	SIGNATURE: <i>Larry Sth</i>	DATE: 4-14-92	FORM SERIAL NUMBER: Preliminary
-----------------------	-----------------------------	---------------	---------------------------------

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA		ALPHA
	Canberra	RS-2	Canberra	SAC-4		PAC-4G	ASP-1	
BACKGROUND	1.80 CPM	CPM	.20 CPM	CPM	SERIAL NO.	4478		1891
EFFICIENCY	17.1 %	%	32.6 %	%	PROBE	AC-21B		AC-3

BUILDING/AREA	FLOOR	GRID	SHEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
4	Basement	N/A	58	6	20	N/A	N/A	≤ Bkg. Unless
			59	0	8			specified
			60	0	8			
			61	0	0			Efficiency: 63.4% Efficiency: 20.2%
			62	0	0			Avg. Bkg: 1104 DPM Avg. Bkg: 74.3 DPM
			63	0	8			Per 100 cm <sup>2</sup> Per 100 cm <sup>2</sup>
			64	0	8			
			65	0	31			
			66	0	0			
			67	0	0			
			68	0	0			
			69	0	0			
			70	0	8			
			71	0	0			
			72	0	0			
			73	0	8			
			74	0	0			
			75	0	43			
			76	0	8			

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

SURVEYOR: Larry Smith	SIGNATURE: <i>Larry S. H.</i>	DATE: 4-14-92	FORM SERIAL NUMBER: Preliminary
-----------------------	-------------------------------	---------------	---------------------------------


COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA		ALPHA
	Canberra	MS-2	Canberra	SAC-4		PAC-4G		
BACKGROUND	1.80 CPM	CPM	.20 CPM	CPM	SERIAL NO.	4478		ASP-1
EFFICIENCY	17.1 %	%	32.6 %	%	PROBE	AC-21B		1891 AC-3

BUILDING/AREA	FLOOR	GRID	SHEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
4	Basement	N/A	77	0	8	N/A	N/A	≤ Bkg. Unless
			78	0	0			specified
			79	0	0			
			80	0	0			Efficiency: 63.4% Efficiency: 20.2%
			81	0	20		Avg. Bkg: 1104 DPM	Avg. Bkg: 74.3 DPM
			82	0	0		Per 100 cm <sup>2</sup>	Per 100 cm <sup>2</sup>
			83	0	0			
			84	0	0			
			85	0	8			
			86	0	8	↓	↓	↓

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

1, 2, 3, 4, 5 or 6

-3-



BUILDING  
LINE  
SET V-N-050  
60' X 10'

PARTS LIST

part no.	description	quantity	material	specification
D	WATERShed Mains and Head Systems British Piping	1		
	BASEMENT FLOOR BUILDING N-4	1		
	WATER LARGE P.A.	1		
	DATE DRAWN BY SP. ACT. SP. CHECKED BY SP. APPROVED BY	1		
	14683 JN-001	1		

APPENDIX B

BUILDING 5, FIRST FLOOR

SURVEYOR: Larry Smith	SIGNATURE: <i>Larry Smith</i>	DATE: 3-18-92	FORM SERIAL NUMBER: Preliminary
-----------------------	-------------------------------	---------------	---------------------------------

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA		ALPHA
	TENNELEC	E	MS-2	TENNELEC	E	SAC-4	E-520	ASP-1
BACKGROUND	2.40	CPM		.10	CPM		5245	1891
EFFICIENCY	43.2	%		33.2	%	% PROBE	7mg/cm <sup>2</sup> m	AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
5	1	N/A	1 See		N/A	N/A	Avg. Bkg. = 270	Avg. Bkg. = 37.5
			2 Attached				DPM	DPM
			3 Printout					
			4				Efficiency: 13%	Efficiency: 20.2%
			5					
			6				4 Bkg.	5 Bkg.
			7					
			8					
			9					
			10					
			11					
			12					
			13					
			14					
			15					
			16					
			17					
			18					
			19					

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

SURVEYOR: Larry Smith	SIGNATURE: <i>Larry S. H.</i>	DATE: 3-18-92	FORM SERIAL NUMBER: Preliminary
-----------------------	-------------------------------	---------------	---------------------------------

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA		ALPHA
	TENNELEC	E	MS-2	TENNELEC	E	SAC-4	E-520	
BACKGROUND	2.40	CPM		.10	CPM		5245	ASP-1 1891
EFFICIENCY	43.2	%	%	33.2	%	% PROBE	7mg/cm <sup>2</sup> m	AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
5	1	N/A	20 See		N/A	N/A	Avg. Bkg.= 270	Avg. Bkg.= 37.5
			21 Attached				DPM	DPM
			22 Printout					
			23				Efficiency: 13%	Efficiency: 20.2%
			24					
			25				\$ Bkg.	\$ Bkg.
			26					
			27					
			28					
			29					
			30					
			31					
			32					
			33					
			34					
			35					
			36					
			37					
			38	V			V	

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

TH&S FORM - SPECIAL  
LRD - 2/92

\* \* \* \* \* \* \* \* \* \* \* \* \* \* \*  
\* DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE \*  
\* \* \* \* \* \* \* \* \* \* \* \* \* \* \*

Page 3 of 8

SURVEYOR: Larry Smith SIGNATURE: *Larry Smith* DATE: 3-18-92 FORM SERIAL NUMBER: Preliminary

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA		ALPHA
	TENNELEC	E	MS-2	TENNELEC	E	SAC-4	E-520	ASP-1
BACKGROUND	2.40	CPM		.10	CPM		5245	1891
EFFICIENCY	43.2	%		33.2	%		7mg/cm <sup>2</sup> m	AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
5	1	N/A	49	See	N/A	N/A	Avg. Bkg. = 270	Avg. Bkg. = 37.5
			40	Attached			DPM	DPM
			41	Printout				
			42				Efficiency: 13%	Efficiency: 20.2%
			43					
			44				<del>2</del> Bkg.	<del>2</del> Bkg.
			45					
			46					
			47					
			48					
			49					
			50					
			51					
			52					
			53					
			54					
			55					
			56					
			57					

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

SURVEYOR: Larry Smith	SIGNATURE: <i>Larry Smith</i>	DATE: 3-18-92	FORM SERIAL NUMBER: Preliminary
-----------------------	-------------------------------	---------------	---------------------------------

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA		ALPHA
	TENNELEC	E	MS-2	TENNELEC	E	SAC-4	E-520	ASP-1
BACKGROUND	2.40	CPM		.10	CPM	CPM	SERIAL NO.	5245
EFFICIENCY	43.2	%	%	33.2	%	%	PROBE	7mg/cm <sup>2</sup> m


BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
5	1	N/A	58	See	N/A	N/A	Avg. Bkg.= 270	Avg. Bkg.= 37.5
			59	Attached			DPM	DPM
			60	Printout				
			61				Efficiency: 13%	Efficiency: 20.2%
			62					
			63				§ Bkg.	§ Bkg.
			64					
			65					
			66					
			67					
			68					
			69					
			70					
			71					
			72					
			73					
			74					
			75					
			X					

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

TH&S FORM - SPECIAL  
ERD - 2/92

\*\*\* DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE \*\*\*

Page 5 of 8

SURVEYOR: Larry Smith SIGNATURE:  DATE: 3-18-92 FORM SERIAL NUMBER: Preliminary

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA		ALPHA
	TENNELEC	E	MS-2	TENNELEC	E	SAC-4	E-520	ASP-1
BACKGROUND	2.40	CPM		.10	CPM		5245	1891
EFFICIENCY	43.2	%		33.2	%	% PROBE	7mg/cm <sup>2</sup> m	AC-3

BUILDING/AREA	FLOOR	GRID	SHEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
5	1	N/A	77	See	N/A	N/A	Avg. Bkg. = 270	Avg. Bkg. = 37.5
			78	Attached			DPM	DPM
			79	Printout				
			80	1			Efficiency: 13%	Efficiency: 20.2%
			81					
			82				<u>5</u> Bkg.	<u>5</u> Bkg.
			83					
			84					
			85					
			86					
			87					
			88					
			89					
			90					
			91					
			92					
			93					
			94					
			95					
			96					
			97					
			98					
			99					
			100					
			101					
			102					
			103					
			104					
			105					
			106					
			107					
			108					
			109					
			110					
			111					
			112					
			113					
			114					
			115					
			116					
			117					
			118					
			119					
			120					
			121					
			122					
			123					
			124					
			125					
			126					
			127					
			128					
			129					
			130					
			131					
			132					
			133					
			134					
			135					
			136					
			137					
			138					
			139					
			140					
			141					
			142					
			143					
			144					
			145					
			146					
			147					
			148					
			149					
			150					
			151					
			152					
			153					
			154					
			155					
			156					
			157					
			158					
			159					
			160					
			161					
			162					
			163					
			164					
			165					
			166					
			167					
			168					
			169					
			170					
			171					
			172					
			173					
			174					
			175					
			176					
			177					
			178					
			179					
			180					
			181					
			182					
			183					
			184					
			185					
			186					
			187					
			188					
			189					
			190					
			191					
			192					
			193					
			194					
			195					
			196					
			197					
			198					
			199					
			200					

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

SURVEYOR:	Larry Smith	SIGNATURE:	DATE: 3-19-92	FORM SERIAL NUMBER: Preliminary
-----------	-------------	------------	---------------	---------------------------------


COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA			ALPHA
	TENNELEC	E	MS-2	TENNELEC	E	SAC-4	E-520	ASP-1	
BACKGROUND	2.50	CPM		.05	CPM	CPM	SERIAL NO.	5245	
EFFICIENCY	43.2	%	%	33.2	%	%	PROBE	7 mg/cm <sup>2</sup>	1891 AC-3

BUILDING/AREA	FLOOR	GRID	SHEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
5	1	N/A	49 See		N/A	N/A	4 Bkg.	4 Bkg.
			90 Attached					
			91 Printout				Avg.Bkg.= 270 DPM	Avg.Bkg.= 37.5 DPM
			92					
			93				Efficiency= 13%	Efficiency= 20.2%
			94					
			95					
			96					
			97					
			98					
			99					
			100					
			101					
			102					
			103					
			104					
			105					
			106					
			107					

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

<u>J. A. Stover</u>	DATE: 3-19-92	FORM SERIAL NUMBER: Preliminary
SAC-4		
SAC-4	INSTRUMENT	E-520
CPM	SERIAL NO.	5245
%	PROBE	7 mg/cm <sup>2</sup>

GAMMA/BETA/GAMMA		
ALPHA		



SAMPLE NUMBER	BETA COUNTS	BETA DPM	BETA 3 SIGMA	ALPHA COUNTS	ALPHA DPM	ALPHA 3 SIGMA	TIME MINS
1	0	-5.5	1.0	0	-0.3	0.2	0.33
2	0	-5.5	1.0	0	-0.3	0.2	0.33
3	4	22.4	10.4	0	-0.3	0.2	0.33
4	1	1.4	5.3	0	-0.3	0.2	0.33
5	3	15.4	9.1	0	-0.3	0.2	0.33
6	2	8.4	7.4	0	-0.3	0.2	0.33
7	1	1.4	5.3	0	-0.3	0.2	0.33
8	0	-5.5	1.0	0	-0.3	0.2	0.33
9	0	-5.5	1.0	0	-0.3	0.2	0.33
10	1	1.4	5.3	0	-0.3	0.2	0.33
11	0	-5.5	1.0	0	-0.3	0.2	0.33
12	1	1.4	5.3	0	-0.3	0.2	0.33
13	0	-5.5	1.0	0	-0.3	0.2	0.33
14	2	8.4	7.4	0	-0.3	0.2	0.33
15	0	-5.5	1.0	1	8.8	5.2	0.33
16	1	1.4	5.3	0	-0.3	0.2	0.33
17	2	8.4	7.4	0	-0.3	0.2	0.33
18	0	-5.5	1.0	0	-0.3	0.2	0.33
19	0	-5.5	1.0	0	-0.3	0.2	0.33
20	0	-5.5	1.0	0	-0.3	0.2	0.33
21	0	-5.5	1.0	0	-0.3	0.2	0.33
22	0	-5.5	1.0	0	-0.3	0.2	0.33
23	2	8.4	7.4	0	-0.3	0.2	0.33
24	1	1.4	5.3	0	-0.3	0.2	0.33
25	2	8.4	7.4	0	-0.3	0.2	0.33
26	2	8.4	7.4	0	-0.3	0.2	0.33
27	0	-5.5	1.0	0	-0.3	0.2	0.33
28	0	-5.5	1.0	0	-0.3	0.2	0.33
29	1	1.4	5.3	0	-0.3	0.2	0.33
30	1	1.4	5.3	0	-0.3	0.2	0.33
31	0	-5.5	1.0	0	-0.3	0.2	0.33
32	0	-5.5	1.0	0	-0.3	0.2	0.33
33	1	1.4	5.3	0	-0.3	0.2	0.33
34	0	-5.5	1.0	0	-0.3	0.2	0.33
35	1	1.4	5.3	0	-0.3	0.2	0.33
36	1	1.4	5.3	0	-0.3	0.2	0.33
37	3	15.4	9.1	0	-0.3	0.2	0.33
38	3	15.4	9.1	0	-0.3	0.2	0.33
39	3	15.4	9.1	0	-0.3	0.2	0.33
40	2	15.4	9.1	0	-0.3	0.2	0.33
41	0	-5.5	1.0	0	-0.3	0.2	0.33
42	0	-5.5	1.0	0	-0.3	0.2	0.33
43	1	1.4	5.3	0	-0.3	0.2	0.33
44	1	1.4	5.3	0	-0.3	0.2	0.33
45	6	36.4	12.8	0	-0.3	0.2	0.33
46	2	8.4	7.4	0	-0.3	0.2	0.33
47	2	8.4	7.4	1	8.8	5.2	0.33
48	2	8.4	7.4	0	-0.3	0.2	0.33
49	0	-5.5	1.0	0	-0.3	0.2	0.33
50	1	1.4	5.3	0	-0.3	0.2	0.33
51	1	1.4	5.3	0	-0.3	0.2	0.33
52	1	1.4	5.3	0	-0.3	0.2	0.33
53	0	-5.5	1.0	0	-0.3	0.2	0.33
54	0	-5.5	1.0	0	-0.3	0.2	0.33
55	0	-5.5	1.0	0	-0.3	0.2	0.33
56	1	1.4	5.3	0	-0.3	0.2	0.33
57	1	1.4	5.3	0	-0.3	0.2	0.33
58	3	15.4	9.1	0	-0.3	0.2	0.33
59	0	-5.5	1.0	0	-0.3	0.2	0.33
60	0	-5.5	1.0	0	-0.3	0.2	0.33
61	4	22.4	10.4	0	-0.3	0.2	0.33

31	0	-5.5	1.0	0	-0.3	0.2	0.33
32	0	-5.5	1.0	0	-0.3	0.2	0.33
33	1	1.4	5.3	0	-0.3	0.2	0.33
34	0	-5.5	1.0	0	-0.3	0.2	0.33
35	1	1.4	5.3	0	-0.3	0.2	0.33
36	1	1.4	5.3	0	-0.3	0.2	0.33
37	3	15.4	9.1	0	-0.3	0.2	0.33
38	3	15.4	9.1	0	-0.3	0.2	0.33
39	3	15.4	9.1	0	-0.3	0.2	0.33
40	3	15.4	9.1	0	-0.3	0.2	0.33
41	0	-5.5	1.0	0	-0.3	0.2	0.33
42	0	-5.5	1.0	0	-0.3	0.2	0.33
43	1	1.4	5.3	0	-0.3	0.2	0.33
44	1	1.4	5.3	0	-0.3	0.2	0.33
45	6	36.4	12.8	0	-0.3	0.2	0.33
46	2	8.4	7.4	1	0.8	5.2	0.33
47	2	8.4	7.4	0	-0.3	0.2	0.33
48	2	8.4	7.4	0	-0.3	0.2	0.33
49	0	-5.5	1.0	0	-0.3	0.2	0.33
50	1	1.4	5.3	0	-0.3	0.2	0.33
51	1	1.4	5.3	0	-0.3	0.2	0.33
52	1	1.4	5.3	0	-0.3	0.2	0.33
53	0	-5.5	1.0	0	-0.3	0.2	0.33
54	0	-5.5	1.0	0	-0.3	0.2	0.33
55	0	-5.5	1.0	0	-0.3	0.2	0.33
56	1	1.4	5.3	0	-0.3	0.2	0.33
57	1	1.4	5.3	0	-0.3	0.2	0.33
58	3	15.4	9.1	0	-0.3	0.2	0.33
59	0	-5.5	1.0	0	-0.3	0.2	0.33
60	0	-5.5	1.0	0	-0.3	0.2	0.33
61	4	22.4	18.4	0	-0.3	0.2	0.33
62	0	-5.5	1.0	0	-0.3	0.2	0.33
63	2	8.4	7.4	0	-0.3	0.2	0.33
64	3	15.4	9.1	0	-0.3	0.2	0.33
65	0	-5.5	1.0	0	-0.3	0.2	0.33
66	0	-5.5	1.0	0	-0.3	0.2	0.33
67	2	8.4	7.4	0	-0.3	0.2	0.33
68	0	-5.5	1.0	0	-0.3	0.2	0.33
69	2	8.4	7.4	0	-0.3	0.2	0.33
70	0	-5.5	1.0	0	-0.3	0.2	0.33
71	2	8.4	7.4	0	-0.3	0.2	0.33
72	0	-5.5	1.0	0	-0.3	0.2	0.33
73	0	-5.5	1.0	0	-0.3	0.2	0.33
74	1	1.4	5.3	0	-0.3	0.2	0.33
75	2	8.4	7.4	0	-0.3	0.2	0.33
76	1	1.4	5.3	0	-0.3	0.2	0.33
77	2	8.4	7.4	0	-0.3	0.2	0.33
78	2	8.4	7.4	0	-0.3	0.2	0.33
79	2	8.4	7.4	0	-0.3	0.2	0.33
80	1	1.4	5.3	0	-0.3	0.2	0.33
81	2	8.4	7.4	0	-0.3	0.2	0.33
82	1	1.4	5.3	0	-0.3	0.2	0.33
83	1	1.4	5.3	0	-0.3	0.2	0.33
84	1	1.4	5.3	0	-0.3	0.2	0.33
85	0	-5.5	1.0	0	-0.3	0.2	0.33
86	0	-5.5	1.0	0	-0.3	0.2	0.33
87	0	-5.5	1.0	0	-0.3	0.2	0.33
88	0	-5.5	1.0	0	-0.3	0.2	0.33

SAMPLE NUMBER	BETA COUNTS	BETA DPM	BETA 3 SIGMA	ALPHA COUNTS	ALPHA DPM	ALPHA 3 SIGMA	TIME MINS
89	1	1.2	5.3	0	-0.1	0.1	0.33
90	1	15.2	9.1	0	-0.1	0.1	0.33
91	4	22.2	18.4	0	-0.1	0.1	0.33
92	1	1.2	5.3	0	-0.1	0.1	0.33
93	2	8.2	7.4	0	-0.1	0.1	0.33
94	0	-5.7	1.0	0	-0.1	0.1	0.33
95	0	-5.7	1.0	0	-0.1	0.1	0.33
96	0	-5.7	1.0	0	-0.1	0.1	0.33
97	1	1.2	5.3	0	-0.1	0.1	0.33
98	0	-5.7	1.0	0	-0.1	0.1	0.33
99	1	1.2	5.3	0	-0.1	0.1	0.33
100	1	1.2	5.3	0	-0.1	0.1	0.33
1	0	-5.7	1.0	0	-0.1	0.1	0.33
2	1	1.2	5.3	0	-0.1	0.1	0.33
3	0	-5.7	1.0	0	-0.1	0.1	0.33
4	2	8.2	7.4	0	-0.1	0.1	0.33
5	1	1.2	5.3	0	-0.1	0.1	0.33
6	2	8.2	7.4	0	-0.1	0.1	0.33
7	1	1.2	5.3	0	-0.1	0.1	0.33
8	0	-5.7	1.0	0	-0.1	0.1	0.33
9	0	-5.7	1.0	0	-0.1	0.1	0.33
10	0	-5.7	1.0	0	-0.1	0.1	0.33
11	1	1.2	5.3	0	-0.1	0.1	0.33
12	0	-5.7	1.0	0	-0.1	0.1	0.33
13	1	1.2	5.3	0	-0.1	0.1	0.33
14	0	-5.7	1.0	0	-0.1	0.1	0.33
15	0	-5.7	1.0	0	-0.1	0.1	0.33
16	2	8.2	7.4	0	-0.1	0.1	0.33




SURVEYOR: Larry Smith		SIGNATURE: <i>Larry Smith</i>		DATE: 3-24-92		FORM SERIAL NUMBER: Preliminary		
	BETA-GAMMA		ALPHA		GAMMA/BETA-GAMMA			ALPHA
COUNTER NO.:	GM-1	GM-2	Alpha-1	Alpha-2	INSTRUMENT	E520		ASP-1
BACKGROUND	21.4 CPM	25.9 CPM	1.05 CPM	.05 CPM	SERIAL NO.	5245		1891
EFFICIENCY	26.1 %	17.54 %	38.9 %	39.8 %	PROBE	7mg/cm <sup>2</sup>		AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT uR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
5	1	N/A	1 0	32	N/A	N/A	Avg. Bkg=270 DPM	Avg Bkg. =37.5 DPM
			1 2 0	0			Efficiency: 13%	Efficiency: 20.2%
			3 0	0			≤ Bkg.	≤ Bkg.
			4 0	57				
			5 5	32				
			6 0	0				
			7 0	0				
			8 0	0				
			9 0	0				
			10 0	0				
			11 0	69				
			12 0	0				
			13 5	48				
			14 0	46				
			15 0	0				
			16 0	0				
			17 0	32				
			18 0	0				
			19 0	8				
↓	↓	↓	↓	↓	↓	↓	↓	↓

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS






## PARTS LIST

	DESCRIPTION	QUANTITY	REFERENCE	NOTE
1	WATER CELLS	3	JN-039	
2	WATER TOWER	1	JN-039	
3	WATER PUMP	1	JN-039	
4	WATER TOWER	1	JN-039	
5	WATER PUMP	1	JN-039	
6	WATER TOWER	1	JN-039	
7	WATER PUMP	1	JN-039	
8	WATER TOWER	1	JN-039	
9	WATER PUMP	1	JN-039	
10	WATER TOWER	1	JN-039	
11	WATER PUMP	1	JN-039	
12	WATER TOWER	1	JN-039	
13	WATER PUMP	1	JN-039	
14	WATER TOWER	1	JN-039	
15	WATER PUMP	1	JN-039	
16	WATER TOWER	1	JN-039	
17	WATER PUMP	1	JN-039	
18	WATER TOWER	1	JN-039	
19	WATER PUMP	1	JN-039	
20	WATER TOWER	1	JN-039	
21	WATER PUMP	1	JN-039	
22	WATER TOWER	1	JN-039	
23	WATER PUMP	1	JN-039	
24	WATER TOWER	1	JN-039	
25	WATER PUMP	1	JN-039	
26	WATER TOWER	1	JN-039	
27	WATER PUMP	1	JN-039	
28	WATER TOWER	1	JN-039	
29	WATER PUMP	1	JN-039	

Page 3 of 3



	DESCRIPTION	QUANTITY	REFERENCE	NOTE
1	WATER CELLS	3	JN-039	
2	WATER TOWER	1	JN-039	
3	WATER PUMP	1	JN-039	
4	WATER TOWER	1	JN-039	
5	WATER PUMP	1	JN-039	
6	WATER TOWER	1	JN-039	
7	WATER PUMP	1	JN-039	
8	WATER TOWER	1	JN-039	
9	WATER PUMP	1	JN-039	
10	WATER TOWER	1	JN-039	
11	WATER PUMP	1	JN-039	
12	WATER TOWER	1	JN-039	
13	WATER PUMP	1	JN-039	
14	WATER TOWER	1	JN-039	
15	WATER PUMP	1	JN-039	
16	WATER TOWER	1	JN-039	
17	WATER PUMP	1	JN-039	
18	WATER TOWER	1	JN-039	
19	WATER PUMP	1	JN-039	
20	WATER TOWER	1	JN-039	
21	WATER PUMP	1	JN-039	
22	WATER TOWER	1	JN-039	
23	WATER PUMP	1	JN-039	
24	WATER TOWER	1	JN-039	
25	WATER PUMP	1	JN-039	
26	WATER TOWER	1	JN-039	
27	WATER PUMP	1	JN-039	
28	WATER TOWER	1	JN-039	
29	WATER PUMP	1	JN-039	



I IH&S FORM I  
I # 1002 I  
I LRD - 7/90 I

\* \* \* \* \* RADIATION SURVEY \* \* \* \* \*

SURVEY TYPE: ROUTINE	<input type="checkbox"/> SPECIAL	<input checked="" type="checkbox"/> RWP	<input type="checkbox"/> (RWP #)	SURVEY DATE: 4-15-92
LOCATION: Blk: #5 FIRST FLOOR				SURVEY TIME: 0900 - 1100
INSTRUMENT: PAC 4G	SERIAL # 4478			PROBE TYPE: AC-21-B
INSTRUMENT: ASP 1	SERIAL # 1891			PROBE TYPE: AC-3

DESCRIPTION OF SURVEY

Contact Alpha / Beta Floor Frisk Area Asbestos Tile Removal AND Allegheny County Health Dept Release.  
100% Floor Surface Surveys of All Areas

INDICATED ON MAP

AREA	AVG. NET OPM		MAX NET OPM	
	ALPHA	BETA	ALPHA	BETA
1	≤ BKG	≤ BKG	≤ BKG	≤ BKG
2	≤ BKG	≤ BKG TO 315	≤ BKG	790 (SEE ON MAP)
3	≤ BKG	≤ BKG TO 315	≤ BKG	315
4	≤ BKG	≤ BKG TO 315	≤ BKG	315
5	≤ BKG	≤ BKG TO 315	≤ BKG	315

SKETCH

SEE ATTACHED FLOOR MAP FOR SURVEY AREAS

REMARKS

INSTRUMENTATION DATA:

INSTRUMENT:	S/N:	Probe:	Efficiency	Avg BKG/100cm <sup>2</sup>	
PAC-4G	4478	AC-21-B	63.4%	1340 OPM	BETA
ASP-1	1891	AC-3	20.2%	74 OPM	ALPHA


H.P. SIGNATURE

Terry Smith

DATE: 4-15-92

*Page 2*

*Areas Having  
Asbestos Floor Tile  
Removed*



APPENDIX C

BUILDING 5, SECOND FLOOR

IH&S FORM - SPECIAL  
LRD - 2/92

DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE

Page 1 of 4

SURVEYOR: Larry Smith

SIGNATURE: *Larry Smith*

DATE: 3-25-92

FORM SERIAL NUMBER: Preliminary

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA			ALPHA
	GM -1	GM-2	Alpha-1	Alpha-2		E-520			
BACKGROUND	21.8	CPM	25.4	CPM	.95	CPM	.05	CPM	SERIAL NO. 5242
EFFICIENCY	26.1	%	17.54	%	38.9	%	39.8	%	PROBE 7mg/cm <sup>2</sup>

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER UR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
5	2	N/A	1 0	8	N/A	N/A	≤ Bkg.	≤ Bkg.
			2 0	0				
			3 0	0				Avg.Bkg.: 270 DPM
			4 0	0				Efficiency: 13%
			5 0	0				Efficiency: 20.2%
			6 5	0				
			7 0	8				
			8 0	57				
			9 0	0				
			10 0	46				
			11 0	8				
			12 0	0				
			13 0	0				
			14 0	0				
			15 0	0				
			16 0	11				
			17 5	23				
			18 0	46				
			19 0	23				

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

SURVEYOR:	Larry Smith	SIGNATURE: <i>Larry S. H.</i>	DATE: 3-25-92	FORM SERIAL NUMBER: Preliminary
-----------	-------------	-------------------------------	---------------	---------------------------------

COUNTER NO.:	BETA-GAMMA		ALPHA		GAMMA/BETA-GAMMA			ALPHA
	GM -1	GM-2	Alpha-1	Alpha-2	INSTRUMENT	E-520	5242	
BACKGROUND	21.8 CPM	25.4 CPM	.95 CPM	.05 CPM	SERIAL NO.			ASP-1
EFFICIENCY	26.1 %	17.54 %	38.9 %	39.8 %	PROBE	7mg/cm <sup>2</sup>		1891 AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
5	2	N/A	20 0	23	N/A	N/A	≤ Bkg.	≤ Bkg.
			21 0	31				
			22 0	34			Avg.Bkg.:270 DPM	Avg.Bkg:37.5 DPM
			23 0	46			Efficiency: 13%	Efficiency:20.2%
			24 0	0				
			25 0	0				
			26 0	0				
			27 0	8				
			28 0	0				
			29 0	0				
			30 0	0				
			31 0	15				
			32 0	68				
			33 0	31				
			34 0	0				
			35 0	8				
			36 0	80				
			37 0	15				
			38 0	0				

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

SURVEYOR: Larry Smith

SIGNATURE: *Larry Smith*


DATE: 3-25-92

FORM SERIAL NUMBER: Preliminary

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA			ALPHA
	GM -1	GM-2	Alpha-1	Alpha-2		E-520			
BACKGROUND	21.8	CPM	25.4	CPM	.95	CPM	.05	CPM	ASP-1
EFFICIENCY	26.1	%	17.54	%	38.9	%	39.8	%	1891
					PROBE	7mg/cm <sup>2</sup>			AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
5	2	N/A	39	0	23	N/A	N/A	≤ Bkg.
			40	0	0			
			41	0	0			Avg. Bkg.: 270 DPM
			42	0	0			Efficiency: 13%
			43	0	15			Efficiency: 20.2%
			44	5	68			
			45	0	0			
			46	0	23			
			47	0	0			
			48	0	46			
			49	0	8			
			50	0	102			
			51	0	15			
			52	0	57			
			53	0	0			
			54	0	46			
			55	0	31			

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS



Winghouse Advanced Early Systems Division				
PARTS LIST		DESCRIPTION		
part	name	part no.	description	specification
1	BRICK	1	ONE 12" X 6" X 3" BRICK	ONE 12" X 6" X 3" BRICK
2	CONCRETE BLOCK END	2	ONE CONCRETE BLOCK END	ONE CONCRETE BLOCK END
3	DRYWALL & PANELING	3	ONE DRYWALL & PANELING	ONE DRYWALL & PANELING
4	SCALE : FEET	4	ONE SCALE : FEET	ONE SCALE : FEET

part	name	part no.	description	specification
1	BRICK	1	ONE 12" X 6" X 3" BRICK	ONE 12" X 6" X 3" BRICK
2	CONCRETE BLOCK END	2	ONE CONCRETE BLOCK END	ONE CONCRETE BLOCK END
3	DRYWALL & PANELING	3	ONE DRYWALL & PANELING	ONE DRYWALL & PANELING
4	SCALE : FEET	4	ONE SCALE : FEET	ONE SCALE : FEET

0 10 20 30

inches

0 10 20 30

feet

0 10 20 30

yards

0 10 20 30

metres

0 10 20 30

centimetres

0 10 20 30

millimetres

0 10 20 30

inches

0 10 20 30

feet

0 10 20 30

yards

0 10 20 30

metres

0 10 20 30

centimetres

0 10 20 30

millimetres

0 10 20 30

inches

0 10 20 30

feet

0 10 20 30

yards

0 10 20 30

metres

0 10 20 30

centimetres

0 10 20 30

millimetres

APPENDIX D

BUILDING 5, THIRD FLOOR

SURVEYOR: Larry Smith	SIGNATURE: <i>Larry Smith</i>	DATE: 4/2/92	FORM SERIAL NUMBER: Preliminary
-----------------------	-------------------------------	--------------	---------------------------------

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA			ALPHA
	Canberra	MS-2	Canberra	SAC-4		PAC-4G			
BACKGROUND	.85 CPM	CPM	.20 CPM	CPM	SERIAL NO.	4478			ASP-1
EFFICIENCY	17.1 %	%	32.6 %	%	PROBE	AC-21B			1891
									AC-3



BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER UR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
5	3	N/A	1 0	7	N/A	N/A	≤ Bkg. Unless specified	≤ Bkg. Unless specified
			2 5	7				
			3 5	0				
			4 0	18			Efficiency: 63.4%	Efficiency: 20.2%
			5 5	18			Avg. Bkg: 1183 DPM	Avg. Bkg: 74.3 DPM
			6 12	7			Per 100 cm <sup>2</sup>	Per 100 cm <sup>2</sup>
			7 0	0				
			8 0	18				
			9 5	7				
			10 0	7				
			11 0	0				
			12 0	0				
			13 0	7				
			14 0	0				
			15 0	7				
			16 0	18				
			17 0	0				
			18 0	0				
			19 5	18				

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS



PAGE 3 OF 3

-10-



O - DESIGNATED SURVEY POINTS

APPENDIX E


BUILDING 6, FIRST FLOOR

SURVEYOR:	Larry Smith	SIGNATURE: <i>Larry Smith</i>
		DATE: 3-19-92
		FORM SERIAL NUMBER: Preliminary

Page 6 of 4

DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE

BETA-GAMMA			ALPHA			GAMMA/BETA-GAMMA			ALPHA		
COUNTER NO.:	TENNELEC E	HS-2	TENNELEC E	SAC-4	INSTRUMENT	E-520	SERIAL NO.	5245	PROBE	7 mg/cm <sup>2</sup>	ASP-1
BACKGROUND	2.50 CPM		CPH	.05 CPH	CPH						1891
EFFICIENCY	43.2 %	%	%	33.2 %	%						AC-3



THIS FORM - SPECIAL  
LTD - 2/92

DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE  
\* \* \* \* \*


Page 2 of 4

SURVEYOR: Larry Smith

SIGNATURE: Larry Smith

DATE: 3-19-92 FORM SERIAL NUMBER: Preliminary

BETA-GAMMA		ALPHA		GAMMA/BETA-GAMMA		ALPHA	
COUNTER NO.:	TENNELEC E	HS-2	TERNELEC E	SAC-4	INSTRUMENT	E-520	ASP-1
BACKGROUND	2.50 CPM		.05 CPM	CPH	SERIAL NO.	5245	1891
EFFICIENCY	43.2 %	%	33.2 %	%	PROBE	7 mg/cm <sup>2</sup>	AC-3





SURVEYOR: Larry Smith

SIGNATURE: *Larry Smith*

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT
	TENNELEC E	MS-2	TENNELEC E	SAC-4	
BACKGROUND	2.50 CPM		.05 CPM		CPM SERIAL
EFFICIENCY	43.2 %	%	33.2 %	%	PROBE

SAMPLE NUMBER	BETA COUNTS	BETA DPM	BETA 3 SIGMA	ALPHA COUNTS	ALPHA DPM	SMEAR		GAMMA RADIATION ONE METER UR/HOUR
						ALPHA	BETA	
1	0	-5.7	1.0	0	-0.1	0.1	0.33	
2	0	-5.7	1.0	0	-0.1	0.1	0.33	
3	2	8.2	7.4	0	-0.1	0.1	0.33	
4	0	-5.7	1.0	0	-0.1	0.1	0.33	
5	2	8.2	7.4	0	-0.1	0.1	0.33	
6	1	1.2	5.3	0	-0.1	0.1	0.33	
7	1	1.2	5.3	0	-0.1	0.1	0.33	
8	0	-5.7	1.0	0	-0.1	0.1	0.33	
9	0	-5.7	1.0	0	-0.1	0.1	0.33	
10	1	1.2	5.3	0	-0.1	0.1	0.33	
11	2	8.2	7.4	0	-0.1	0.1	0.33	
12	2	8.2	7.4	0	-0.1	0.1	0.33	
13	1	1.2	5.3	0	-0.1	0.1	0.33	
14	0	-5.7	1.0	0	-0.1	0.1	0.33	
15	1	1.2	5.3	0	-0.1	0.1	0.33	
16	1	1.2	5.3	0	-0.1	0.1	0.33	
17	1	1.2	5.3	0	-0.1	0.1	0.33	
18	1	1.2	5.3	0	-0.1	0.1	0.33	
19	0	-5.7	1.0	0	-0.1	0.1	0.33	
20	0	-5.7	1.0	0	-0.1	0.1	0.33	
21	0	-5.7	1.0	0	-0.1	0.1	0.33	
22	1	1.2	5.3	0	-0.1	0.1	0.33	
23	0	-5.7	1.0	0	-0.1	0.1	0.33	
24	0	-5.7	1.0	0	-0.1	0.1	0.33	
25	2	8.2	7.4	0	-0.1	0.1	0.33	
26	2	8.2	7.4	0	-0.1	0.1	0.33	
27	0	-5.7	1.0	0	-0.1	0.1	0.33	IE CENTIMETERS
28	1	1.2	5.3	0	-0.1	0.1	0.33	
29	1	1.2	5.3	0	-0.1	0.1	0.33	
30	0	-5.7	1.0	0	-0.1	0.1	0.33	
31	1	1.2	5.3	0	-0.1	0.1	0.33	
32	1	1.2	5.3	0	-0.1	0.1	0.33	
33	2	8.2	7.4	0	-0.1	0.1	0.33	
34	0	-5.7	1.0	0	-0.1	0.1	0.33	
35	6	36.2	12.8	0	-0.1	0.1	0.33	
36	1	1.2	5.3	0	-0.1	0.1	0.33	
37	2	8.2	7.4	0	-0.1	0.1	0.33	
38	1	1.2	5.3	0	-0.1	0.1	0.33	
39	1	1.2	5.3	0	-0.1	0.1	0.33	
40	1	1.2	5.3	0	-0.1	0.1	0.33	
41	0	-5.7	1.0	0	-0.1	0.1	0.33	
42	1	1.2	5.3	0	-0.1	0.1	0.33	



SURVEYOR: Larry Smith		SIGNATURE: <i>Larry Smith</i>	DATE: 4/2/92	FORM SERIAL NUMBER: Preliminary
-----------------------	--	-------------------------------	--------------	---------------------------------

	BETA-GAMMA		ALPHA		GAMMA/BETA-GAMMA			ALPHA
COUNTER NO.:	Canberra	MS-2	Canberra	SAC-4	INSTRUMENT	PAC-4G		ASP-1
BACKGROUND	.85 CPM	CPM	.20 CPM	CPM	SERIAL NO.	4478		1891
EFFICIENCY	17.1 %	%	32.6 %	%	PROBE	AC-21B		AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
6	1	N/A	1 0	7	N/A	N/A	≤ Bkg. Unless	≤ Bkg. Unless
			2 0	0			specified	specified
			3 0	0				
			4 0	7			Efficiency: 63.4%	Efficiency: 20.2%
			5 0	0			Avg. Bkg: 1183 DPM	Avg. Bkg: 74.3 DPM
			6 0	7			Per 100 cm <sup>2</sup>	Per 100 cm <sup>2</sup>
			7 0	18				
			8 0	7				
			9 0	0				
			10 0	7				
			11 0	0				
			12 0	7				
			13 0	0				
			14 0	0				
			15 0	18				
			16 0	7				
			17 0	18				
			18 0	0				
			19 0	0				

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

IH&S FORM - SPECIAL  
ERD - 2/92


DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE

Page 2 of 3

SURVEYOR:	Larry Smith		SIGNATURE:	<i>Larry Smith</i>		DATE:	4/2/92	FORM SERIAL NUMBER: Preliminary
-----------	-------------	--	------------	--------------------	--	-------	--------	---------------------------------


COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA			ALPHA
	Canberra	MS-2	Canberra	SAC-4		PAC-4G			
BACKGROUND	.85 CPM	CPM	.20 CPM	CPM	SERIAL NO.	4478			ASP-1
EFFICIENCY	17.1 %	%	32.6 %	%	PROBE	AC-21B			1891
									AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
6	1	N/A	20	0	N/A	N/A	≤ Bkg. Unless	≤ Bkg. Unless
			21	5	18		specified	specified
			22	0	0			
			23	5	30		Efficiency: 63.4%	Efficiency: 20.2%
			24	0	30		Avg. Bkg: 1183 DPM	Avg. Bkg: 74.3 DPM
			25	0	7		Per 100 cm <sup>2</sup>	Per 100 cm <sup>2</sup>
			26	0	0			



SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

Face 3 or 3



O - DESIGNATES SURVEY POINTS

PART L121		Building Material Specified		Building Material Specified	
WALLS, FLOORING, CEILINGS	INTERIOR AND EXTERIOR	WOODEN	WOODEN	WOODEN	WOODEN
FLOORING	NO FLOORING	NO FLOORING	NO FLOORING	NO FLOORING	NO FLOORING
ROOF	NO ROOF	NO ROOF	NO ROOF	NO ROOF	NO ROOF
DOORS	NO DOORS	NO DOORS	NO DOORS	NO DOORS	NO DOORS
WINDOWS	NO WINDOWS	NO WINDOWS	NO WINDOWS	NO WINDOWS	NO WINDOWS
STAIRCASES	NO STAIRCASES	NO STAIRCASES	NO STAIRCASES	NO STAIRCASES	NO STAIRCASES
WALLS, CEILINGS, FLOORS	NO WALLS, CEILINGS, FLOORS	NO WALLS, CEILINGS, FLOORS	NO WALLS, CEILINGS, FLOORS	NO WALLS, CEILINGS, FLOORS	NO WALLS, CEILINGS, FLOORS
CEILINGS	NO CEILINGS	NO CEILINGS	NO CEILINGS	NO CEILINGS	NO CEILINGS
DOORS, WINDOWS	NO DOORS, WINDOWS	NO DOORS, WINDOWS	NO DOORS, WINDOWS	NO DOORS, WINDOWS	NO DOORS, WINDOWS
STAIRCASES	NO STAIRCASES	NO STAIRCASES	NO STAIRCASES	NO STAIRCASES	NO STAIRCASES

14083 JN-011 A

SURVEYOR: Larry Smith	SIGNATURE: <i>Larry Smith</i>	DATE: 3-24-92	FORM SERIAL NUMBER: Preliminary
-----------------------	-------------------------------	---------------	---------------------------------

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA		ALPHA
	GM-1	GM-2	Alpha-1	Alpha-2		E520		
BACKGROUND	21.4 CPM	25.9 CPM	1.05 CPM	.05 CPM	SERIAL NO.	5245		ASP-1
EFFICIENCY	26.1 %	17.54 %	38.9 %	39.8 %	PROBE	7mg/cm <sup>2</sup>		1891

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT uR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
6	1	N/A	1 5	0	N/A	N/A	Avg. Bkg=270 DPM	Avg Bkg =37.5 DPM
		1	2 0	68			Efficiency: 13%	Efficiency: 20.2%
		3	0 0				≤ Bkg.	≤ Bkg.
		4	0 7					
		5	0 31					
		6	0 0					
		7	0 8					
		8	0 6					
		9	0 0					
		10	0 11					
		11	0 0					
		12	0 34					
		13	5 31					
		14	0 23					
		15	0 0					
		16	0 0					
		17	5 0					
		18	0 0					
		19	0 0					

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

I THE FORM - SPECIAL  
I LRO - 2/92

DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE

page 2 of 4

SURVEYOR: Larry Smith

SIGNATURE: Darry DATE: 3-24-92 FORM SERIAL NUMBER: Preliminary

COUNTER NO.:	BETA-GAMMA			ALPHA			INSTRUMENT	SERIAL NO.	PROBE	IMR./CM <sup>2</sup>	GAMMA/BETA/GAMMA	ALPHA
	GM-1	GM-2	CPM	Alpha-1	Alpha-2	CPM						
BACKGROUND	21.4	CPM	25.9	CPM	1.05	CPM	.05	5245				ASP-1
EFFICIENCY	26.1	%	17.54	%	38.9	%	39.8					1891

BUILDING/AREA	FLOOR	GRID	SMEAR			GAMMA RADIATION ONE METER UR/HOUR	N/A	N/A	BETA-GAMMA RADIATION CONTACT MR/HOUR	BETA RADIATION CONTACT DPM/100 SQUARE CM	Ave. Bkg=270 DPM	Efficiency: 13%	Alpha Radiation Contact DPM/100 Square cm
			ALPHA	BETA	GAMMA								
6	/	N/A	20	0	57		N/A						
			21	0	6								
			22	0	34								
			23	0	0								
			24	0	125								
			25	0	15								
			26	0	23								
			27	0	23								
			28	0	57								
			29	0	0								
			30	0	46								
			31	5	0								
			32	0	57								
			33	0	39								
			34	0	34								
			35	0	23								
			36	0	0								
			37	5	0								
			38	0	0								

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS


SURVEYOR: Larry Smith			SIGNATURE: <i>Larry Smith</i>			DATE: 3-24-92		FORM SERIAL NUMBER: Preliminary		
COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA			ALPHA	
	GM-1	GM-2	Alpha-1	Alpha-2		E520				
	BACKGROUND	21.4 CPM	25.9 CPM	1.05 CPM		.05 CPM	SERIAL NO.	5245		
EFFICIENCY	26.1 %	17.54 %	38.9 %	39.8 %	PROBE	7mg/cm <sup>2</sup>			ASP-1	


BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER mR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
6	1	N/A	39	0	0	N/A	N/A	Avg. Bkg = 270 DPM
			40	0	0			Efficiency: 13%
			41	0	0			≤ Bkg.
			42	0	34			≤ Bkg.

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

Page 4 of 4



-12-



PARTS LIST		EXPLANATION	
part no.	description	part no.	description
1	BRICK	2	WALL BRICK
3	CONCRETE BLOCK EXT.	4	CONCRETE BLOCK INT.
5	DRYWALL & PLASTERING		

SCALE : FEET  
0' 0" 10' 0" 20' 0"

DRAWING COPIES MADE

LEGEND

- BRICK
- CONCRETE BLOCK EXT.
- DRYWALL & PLASTERING

SCALE : FEET  
0' 0" 10' 0" 20' 0"

BUILDING #011A  
SEE JN-039  
SEE JN-012  
SEE JN-011

WATERPROOFING ADVICE OF FIVE E SYSTEMS DIVISION  
FIVE E SYSTEMS DIVISION  
PO BOX 3074  
INDIANAPOLIS, IN 46201  
TELE: 317-273-7474

FIRST FLOOR  
BUILDING #011A  
WALES LARG, PA  
D 14683 JN-011A

\*\*\*\*\*  
I IH&S FORM I  
I #1004 I  
I LRD 3/88 I  
\*\*\*\*\*

\*\*\*\*\*  
\* SMEAR SAMPLE \*  
\*\*\*\*\*

PAGE 1 OF 4



LOCATION : <u>BLDG 6</u>	SURVEYOR : "HP STAFF"	SURVEY DATE <u>3-30-92</u>
<u>VENTILATION DUCTS</u>	COUNTED BY : "HP STAFF"	COUNT DATE <u>3-30-92</u>
BETA/GAMMA		ALPHA
COUNTER NUMBER	<u>Linacores</u>	<u>Cancores</u>
BACKGROUND (CPM)	<u>.80</u> CPM	CPM <u>.20</u> CPM
EFFICIENCY (%)	<u>17.1</u> %	% <u>32.6</u> %
ACTIVITY INT:	MICROCURIES <input type="checkbox"/>	DPM <u>88</u> CPM <input type="checkbox"/>

	A	B	A	B	A	B	A	B	A	B
1	<u>SEE</u>	21		22		23		24		25
2		22		23		24		25		26
3	<u>ATTACHED</u>	23		24		25		26		27
4		24		25		26		27		28
5	<u>PRINTOUT</u>	25		26		27		28		29
6		26		27		28		29		30
7		27		28		29		30		31
8		28		29		30		31		32
9		29		30		31		32		33
10	↓	30		31		32		33		34
11		31		32		33		34		35
12		32		33		34		35		36
13		33		34		35		36		37
14		34		35		36		37		38
15		35		36		37		38		39
16		36		37		38		39		40
17		37		38		39		40		41
18		38		39		40		41		42
19		39		40		41		42		43
20		40		41		42		43		44

REMARKS : — <200 DPM / 100cm<sup>2</sup> BT — <10 DPM / 100cm<sup>2</sup> A

SMEARS

LOCATION

1-5

A

6-10

B

HIGH VOLTAGE: 1450  
DISC WINDOW: 300.  
START SAMPLE : 1.  
STOP SAMPLE: 99.  
ERROR: (SIGMA)  $\pm$  2.99  
REPEAT #: 0  
A EFFIC (%): 32.60  
A CROSTLK (%): 4.00E-3  
A BKGND (CPM): .20  
B EFFIC (%): 17.10  
B BKGND (CPM): 1.80  
BKGD TIME (M): 20.00  
VOL(cm<sup>2</sup>): 1.00  
ALARM (dpm/V): 200.00  
USER EQUATION:

PAGE 2 OF 4

SAMPLE #:	TIME (M):	TIME:	DATE:	
1.	.25	15:30:05	MAR 30, 1992	
ALPHA GROSS: 0	NET: 0	+/- .29	dpm/cm <sup>2</sup> : 0	+/- .91
BETA GROSS: 0	NET: 0	+/- .89	dpm/cm <sup>2</sup> : 0	+/- 5.24
GAMMA GROSS: 0	C FACTOR: 1.0000			
2.	.25	15:30:32	MAR 30, 1992	
ALPHA GROSS: 1.	NET: 3.80	+/- 11.66	dpm/cm <sup>2</sup> : 11.65	+/- 35.76
BETA GROSS: 0	NET: 0	+/- .89	dpm/cm <sup>2</sup> : 0	+/- 5.24
GAMMA GROSS: 0	C FACTOR: 1.0000			
3.	.25	15:31:00	MAR 30, 1992	
ALPHA GROSS: 0	NET: 0	+/- .29	dpm/cm <sup>2</sup> : 0	+/- .91
BETA GROSS: 0	NET: 0	+/- .89	dpm/cm <sup>2</sup> : 0	+/- 5.24
GAMMA GROSS: 0	C FACTOR: 1.0000			
4.	.25	15:31:28	MAR 30, 1992	
ALPHA GROSS: 0	NET: 0	+/- .29	dpm/cm <sup>2</sup> : 0	+/- .91
BETA GROSS: 0	NET: 0	+/- .89	dpm/cm <sup>2</sup> : 0	+/- 5.24
GAMMA GROSS: 0	C FACTOR: 1.0000			
5.	.25	15:31:55	MAR 30, 1992	
ALPHA GROSS: 0	NET: 0	+/- .29	dpm/cm <sup>2</sup> : 0	+/- .91
BETA GROSS: 2.	NET: 6.20	+/- 14.91	dpm/cm <sup>2</sup> : 3t. 25	+/- 87.23
GAMMA GROSS: 0	C FACTOR: 1.0000			
6.	.25	15:32:23	MAR 30, 1992	
ALPHA GROSS: 0	NET: 0	+/- .29	dpm/cm <sup>2</sup> : 0	+/- .91
BETA GROSS: 0	NET: 0	+/- .89	dpm/cm <sup>2</sup> : 0	+/- 5.24
GAMMA GROSS: 0	C FACTOR: 1.0000			
7.	.25	15:32:50	MAR 30, 1992	
ALPHA GROSS: 0	NET: 0	+/- .29	dpm/cm <sup>2</sup> : 0	+/- .91
BETA GROSS: 1.	NET: 2.20	+/- 8.91	dpm/cm <sup>2</sup> : 12.86	+/- 52.13
GAMMA GROSS: 0	C FACTOR: 1.0000			
8.	.25	15:33:19	MAR 30, 1992	
ALPHA GROSS: 0	NET: 0	+/- .29	dpm/cm <sup>2</sup> : 0	+/- .91
BETA GROSS: 1.	NET: 2.20	+/- 8.91	dpm/cm <sup>2</sup> : 12.86	+/- 52.13
GAMMA GROSS: 0	C FACTOR: 1.0000			
9.	.25	15:33:47	MAR 30, 1992	
ALPHA GROSS: 0	NET: 0	+/- .29	dpm/cm <sup>2</sup> : 0	+/- .91
BETA GROSS: 0	NET: 0	+/- .89	dpm/cm <sup>2</sup> : 0	+/- 5.24
GAMMA GROSS: 0	C FACTOR: 1.0000			
10.	.25	15:34:15	MAR 30, 1992	
ALPHA GROSS: 0	NET: 0	+/- .29	dpm/cm <sup>2</sup> : 0	+/- .91
BETA GROSS: 0	NET: 0	+/- .89	dpm/cm <sup>2</sup> : 0	+/- 5.24
GAMMA GROSS: 0	C FACTOR: 1.0000			

I IH&S FORM I  
I # 1002 I  
I LRD - 7/90 I


\* \* \* \* \* RADIATION SURVEY \* \* \* \* \*

PAGE 3 OF 4




SURVEY TYPE: ROUTINE <input type="checkbox"/> SPECIAL <input checked="" type="checkbox"/> RWP <input type="checkbox"/> (RWP # )	SURVEY DATE: 3-30-92	
LOCATION: BLDG. 6	SURVEY TIME: 1300	
INSTRUMENT: PAC-46 INSTRUMENT: ASP-1	SERIAL # 4478 SERIAL # 1891	PROBE TYPE: AC21-B PROBE TYPE: AC-3
DESCRIPTION OF SURVEY		
BETA CONTACT	ALPHA CONTACT	
NET DPM/100cm <sup>2</sup>	NET DPM/100cm <sup>2</sup>	
SAMPLE LOCATION "A" INSIDE DUCT	= BKG	= BKG
SAMPLE LOCATION "B" INSIDE DUCT	315 DPM	= BKG
SKETCH		
SEE ATTACHED MAP FOR SURVEY POINTS A & B		
AC-3 ASP-1	REMARKS	AC-21-B PAC 46
EFFICIENCY - 20.2%	- - -	63.4%
Avg. BKG - 37.1 DPM/50cm <sup>2</sup>	- - -	473 DPM/50cm <sup>2</sup>
Avg BKG - 74.2 DPM/100cm <sup>2</sup>	- - -	946 DPM/100cm <sup>2</sup>
H.P. SIGNATURE: Tony Jth	DATE: 3-30-92	

PAGE 4 OF 4



△ - DENOTES SURVEY LOCATIONS



PARTS LIST		Welded Advanced Steel Systems Sketch	
Part No.	Description	Quantity	Comments
S-1000	BACK	1	
S-2000	CORNER BLOCK SET	1	
	INTERHALL & PARENTLANG		
D 14683	JN-011 A		

APPENDIX F

BUILDING 6, SECOND FLOOR

SURVEYOR:	Larry Smith	SIGNATURE:	DATE: 4/2/92	FORM SERIAL NUMBER: Preliminary
-----------	-------------	------------	--------------	---------------------------------

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA			ALPHA
	Canberra	MS-2	Canberra	SAC-4		PAC-4G			
BACKGROUND	.85 CPM	CPM	.20 CPM	CPM	SERIAL NO.	4478			ASP-1
EFFICIENCY	17.1 %	%	32.6 %	%	PROBE	AC-21B			1891 AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT uR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
6	2	N/A	1 0	0	N/A	N/A	≤ Bkg. Unless	≤ Bkg. Unless
			2 0	7			specified	specified
			3 0	0				
			4 0	0			Efficiency: 63.4%	Efficiency: 20.2%
			5 0	7			Avg. Bkg: 1183 DPM	Avg. Bkg: 74.3 DPM
			6 0	7			Per 100 cm <sup>2</sup>	Per 100 cm <sup>2</sup>
			7 0	0				
			8 0	7				
			9 0	7				
			10 0	0				
			11 0	7				
			12 0	0				
			13 0	7				
			14 12	7				
			15 0	18				
			16 0	7				
			17 0	0				
			18 0	7				
▼	▼	▼	19 0	7	▼	▼	▼	▼

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

SURVEYOR: Larry Smith	SIGNATURE: <i>Larry Smith</i>	DATE: 4/2/92	FORM SERIAL NUMBER: Preliminary
-----------------------	-------------------------------	--------------	---------------------------------

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA		ALPHA
	Canberra	MS-2	Canberra	SAC-4		PAC-4G		
BACKGROUND	.85 CPM	CPM	.20 CPM	CPM	SERIAL NO.	4478		ASP-1
EFFICIENCY	17.1 %	%	32.6 %	%	PROBE	AC-21B		1891
								AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
6	2	N/A	20	0	7	N/A	N/A	≤ Bkg. Unless
			21	0	7			≤ Bkg. Unless
			22	0	18			specified
			23	0	0			
			24	0	7			Efficiency: 63.4%
			25	0	0			Avg. Bkg: 1183 DPM
			26	0	7			Per 100 cm <sup>2</sup>
			27	0	0			Per 100 cm <sup>2</sup>
			28	0	7			
			29	0	0			
			30	0	0			
			31	0	18			
			32	0	0			
			33	0	7			
			34	0	0			
			35	0	18			
			36	5	0			
			37	5	0			
			38	0	7			
	↓	↓	↓	↓	↓	↓	↓	↓

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

THIS FORM - SPECIAL!  
LTD - 2/92

DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE  
\*\*\*\*\*


page 3 of 4

SURVEYOR: Larry Smith

SIGNATURE:



		DATE: 4/2/92		FORM SERIAL NUMBER: Preliminary
--	--	--------------	--	---------------------------------

BETA-GAMMA		ALPHA		GAMMA/BETA-GAMMA
COUNTER NO.:	Canberra	MS-2	SAC-4	INSTRUMENT
BACKGROUND	.85 CPM	.20 CPM	CPH	SERIAL NO.
EFFICIENCY	17.1 %	%	32.6 %	PROBE



Page 4 of 4

-13-



PARTS LIST		Welded Structural Steel Systems Details	
part	ref. no.	part no.	description
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
32			
33			
34			

part	ref. no.	part no.	description
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
32			
33			
34			

LEGEND

— BENCH

— CONCRETE BLOCK TEST

— CONCRETE BLOCK SET

— INTERNAL & EXTERNAL

SCALE : FEET

0 50 100 150 200

O - DESIGNATES Survey Points

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

—

APPENDIX G  
BUILDING 6A, FIRST FLOOR

SURVEYOR:	Larry Smith	SIGNATURE:	Larry Smith		DATE:	3-20-92	FORM SERIAL NUMBER:	Preliminary
-----------	-------------	------------	-------------	--	-------	---------	---------------------	-------------

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA		ALPHA
	TENNELEC E	MS-2	TENNELEC E	SAC-4		E-520		
BACKGROUND	2.15 CPM	CPM	.05 CPM	CPM	SERIAL NO.	5245		ASP-1
EFFICIENCY	43.2 %	%	33.2 %	%	PROBE	7 mg/cm <sup>2</sup>		1891 AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT uR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
6A	1	N/A	1 See		N/A	N/A	≤ Bkg.	≤ Bkg.
			2 Attached					
			3 Printout				Avg. Bkg.=270	Avg. Bkg.=37.5
			4				DPM	DPM
			5					
			6				Efficiency= 13%	Efficiency= 20.2%
			7					
			8					
			9					
			10					
			11					
			12					
			13					
			14					
			15					
			16					
			17					
			18					
			19					

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

SURVEYOR:	Larry Smith	SIGNATURE: <i>Larry Smith</i>	DATE: 3-20-92	FORM SERIAL NUMBER: Preliminary
-----------	-------------	-------------------------------	---------------	---------------------------------

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA			ALPHA
	TENNELEC E	MS-2	TENNELEC E	SAC-4		E-520	5245	7 mg/cm <sup>2</sup>	
BACKGROUND	2.15 CPM	CPM	.05 CPM	CPM					ASP-1 1891
EFFICIENCY	43.2 %	%	33.2 %	%	PROBE				AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT uR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
6A	1	N/A	20 See		N/A	N/A	4 Bkg.	4 Bkg.
			21 Attached					
			22 Printout				Avg. Bkg.=270	Avg. Bkg.=37.5
			23				DPM	DPM
			24					
			25				Efficiency= 13%	Efficiency= 20.2%
			26					
			27					
			28					
			29					
			30					
			31					
			32					
			33					
			34					
			35					
			36					
			37					
			38					

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

\* \* \* \* \*  
RING SURVEYS - WESTINGHOUSE LARGE SITE  
\* \* \* \* \*

Page 3 of 4

*gsht* DATE: 3-20-92 FORM SERIAL NUMBER: Preliminary



		GAMMA/BETA-GAMMA		ALPHA
SAC-4	INSTRUMENT	E-520		ASP-1
CPM	SERIAL NO.	5245		1891
%	PROBE	7 mg/cm <sup>2</sup>		AC-3

6A	1	N/A	39	See	GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/HOUR	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			40	Attached				
			41	Printout			Avg.Bkg.=270	Avg.Bkg.=37.5
			42				DPM	DPM
			43					
			44				Efficiency= 13%	Efficiency= 20.2%
			45					
			46					
			47					
			48					
			49					
			50					
			51					
			52					
			53					
			54					

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

EFFICIENCY	43.2 %		%	33.2 %		%		
BUILDING/AREA	FLOOR	GRID	SMEAR			GAMMA RAI ONE MI UR/H		
			ALPHA		BETA			
SAMPLE NUMBER	BETA COUNTS	BETA DPM	BETA 3 SIGMA	ALPHA COUNTS	ALPHA DPM	ALPHA 3 SIGMA	TIME MINS	N
1	1	2.0	5.3	0	-0.1	0.1	0.33	
2	0	-4.9	0.9	0	-0.1	0.1	0.33	
3	2	9.0	7.4	0	-0.1	0.1	0.33	
4	1	2.0	5.3	0	-0.1	0.1	0.33	
5	2	9.0	7.4	0	-0.1	0.1	0.33	
6	0	-4.9	0.9	0	-0.1	0.1	0.33	
7	2	9.0	7.4	1	0.9	5.2	0.33	
8	1	2.0	5.3	0	-0.1	0.1	0.33	
9	1	2.0	5.3	0	-0.1	0.1	0.33	
10	1	2.0	5.3	0	-0.1	0.1	0.33	
11	1	2.0	5.3	0	-0.1	0.1	0.33	
12	1	2.0	5.3	0	-0.1	0.1	0.33	
13	1	2.0	5.3	0	-0.1	0.1	0.33	
14	1	2.0	5.3	0	-0.1	0.1	0.33	
15	0	-4.9	0.9	0	-0.1	0.1	0.33	
16	0	-4.9	0.9	0	-0.1	0.1	0.33	
17	1	2.0	5.3	0	-0.1	0.1	0.33	
18	0	-4.9	0.9	0	-0.1	0.1	0.33	
19	0	-4.9	0.9	0	-0.1	0.1	0.33	
20	0	-4.9	0.9	0	-0.1	0.1	0.33	
21	0	-4.9	0.9	0	-0.1	0.1	0.33	
22	0	-4.9	0.9	0	-0.1	0.1	0.33	
23	1	2.0	5.3	0	-0.1	0.1	0.33	
24	0	-4.9	0.9	0	-0.1	0.1	0.33	
25	1	2.0	5.3	1	0.9	5.2	0.33	
26	1	2.0	5.3	0	-0.1	0.1	0.33	
27	2	9.0	7.4	0	-0.1	0.1	0.33	
28	2	9.0	7.4	0	-0.1	0.1	0.33	
29	0	-4.9	0.9	0	-0.1	0.1	0.33	
30	1	2.0	5.3	0	-0.1	0.1	0.33	
31	2	9.0	7.4	0	-0.1	0.1	0.33	
32	0	-4.9	0.9	0	-0.1	0.1	0.33	
33	1	2.0	5.3	0	-0.1	0.1	0.33	
34	0	-4.9	0.9	0	-0.1	0.1	0.33	
35	4	23.0	10.4	0	-0.1	0.1	0.33	
36	1	2.0	5.3	0	-0.1	0.1	0.33	
37	1	2.0	5.3	0	-0.1	0.1	0.33	
38	1	2.0	5.3	0	-0.1	0.1	0.33	
39	2	9.0	7.4	0	-0.1	0.1	0.33	
40	0	-4.9	0.9	0	-0.1	0.1	0.33	
41	2	9.0	7.4	0	-0.1	0.1	0.33	
42	2	9.0	7.4	0	-0.1	0.1	0.33	
43	3	16.0	9.0	0	-0.1	0.1	0.33	
44	0	-4.9	0.9	0	-0.1	0.1	0.33	
45	21	43.5	13.7	0	-0.1	0.1	1.00	
46	2	9.0	7.4	0	-0.1	0.1	0.33	
47	1	2.0	5.3	0	-0.1	0.1	0.33	
48	0	-4.9	0.9	0	-0.1	0.1	0.33	
49	2	9.0	7.4	0	-0.1	0.1	0.33	
50	1	2.0	5.3	0	-0.1	0.1	0.33	
51	1	2.0	5.3	0	-0.1	0.1	0.33	
52	1	2.0	5.3	0	-0.1	0.1	0.33	
53	0	-4.9	0.9	0	-0.1	0.1	0.33	
54	0	-4.9	0.9	0	-0.1	0.1	0.33	

CENTIMETERS



1 IH&S FORM  
#1006  
1 LRD 3/88

ROUTINE AREA  
SHEAR & RADIATION SURVEY

PAGE 1 OF 5



LOCATION	BLOG 6A	SURVEYOR	L. Smith	SURVEY DATE	3-31-92
		COUNTED BY	L. Smith	COUNT DATE	3-31-92

COUNTER NO.	BETA/GAMMA			ALPHA		
	CANBERRA			CANBERRA		
BKG. (CPM)	1.04	CPM	CPM	CPM	.3	CPM
EFF. (%)	17.1	%	%	%	32.6	%
ACTIVITY IN :	REMARKS : — < 200 DPM / 100 cm <sup>2</sup> BT			— < 10 DPM / 100cm <sup>2</sup> A		
<input type="checkbox"/> UCI <input checked="" type="checkbox"/> DPM <input type="checkbox"/> CPM	SURVEY INSTRU. MODEL PAC 46 SN. NO. 4478 PROBE TYPE AC-21-B			ASPI 1891 AC-3		

	A	B		A	B		A	B		A	B	
1	SEE		16	SEE		31			46			61
2	ATTACHED		17	ATTACHED		32			47			62
3	PRINTOUT		18	PRINTOUT		33			48			63
4			19			34			49			64
5			20	↓	↓	35			50			65
6			21			36			51			66
7			22			37			52			67
8			23			38			53			68
9			24			39			54			69
10			25			40			55			70
11			26			41			56			71
12			27			42			57			72
13			28			43			58			73
14			29			44			59			74
15	↓	↓	30			45			60			75

SMEAR NOS.	SMEAR LOCATION
1-5	VENT DUCT (Point A)
6-10	VENT DUCT (Point B)
11-15	VENT DUCT (Point C)
16-20	VENT DUCT (Point D)

ACTION ITEMS OR COMMENTS	DATE CORRECTED	HP INIT.
SEE ATTACHED MAP For Locations	N/A	JR
↓	↓	↓

PROGRAM #:1  
RESET COUNT:99999, ALPHA ---  
SET TIME (M): .50  
HIGH VOLTAGE:1450  
LSC WINDOW:300  
START SAMPLE: 1  
IP SAMPLE:99  
ERROR (SIGMA):2.99  
CPEAT #:0  
EFFIC (%):32.60  
CROSSTK (%):4.00E-3  
BKGND (CPM):.20  
EFFIC (%):17.10  
BKGND (CPM):1.80  
KGD TIME (M):20.00  
QI (cm<sup>2</sup>):1.00  
LARM (dpm/V):200.00  
SER EQUATION:

PAGE 4 OF 5

AMPLE #	TIME (M)	TIME	DATE
ALPHA GROSS: 1	.50	13:04:20	MAR 31, 1992
NET: 1.80	+/- .68	dpm/cm <sup>2</sup> :	5.52      +/- 17.42
BETA GROSS: 3	.50	13:04:20	MAR 31, 1992
NET: 4.19	+/- .71	dpm/cm <sup>2</sup> :	24.56      +/- 50.94
GAMMA GROSS: 0	.50	13:04:20	MAR 31, 1992
C FACTOR: 1.0000			
AMPLE #2	.50	13:05:03	MAR 31, 1992
ALPHA GROSS: 0	0	+/- .29	dpm/cm <sup>2</sup> : 0      +/- .91
BETA GROSS: 0	0	+/- .84	dpm/cm <sup>2</sup> : 0      +/- 5.24
MMA GROSS: 0	.50	13:05:03	MAR 31, 1992
C FACTOR: 1.0000			
AMPLE #3	.50	13:05:48	MAR 31, 1992
ALPHA GROSS: 0	0	+/- .29	dpm/cm <sup>2</sup> : 0      +/- .91
BETA GROSS: 1	.20	+/- 2.09	dpm/cm <sup>2</sup> : 1.16      +/- 12.23
GAMMA GROSS: 0	.50	13:05:48	MAR 31, 1992
C FACTOR: 1.0000			
AMPLE #4*****TIME (M): .50	TIME: 13:06:37	DATE: MAR 31, 1992	
ALPHA GROSS: 0	0	+/- .29	dpm/cm <sup>2</sup> : 0      +/- .91
BETA GROSS: 1	.20	+/- 2.09	dpm/cm <sup>2</sup> : 1.16      +/- 12.23
GAMMA GROSS: 0	.50	13:06:37	MAR 31, 1992
C FACTOR: 15106110			
AMPLE #5	.50	13:07:20	MAR 31, 1992
ALPHA GROSS: 0	0	+/- .29	dpm/cm <sup>2</sup> : 0      +/- .91
BETA GROSS: 1	.20	+/- 2.09	dpm/cm <sup>2</sup> : 1.16      +/- 12.23
GAMMA GROSS: 0	.50	13:07:20	MAR 31, 1992
C FACTOR: 1.0000			
AMPLE #6	.50	13:08:03	MAR 31, 1992
ALPHA GROSS: 0	0	+/- .29	dpm/cm <sup>2</sup> : 0      +/- .91
BETA GROSS: 1	.20	+/- 2.09	dpm/cm <sup>2</sup> : 1.16      +/- 12.23
GAMMA GROSS: 0	.50	13:08:03	MAR 31, 1992
C FACTOR: 1.0000			
AMPLE #7	.50	13:08:46	MAR 31, 1992
ALPHA GROSS: 0	0	+/- .29	dpm/cm <sup>2</sup> : 0      +/- .91
BETA GROSS: 2	.20	+/- 6.33	dpm/cm <sup>2</sup> : 12.86      +/- 37.05
GAMMA GROSS: 0	.50	13:08:46	MAR 31, 1992
C FACTOR: 1.0000			
AMPLE #8	.50	13:09:29	MAR 31, 1992
ALPHA GROSS: 0	0	+/- .29	dpm/cm <sup>2</sup> : 0      +/- .91
BETA GROSS: 2	.20	+/- 6.33	dpm/cm <sup>2</sup> : 12.86      +/- 37.05
MMA GROSS: 0	.50	13:09:29	MAR 31, 1992
C FACTOR: 1.0000			
AMPLE #9	.50	13:10:13	MAR 31, 1992
ALPHA GROSS: 0	0	+/- .29	dpm/cm <sup>2</sup> : 0      +/- .91
BETA GROSS: 1	.20	+/- 2.09	dpm/cm <sup>2</sup> : 1.16      +/- 12.23
GAMMA GROSS: 0	.50	13:10:13	MAR 31, 1992
C FACTOR: 1.0000			

SAMPLE #: 10 TIME (M): .50 TIME: 13:10:56 DATE: MAR 31, 1992  
 ALPHA GROSS: 0 NET: 0 +/- .29 dpm/cm<sup>2</sup>: 0 +/- .91  
 BETA GROSS: 1 NET: .20 +/- 2.09 dpm/cm<sup>2</sup>: 1.16 +/- 12.23 PAGE 3 OF 5  
 GAMMA GROSS: 0 C FACTOR: 1.0000

SAMPLE #: 11 TIME (M): .50 TIME: 13:11:39 DATE: MAR 31, 1992  
 ALPHA GROSS: 0 NET: 0 +/- .29 dpm/cm<sup>2</sup>: 0 +/- .91  
 BETA GROSS: 0 NET: .20 +/- 6.33 dpm/cm<sup>2</sup>: 0 +/- 5.24  
 GAMMA GROSS: 0 C FACTOR: 1.0000

SAMPLE #: 12 TIME (M): .50 TIME: 13:12:22 DATE: MAR 31, 1992  
 ALPHA GROSS: 0 NET: 0 +/- .29 dpm/cm<sup>2</sup>: 0 +/- .91  
 BETA GROSS: 2 NET: 2.20 +/- 6.33 dpm/cm<sup>2</sup>: 12.86 +/- 37.05  
 GAMMA GROSS: 0 C FACTOR: 1.0000

SAMPLE #: 13 TIME (M): .50 TIME: 13:13:05 DATE: MAR 31, 1992  
 ALPHA GROSS: 0 NET: 0 +/- .29 dpm/cm<sup>2</sup>: 0 +/- .91  
 BETA GROSS: 2 NET: 2.20 +/- 6.33 dpm/cm<sup>2</sup>: 12.86 +/- 37.05  
 GAMMA GROSS: 0 C FACTOR: 1.0000

SAMPLE #: 14 TIME (M): .50 TIME: 13:13:48 DATE: MAR 31, 1992  
 ALPHA GROSS: 0 NET: 0 +/- .29 dpm/cm<sup>2</sup>: 0 +/- .91  
 BETA GROSS: 0 NET: .20 +/- 6.33 dpm/cm<sup>2</sup>: 0 +/- 5.24  
 GAMMA GROSS: 0 C FACTOR: 1.0000

SAMPLE #: 15 TIME (M): .50 TIME: 13:14:31 DATE: MAR 31, 1992  
 ALPHA GROSS: 0 NET: 0 +/- .29 dpm/cm<sup>2</sup>: 0 +/- .91  
 BETA GROSS: 2 NET: 2.20 +/- 6.33 dpm/cm<sup>2</sup>: 12.86 +/- 37.05  
 GAMMA GROSS: 0 C FACTOR: 1.0000

SAMPLE #: 16 TIME (M): .50 TIME: 13:15:14 DATE: MAR 31, 1992  
 ALPHA GROSS: 0 NET: 0 +/- .29 dpm/cm<sup>2</sup>: 0 +/- .91  
 BETA GROSS: 0 NET: .20 +/- 6.33 dpm/cm<sup>2</sup>: 0 +/- 5.24  
 GAMMA GROSS: 0 C FACTOR: 1.0000

SAMPLE #: 17 TIME (M): .50 TIME: 13:16:05 DATE: MAR 31, 1992  
 ALPHA GROSS: 0 NET: 0 +/- .29 dpm/cm<sup>2</sup>: 0 +/- .91  
 BETA GROSS: 2 NET: 2.20 +/- 6.33 dpm/cm<sup>2</sup>: 12.86 +/- 37.05  
 GAMMA GROSS: 0 C FACTOR: 1.0000

SAMPLE #: 18 TIME (M): .50 TIME: 13:16:49 DATE: MAR 31, 1992  
 ALPHA GROSS: 0 NET: 0 +/- .29 dpm/cm<sup>2</sup>: 0 +/- .91  
 BETA GROSS: 0 NET: .20 +/- 6.33 dpm/cm<sup>2</sup>: 0 +/- 5.24  
 GAMMA GROSS: 0 C FACTOR: 15106110

SAMPLE #: 19 TIME (M): .50 TIME: 13:17:32 DATE: MAR 31, 1992  
 ALPHA GROSS: 0 NET: 0 +/- .29 dpm/cm<sup>2</sup>: 0 +/- .91  
 BETA GROSS: 1 NET: .20 +/- 2.09 dpm/cm<sup>2</sup>: 1.16 +/- 12.23  
 GAMMA GROSS: 0 C FACTOR: 1.0000

SAMPLE #: 20 TIME (M): .50 TIME: 13:18:23 DATE: MAR 31, 1992  
 ALPHA GROSS: 0 NET: 0 +/- .29 dpm/cm<sup>2</sup>: 0 +/- .91  
 BETA GROSS: 2 NET: 2.20 +/- 6.33 dpm/cm<sup>2</sup>: 12.86 +/- 37.05  
 GAMMA GROSS: 0 C FACTOR: 1.0000

I IH&S FORM I  
I # 1002 I  
I LRD - 7/90 I


\* \* \* \* \* RADIATION SURVEY \* \* \* \* \*

PAGE 4 OF 5



SURVEY TYPE: ROUTINE <input type="checkbox"/> SPECIAL <input checked="" type="checkbox"/> RWP <input type="checkbox"/> CRWP # )	SURVEY DATE: 3-31-92	
LOCATION: BLDG 6A VENT DUCTS	SURVEY TIME: 1300	
INSTRUMENT: PAC-46 INSTRUMENT: ASP-1	SERIAL #: 4478 SERIAL #: 1891	PROBE TYPE: AC-21B PROBE TYPE: AC-3
DESCRIPTION OF SURVEY		
SAMPLE Point	BETA CONTACT IN NET DEM/100cm <sup>2</sup>	ALPHA CONTACT IN NET DEM/100cm <sup>2</sup>
Point 'A'	= BKG	= BKG
Point 'B'	= BKG	= BKG
Point 'C'	= BKG	= BKG
Point 'D'	= BKG	= BKG
SKETCH		
SEE ATTACHED MAP for SURVEY Point LOCATIONS.		
PAC-46 REMARKS AC-21B		ASP-1 AC-3
EFFICIENCY	20.2 %	63.4 %
Avg. BKG/50 cm <sup>2</sup>	371 OPM/50cm <sup>2</sup>	513 OPM/50cm <sup>2</sup>
Avg BKG/100 cm <sup>2</sup>	74.2 OPM/100cm <sup>2</sup>	1025 OPM/100cm <sup>2</sup>
H.P. SIGNATURE	Larry A. H.	
		DATE: 3-31-92

Page 5 of 5




△ - Denotes Survey Points

LEGEND

- SPOT MARK
- CONCRETE CONIC BLOCK EXIT
- CONCRETE BLOCK EXIT
- CERAMIC & PLASTERING

SCALE : FEET

0 5 10 15 20 25



Part No.	Description	Quantity	Dimensions		Notes
			Length	Width	
PARTS LIST					
1	WALLS, EXTERIOR, EXPOSED TYPICAL, NO. 200 20' X 10' X 8"	4	20'	10'	WALLS, EXTERIOR, EXPOSED, TYPICAL, NO. 200, 20' X 10' X 8", NO. 10 REINFORCEMENT, NO. 8 TECHNICAL - NO. 8 REINFORCEMENT
2	DOORS, 36" X 84"	1	36"	84"	DOORS, 36" X 84"
3	WINDOWS, 36" X 48"	1	36"	48"	WINDOWS, 36" X 48"
4	ROOF, GUTTER, DOWNPIPE, 10 FT 20 FT, 10 FT, 10 FT	1	20'	10'	ROOF, GUTTER, DOWNPIPE, 10 FT 20 FT, 10 FT, 10 FT
5	STAIRS, 10 FT X 10 FT X 10 FT	1	10'	10'	STAIRS, 10 FT X 10 FT X 10 FT
6	CEILINGS, 8 FT X 10 FT	1	8'	10'	CEILINGS, 8 FT X 10 FT
7	FLOOR, 10 FT X 10 FT	1	10'	10'	FLOOR, 10 FT X 10 FT
8	WALLS, INTERNAL, EXPOSED TYPICAL, NO. 200, 10' X 8"	4	10'	8"	WALLS, INTERNAL, EXPOSED, TYPICAL, NO. 200, 10' X 8"
9	DOORS, 36" X 84", 10 FT X 10 FT	1	10'	84"	DOORS, 36" X 84", 10 FT X 10 FT
10	WINDOWS, 36" X 48", 10 FT X 10 FT	1	10'	48"	WINDOWS, 36" X 48", 10 FT X 10 FT
11	STAIRS, 10 FT X 10 FT X 10 FT	1	10'	10'	STAIRS, 10 FT X 10 FT X 10 FT
12	CEILINGS, 8 FT X 10 FT	1	8'	10'	CEILINGS, 8 FT X 10 FT
13	FLOOR, 10 FT X 10 FT	1	10'	10'	FLOOR, 10 FT X 10 FT
D	PRINTED BY: JN-012	1			
	PRINTED ON: 12/20/2023	1			
	SCALING: 1:64	1			
	PRINTED BY: JN-012	1			
	PRINTED ON: 12/20/2023	1			
	SCALING: 1:64	1			

APPENDIX H

BUILDING 7, FIRST FLOOR

SURVEYOR: Larry Smith		SIGNATURE: <i>Larry Smith</i>	DATE: 4-1-92	FORM SERIAL NUMBER: Preliminary
-----------------------	--	-------------------------------	--------------	---------------------------------

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA		ALPHA
	Canberra		Canberra			PAC-4G		
BACKGROUND	1.0	CPM	CPM	.35 CPM	CPM	SERIAL NO.	4478	ASP-1
EFFICIENCY	17.1 %	%	%	32.6 %	%	PROBE	AC-21B	1891 AC-3

BUILDING/AREA	FLOOR	GRID	SHEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
7	1	N/A	1 0	6	N/A	N/A	\$ Bkg. Unless	≤ Bkg. Unless
			2 0	0			Specified	Specified
			3 0	18			↓	
			4 0	0			158	
			5 0	0			≤ BKG	
			6 0	0			Efficiency: 63.4%	Efficiency: 20.2%
			7 0	18			Avg. Bkg.: 1183 DPM	Avg. Bkg.: 74.3 DPM
			8 0	0			Per 100 cm <sup>2</sup>	Per 100 cm <sup>2</sup>
			9 0	0				
			10 0	0				
			11 0	6				
			12 0	0				
			13 0	18				
			14 5	0			↓	
			15 0	18			158	
			16 0	18			≤ BKG	
			17 0	6				
			18 0	0				
			19 0	6				

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

SURVEYOR: Larry Smith

SIGNATURE: *Larry Smith*

DATE: 4-1-92

FORM SERIAL NUMBER: Preliminary

	BETA-GAMMA		ALPHA			GAMMA/P-A-GAMMA			ALPHA
COUNTER NO.:	Canberra		Canberra		INSTRUMENT	PAC-4G			ASP-1
BACKGROUND	1.0 CPM	CPM	.35 CPM	CPM	SERIAL NO.	4478			1891
EFFICIENCY	17.1 %	%	32.6 %	%	PROBE	AC-21B			AC-3

BUILDING/AREA	FLOOR	GRID	SHEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT uR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
7	1	N/A	20 0	6	N/A	N/A	\$ Bkg. Unless	\$ Bkg. Unless
			21 5	6			Specified	Specified
			22 0	6				
			23 0	18				
			24 0	6				
			25 0	18			Efficiency: 63.4%	Efficiency: 20.2%
			26 5	6			Avg. Bkg.: 1183 DPM	Avg. Bkg.: 74.3 DPM
			27 5	0			Per 100 cm <sup>2</sup>	Per 100 cm <sup>2</sup>
			28 0	0				
			29 0	18				
			30 0	29				
			31 0	18				
			32 0	0				
			33 0	181				
			34 0	29				
			35 0	18				
			36 0	6				
			37 0	6				
			38 0	6				

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

SURVEYOR: Larry Smith	SIGNATURE: <i>Larry Smith</i>	DATE: 4-1-92	FORM SERIAL NUMBER: Preliminary
-----------------------	-------------------------------	--------------	---------------------------------

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA			ALPHA
	Canberra	CPM	Canberra	CPM		CPM	SERIAL NO.	PAC-4G	
BACKGROUND	1.0	CPM	CPM	.35 CPM		CPM	4478		ASP-1
EFFICIENCY	17.1 %	%	%	32.6 %		%	PROBE	AC-21B	1891 AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER UR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
7	1	N/A	39	0	6	N/A	N/A	\$ Bkg. Unless
			40	0	6			≤ Bkg. Unless
			41	0	18			Specified
			42	0	0			Specified
			43	0	0			
			44	0	6			Efficiency: 63.4% Efficiency: 20.2%
			45	0	6			Avg. Bkg.: 1183 DPM Avg. Bkg.: 74.3 DPM
			46	0	0			Per 100 cm <sup>2</sup> Per 100 cm <sup>2</sup>
			47	0	0			
			48	0	0			
			49	0	0			
			50	0	6			
			51	0	6			
			52	0	0			158
			53	0	6			≤ BKG
			54	0	0			
			55	0	6			
			56	0	0			
			57	0	18			

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

SURVEYOR: Larry Smith	SIGNATURE: <i>Larry Smith</i>	DATE: 4-1-92	FORM SERIAL NUMBER: Preliminary
-----------------------	-------------------------------	--------------	---------------------------------

COUNTER NO.:	BETA-GAMMA		ALPHA		INSTRUMENT	GAMMA/BETA-GAMMA			ALPHA
	Canberra	CPM	Canberra	CPM		CPM	SERIAL NO.	PAC-4G	
BACKGROUND	1.0	CPM		.35 CPM		CPM	4478		ASP-1
EFFICIENCY	17.1 %	%		32.6 %	%	PROBE	AC-21B		1891 AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER UR/HOUR	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
7	11	N/A	58	0	41	N/A	N/A	≤ Bkg. Unless
			59	0	0			Specified
			60	0	6			
			61	0	6			
			62	0	29			
			63	0	6			
			64	0	0			
			65	0	41			
			66	0	0			
			67	0	6			
			68	0	0			
			69	0	0			
			70	0	0			
			71	.5	0			
			72	0	6			
			73	0	0			
			74	0	0			
			75	0	0			
			76	0	0			

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS


SURVEYOR: Larry Smith

SIGNATURE: *Derry*

DATE: 4-1-92


FORM SERIAL NUMBER: Preliminary

BETA/GAMMA		ALPHA		GAMMA/BETA-GAMMA		ALPHA	
COUNTER NO.:	Canberra			INSTRUMENT	PAC-4G		
BACKGROUND	1.0 CPM	CPM	35	CPM	SERIAL NO.	4478	ASP-1
EFFICIENCY	17.1 %	%	32.6 %	% PROBE		AC-21B	1891



SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

Page 6 or 6



○ - indicates survey points

[View more products from this brand](#)

**LEGEND**

SCALE : FEET  
0 5 10 15 20 25

APPENDIX I

BUILDING 8A, FIRST FLOOR

SURVEYOR: Larry Smith

SIGNATURE: *Larry Smith*

DECOMMISSIONING SURVEYS WESTINGHOUSE LARGE SITE  
FORM SERIAL NUMBER: Preliminary

Page 1 of 3

DATE: 6-8-92 FORM SERIAL NUMBER: Preliminary

INSTRUMENT: PAC-4G

BETA-GAMMA		ALPHA		GAMMA/BETA-GAMMA		ALPHA	
COUNTER NO.:	Canberra	INSTRUMENT	PAC-4G	SERIAL NO.		INSTRUMENT	ASP-i
BACKGROUND	CPM	CPM	CPM	SERIAL NO.	4478	CPM	1891
EFFICIENCY	17.1 %	%	32.6 %	%	PROBE	AC-21-B	AC-3

BUILDING/AREA	FLOOR	GRID	SHEAR		GAMMA RADIATION		BETA RADIATION		ALPHA RADIATION
			ALPHA	BETA	ONE METER HR/HOUR	DPM/100 SQUARE CM	CONTACT HR/HOUR	DPM/100 SQUARE CM	
SA	/	N/A	1	0	6	N/A	N/A	N/A	≤ BKG
			2	0	18			90	
			3	6	2			≤ BKG	
			4	0	6			90	
			5	0	0			90	
			6	0	0			180	
			7	0	0			90	
			8	6	0			180	
			9	0	0			90	
			10	0	0			90	
			11	0	6			90	
			12	0	6			90	
			13	0	6			180	
			14	0	0			90	
			15	0	6			90	
			16	0	18			≤ BKG	
			17	0	18			≤ BKG	
			18	0	6			90	
			19	0	18			≤ BKG	
			↓	↓	↓			↓	

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

Instrument  
PAC-4G  
9:00,

Ex C.F. BKG  
55.1 1.8 150 cm

INHS FORM - SPECIAL  
LRO - 2/92


DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE  
Page 2 of 3

SURVEYOR: Larry Smith

SIGNATURE: Larry Smith DATE: 6-9-92 FORM SERIAL NUMBER: preliminary

BETA/GAMMA		ALPHA	
COUNTER NO.:	Canberra	INSTRUMENT	PAC-4G
BACKGROUND	CPM	CPM	SERIAL NO.
EFFICIENCY	17.1 %	%	32.6 %

BETA/GAMMA		ALPHA	
COUNTER NO.:	Canberra	INSTRUMENT	PAC-4G
BACKGROUND	CPM	CPM	SERIAL NO.
EFFICIENCY	17.1 %	%	32.6 %




SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

Instrument EFC C.F. BKC 1.5  
PAC-4G 150 CPM

Page 3 of 3

四〇〇



O - DENOTES SIGHTS & SURVEY  
POINT LOCATIONS

**LEGEND**

CONC BLOCK CITY  
CONC BLOCK MFT  
BENMILL S. PHARMACEUT

I THIS FORM - SIGNED  
I LRD - 2/92

SURVEYOR: Larry Smith

SIGNATURE: *Larry Smith*

Page / of 5

DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE

DATE: 6-10-92 FORM SERIAL NUMBER: Preliminary

CPM

Efficiency

Counting Time

BETA/GAMMA			ALPHA		
COUNTER NO.:	Canberra		INSTRUMENT	PAC-4G	GAMMA/BETA-GAMMA
BACKGROUND	55 CPM	CPM	CPM	SERIAL NO.	4478
EFFICIENCY	17.1 %	%	%	PROBE	AC-21-B
	32.6 %	%	%		

BUILDING/AREA	FLOOR	GR10	SHEAR			GAMMA RADIATION ONE METER CPM/HOUR	BETA/GAMMA RADIATION CONTACT CPM/HOUR	BETA/GAMMA RADIATION CONTACT CPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA	Gamma				
8A	1 st.	N/A	16	8	0	N/A	N/A	≤ BKG	≤ BKG
			20	0	0			↓	
			30	0	0			90	
			40	0	0			90	
			50	0	0			70	
			60	0	0			90	
			70	0	0			≤ BKG	
			80	0	0			90	
			90	0	0			90	
			100	0	0			≤ BKG	
			110	0	0			180	
			120	0	0			90	
			130	0	0			≤ BKG	
			140	0	0			90	
			150	0	0			90	
			160	0	0			90	
			170	0	0			90	
			180	0	0			270	
			190	0	0			90	

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

Instrument Efficiency C. F.

PAC-4G

Efficiency

Background

ASP-1

Background

1.8 cpm

Background

150 cpm

Background

5.0

Background

SURVEYOR: Larry Smith  
SIGNATURE: *Larry Smith*  
DATE: 6-10-92 FORM SERIAL NUMBER: Preliminary

BETA-GAMMA		ALPHA		GAMMA/BETA-GAMMA		ALPHA	
COUNTER NO.:	Canberra	INSTRUMENT	PAC-4C	SERIAL NO.	4478	INSTRUMENT	ASP-1
BACKGROUND	.55 CPM	CPM	.05 CPM	PROBE	AC-21-3	SERIAL NO.	1891
EFFICIENCY	17.1 %	%	32.6 %	%			AC-3

BUILDING/AREA	FLOOR	GRID	SHEAR		GAMMA RADIATION ONE METER UF/HOUR	BETA-GAMMA RADIATION CONTACT UF/HOUR	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
8A	1 ST.	N/A	20	0	0	N/A	N/A	≤ 0KC
			21	0	0		90	
			22	0	0		180	
			23	0	0		90	
			24	0	32		90	
			25	0	9		≤ 0KC	
			26	0	0		90	
			27	0	9		≤ 0KC	
			28	0	0		90	
			29	0	0		90	
			30	0	0		90	
			31	0	8		≤ 0KC	
			32	0	0		90	
			33	0	0		180	
			34	0	20		90	
			35	0	8		180	
			36	0	0		≤ 0KC	
			37	0	8		90	
			38	0	0		180	

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

Instrument  
PAC-4C  
ASP-1

Efficiency  
55.1  
20.2

C. F.  
1.8  
5.0

Background  
150 cpm  
5 cpm

SURVEYOR: Larry Smith		SIGNATURE: <i>Larry Smith</i>	DATE: 6-10-92	FORM SERIAL NUMBER: Preliminary				
	BETA-GAMMA		ALPHA		GAMMA/BETA-GAMMA			ALPHA
COUNTER NO.:	Canberra		Canberra		INSTRUMENT	PAC-4G		ASP-1
BACKGROUND	.55	CPM	CPM	.05	CPM	SERIAL NO.	4478	1891
EFFICIENCY	17.1	%	%	32.6	%	PROBE	AC-21-B	AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER UR/HOUR	BETA-GAMMA RADIATION CONTACT UR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
8A	1 st.	N/A	39	0	0	N/A	N/A	90
			40	0	0			90
			41	0	8			90
			42	0	0			90
			43	0	0			90
			44	0	0			90
			45	0	0			180
			46	0	0			90
			47	0	0			90
			48	0	8			90
			49	0	20			180
			50	0	20			90
			51	0	0			90
			52	0	0			180
			53	0	8			90
			54	0	8			≤ BRG
			55	0	8			≤ BRG
			56	0	8			90
			57	0	50			180

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

Instrument	Efficiency	C. F.	Background
PAC-4G	55.1	1.8	150 cpm
ASP-1	20.2	5.0	5 cpm


SURVEYOR: Larry Smith

SIGNATURE:

DATE: 6-10-92 FORM SERIAL NUMBER: Preliminary  
Page 4 of 5

	BETA/GAMMA		ALPHA	
COUNTER NO.:	Canberra	Canberra	INSTRUMENT	PAC-4G
BACKGROUND	.55 CPM	CPM	SERIAL NO.	4478
EFFICIENCY	17.1 %	%	PROBE	AC-21-B


	GAMMA/BETA-GAMMA		ALPHA	
ASP-1				
1891				
AC-3				



SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

Instrument	Efficiency	C. F.	Background
PAC-4G	55.1	1.8	150 cpm
ASP-1	20.2	5.0	5 cpm

Page 5 of 5



PARTS LIST	
Part No.	Description
1	WALL SECTION, SPECIFIC 1/2 IN. X 1/2 IN. X 1/2 IN. 1/2 IN. X 1/2 IN. X 1/2 IN. 1/2 IN. X 1/2 IN. X 1/2 IN.
2	DOOR, 36 IN. X 80 IN.
3	DOOR, 36 IN. X 80 IN.
4	DOOR, 36 IN. X 80 IN.
5	DOOR, 36 IN. X 80 IN.
6	DOOR, 36 IN. X 80 IN.
7	DOOR, 36 IN. X 80 IN.
8	DOOR, 36 IN. X 80 IN.
9	DOOR, 36 IN. X 80 IN.
10	DOOR, 36 IN. X 80 IN.
11	DOOR, 36 IN. X 80 IN.
12	DOOR, 36 IN. X 80 IN.
13	DOOR, 36 IN. X 80 IN.
14	DOOR, 36 IN. X 80 IN.
15	DOOR, 36 IN. X 80 IN.
16	DOOR, 36 IN. X 80 IN.
17	DOOR, 36 IN. X 80 IN.
18	DOOR, 36 IN. X 80 IN.
19	DOOR, 36 IN. X 80 IN.
20	DOOR, 36 IN. X 80 IN.
21	DOOR, 36 IN. X 80 IN.
22	DOOR, 36 IN. X 80 IN.
23	DOOR, 36 IN. X 80 IN.
24	DOOR, 36 IN. X 80 IN.
25	DOOR, 36 IN. X 80 IN.
26	DOOR, 36 IN. X 80 IN.
27	DOOR, 36 IN. X 80 IN.
28	DOOR, 36 IN. X 80 IN.
29	DOOR, 36 IN. X 80 IN.
30	DOOR, 36 IN. X 80 IN.
31	DOOR, 36 IN. X 80 IN.
32	DOOR, 36 IN. X 80 IN.
33	DOOR, 36 IN. X 80 IN.
34	DOOR, 36 IN. X 80 IN.
35	DOOR, 36 IN. X 80 IN.
36	DOOR, 36 IN. X 80 IN.
37	DOOR, 36 IN. X 80 IN.
38	DOOR, 36 IN. X 80 IN.
39	DOOR, 36 IN. X 80 IN.
40	DOOR, 36 IN. X 80 IN.
41	DOOR, 36 IN. X 80 IN.
42	DOOR, 36 IN. X 80 IN.
43	DOOR, 36 IN. X 80 IN.
44	DOOR, 36 IN. X 80 IN.
45	DOOR, 36 IN. X 80 IN.
46	DOOR, 36 IN. X 80 IN.
47	DOOR, 36 IN. X 80 IN.
48	DOOR, 36 IN. X 80 IN.
49	DOOR, 36 IN. X 80 IN.
50	DOOR, 36 IN. X 80 IN.
51	DOOR, 36 IN. X 80 IN.
52	DOOR, 36 IN. X 80 IN.
53	DOOR, 36 IN. X 80 IN.
54	DOOR, 36 IN. X 80 IN.
55	DOOR, 36 IN. X 80 IN.
56	DOOR, 36 IN. X 80 IN.
57	DOOR, 36 IN. X 80 IN.
58	DOOR, 36 IN. X 80 IN.
59	DOOR, 36 IN. X 80 IN.
60	DOOR, 36 IN. X 80 IN.
61	DOOR, 36 IN. X 80 IN.
62	DOOR, 36 IN. X 80 IN.
63	DOOR, 36 IN. X 80 IN.
64	DOOR, 36 IN. X 80 IN.
65	DOOR, 36 IN. X 80 IN.
66	DOOR, 36 IN. X 80 IN.
67	DOOR, 36 IN. X 80 IN.
68	DOOR, 36 IN. X 80 IN.
69	DOOR, 36 IN. X 80 IN.
70	DOOR, 36 IN. X 80 IN.
71	DOOR, 36 IN. X 80 IN.
72	DOOR, 36 IN. X 80 IN.
73	DOOR, 36 IN. X 80 IN.
74	DOOR, 36 IN. X 80 IN.
75	DOOR, 36 IN. X 80 IN.
76	DOOR, 36 IN. X 80 IN.
77	DOOR, 36 IN. X 80 IN.
78	DOOR, 36 IN. X 80 IN.
79	DOOR, 36 IN. X 80 IN.
80	DOOR, 36 IN. X 80 IN.
81	DOOR, 36 IN. X 80 IN.
82	DOOR, 36 IN. X 80 IN.
83	DOOR, 36 IN. X 80 IN.
84	DOOR, 36 IN. X 80 IN.
85	DOOR, 36 IN. X 80 IN.
86	DOOR, 36 IN. X 80 IN.
87	DOOR, 36 IN. X 80 IN.
88	DOOR, 36 IN. X 80 IN.
89	DOOR, 36 IN. X 80 IN.
90	DOOR, 36 IN. X 80 IN.
91	DOOR, 36 IN. X 80 IN.
92	DOOR, 36 IN. X 80 IN.
93	DOOR, 36 IN. X 80 IN.
94	DOOR, 36 IN. X 80 IN.
95	DOOR, 36 IN. X 80 IN.
96	DOOR, 36 IN. X 80 IN.
97	DOOR, 36 IN. X 80 IN.
98	DOOR, 36 IN. X 80 IN.
99	DOOR, 36 IN. X 80 IN.
100	DOOR, 36 IN. X 80 IN.

APPENDIX J

BUILDING 9, BASEMENT

IH&S FORM - SPECIAL  
LRO - 2/92

DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE

SURVEYOR:

LARRY SAWYER

SIGNATURE:

DATE: 3-5-92

FORM SERIAL NUMBER: A001 REPORTAGE

BETA-GAMMA			ALPHA			GAMMA/BETA-GAMMA			ALPHA		
COUNTER NO.:	TENNELEC D	MS-2	TENNELEC D	SAC-4	INSTRUMENT	E520			ASP-1		
BACKGROUND	1.81 CPM	CPM	16 CPM	CPM	SERIAL NO.	5242			1891		
EFFICIENCY	44.7 %	%	37.1 %	%	PROBE	30 MC/cm <sup>2</sup>			AC-3		

BUILDING/AREA	FLOOR	GRID	SHEAR			GAMMA RADIATION			BETA RADIATION		
			ALPHA	BETA	ONE METER UR/HOUR	ONE METER UR/HOUR	CONTACT HR/HOUR	CONTACT DPM/100 SQUARE CM	CONTACT HR/HOUR	CONTACT DPM/100 SQUARE CM	CONTACT HR/HOUR
9	Pj	See	1 0	0	6	NA	NA	≤ 6KG	≤ 6KG	≤ 6KG	≤ 6KG
			Mac	2 0	6						
				3 7	20						
			All	4 0	6						
			Floor	5 0	0						
			Stair	6 0	0						
			Stair	7 0	0						
			8 0	0	13						
			9 7	6							
			10 0	0	0						
			11 0	0	0						
			12 0	0	0						
			13 0	0	6						
			14 7	13							
			15 0	0	6						
			16 0	0	6						
			17 0	0	6						
			18 7	40	0						
			19 0	0	0						

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

I H&S FORM - SPECIAL!  
LRD - 2/92

SURVEYOR: LARRY SOLIZ SIGNATURE: Larry Soliz DATE: 3-5-92 FORM SERIAL NUMBER: New Reserve

BETA-GAMMA		ALPHA		GAMMA/BETA-GAMMA		ALPHA	
COUNTER NO.:	TENNELEC 0	HS-2	TENNELEC D	SAC-4	INSTRUMENT	E520	
BACKGROUND	1.3/ CPM	CPM	1/6 CPM	CPM	SERIAL NO.	5242	
EFFICIENCY	44.7 %	24.4 %	37.1 %	38.9 %	PROBE	3046/cm <sup>2</sup>	AC-3

BUILDING/AREA	FLOOR	GRID	SHEAR		GAMMA RADIATION ONE METER HR/HOUR	BETA-GAMMA RADIATION CONTACT MR/HOUR	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
9	Pit	See	0	0	NA	NA	≤ 8KC	≤ 8KC
			Max.	0	0	0		
			(All)	0	6			
			Floor	0	13			
			Surface	0	0			
			Concrete	0	13			
			Soil	0	0			
			Rock	0	0			
			07	0	6			
			28	7	6			
			29	0	6			
			30	0	0			
			31	0	0			
			32	0	0			
			33	0	6			
			34	0	0			
			35	0	6			
			36	0	6			
			37	0	6			
			38	0	0			

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

SURVEYOR: Larry Bain SIGNATURE: Doug Smith DATE: 3-5-92 FORM SERIAL NUMBER: New B-92


BETA-GAMMA		ALPHA		GAMMA/BETA-GAMMA		ALPHA	
COUNTER NO.:	TENNELEC <u>D</u>	MS 2	TENNELEC <u>D</u>	SAC-4	INSTRUMENT	<u>E520</u>	
BACKGROUND	1.81 CPM	CPM	16 CPM	CPM	SERIAL NO.	<u>5242</u>	
EFFICIENCY	44.7 %	%	37.1 %	%	PROBE	<u>HPLCO</u>	

BUILDING/AREA	FLOOR	GR10	SHEAR		GAMMA RADIATION ONE METER UR/HOUR	BETA-GAMMA RADIATION CONTACT MP/HOUR	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
9	1st	SEC	39	0	0	NA	≤ 6K6	≤ 6K6
		MAZ	40	0	0			
		41	0	0	6			
		All	42	0	0			
		Froze	43	0	6			
		Water	44	0	6			
		Soil	45	0	0			
		46	0	6				
		47	0	0				
		48	0	0				
		49	0	6				
		50	0	13				
		51	0	0				
		52	7	0				
		53	0	0				
		54	7	6			240	
		55	0	27			≤ 6K6	
		56	0	0				2640

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

BUILDING #9 PIT (DETAILS)

-30-



SURVEYOR S. Gill/csi:ec

SIGNATURE: J. U. Ballou

DATE: 7/23/92 FORM SERIAL NUMBER: Preliminary

BETA-GAMMA		ALPHA	
COUNTER NO.:	TENNELEC	MS-2	TERNELEC
BACKGROUND	CPM	CPM	SAC-4
EFFICIENCY	%	%	CPM
		%	SERIAL NO.
		%	PROBE
			PAC-4G
			4478
			AC-21-B
			AC-3

BETA-GAMMA		ALPHA		GAMMA/BETA-GAMMA		ALPHA	
COUNTER NO.:	TENNELEC	MS-2	TERNELEC	SAC-4	INSTRUMENT	PAC-4G	INSTRUMENT
BACKGROUND	CPM	CPM	CPM	CPM	SERIAL NO.	4478	SERIAL NO.
EFFICIENCY	%	%	%	%	PROBE	AC-21-B	PROBE
Building/Area	Floor	Grid	Shear	GAMMA RADIATION ONE METER	BETA GAMMA RADIATION	BETA RADIATION	ALPHA RADIATION
#-9 P/B at-S				HR/HOUR	CONTACT hr/HOUR	CONTACT DPM/100 SQUARE CM	CONTACT DPM/100 SQUARE CM
00'	N/A	N/A	ALPHA	BETA	N/A	N/A	N/A
03'							<u>&lt; 30s</u>
06'							
09'							
12'							
15'							
18'							
21'							
24'							
27'							

Building/Area	Floor	Grid	Shear	GAMMA RADIATION ONE METER	BETA GAMMA RADIATION	BETA RADIATION	ALPHA RADIATION
#-9 P/B at-S				HR/HOUR	CONTACT hr/HOUR	CONTACT DPM/100 SQUARE CM	CONTACT DPM/100 SQUARE CM
00'	N/A	N/A	ALPHA	BETA	N/A	N/A	N/A
03'							<u>&lt; 30s</u>
06'							
09'							
12'							
15'							
18'							
21'							
24'							
27'							

Shear levels are in units of DPM/100 square centimeters

Instrument Data: PAC-4G (Beta) 55.1% Eff. 1.8 C. F. Bkg. 200 DPM  
ASP-1 (Alpha) 21.8% Eff. 4.6 C. F. Bkg. 5 DPM

SURVEYOR: S.D. G. /CGP: e

SIGNATURE: *John H. Miller*

DATE: 7-23-92 FORM SERIAL NUMBER:

COUNTER NO.:	BETA-GAMMA		ALPHA		GAMMA/BETA-GAMMA		ALPHA
	TENNELEC	MS-2	TENNELEC	E.C. 4	INSTRUMENT		
BACKGROUND	CPM	CPM	CPM	CPM	SERIAL NO.		
EFFICIENCY	%	%	%	%	% PROBE		
ABORTED							
BUILDING/AREA	WALLS	GRID					
9 Pit left to right							
0' 6' high							
5'							
10'							
15'							
20'							
0' 3' high							
5'							
10'							
15'							
20'							
0' 6' high							
5'							
10'							
15'							
20'							

ABORTED	BUILDING/AREA	WALLS	GRID	SHEAR		GAMMA RADIATION ONE METER UP/HOUR	BETA-GAMMA RADIATION CONTACT RPS/HOUR	BETA RADIATION CONTACT RPS/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
				ALPHA	BETA				
0' 6' high	9 Pit left to right			N/A	N/A	N/A	N/A	6.3	≤ 0.45
5'								6.3	≤ 0.45
10'								6.3	≤ 0.45
15'								6.3	≤ 0.45
20'								6.3	≤ 0.45
0' 3' high								/	
5'								6.3	≤ 0.45
10'								6.3	≤ 0.45
15'								6.3	≤ 0.45
20'								6.3	≤ 0.45
0' 6' high								/	
5'								6.3	≤ 0.45
10'								6.3	≤ 0.45
15'								9.0	≤ 0.45
20'								9.0	≤ 0.45

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

BETAS 5 DPM *Abc 45(B)* 55.1% eff 1.8 C.R.  
1345 200 DPM *Abc 45P-1(A)* 21.8 % eff 4.6 C.R.

THIS FORM - SPECIAL  
LRC - 2/92

DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE

P. 1 of 2

SURVEYOR: S.D. G. /cs2/e

SIGNATURE: J. H. Bellanca

DATE: 7-23-92 FORM SERIAL NUMBER:

SACY F/IC SEC 79

COUNTER NO.:	BETA-GAMMA		ALPHA		GAMMA/BETA-GAMMA		ALPHA
	TENNELEC	NS-2	TEHNE LEC	SAC-4	INSTRUMENT	SERIAL NO.	
BACKGROUND	CPM	CPM	CPM	CPM			
EFFICIENCY	%	%	%	%	PROBE		

EAST WALL BUILDING/AREA 9 Pit left to right	WALLS	GR10	SHEAR		GAMMA RADIATION ONE METER UB/HOUR	BETA-GAMMA RADIATION CONTACT UB/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
0' 6" H.54			A/4	A/4		A/4	A/4	L 3K5
1'								
18'								
15'								
20'								
25'								
30'								
35'								
40'								
0' 3' high								
5'								
10'								
15'								
20'								
25'								
30'								
35'								
40'								

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

BK5

DPM

Pac-45 CB)

55.1% eff

1.8 CCR

BK5 300 DPM

(A) 21.8 % eff

4.C CCR

SURVEYOR: S. O. G. 11 CCP: C

SIGNATURE: J. W. Bellies

File Survey Sect # 9

DATE: 2-23-92 FORM SERIAL NUMBER:

DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE

8.24.2

COUNTER NO.:	BETA-GAMMA		ALPHA		GAMMA/BETA-GAMMA		ALPHA
	TENNELEC	HS-2	TENNELEC	SAC-4	INSTRUMENT		
BACKGROUND	CPM	CPM	CPM	CPM	SERIAL NO.		
EFFICIENCY	%	%	%	%	% PROBE		
EAST WALL	WALLS	GRID	SHEAR	GAMMA RADIATION ONE METER uR/HOUR	BETA-GAMMA RADIATION CONTACT uR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
0'	Pit left to right	N/A	ALPHA	BETA	N/A	N/A	N/A
5'	44.57	N/A	N/A	N/A	N/A	< BKS	< BKS
10'							
15'							
20'							
25'							
30'							
35'							
40'							

EAST WALL BUILDING/AREA	WALLS	GRID	SHEAR	GAMMA RADIATION ONE METER uR/HOUR	BETA-GAMMA RADIATION CONTACT uR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
0'	Pit left to right	N/A	ALPHA	BETA	N/A	N/A	N/A
5'	44.57	N/A	N/A	N/A	N/A	< BKS	< BKS
10'							
15'							
20'							
25'							
30'							
35'							
40'							
45'							
50'							
55'							
60'							
65'							
70'							
75'							
80'							
85'							
90'							
95'							
100'							

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

DKS 300 DPM 100% (B) 35.7% off 18 CP  
BKS 5 DPM ASP-1 (B) 21.8% off 4.6 CF

P.1042

THIS FORM - SPECIAL  
LRD - 2/92

SURVEYOR: S.D. G. #324

SIGNATURE: J. D. Hilliger

DATE: 2-23-92 FORM SERIAL NUMBER:

DECOMMISSIONING SURVEYS - MESTINGHOUSE LARGE SITE

FIRE Survey Sect #9

BETA-GAMMA			ALPHA			GAMMA/BETA-GAMMA			ALPHA		
COUNTER NO.:	TENNELEC	MS-2	TENNELEC	SAC-4	INSTRUMENT						
BACKGROUND	CPM	CPM	CPM	CPM	SERIAL NO.						
EFFICIENCY	%	%	%	%	PROBE						
0'	6' High		A/A	A/A	ONE METER HR/HOUR	GAMMA RADIATION ONE METER HR/HOUR	BETA-GAMMA RADIATION CONTACT HR/HOUR	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM		
5'											
10'											
15'											
20'											
25'											
30'											
35'											
40'											

lowest wall BUILDING AREA 9 Pit left to right	WALLS	GRID	SHEAR	GAMMA RADIATION ONE METER HR/HOUR	BETA-GAMMA RADIATION CONTACT HR/HOUR	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
0'	6' High	A/A	A/A	A/A	A/A	≤ 0KS	≤ 0KS
5'						6.3	
10'						≤ 0KS	
15'						≤ 0KS	
20'						6.3	
25'						≤ 0KS	
30'						6.3	
35'						≤ 0KS	
40'						6.3	

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

3KS 5 DPM PER-49 (Beta) 55.1% off 1.8 C.R.  
3KS 200 DPM ASP-1 (Alpha) 21.9% off 4.6 C.R.

RS FORM - SPECIAL  
LRD - 2/92

DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE  
\*\*\*\*\*

P72042

SURVEYOR: S.D. Gilligan

SIGNATURE:

File Survey Sat # 9

BETA-GAMMA		ALPHA		GAMMA/BETA-GAMMA		ALPHA	
COUNTER NO.:	TENNELEC	HS-2	TENNELEC	SAC-4	INSTRUMENT	SAC-4	INSTRUMENT
BACKGROUND	CPN	CPN	CPN	CPN	SERIAL NO.	CPN	SERIAL NO.
EFFICIENCY	%	%	%	%	PROBE	%	PROBE
0'	00' High	Walls	GRID	SHEAR	GAMMA RADIATION TIME METER UR/HOUR	BETA-GAMMA RADIATION CONTACT UR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM
5'		n/a	n/a	n/a	n/a	6.3	< DPM
10'						9.0	
15'						< DPM	
20'						6.3	
25'						9.0	
30'						< DPM	
35'						6.3	
40'						< DPM	

LAST URGENT BUILDING/AREA 9 pit left to right	WALLS	GRID	ALPHA	BETA	GAMMA RADIATION TIME METER UR/HOUR	BETA-GAMMA RADIATION CONTACT UR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
0'	00' High	n/a	n/a	n/a	n/a	6.3	< DPM	< DPM
5'						9.0		
10'						< DPM		
15'						6.3		
20'						9.0		
25'						< DPM		
30'						6.3		
35'						9.0		
40'						< DPM		

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

DAS 5 DPM PHC-46 (DB07A) 56.1 % EFF - 1.8 C/F

DAS 200 DPM A57-1 (41248) 21.8 % EFF 4.6 C/F

FHSS FORM - SPECIAL  
LRD - 2/92

DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE

SURVEYOR: S. D. G. / HESPE

FILE SURVEY SEC 7 #5

FORM SERIAL NUMBER:

SIGNATURE: J. D. Hespe

DATE: 7-13-72

BETA-GAMMA			ALPHA		
COUNTER NO.:	TENNELEC	MS-2	TENNELEC	SAC-4	INSTRUMENT
BACKGROUND	CPM	CPM	CPM	CPM	SERIAL NO.
EFFICIENCY	%	%	%	%	PROBE

SOUTH Wall		WALLS	GR10	SHEAR		GAMMA RADIATION	BETA-GAMMA RADIATION	BETA RADIATION	ALPHA RADIATION
BUILDING/AREA	9 Pit left to right			ALPHA	BETA	ONE METER UR/HOUR	CONTACT HR/HOUR	DPM/100 SQUARE CM	CONTACT DPM/100 SQUARE CM
0'	6' high			N/A	N/A	N/A	N/A	60	< BkS
5'								≤ BkS	
10'								63	
15'								63	
20'								90	
0'	3' high						/		
5'							63		
10'							63		
15'							63		
20'							90		
0'	0' high						/		
5'							≤ BkS		
10'									
15'									
20'									

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

BkS 300 DPM PAC-45 (B) 53.1% eff 1.8 cc

BkS 5 DPM 85P-1 (B) 21.8% eff 4.6 cc

APPENDIX K

BUILDING 9, FIRST FLOOR

IN&S FORM - SPECIAL  
LRD - 2/92

DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE

page 4 of 5

SURVEYOR: Larry Smith

SIGNATURE: *Larry Smith*

DATE: 3-23/24/92 FORM SERIAL NUMBER: Preliminary

BETA-GAMMA		ALPHA		GAMMA/BETA-GAMMA			ALPHA
COUNTER NO.:	Tenn E		Tenn E		INSTRUMENT	E-520	
BACKGROUND	1.95 CPM	CPM	.10 CPM	CPM	SERIAL NO.	5245	ASP-1
EFFICIENCY	43.2 %	%	33.2 %	%	PROBE	7mg/cm <sup>2</sup>	1891 AC-3


BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
9	1	N/A	1 See		N/A	N/A	Bkg.	Bkg.
			2 Attached				Avg. Bkg. = 270 DPM	Avg. Bkg. = 37.5 DPM
			3 Printout				Efficiency=13%	Efficiency=20.2%
			4					
			5					
			6					
			7					
			8					
			9					
			10					
			11					
			12					
			13					
			14					
			15					
			16					
			17					
			18					
			19					


SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

SURVEYOR: Larry Smith

SIGNATURE: *Larry Smith* DATE: 3-23/24-92 FORM SERIAL NUMBER: Preliminary

BETA-GAMMA		ALPHA	
COUNTER NO.:	Tenn E	INSTRUMENT	E-520
BACKGROUND	1.95 CPM	CPM	-10
EFFICIENCY	43.2 %	%	33.2 %



SURVEYOR: Larry Smith	SIGNATURE: 	DATE: 3-23/24-92	FORM SERIAL NUMBER: Preliminary
-----------------------	---	------------------	---------------------------------

BETA-GAMMA			ALPHA			GAMMA/BETA-GAMMA			ALPHA	
COUNTER NO.:	Tenn E		Tenn E		INSTRUMENT	E-520			ASP-I	
BACKGROUND	1.95	CPM	CPM	.10	CPM	CPM	SERIAL NO.	5245		1891
EFFICIENCY	43.2	%	%	33.2	%	%	PROBE	7mg/cm <sup>2</sup>		AC-3

BUILDING/AREA	FLOOR	GRID	SHEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
9	1	N/A	39	See	N/A	N/A	Bkg.	Bkg.
			40	Attached			Avg. Bkg. = 270 DPM	Avg. Bkg. = 37.5 DPM
			41	Printout			Efficiency = 13%	Efficiency = 20.2%
			42					
			43					
			44					
			45					
			46					
			47					
			48					
			49					
			50					
			51					
			52					
			53					
			54					
			55					
			56					
			57					

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

NING SURVEYS - WESTINGHOUSE LARGE SITE

*John J. Hart* DATE: 3-23/24-92 FORM SERIAL NUMBER: Preliminary  
page 4 of 5

GAMMA/BETA-GAMMA			ALPHA
INSTRUMENT	E-520		ASP-1
CPN	SERIAL NO.	5245	1891
% PROBE		7mg / cm <sup>2</sup>	AC-3

BUILDING/AREA	FLOOR	GRID	SHEAR		GAMMA RADIATION ONE METER UR/HOUR	BETA CONTACT mR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA					
9	1		N/A	58	See	N/A	N/A	N/A	Bkg.
				59	Attached				Bkg.
				60	Printout			Avg. Bkg. = 270 DPM	Avg. Bkg. = 37.5 DPM
				61				Efficiency=13%	Efficiency=20.2%
				62					
				63					
				64					
				65					
				66					
				67					
				68					
				69					
				70					
				71					
				72					
				73					
				74					
				75					
				76					
				77					
				78					
				79					
				80					
				81					
				82					
				83					
				84					
				85					
				86					
				87					
				88					
				89					
				90					
				91					
				92					
				93					
				94					
				95					
				96					
				97					
				98					
				99					
				100					
				101					
				102					
				103					
				104					
				105					
				106					
				107					
				108					
				109					
				110					
				111					
				112					
				113					
				114					
				115					
				116					
				117					
				118					
				119					
				120					
				121					
				122					
				123					
				124					
				125					
				126					
				127					
				128					
				129					
				130					
				131					
				132					
				133					
				134					
				135					
				136					
				137					
				138					
				139					
				140					
				141					
				142					
				143					
				144					
				145					
				146					
				147					
				148					
				149					
				150					
				151					
				152					
				153					
				154					
				155					
				156					
				157					
				158					
				159					
				160					
				161					
				162					
				163					
				164					
				165					
				166					
				167					
				168					
				169					
				170					
				171					
				172					
				173					
				174					
				175					
				176					
				177					
				178					
				179					
				180					
				181					
				182					
				183					
				184					
				185					
				186					
				187					
				188					
				189					
				190					
				191					
				192					
				193					
				194					
				195					
				196					
				197					
				198					
				199					
				200					
				201					
				202					
				203					
				204					
				205					
				206					
				207					
				208					
				209					
				210					
				211					
				212					
				213					
				214					
				215					
				216					
				217					
				218					
				219					
				220					
				221					
				222					
				223					
				224					
				225					
				226					
				227					
				228					
				229					
				230					
				231					
				232					
				233					
				234					
				235					
				236					
				237					
				238					
				239					
				240					
				241					
				242					
				243					
				244					
				245					
				246					
				247					
				248					
				249					
				250					
				251					
				252					
				253					
				254					
				255					

\*\*\*\*\*  
I IH&S FORM - SPECIAL !  
I LRD - 2/92 !  
\*\*\*\*\*

\*\*\*\*\*  
DECOMMISSIONING SURVEYS - WESTINGHOUSE  
\*\*\*\*\*

SURVEYOR: Larry Smith

SIGNATURE: *Lawrence J. Smith*

COUNTER NO.:	BETA-GAMMA			ALPHA			INSTRUMENT
	Tenn E	CPM	CPM	Tenn E	CPM	CPM	
BACKGROUND	1.95			.10			SERIAL NO.
EFFICIENCY	43.2	%	%	33.2	%	%	PROBE



SAMPLE NUMBER	BETA COUNTS	BETA DPM	BETA 3 SIGMA	ALPHA COUNTS	ALPHA DPM	ALPHA 3 SIGMA	TIME MINS	GAMMA RADIATION ONE METER UR/HOUR
1	1	2.4	5.3	0	-0.3	0.2	0.33	
2	2	9.4	7.4	0	-0.3	0.2	0.33	N/A
3	1	2.4	5.3	0	-0.3	0.2	0.33	
4	0	-4.5	0.9	0	-0.3	0.2	0.33	
5	1	2.4	5.3	1	0.8	5.2	0.33	
6	3	16.4	9.0	0	-0.3	0.2	0.33	
7	0	-4.5	0.9	1	0.8	5.2	0.33	
8	0	-4.5	0.9	0	-0.3	0.2	0.33	
9	0	-4.5	0.9	0	-0.3	0.2	0.33	
10	5	38.4	11.7	0	-0.3	0.2	0.33	
11	2	9.4	7.4	1	0.8	5.2	0.33	
12	0	-4.5	0.9	0	-0.3	0.2	0.33	
13	2	9.4	7.4	0	-0.3	0.2	0.33	
14	1	2.4	5.3	0	-0.3	0.2	0.33	
15	2	9.4	7.4	0	-0.3	0.2	0.33	
16	1	2.4	5.3	0	-0.3	0.2	0.33	
17	2	9.4	7.4	0	-0.3	0.2	0.33	
18	0	-4.5	0.9	0	-0.3	0.2	0.33	
19	0	-4.5	0.9	1	0.8	5.2	0.33	
20	0	-4.5	0.9	0	-0.3	0.2	0.33	
21	0	-4.5	0.9	0	-0.3	0.2	0.33	
22	0	-4.5	0.9	0	-0.3	0.2	0.33	
23	2	9.4	7.4	0	-0.3	0.2	0.33	
24	1	2.4	5.3	0	-0.3	0.2	0.33	
25	1	2.4	5.3	0	-0.3	0.2	0.33	
26	0	-4.5	0.9	0	-0.3	0.2	0.33	
27	1	2.4	5.3	0	-0.3	0.2	0.33	
28	0	-4.5	0.9	0	-0.3	0.2	0.33	
29	0	-4.5	0.9	0	-0.3	0.2	0.33	
30	0	-4.5	0.9	0	-0.3	0.2	0.33	
31	0	-4.5	0.9	0	-0.3	0.2	0.33	
32	1	2.4	5.3	0	-0.3	0.2	0.33	
33	1	2.4	5.3	0	-0.3	0.2	0.33	
34	2	9.4	7.4	0	-0.3	0.2	0.33	
35	3	16.4	9.0	0	-0.3	0.2	0.33	
36	2	9.4	7.4	0	-0.3	0.2	0.33	
37	1	2.4	5.3	0	-0.3	0.2	0.33	
38	2	9.4	7.4	0	-0.3	0.2	0.33	
39	5	38.4	11.7	0	-0.3	0.2	0.33	
40	0	-4.5	0.9	0	-0.3	0.2	0.33	
41	1	2.4	5.3	0	-0.3	0.2	0.33	
42	0	-4.5	0.9	0	-0.3	0.2	0.33	
43	2	9.4	7.4	0	-0.3	0.2	0.33	
44	0	-4.5	0.9	0	-0.3	0.2	0.33	
45	37	88.9	18.2	1	2.7	3.0	1.00	
46	0	-4.5	0.9	0	-0.3	0.2	0.33	
47	0	-4.5	0.9	0	-0.3	0.2	0.33	
48	0	-4.5	0.9	0	-0.3	0.2	0.33	

INCHIMETERS

21	0	-4.5	8.9	0	-0.3	0.2	0.33
22	0	-4.5	8.9	0	-0.3	0.2	0.33
23	2	9.4	7.4	0	-0.3	0.2	0.33
24	1	2.4	5.3	0	-0.3	0.2	0.33
25	1	2.4	5.3	0	-0.3	0.2	0.33
26	0	-4.5	8.9	0	-0.3	0.2	0.33
27	1	2.4	5.3	0	-0.3	0.2	0.33
28	0	-4.5	8.9	0	-0.3	0.2	0.33
29	0	-4.5	8.9	0	-0.3	0.2	0.33
30	0	-4.5	8.9	0	-0.3	0.2	0.33
31	0	-4.5	8.9	0	-0.3	0.2	0.33
32	1	2.4	5.3	0	-0.3	0.2	0.33
33	1	2.4	5.3	0	-0.3	0.2	0.33
34	2	9.4	7.4	0	-0.3	0.2	0.33
35	3	16.4	9.0	0	-0.3	0.2	0.33
36	2	9.4	7.4	0	-0.3	0.2	0.33
37	1	2.4	5.3	0	-0.3	0.2	0.33
38	2	9.4	7.4	0	-0.3	0.2	0.33
39	5	38.4	11.7	0	-0.3	0.2	0.33
40	0	-4.5	8.9	0	-0.3	0.2	0.33
41	1	2.4	5.3	0	-0.3	0.2	0.33
42	0	-4.5	8.9	0	-0.3	0.2	0.33
43	2	9.4	7.4	0	-0.3	0.2	0.33
44	0	-4.5	8.9	0	-0.3	0.2	0.33
45	37	88.9	18.2	1	2.7	3.0	1.00
46	0	-4.5	8.9	0	-0.3	0.2	0.33
47	0	-4.5	8.9	0	-0.3	0.2	0.33
48	0	-4.5	8.9	0	-0.3	0.2	0.33
49	3	16.4	9.0	0	-0.3	0.2	0.33
50	2	9.4	7.4	0	-0.3	0.2	0.33
51	2	9.4	7.4	0	-0.3	0.2	0.33
52	0	-4.5	8.9	0	-0.3	0.2	0.33
53	4	23.4	18.4	0	-0.3	0.2	0.33
54	1	2.4	5.3	0	-0.3	0.2	0.33
55	1	2.4	5.3	0	-0.3	0.2	0.33
56	2	9.4	7.4	0	-0.3	0.2	0.33
57	0	-4.5	8.9	0	-0.3	0.2	0.33
58	2	9.4	7.4	0	-0.3	0.2	0.33
59	2	9.4	7.4	0	-0.3	0.2	0.33
60	0	-4.5	8.9	0	-0.3	0.2	0.33
61	0	-4.5	8.9	0	-0.3	0.2	0.33
62	2	9.4	7.4	0	-0.3	0.2	0.33
63	0	-4.5	8.9	0	-0.3	0.2	0.33
64	3	16.4	9.0	0	-0.3	0.2	0.33
65	1	2.4	5.3	0	-0.3	0.2	0.33
66	2	9.4	7.4	0	-0.3	0.2	0.33
67	2	9.4	7.4	0	-0.3	0.2	0.33
68	2	9.4	7.4	0	-0.3	0.2	0.33
69	0	-4.5	8.9	0	-0.3	0.2	0.33

INCHIMETERS

SCE JUL 02



131

BERNIE ALEX. B. P. AMERICA

SCALE : FEET

14&S FOR: - SPECIAL  
LRD - 2/92

\* DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE

page 1 of 4

SURVEYOR: Larry Smith SIGNATURE:  DATE: 3-23/24-92 FORM SERIAL NUMBER: Preliminary

BETA-GAMMA			ALPHA			GAMMA/BETA-GAMMA			ALPHA
COUNTER NO.:	Tenn E		Tenn E		INSTRUMENT	E-520			ASP-1
BACKGROUND	1.95	CPM		.10	CPM		SERIAL NO.	5245	
EFFICIENCY	43.2	%		%	33.2	%	PROBE	7mg/cm <sup>2</sup>	

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT uR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
9	1	N/A	/ See		N/A	N/A	Bkg.	Bkg.
			2 Attached				Avg. Bkg.=270 DPM	Avg. Bkg.=37.5 DPM
			3 Printout				Efficiency=13%	Efficiency=20.2%
			4					
			5					
			6					
			7					
			8					
			9					
			10					
			11					
			12					
			13					
			14					
			15					
			16					
			17					
			18					
			19					

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

IH&S FORM - SPECIAL  
LRD - 2/92

DECOMMISSIONING SURVEYS - WESTINGHOUSE LARGE SITE

page 2 of 4

SURVEYOR:	Larry Smith	SIGNATURE:	<i>Tawna Smith</i>	DATE:	3-23/24/92	FORM SERIAL NUMBER:	Preliminary
-----------	-------------	------------	--------------------	-------	------------	---------------------	-------------

COUNTER NO.:	BETA-GAMMA		ALPHA		GAMMA/BETA-GAMMA			ALPHA
	Tenn E		Tenn E		INSTRUMENT	E-520		
BACKGROUND	1.95 CPM	CPM	.10 CPM	CPM	SERIAL NO.	5245		ASP-1
EFFICIENCY	43.2 %	%	33.2 %	%	PROBE	7mg/cm <sup>2</sup>		1891
								AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
9	1	N/A	20	See	N/A	N/A	Bkg.	Bkg.
			21	Attached			Avg. Bkg.=270 DPM	Avg. Bkg.=37.5 DPM
			22	Printout			Efficiency=13%	Efficiency=20.2%
			23					
			24					
			25					
			26					
			27					
			28					
			29					
			30					
			31					
			32					
			33					
			34					
			35					
			36					
			37					
			38	↓	↓	↓	↓	↓

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

ING SURVEYS - WESTINGHOUSE LARGE SITE

page 3 of 4

<i>one J. Stith</i>	DATE: 3-23/24-92	FORM SERIAL NUMBER: Preliminary
	GAMMA/BETA - GAMMA	ALPHA
INSTRUMENT	E-520	ASP-1
CPM	SERIAL NO.	5245
%	PROBE	7mg/cm <sup>2</sup>
		AC-3


BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
9	1	N/A	39	See	N/A	N/A	Bkg.	Bkg.
			40	Attached			Avg. Bkg.=270 DPM	Avg. Bkg.=37.5 DPM
			41	Printout			Efficiency=13%	Efficiency=20.2%
			42					
			43					
			44					
			45					
			46					
			47					
			48					
			49					
			50					
			51					
			52					
			53					
			54					

SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

COUNTER NO.:	Tenn E		Tenn E				INSI
BACKGROUND	1.95	CPM	CPM	.10	CPM	CPM	SER
EFFICIENCY	43.2	%	%	33.2	%	%	PROF

SAMPLE NUMBER	BETA COUNTS	BETA DPM	BETA 3 SIGMA	ALPHA COUNTS	ALPHA DPM	ALPHA 3 SIGMA	TIME MINS	GAMMA RADIATION ONE METER UR/HOUR
1	2	9.4	7.4	0	-0.3	0.2	0.33	N/A
2	1	2.4	5.3	0	-0.3	0.2	0.33	
3	2	9.4	7.4	0	-0.3	0.2	0.33	
4	8	-4.5	0.9	0	-0.3	0.2	0.33	
5	0	-4.5	0.9	0	-0.3	0.2	0.33	
6	0	-4.5	0.9	0	-0.3	0.2	0.33	
7	1	2.4	5.3	0	-0.3	0.2	0.33	
8	0	-4.5	0.9	0	-0.3	0.2	0.33	
9	1	2.4	5.3	0	-0.3	0.2	0.33	
10	0	-4.5	0.9	0	-0.3	0.2	0.33	
11	0	-4.5	0.9	0	-0.3	0.2	0.33	
12	0	-4.5	0.9	0	-0.3	0.2	0.33	
13	1	2.4	5.3	0	-0.3	0.2	0.33	
14	1	2.4	5.3	0	-0.3	0.2	0.33	
15	1	2.4	5.3	0	-0.3	0.2	0.33	
16	0	-4.5	0.9	0	-0.3	0.2	0.33	
17	2	9.4	7.4	0	-0.3	0.2	0.33	
18	2	9.4	7.4	0	-0.3	0.2	0.33	
19	1	2.4	5.3	0	-0.3	0.2	0.33	
20	1	2.4	5.3	0	-0.3	0.2	0.33	
21	1	2.4	5.3	0	-0.3	0.2	0.33	
22	2	9.4	7.4	0	-0.3	0.2	0.33	
23	2	9.4	7.4	0	-0.3	0.2	0.33	
24	3	16.4	9.0	0	-0.3	0.2	0.33	
25	1	2.4	5.3	0	-0.3	0.2	0.33	
26	1	2.4	5.3	0	-0.3	0.2	0.33	
27	3	16.4	9.0	0	-0.3	0.2	0.33	
28	1	2.4	5.3	0	-0.3	0.2	0.33	
29	2	9.4	7.4	0	-0.3	0.2	0.33	
30	1	2.4	5.3	0	-0.3	0.2	0.33	INTIMETERS
31	1	2.4	5.3	0	-0.3	0.2	0.33	
32	1	2.4	5.3	0	-0.3	0.2	0.33	
33	0	-4.5	0.9	0	-0.3	0.2	0.33	
34	1	2.4	5.3	0	-0.3	0.2	0.33	
35	1	2.4	5.3	0	-0.3	0.2	0.33	
36	1	2.4	5.3	0	-0.3	0.2	0.33	
37	4	23.4	18.4	0	-0.3	0.2	0.33	
38	1	2.4	5.3	0	-0.3	0.2	0.33	
39	3	16.4	9.0	0	-0.3	0.2	0.33	
40	0	-4.5	0.9	0	-0.3	0.2	0.33	
41	2	9.4	7.4	0	-0.3	0.2	0.33	
42	1	2.4	5.3	0	-0.3	0.2	0.33	
43	5	38.4	11.7	1	8.8	5.2	0.33	
44	1	2.4	5.3	0	-0.3	0.2	0.33	
45	39	85.5	18.7	0	-0.3	0.2	1.00	
46	0	-4.5	0.9	0	-0.3	0.2	0.33	
47	1	2.4	5.3	0	-0.3	0.2	0.33	
48	0	-4.5	0.9	0	-0.3	0.2	0.33	
49	0	-4.5	0.9	0	-0.3	0.2	0.33	
50	0	-4.5	0.9	0	-0.3	0.2	0.33	
51	1	2.4	5.3	0	-0.3	0.2	0.33	
52	0	-4.5	0.9	0	-0.3	0.2	0.33	
53	0	-4.5	0.9	0	-0.3	0.2	0.33	
54	0	-4.5	0.9	0	-0.3	0.2	0.33	

-21-



**LEGENDO**

卷之三

Journal of Health Politics, Policy and Law

S Y - 1 3 0 0 8

1 D : N G N > q

S O L A R G E . P A

卷之三

JN-U20 A

\*\*\*\*\*  
IHS FORM I  
#1004  
LRD 3/88  
\*\*\*\*\*

\*\*\*\*\*  
SHEAR SAMPLE  
\*\*\*\*\*

PAGE 1 OF 3



LOCATION : <u>BLDG 9</u>	SURVEYOR : "HP STAFF"	SURVEY DATE <u>3-30-92</u>
<u>VENTILATION DUCTS</u>	COUNTED BY : "HP STAFF"	COUNT DATE <u>3-30-92</u>
BETA/GAMMA		ALPHA
COUNTER NUMBER	<u>CANBERRA</u>	
BACKGROUND (CPM)	<u>1.80</u> CPM	CPM <u>.20</u> CPM
EFFICIENCY (%)	<u>17.1</u> %	% <u>36.6</u> %
ACTIVITY IN:	MICROCURIES <input type="checkbox"/>	DPM <input checked="" type="checkbox"/> CPM <input type="checkbox"/>

	A	B		A	B		A	B		A	B
1	0	13	21		-1		61			81	
2	0	0	22		-2		62			82	
3	0	13	23		-3		63			83	
4	0	36	24		-4		64			84	
5	0	13	25		-5		65			85	
6	0	0	26		-6		66			86	
7	0	13	27		-7		67			87	
8	0	0	28		-8		68			88	
9			29		-9		69			89	
10			30		-10		70			90	
11			31		-11		71			91	
12			32		-12		72			92	
13			33		-13		73			93	
14			34		-14		74			94	
15			35		-15		75			95	
16			36		-16		76			96	
17			37		-17		77			97	
18			38		-18		78			98	
19			39		-19		79			99	
20			40		-20		80			100	

REMARKS : --- <200 DPM / 100cm<sup>2</sup> BT --- <10 DPM / 100cm<sup>2</sup> A

Sample

LOCATION

1-5 - - - - - A  
6-8 - - - - - B

IH&S FORM 1  
# 1002  
LRD - 7/90

\* \* \* \* \* RADIATION SURVEY \* \* \* \* \*

PAGE 2 OF 3



SURVEY TYPE: ROUTINE <input type="checkbox"/> SPECIAL <input checked="" type="checkbox"/> RWP <input type="checkbox"/> (RWP # )	SURVEY DATE: 3-30-92	
LOCATION: Bloc 9	SURVEY TIME: 1400	
INSTRUMENT: PAC 4G INSTRUMENT: ASP-1	SERIAL #: 4478 SERIAL #: 1891	PROBE TYPE: AC-21 B PROBE TYPE: AC-3
DESCRIPTION OF SURVEY		
BETA CONTACT		ALPHA CONTACT
NET DPM/100 cm <sup>2</sup>		NET DPM/100cm <sup>2</sup>
SAMPLE LOCATION 'A' INSIDE Duct	473 DPM	≤ BKG
SAMPLE LOCATION 'B' INSIDE Duct	≤ BKG	≤ BKG
SKETCH		
SEE ATTACHED MAP FOR SURVEY POINTS A & B.		
AC-3 ASP-1	REMARKS	AC-21 B PAC4G
EFFICIENCY	20.2 %	63.4 %
Avg. BKG.	37.1 DPM/50 cm <sup>2</sup>	473 DPM/50cm <sup>2</sup>
Avg. REC	74.1 DPM/100 cm <sup>2</sup>	946 DPM/100cm <sup>2</sup>
H.P. SIGNATURE	DATE:	



APPENDIX L

HYDROGEN BUILDING

SURVEYOR: Larry Smith	SIGNATURE: <i>Larry Smith</i>	DATE: 4/2/92	FORM SERIAL NUMBER: Preliminary
-----------------------	-------------------------------	--------------	---------------------------------

BETA-GAMMA			ALPHA		GAMMA/BETA-GAMMA			ALPHA	
COUNTER NO.:	Canberra	MS-2	Canberra	SAC-4	INSTRUMENT	PAC-4G			ASP-1
BACKGROUND	.85 CPM	CPM	.20 CPM	CPM	SERIAL NO.	4478			1891
EFFICIENCY	17.1 %	%	32.6 %	%	PROBE	AC-21B			AC-3

BUILDING/AREA	FLOOR	GRID	SMEAR		GAMMA RADIATION ONE METER uR/Hour	BETA-GAMMA RADIATION CONTACT mR/Hour	BETA RADIATION CONTACT DPM/100 SQUARE CM	ALPHA RADIATION CONTACT DPM/100 SQUARE CM
			ALPHA	BETA				
HYDROGEN FACILITY	1	N/A	1	5	0	N/A	N/A	\$ Bkg. Unless
			2	0	0			specified
			3	5	0			1
			4	0	0			Efficiency: 63.4%
			5	0	0			Avg. Bkg: 1183 DPM
			6	0	0			Efficiency: 20.2%
			7	0	7			Per 100 cm <sup>2</sup>
			8	0	0			Per 100 cm <sup>2</sup>
			9	0	0			
			10	0	42			
			11	0	0			99
			12	0	7			\$ BKG
			13	0	0			
			14	5	0			
			15	5	0			
			16	0	42			
			17	0	0			
			18	0	7			
			19	0	0			

SHEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

SURVEYOR: Larry Smith

**SIGNATURE**

DATE: 4/2/9

FORM SERIAL NUMBER: Preliminary

BETA-GAMMA			ALPHA		GAMMA/BETA-GAMMA				ALPHA	
COUNTER NO.:	Canberra	MS-2	Canberra	SAC-4	INSTRUMENT	PAC-4G				ASP-1
BACKGROUND	.85 CPM	CPM	.20 CPM	CPM	SERIAL NO.	4478				1891
EFFICIENCY	17.1 %	%	32.6 %	%	PROBE	AC-21B				AC-3


SMEAR LEVELS ARE IN UNITS OF DPM/100 SQUARE CENTIMETERS

-27-

Age 2 or 3



### ELEVATION



245

卷之三

O - DESIGNATES Success Points

