

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | P | A | B | V | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ | 5
7 8 9 14 15 25 26 57 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T
0 1 | R | E | P | O | R | T | S | O | U | R | C | E | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 3 | 4 | 7 | 0 | 7 | 1 | 8 | 7 | 7 | 8 | 1 | 2 | 2 | 2 | 7 | 8 | 9
7 8 60 61 68 69 74 75 80
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | During a review of surveillance test records, it was determined that the monthly
0 3 | test for the 1B Reactor Plant River Water (RPRW) Pump was not performed by 7/18/77
0 4 | as required. However, it was performed satisfactorily on 7/22/77.
0 5 |
0 6 |
0 7 |
0 8 |
0 9 |

0 9 | SYSTEM CAUSE CAUSE COMPONENT COMP. VALVE
CODE CODE SUBCODE CODE SUBCODE SUBCODE
W A 11 A 12 B 13 P U M P X X 14 B 15 Z 16
9 10 11 12 13 18 19 20
17 | LER/RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.
7 8 21 22 23 24 26 27 28 29 30 31 32
X 18 Z 19 Z 20 Z 21 0 0 0 0 22 N 23 N 24 A 25 B 5 8 0 26
33 34 35 36 37 40 41 42 43 44 47
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHODG HOURS ATTACHMENT SUBMITTED NPR-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 | The incident resulted from improper scheduling of the surveillance test. The
1 1 | 1A RPRW Pump was tested twice during the month while the 1B RPRW Pump was omitted.
1 2 | The surveillance tests are now being tracked on a computer program to insure proper
1 3 | scheduling of the tests.
1 4 |

1 5 | FACILITY STATUS | % POWER | OTHER STATUS (30) | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION (32)
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
E 28 1 0 0 0 29 N/A C 31 Records review

1 6 | ACTIVITY RELEASED | CONTENT OF RELEASE | AMOUNT OF ACTIVITY (35) | LOCATION OF RELEASE (36)
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
Z 33 Z 34 N/A N/A

1 7 | PERSONNEL EXPOSURE: NUMBER | TYPE | DESCRIPTION (39)
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
0 0 0 0 37 Z 38 N/A

1 8 | PERSONNEL INJURIES: NUMBER | DESCRIPTION (41)
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
0 0 0 0 40 N/A

1 9 | LOSS OF OR DAMAGE TO FACILITY: TYPE | DESCRIPTION (43)
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
Z 42 N/A

2 0 | PUBLICITY ISSUED: DESCRIPTION (45)
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
N 44 N/A

781229 0227