U. S. NUCLEAR REGULATORY COMMISSION

UPDATE REPORT: Previous Report Date 1-3-83

LICENSEE EVENT REPORT

	CONTROL BLOCK: (PLEASE PRINT OR TY"E ALL REQUIRED INFORMATION)
0 1	I I A D A C 1 2 0 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 1 1 3 37 CAT 54 3
OII	SOURCE (0) (0) (0) (0) (0) (0) (0) (0) (0) (0)
0 2	During normal operation, air was discovered leaking from the air start r
0 3	egulator located on the crankcase of the 'A' standby diesel generator (D
0 4	/G), 1G-31. Although the air leak would not have kept the D/G from start
0 5	ing in the required 10 sec, 1G-31 was declared inoperable for repairs. R
0 6	edundant 1G-21 was operable. A 7-day LCO was entered for approximately 3
0 7	hours per T.S.3.5.G.1. There have been no previous similar occurrences.
0 8	2
0 9	SYSTEM CAUSE CODE SUBCODE COMPONENT CODE SUBCODE SUBCO
	1) REPORT NO. 10 7 8 2 1 1 1 1 1 1 1 1 1
	TAKEN ACTION ON PLANT METHOD HOURS 22 SUBMITTED FORM SUB. SUPPLIER MANUFACTURER MAN
	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0	Air leaking from flared end of 3/8 inch air inlet line. Tubing was broke
1 1	n at the flare by normal D/G vibration and the weakening effects of flar
1 2	ing. Flare removed and tubing reflared. Similar connection on 1G-21 chec
1 3	ked, found sat. Connections on 1G-21 and 1G-31 to be checked next refuel
1 4	Design Review initiated to determine any additional corrective action.
1 5	STATUS OTHER STATUS OF DISCOVERY DESCRIPTION (32) [E] (38) [O] 9 1 (39) NA [C] (37) INPO Visual Inspection 30 10 12 13 14 15 15 15 15 15 15 15
	ACTIVITY CONTENT RELEASE OF RELEASE AMOUNT OF ACTIVITY 35 NA PERSONNEL EXPOSURES NA NA NA NA NA NA NA NA NA N
7 8	O O O O O O NA
14	O O O O NA
1 9	COSS OF ON DAWAGE TO PACILITY 43 TYPE DESCRIPTION Z 42 NA PDR 10 NA PDR 2 10 NA PDR 3 10 PDR 4 PDR 5 PDR 6 PDR 7 PDR 8 PDR 9 PDR 10 PDR
20	PUBLICITY ISSUED DESCRIPTION 45 NRC USE ONLY NRC USE ONLY NRC USE ONLY SECONDARY OF SECONDARY NRC USE ONLY SECONDARY NRC USE ONLY
	NAME OF PREPARER Kimuel L. Hill PHONE: 319-851-5611