

**Diesel Generator Building & Annex
Yankee Nuclear Power Station
Structural Analysis Report**

**For: Yankee Atomic Electric Company
By: Cygna Energy Services**




8301170542 830111
PDR ADOCK 05000029
P PDR

Job No. 80023
Report No. EY-YR-80023-8
January, 1983
Rev. 2

Diesel Generator Building and Annex
Yankee Nuclear Power Station
Rowe, Massachusetts

Prepared by: 
J. K. Kacyrat

Reviewed by: 
Jose Vallenias

Approved by: 
Eric van Stijgeren




TABLE OF CONTENTS

	<u>Section</u>	<u>Page</u>
I.	EXECUTIVE SUMMARY.....	1
	I.1 Purpose	1
	I.2 Scope	1
	I.3 Conclusion.....	1
II.	DESCRIPTION OF STRUCTURE.....	2
	II.1 Diesel Generator Building.....	2
	II.2 Annex	3
III.	PERFORMANCE CRITERIA.....	4
	III.1 Materials.....	4
	(a) Steel Frames.....	4
	(b) Diagonal and K-Braces.....	4
	(c) Shear Walls in Annex.....	4
	III.2 Earthquake Loadings.....	5
IV.	ANALYSIS PROCEDURES.....	6
	IV.1 General	6
	IV.2 Computer Programs.....	6
	IV.3 Assumptions.....	6
	IV.4 Mathematical Models.....	7
	IV.4.1 Horizontal Models.....	7
	IV.4.2 Vertical Models.....	7



TABLE OF CONTENTS (cont'd.)

<u>Section</u>	<u>Page</u>
V. STRUCTURAL CHARACTERISTICS AND ANALYTICAL RESULTS.....	9
V.1 Structural Characteristics.....	9
V.2 Analytical Results for NRC Spectrum.....	9
VI. SUMMARY OF REVIEW.....	11

APPENDICES

- A. Building Plans (DGB & Annex)
- B. Computer Models
- C. Earthquake Spectrum
- D. Table of Frequencies, Mode Shape and Participation Factors
- E. Summary of Stresses and Displacements
- F. References



I. EXECUTIVE SUMMARY

I.1 Purpose

The purpose of this report is to summarize the results of the structural analyses performed by Cygna Energy Services (Cygna) for Yankee Atomic Electric Company (YAEC). The results described in this report pertain to the Diesel Generator Building (DGB) and the newly-built and attached Annex at the Yankee Nuclear Power Station (YNPS) at Rowe, Massachusetts.

I.2 Scope

As requested by YAEC, Cygna has performed detailed structural analysis of the existing DGB and Annex with minor modification. These analyses were based on the following input data for YNPS:

- Structural drawings of existing DGB (See Appendix A)
- Structural drawings of new Annex
- Design Criteria (See Section III)
- Seismic ground motion (See Appendix C)

I.3 Conclusion

After attaching the new Annex to the DGB, the DGB will be able to withstand Dead Load and Live Load (DL+LL) plus the Yankee Composite Spectrum (YCS) or the Nuclear Regulatory Commission (NRC) spectrum loads with minor modifications for load paths and member strengthening.



II. DESCRIPTION OF STRUCTURE

II.1 Diesel Generator Building

The DGB was originally constructed of braced steel frames and it is structurally connected to the north-west corner of the Primary Auxiliary Building as shown in Figs. A.1 through A.11. Outside the steel frames, the building is enclosed by unreinforced concrete block walls. The building consists of three parts: the Main Structure, the Accumulator Tank Room and the Nitrogen Storage Tank Supporting Frame. The weight of the entire building excluding the Annex is 388 kips.

The original Main Structure is "L" shaped and has one level. The dimensions of the Main Structure are 36'-2" x 24'-0" between Column Lines 102 and 104 and 32'-0" x 60'-0" between Columns Lines 104 and 105. The height of the structure is 14'-3".

The Accumulator Tank Room is located between Column Lines 101 and 102. It has three levels with heights from top to bottom equal to 9'-1 1/2", 10'-0" and 14'-3", respectively. The dimensions of this room are 10'-4" x 14'-6".

The Nitrogen Storage Tank Supporting Frame is connected to the roof of the Main Structure and its top extends 12'-2" above the roof of the Main Structure. It has dimensions of 17'-0" x 13'-10".

As indicated in Figs. A.4 and A.5, the column-to-foundation connections and the beam-to-column connections cannot resist moment. Therefore, the lateral stiffness of the main structure is provided mainly by the recently added Annex as shown in Fig. A.9. The lateral stiffness of the Accumulator Tank Room and the Nitrogen Storage Tank Supporting Frame is provided by "X" and single diagonal braces.



II.2 Annex

In 1982 the Annex, measuring 36'-0" x 17"-0", was added to the northern side of the DGB between column lines 103, 104, X and Y. The annex is composed of a reinforced concrete slab roof supported on reinforced blockwalls as shown in Fig 9. The foundation is primarily a reinforced concrete grade beam. The annex is structurally connected to the DGB along the roof slab. Thus the walls of the Annex will resist lateral forces developed in the DGB.



III. PERFORMANCE CRITERIA

III.1 Materials

(a) Steel Frames


Except for the diagonal braces, the stress developed in structural steel members is limited by the allowable stresses specified in the Part 1 of the AISC Specifications [2]. The 1/3 increase in the allowable stresses when the seismic loading is combined with other loads (Section 1.5.6 of the AISC Specification) was also employed.

(b) Diagonal and K-Braces

The diagonal braces are made of slender members. This reduces significantly the capacity of these braces to resist compression. For a pair of X-braces, it was assumed that only the tension member is effective in resisting the loads. More specifically, the combined tension and compression stresses in a pair of X-braces shall not exceed $1.33 \times 0.6 f_y = 26.4$ ksi. For a single diagonal brace or a K-brace, the maximum stress shall be limited by the allowable compression stress as discussed in Item (a).


(c) Shear Walls in Annex

The 12" reinforced blockwalls of the Annex are assumed to act as shearwalls in resisting most of the lateral forces developed in the DGB. The allowable stresses conform to the requirement of UBC (1979) Reinforced Masonry Design provisions for walls where special inspection is required [2].



III.2 Earthquake Loadings

The DGB and Annex were analyzed for the Yankee Composite Spectrum (YCS) and NRC Spectrum with 7% critical damping ratio (Fig. C.1). Each spectrum was applied in two horizontal directions and it was scaled down to two-thirds of the original magnitude when applied in the vertical direction. The stresses introduced by the spectrum applied in two horizontal directions are combined by the SRSS method and those introduced by the vertical spectrum are added to the horizontal results by the absolute sum method.



IV. ANALYSIS PROCEDURES

IV.1 General

The DGB and interconnected Annex were analyzed without considering the stiffness of the unreinforced concrete block walls. The DGB building and the Annex were modeled together since structurally they form one unit. The modeled structure was then analyzed using the YCS and NRC response spectra.


The Accumulator Tank, which is structurally independent of the building, was analyzed separately.

IV.2 Computer Programs

Two computer programs were used to perform the analyses. BATS [3] and SAP IV [5] computer programs were used to run the response spectra analyses.

IV.3 Assumptions

1. The dynamic analysis of the model was carried out assuming that the DGB and the Annex form one unit structurally. This was achieved by connecting the Annex to the DGB in the X and Y directions.
2. The concrete blockwalls (reinforced) were assumed to be acting as shear walls to carry most of the lateral forces generated in the DGB.
3. In order for the Annex to act efficiently in resisting lateral forces generated in the DGB, the DGB roof will have to act as a rigid diaphragm. This is possible only if horizontal X-braces are introduced in the roof as modifications; this was assumed in the model. Also, since the Annex is weaker in the X-direction due to large unavoidable opening, and in order to avoid larger drift, more braces have to be



introduced in the Nitrogen and Accumulator towers. These are assumed in the model.

4. As shown in Detail B of Fig. A.4, the 1-1/2" hole along X-direction was provided for the 3/4" diameter bolts which connect the steel beam to the reinforced concrete wall of the Primary Auxiliary Building. Therefore, it was assumed that the reinforced concrete wall of the Primary Auxiliary Building provides only the vertical but not lateral support to the steel beam of the DGB. For this reason, the seismic analyses of the DGB and Annex was made independently of the Primary Auxiliary Building.

IV.4 Mathematical Models

IV.4.1 Horizontal Models


The horizontal model of the DGB and interconnected Annex is shown in Figs. B.1 to B.6. This model was used to study the responses of the building to the horizontal earthquake loads.

The horizontal model of the Accumulator Tank is shown in Fig. B.7. It is a simple stick model with only one column line and three levels.

IV.4.2 Vertical Models

The vertical model of the DGB is shown in Fig. B.8. This model was used to study the responses of the building to the vertical earthquake loads.

BATS computer program cannot handle the motion in the vertical direction. Therefore, the vertical model was turned in the horizontal direction as shown in Fig. B.8. As shown in this figure, Springs K1 through K4 represent the axial stiffness of the columns located in the corre-



sponding column lines. The dummy column indicated has zero stiffness.

The vertical model for the Nitrogen Storage Tank Supporting Frame is shown in Fig. B.9. Similarly, this model was turned in the horizontal direction. The dummy columns indicated have also zero stiffness.

The vertical model for the Accumulator Tank is similar to the horizontal model shown in Fig. B.7 except it was turned in the horizontal direction. The column elements used in the horizontal model were replaced by the spring elements in the vertical model.



V. STRUCTURAL CHARACTERISTICS AND ANALYTICAL RESULTS

V.1 Structural Characteristics

The first twenty modes of the DGB and interconnected Annex were included in the dynamic analysis. Table D.1 shows the frequencies and mode shapes of these twenty modes. From Table D.1, the fundamental frequency of the structure is equal to 3.5 Hz. This frequency is an improvement over the frequency of the DGB without the Annex connected to it, since it was estimated to be very low. The cumulative percent mass of the first twenty modes is almost equal to 100% in the X and Y directions. Therefore, it can be concluded that the first twenty modes are sufficient to accurately study the dynamic responses of the structure.


The horizontal model of the Accumulator Tank has three degrees of freedom. The characteristics of the first three modes of the tank are shown in Table D.3.

Table D.4 shows the dynamic characteristics of the vertical models. For all the structures analyzed, 100% of the cumulative percent mass has been accounted for.

V.2 Analytical Results for NRC Spectrum

The results of the dynamic analysis of the DGB and interconnected Annex under dead load, live load and NRC spectrum loads are shown in Tables E.1 through E.3. Under this loading condition, and with the Annex and minor modifications, stresses in all members of the existing building are within the allowables.

The maximum displacements at selected points of the structure under the NRC spectrum loads are shown in Table E.3. The maximum X-displacement at Column



Lines X and 105 of Level 1 due to translational and torsional movement is 0.27" and the corresponding story drift index is 0.016. The maximum Y-displacement is also 0.28" at Lines Z and 105 and corresponds to the same drift which is less than the maximum allowable index of 0.005 h as specified in Section 2312(h) of the 1979 UBC [2].



VI. SUMMARY OF REVIEW


1. The fundamental frequency of the DGB with the Annex is 3.5 Hz. The displacements are within acceptable magnitudes and the stresses within specified allowable.
2. Under dead load, live load, YCS or NRC spectrum loads, stresses in members of the existing building and drift are within acceptable limits with minor modifications. Minor modifications required are as follows:
 - a. Horizontal X-braces to achieve rigid diaphragm action of the roof of the DGB.
 - b. Vertical bracing in the Nitrogen Tower and Accumulator Building.
3. Existing connections can withstand the forces developed under DL, LL, and YCS or NRC spectrum loads.
4. As far as the Foundations are concerned, the bearing pressure is found to be within the allowables for YCS or NRC spectrum loading.



APPENDIX A











BUILDING PLANS

<u>Figure No.</u>	<u>Contract Drawing No.</u>
Fig. A.1	S&W DWG 9699-FA-19A
A.2	-20A
A.3	-21A
A.4	FS-25A
A.5	FS-25B
A.6	FC-63A
A.7	FC-63B
A.8	FC-63C
A.9	SPD 81061-U1
A.10	SPD 81061-S1
A.11	SPD 81061-A1



DOOR SCHEDULE

DOOR										FRAME		GENERAL	
NO.	GROUP	TYPE	SIZE	FIN.	HT.	WT.	SW.	HT.	WT.	SECTION	LOCATION	REMARKS	
1	H.M.	D	1'8" x 6'8"	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"	H-1	DOOR FROM OFFICE TO STAIR		
2	H.M.	D	1'8" x 6'8"	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"	H-2	DOOR FROM OFFICE TO STAIR		
3	H.M.	D	1'8" x 6'8"	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"	H-3	DOOR FROM OFFICE TO STAIR		
4	H.M.	D	1'8" x 6'8"	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"	H-1	DOOR FROM OFFICE TO STAIR		
5	H.M.	D	1'8" x 6'8"	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"	H-2	DOOR FROM OFFICE TO STAIR		
6	H.M.	D	1'8" x 6'8"	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"	H-3	DOOR FROM OFFICE TO STAIR		
7	H.M.	D	1'8" x 6'8"	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"	H-1	DOOR FROM OFFICE TO STAIR		
8	H.M.	D	1'8" x 6'8"	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"	H-2	DOOR FROM OFFICE TO STAIR		
9	H.M.	D	1'8" x 6'8"	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"	H-3	DOOR FROM OFFICE TO STAIR		
10	H.M.	D	1'8" x 6'8"	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"	H-1	DOOR FROM OFFICE TO STAIR		




HARDWARE SCHEDULE

ALL HARDWARE TO BE FURNISHED BY OTHERS UNLESS SPECIFIED OTHERWISE.


SYMBOL	DESCRIPTION
A	1-1/2" DIA. BRASS BUSHING - 1/2" DIA. x 1-1/2" LONG
B	1-1/2" DIA. BRASS BUSHING - 1/2" DIA. x 1-1/2" LONG
C	1-1/2" DIA. BRASS BUSHING - 1/2" DIA. x 1-1/2" LONG
D	1-1/2" DIA. BRASS BUSHING - 1/2" DIA. x 1-1/2" LONG
E	1-1/2" DIA. BRASS BUSHING - 1/2" DIA. x 1-1/2" LONG
F	1-1/2" DIA. BRASS BUSHING - 1/2" DIA. x 1-1/2" LONG

MISC. DETAILS & SCHEDULES
DIESEL GENERATOR BUILDING
POWER STATION
YANKEE ATOMIC ELECTRIC COMPANY
ROWE, MASS.
SPONSOR & CONTRACTOR'S COOPERATION
DIESEL UNIT
GC 9699 FA 21A



Yankee Atomic Electric Company
Diesel Generator Building and Annex
80023; Report No. EY-YR-80023-8; Rev. 2


FIG. A.3




NO.	REVISION	DATE	BY	DESCRIPTION
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				

Yankee Atomic Electric Company
Diesel Generator Building and Annex
80023; Report No. EY-YR-80023-8; Rev. 2

FIG. A.6





NOTES:


- SCALE AS NOTED
- GENERAL NOTES RC-60A
- SLAB TO BE SUPPORTED ON WELL COMPACTED GRAVEL OR MATERIAL HAVING A MINIMUM BEARING VALUE OF 5000 LB PER SQ FT.
- PROVIDE BREAKABLE JOINT FILLER BETWEEN EXISTING & NEW CONSTRUCTION.
- ANCHOR BOLT SCHEDULE RC-60C
- FIELD TO PROVIDE ADEQUATE PROTECTION FOR EXISTING DUCTS & ELECTRICAL DUCTS DURING CONSTRUCTION SUBSTRUC THAT SOIL UNDER DUCTS IS NOT DISTURBED.
- ALL DISTURBED & LOOSE SOIL UNDER STRUCT FLOOR (SUCH AS MAY OCCUR WHERE A LARGE BOLLER IS REMOVED) SHALL BE EXCAVATED WITH SIDE SLOPES NOT STEEPER THAN 45° AND THE DISTURBED AREA BACKFILLED TO FOOTING GRADE WITH LEAN MIX CONCRETE.

FOUNDATION PLAN & DETAILS-SH.2
DIESEL GENERATOR BUILDING
 POWER STATION
YANKEE ATOMIC ELECTRIC COMPANY
 ROWE, MASS.
 BEYER & WHITNEY ENGINEERING CORPORATION
 9699 FC-63B

Yankee Atomic Electric Company
 Diesel Generator Building and Annex
 80023; Report No. EY-YR-80023-8; Rev. 2


FIG. A.7





Yankee Atomic Electric Company
 Diesel Generator Building and Annex
 80023; Report No. EY-YR-80023-8; Rev. 2

FIG. A.8




NO.	81061	SPD81061-U1	1
PROJECT	YANKEE ATOMIC POWER STATION		
CLIENT	ATOMIC ENERGY COMMISSION		
DESIGNER	GENERAL ELECTRIC COMPANY		
DATE	MAY 1964		
SCALE	AS SHOWN		
BY	[Signature]		
CHECKED BY	[Signature]		
APPROVED BY	[Signature]		

- 1. FOUNDATION PLAN FOR DIESEL GENERATOR BLDG. AND ANNEX.
- 2. FOUNDATION PLAN FOR DIESEL GENERATOR BLDG. AND ANNEX.
- 3. FOUNDATION PLAN FOR DIESEL GENERATOR BLDG. AND ANNEX.
- 4. FOUNDATION PLAN FOR DIESEL GENERATOR BLDG. AND ANNEX.
- 5. FOUNDATION PLAN FOR DIESEL GENERATOR BLDG. AND ANNEX.
- 6. FOUNDATION PLAN FOR DIESEL GENERATOR BLDG. AND ANNEX.
- 7. FOUNDATION PLAN FOR DIESEL GENERATOR BLDG. AND ANNEX.
- 8. FOUNDATION PLAN FOR DIESEL GENERATOR BLDG. AND ANNEX.
- 9. FOUNDATION PLAN FOR DIESEL GENERATOR BLDG. AND ANNEX.
- 10. FOUNDATION PLAN FOR DIESEL GENERATOR BLDG. AND ANNEX.

Yankee Atomic Electric Company
 Diesel Generator Building and Annex
 80023; Report No. EY-YR-80023-8; Rev. 2



FIG. A.9



Yankee Atomic Electric Company
 Diesel Generator Building and Annex
 80023; Report No. EY-YR-80023-8; Rev. 2



APPENDIX B

COMPUTER MODELS



Yankee Atomic Electric Company
Diesel Generator Building and Annex
80023; Report No. EY-YR-80023-8; Rev. 2




FIGURE B-1

MODEL NODAL POINTS GROUND LEVEL ELEV. 1022'11"



Yankee Atomic Electric Company
 Diesel Generator Building and Annex
 80023; Report No. EY-YR-80023-8; Rev. 2








FIGURE B-2



MODEL NODAL POINTS LEVEL @ ELEV. 1037'4½" (ROOF)



Yankee Atomic Electric Company
 Diesel Generator Building and Annex
 80023; Report No. EY-YR-80023-8; Rev. 2



Accumulator Tower



Nitrogen Tower

FIGURE B-3

MODEL NODAL POINTS FOR ACCUMULATOR & NITROGEN TOWERS



Yankee Atomic Electric Company
 Diesel Generator Building and Annex
 80023; Report No. EY-YR-80023-8; Rev. 2




FIGURE B-4

MODEL MEMBERS BELOW EL. 1037'4½" (ROOF)



Yankee Atomic Electric Company
 Diesel Generator Building and Annex
 80023; Report No. EY-YR-80023-8; Rev. 2




FIGURE B-5

MODEL MEMBERS OF NITROGEN TOWER AND ACCUMULATOR TOWER



Yankee Atomic Electric Company
 Diesel Generator Building and Annex
 80023; Report No. EY-YR-80023-8; Rev. 2




FIGURE B-6
 REVISED NODEL OF WALL ON LINE X







FIG. B.7 HORIZONTAL AND VERTICAL MODEL OF ACCUMULATOR TANK



Yankee Atomic Electric Company
 Diesel Generator Building and Annex
 80023; Report No. EY-YR-80023-8; Rev. 2



NOTE: Accumulator storage tank is not included.

LEGEND: (TYPICAL)



-  COLUMN LINE NO.
-  BEAM NO.

FIG. B.8 VERTICAL MODEL OF DIESEL GENERATOR BUILDING



Yankee Atomic Electric Company
 Diesel Generator Building and Annex
 80023; Report No. EY-YR-80023-8; Rev. 2





FIG. B.9 VERTICAL MODEL OF NITROGEN STORAGE TANK SUPPORTING FRAME



Yankee Atomic Electric Company
 Diesel Generator Building and Annex
 80023; Report No. EY-YR-80023-8; Rev. 2

APPENDIX C

EARTHQUAKE SPECTRUM



Yankee Atomic Electric Company
Diesel Generator Building and Annex
80023; Report No. EY-YR-80023-8; Rev. 2

- ① NRC SPECTRUM,
- ② YANKEE COMPOSITE SPECTRUM,

PGA = 0.19G, DAMPING = 7%

PGA = 0.10G, DAMPING = 7%





FIG. C.1 EARTHQUAKE SPECTRA



Yankee Atomic Electric Company
 Diesel Generator Building and Annex
 80023; Report No. EY-YR-80023-8; Rev. 2

APPENDIX D

TABLE OF FREQUENCIES, MODE SHAPE
AND PARTICIPATION FACTORS



Yankee Atomic Electric Company
Diesel Generator Building and Annex
80023; Report No. EY-YR-80023-8; Rev. 2

TABLE D.1

FREQUENCIES OF DGB & ANNEX

MODE NUMBER	FREQUENCY (CYCLES/SEC)	PERIOD (SEC)
1	0.3499E 01	0.2858E 00
2	0.3515E 01	0.2845E 00
3	0.4561E 01	0.2193E 00
4	0.5082E 01	0.1968E 00
5	0.5130E 01	0.1949E 00
6	0.5205E 01	0.1921E 00
7	0.6126E 01	0.1632E 00
8	0.6582E 01	0.1519E 00
9	0.6897E 01	0.1450E 00
10	0.7699E 01	0.1299E 00
11	0.7902E 01	0.1266E 00
12	0.8423E 01	0.1187E 00
13	0.8754E 01	0.1142E 00
14	0.9937E 01	0.1006E 00
15	0.9966E 01	0.1003E 00
16	0.1101E 02	0.9079E-01
17	0.1103E 02	0.9066E-01
18	0.1218E 02	0.8208E-01
19	0.1233E 02	0.8107E-01
20	0.1338E 02	0.7476E-01




TABLE D-3

DYNAMIC CHARACTERISTICS OF HORIZONTAL MODEL OF
ACCUMULATOR TANK

Mode No.	Frequency (Hz)	Modal Mass (lb-sec ² /in)	Percent Mass (%)	Cumulative Percent Mass (%)
1	15.7	1.543	81.1	81.1
2	56.8	0.352	18.5	99.6
3	115.5	0.007	0.4	100.0



TABLE D-2

MODAL PARTICIPATION FACTORS

MODE	X-DIRECTION	Y-DIRECTION	Z-DIRECTION
1	-0.4028E-01	0.1076E 00	0.2317E-03
2	-0.2918E-03	0.4215E-02	-0.4250E-05
3	0.7175E 00	-0.1888E 00	-0.8835E-02
4	-0.2214E 00	0.1202E 00	0.3062E-02
5	0.3006E-01	0.2300E-01	0.9736E-03
6	0.6482E-01	0.6180E-01	0.1779E 00
7	0.3135E-01	0.1190E-01	-0.3912E-03
8	-0.3323E 00	-0.6898E 00	-0.3530E-02
9	0.4364E 00	0.1927E 00	-0.2079E-01
10	-0.2412E 00	0.2636E 00	-0.3955E-01
11	-0.6544E-01	0.1231E 00	-0.1524E-01
12	0.5582E 00	-0.8534E-01	0.2237E-01
13	-0.6129E 00	-0.3693E-02	-0.2576E-01
14	-0.4746E-02	0.4751E-02	-0.7767E-03
15	-0.1662E-01	-0.3623E-01	-0.1954E-02
16	-0.1720E-03	0.3073E-01	0.1242E-03
17	-0.1533E-01	0.1106E-02	-0.9279E-03
18	-0.4618E-01	-0.2835E 00	0.5103E-01
19	0.2169E-01	0.1577E-01	-0.5070E-02
20	0.5373E 00	-0.2333E 00	-0.1854E-01



TABLE D-4

DYNAMIC CHARACTERISTICS OF VERTICAL MODELS

Structure	Mode No.	Freq. (Hz)	Modal Mass (lb-sec ² /in)	Percent Mass (%)	Cumulative Percent Mass (%)
DGB Main Structure	1	13.89	237.3	27.8	27.8
	2	17.43	353.4	41.3	69.1
	3	19.33	121.1	14.2	83.3
	4	27.45	143.1	16.7	100.0
Nitrogen Storage Tank Supporting Frame	1	33.44	162.1	64.5	64.5
	2	33.44	57.3	22.8	87.3
	3	91.57	22.8	9.1	96.4
	4	91.6	2.4	1.0	97.4
	5	127.2	6.4	2.5	99.9
	6	127.2	0.3	0.1	100.0
Accumulator Tank	1	73.67	1.83	96.39	96.39
	2	198.9	0.07	3.56	99.95
	3	319.0	0.001	0.05	100.0



APPENDIX E

SUMMARY OF STRESSES AND DISPLACEMENTS



Yankee Atomic Electric Company
Diesel Generator Building and Annex
80023; Report No. EY-YR-80023-8; Rev. 2

TABLE E-1

STRESSES DEVELOPED IN COLUMNS DUE TO DL + LL + NRC

LEVEL	INTERSECTION OF COLUMN LINES	STRESSES (KSI) DUE TO			TOTAL STRESS F_T (KSI)	ALLOWABLE STRESS F_a (KSI)	STRESS RATIO F_T/F_a
		DEAD LOAD	LIVE LOAD	EQ			
1	X & 102	.16	.22	4.72	5.10	9.14	0.56
1	Y & 103	3.30	.30	3.05	6.65	9.14	0.73
1	Y & 104	3.41	.30	3.41	7.12	15.60	0.46
1	Z & 104	3.17	.16	12.09	15.42	21.44	0.72
2	Z & 103	2.69	.30	11.5	14.54	24.97	0.58
2	Y & 104	2.69	.30	14.58	17.57	24.97	0.70



Yankee Atomic Electric Company
 Diesel Generator Building
 80023; Report No. EY-YR-80023-8; Rev. 2

TABLE E-2

FORCES DEVELOPED IN DIAGONAL BRACE UNDER NRC

BRACE ELEMENT MODEL NO.	LOCATION		AREA (IN ²)	AXIAL FORCE (KIPS)	AXIAL STRESS (KSI)	ALLOWABLE TENSILE STRESS F _T (KSI)	STRESS RATIO $\frac{\text{AXIAL STRESS}}{F_T}$
	LEVER NO.	COLUMN LINE					
114*	3	2-103	1.88	12.43	6.61	31.35	0.21
121*	2	X-101	1.78	23.9	13.43	31.35	0.43
121A**	2	X-102	1.78	23.9	13.43	31.35	0.43
124*	2	102-Y	1.78	18.3	10.28	31.35	.33
124A**	2	102-X	1.78	18.3	10.28	31.35	.33

* EXISTING DIAGONAL BRACE

** PROPOSED DIAGONAL BRACE REQUIRED TO FORM X-PAIR



Yankee Atomic Electric Company
 Diesel Generator Building
 80023; Report No. EY-YR-80023-8; Rev. 2

TABLE E-3

MAXIMUM DISPLACEMENT OF CERTAIN
MODEL NODES UNDER NRC

STRUCTURE	NODE NO.	MAXIMUM X-DISPLACEMENT (IN)	MAXIMUM Y-DISPLACEMENT (IN)
MAIN STRUCTURE	17	0.18	0.12
	18	0.18	0.00
	24	0.20	0.28
	38	0.27	0.27
	43	0.03	0.26
NITROGEN TOWER	72	0.36	0.11
	73	0.36	0.15
ACCUMULATOR TANK	62	0.36	0.36



APPENDIX F

REFERENCES



Yankee Atomic Electric Company
Diesel Generator Building and Annex
80023; Report No. EY-YR-80023-8; Rev. 2

APPENDIX G

REFERENCES

1. "Seismic Reevaluation and Retrofit Criteria for Yankee Nuclear Power Station, Rowe, Massachusetts," Cygna Energy Services, Inc., Aug, 1982.
2. "Uniform Building Code," 1979 Edition.
3. "Manual of Steel Construction," Eighth Edition, AISC, 1980.
4. Ozdemir, H., and P. Lau "BATS, A Computer Program for Analysis of Multistory Frame and Shear Wall Building Systems," Earthquake Engineering Systems, Inc., February, 1980.
5. Bathe, K., E. L. Wilson, and F. E. Peterson "SAP IV, A Structural Analysis Program for Static and Dynamic Response of Linear Systems," Earthquake Engineering Research Center, University of California, Report # EERC 73-11, 1974 Revision.

