

JAN 12 1983

DISTRIBUTION:

Docket File

NRC PDR
Local PDR
NSIC
PRC

Docket Nos.: 50-416/417

Mr. James P. McGaughy, Jr.
Assistant Vice President
Mississippi Power & Light Co.
P. O. Box 1640
Jackson, Mississippi 39205

LB#2 File
DHouston
EHylton
Region II
ELJordan, DEQA:IE
JMTaylor, DRP:IE
Wagner, OELD
ACRS (16)

Dear Mr. McGaughy:

Subject: Request for Additional Information - Past Due Submittals

During the review of input for the forthcoming Supplement to the Grand Gulf Safety Evaluation Report, we have become aware that certain information submittals requested from MP&L are past due. Most of these submittals fail to meet a schedule set and committed to by MP&L. Some of the information is required to close out full power issues while some is to be reviewed during the first operating cycle. You should review the issues listed below and plan to provide submittals to us on a schedule that will not impact the licensing process.

The following three information submittals are past due:

(1) Deep Draft Pumps - Trending Analysis

By letter dated August 9, 1982, MP&L committed to provide a summary of the trend analysis program for deep draft pumps by December 1982. This information was required for our review of deep draft pump reliability. The lack of this information may impact full power licensing since in this area, only low power operation has been approved.

(2) Humphrey's Containment Concerns

By letter dated December 3, 1982, MP&L committed to have all the information requested by the staff and their consultants submitted by the end of December 1982. At this time, responses to some of the consultant's questions have not been submitted. It appears that this information will be confirmatory in nature and not required to justify full power licensing.

8301170557 830112
PDR ADOCK 05000416
E PDR

OFFICE
SURNAME
DATE

(3) Soil Structure Interaction

During a meeting at Bechtel-Gaithersburg on July 16, 1982, MP&L committed to provide additional information on the generic methodology that justifies the use of an average acceleration of two adjacent floors for wall design. No specific schedule was established but six months should have been a sufficient time to generate this response. The information is required for our continuing review during the first operating cycle and is not required to justify full power licensing.

Please review the status of these past due submittals and provide the information on a schedule that will not impact the licensing process. If you have any questions about this request, please contact M. Dean Houston, Project Manager (301) 492-7564.

Sincerely,

A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing

cc: See next page

OFFICE	DL:LB#2/PM	DL:LB#2/BC					
SURNAME	DHouston:pt	ASchwencer					
DATE	1/18/83	1/17/83					

Grand Gulf

Mr. J. P. McGaughy
Assistant Vice President
Nuclear Production
Mississippi Power & Light Company
P. O. Box 1640
Jackson, Mississippi 39205

cc: Robert B. McGehee, Esquire
Wise, Carter, Child, Steen and Caraway
P. O. Box 651
Jackson, Mississippi 39205

Troy B. Conner, Jr., Esquire
Conner and Wetterhahn
1747 Pennsylvania Avenue, N. W.
Washington, D. C. 20006

Dr. D. C. Gibbs, Vice President
Middle South Energy, Inc.
225 Baronne Street
P. O. Box 6100
New Orleans, Louisiana 70161

Mr. John Richardson
Mississippi Power & Light Company
P. O. Box 1640
Jackson, Mississippi 39205

Mr. R. Trickovic, Project Engineer
Grand Gulf Nuclear Station.
Bechtel Power Corporation
Gaithersburg, Maryland 20760

Mr. Alan G. Wagner
Resident Inspector
Route 2, Box 150
Port Gibson, Mississippi 39150

Office of the Attorney General
Attn: William J. Guste, Jr.
Department of Justice, Suite C
7434 Parkins Road
Baton Rouge, Louisiana 70808