

05/03/82

111-8111

FACILITY/LICENSEE

NOTIFICATION

ITEM OR EVENT

REGIONAL ACTION

DIVISION OF PROJECT & RESIDENT PROGRAMS

RAIRIE ISLAND 2

TELECON FROM SRI
AND HOLD ON
5/1 & 3/82

THE LICENSEE NOTIFIED THE NRC ON 5/01/82 THAT CONTROL ROD BANKS R & D AND SHUTDOWN BANK B WOULD NOT MOVE IN RESPONSE TO NORMAL CONTROL SIGNALS. THE LICENSEE COMMENCED A SHUTDOWN BUT HELD AT 93 PERCENT POWER AFTER A PRELIMINARY ASSESSMENT INDICATED THAT CONTINUED OPERATION WAS ACCEPTABLE SINCE THE FAILURE WAS IN A NON-SAFETY RELATED AREA OF THE CONTROL ROD DRIVE MECHANISM CIRCUITRY WHICH WOULD NOT PREVENT THE RODS FROM BEING SCRAMMED. ON 5/2/82 A REVIEW OF THE EVENT BY THE ONSITE SAFETY REVIEW COMMITTEE DETERMINED THAT AN APPLICABLE TECHNICAL SPECIFICATION LCO HAD BEEN VIOLATED AND A SHUTDOWN WAS REQUIRED. THE LICENSEE DECLARED AN UNUSUAL EVENT BECAUSE OF THE SHUTDOWN AT 12:20 P.M. ON 5/02/82. SUBSEQUENT TROUBLESHOOTING INDICATED AT A PHASE B MULTIPLEXING THYRISTOR IN THE CONTROL ROD DRIVE MECHANISM FOR THE MOVABLE GRIPPER ASSEMBLIES HAD FAILED. THE FAILED THYRISTOR HAD BEEN REPLACED AND ALL NECESSARY SURVEILLANCE HAVE BEEN PERFORMED. THE LICENSEE IS PREPARING TO START UP THE REACTOR.

THE RESIDENT INSPECTORS ARE FOLLOWING THE LICENSEE'S ACTION. FOLLOWUP PER MC 2515.

PERRY 1 & 2

TELECON FROM SRI

ON FRIDAY, 4/30/82, THE UNION CONTRACT EXPIRED. INFORMATION. THE CENTRAL TRADES COUNCIL ACTING AS THE NEGOTIATION AGENT IS ATTEMPTING TO RENEGOTIATE A NEW CONTRACT. PAINTERS, CONCRETE WORKERS, AND IRON WORKERS ARE ON STRIKE PENDING A NEW CONTRACT. NO VIOLENCE OR PICKETING HAS TAKEN PLACE. THE LABORERS ARE WORKING WITHOUT A CONTRACT.

ITEM
A

8301180056 830112
PDR FDIA
SAMICK182-397 PDR