

U.S. NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT

Region I

Report No. 50-219/78-30

Docket No. 50-219

License No. DPR-16 Priority -- Safeguards Group IV
Category C

Licensee: Jersey Central Power and Light Company

Madison Avenue at Punch Bowl Road

Morristown, New Jersey 07960

Facility Name: Oyster Creek Nuclear Generating Station

Inspection at: Forked River, New Jersey

Inspection conducted: November 6-9, 1978

Inspectors: R. E. Shepherd 12-11-78
R. E. Shepherd, Physical Security Inspector date signed

L. M. McKeown 12/11/78
L. M. McKeown, Physical Security Inspector (Intern) date signed

Approved by: J. W. Bevlin 1/3/79
J. W. Bevlin, Chief, Security & Investigation date signed
Section, Safeguards Branch

Inspection Summary:

Inspection on November 6-9, 1978 (Report No. 50-219/78-30)

Areas Inspected: Routine, unannounced, Physical Protection Inspection by regional based inspectors of the implementation of the licensee's accepted Security Plan and applicable sections of 10 CFR 73.55 related to security organization; physical barriers; access controls; communication controls; detection aids; testing and maintenance; response procedures; licensee action on previously identified items of noncompliance related to physical security and follow-up on IE Circular 78-17 related to guard training records. The inspection was initiated during regular hours and involved 57 inspector-hours on site by two NRC regional based inspectors. Results: Of the nine areas inspected, no apparent items of noncompliance were identified in six areas; six apparent items of noncompliance were identified in three areas (Infraction - licensee watchman failed to pass required physical

Inspection Summary

2

examination - Paragraph 5.a; Infraction - did not control access to a vital area - Paragraph 7.a; Infraction - did not lock two exterior building doors - Paragraph 7.b; Infraction - did not exercise positive control over two licensee vehicles - Paragraph 7.c; Infraction - did not properly search contractor personnel entering protected area - Paragraph 7.d; Infraction - personnel search equipment not properly maintained - Paragraph 10).