Iowa Electric Light and Power Company

March 15, 1994 NG-94-0981

Mr. John B. Martin Regional Administrator Region III U.S. Nuclear Regulatory Commission 801 Warrenville Road Lisle, IL 60532-4351

Subject: Duane Arnold Energy Center

Docket No: 50-331 Operating License DPR-49

February 1994 Monthly Operating Report

Dear Mr. Martin:

Please find enclosed the Duane Arnold Energy Center Monthly Operating Report for February 1994. The report has been prepared in accordance with the guidelines of NUREG-0020 and distribution has been made in accordance with DAEC Technical Specifications, Section 6.11.1.c.

Very truly yours.

David Wilson

Plant Superintendent, Nuclear

Mr. Dennis Murdock

DLW/RBW/cc Enclosures File A-118d cc:

> Dir. of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Mail Station P1-137 Washington, D.C. 20555 (Orig.)

Mr. Robert Pulsifer Project Manager 1 Whiteflint North Mail Stop 13E21 11555 Rockville Pike Rockville, MD 20852

Document Control Desk INPO Records Center 1100 Circle 75 Parkway Suite 1500 Atlanta, GA 30339-3064

Mr. Steve Brown Iowa State Utilities Board Lucas State Office Building Des Moines, IA 50319

Mr. Fred Yost Director, Research Services Utility Data Institute 1700 K St. NW, Suite 400 Washington, DC 20006 Central Iowa Power Cooperative Box 2517 Cedar Rapids, IA 52406

Mr. William Loveless U.S. NRC 1 Whiteflint North Mail Stop 11C14 11555 Rockville Pike Rockville, MD 20852 (2)

Dr. William A. Jacobs, Jr. GDS Associates, Inc. Suite 720 1850 Parkway Place Marietta, GA 30068-8237

Mr. Dale Arends Corn Belt Power Cooperative 1300 13th Street North Humboldt, IA 50548

DCRC

NRC Resident Inspector

JEZY

210097

OPERATING DATA REPORT

DOCKET NO:

50-0331

DATE: Unit: 03/15/94 Duane Arnold Energy Center

COMPLETED BY: TELEPHONE: Richard Woodward

E: (319) 851-7318

OPERATING STATUS

1. Unit Name: Duane Arnold Energy Center

2. Reporting Period: February 1994

3. Licensed Thermal Power (MWth): 1658


4. Nameplate Rating (Gross MWe DER): 565.7 (Turbine)

5. Design Electrical Rating (Net MWe DER): 538

6. Maximum Dependable Capacity (Gross MWe MDC): 545

7. Maximum Dependable Capacity (Net MWe MDC): 515

 If Changes Occur in Capacity Ratings (Items Number 3 through 7) since the last report, Give Reasons: N/A



9. Power Level to Which Restricted, If Any (Net MWe): Not Applicable

10. Reasons for Restrictions, If Any: Not Applicable

		Feb-94	Year	Cummulative
11.	Hours in Reporting Period	672.0	1,416.0	167,232.0
12.	Number of Hours Reactor Was Cri.:cal	672.0	1,416.0	124,360.6
13.	Reactor Reserve Shutdown Hours	0.0	0.0	192.8
14.	Hours Generator On-Line	672.0	1,416.0	121,194.7
15.	Unit Reserve Shutdown Hours	0.0	0.0	0.0
16.	Gross Thermal Energy Generated (MWH)	1,109,658.4	2,334,521.6	166,793,085.8
17.	Gross Electrical Energy Generated (MWH)	375,360.0	790,441.0	55,870,826.5
18.	Net Electrical Energy Generated (MWH)	354,109.5	745,606.5	52,377,269.4
19.	Unit Service Factor	100.0%	100.0%	72.5%
20.	Unit Availability Factor	100.0%	100.0%	72.5%
21.	Unit Capacity Factor (Using MDC Net)	102.3%	102.2%	62.2%
22.	Unit Capacity Factor (Using DER Net)	97.9%	97.9%	59.5%
23.	Unit Forced Outage Rate	0.0%	0.0%	11.8%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of each): None Scheduled

25. If Shutdown at End of Report Period, Est. Date of Startup: (Not Applicable)

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-0331

DATE: 03/15/94
Unit: Duane Arnold Energy Center
COMPLETED BY: Richard Woodward
TELEPHONE: (319) 851-7318

MONTH February 1994

Day	Average Daily
	Power Level
	(MWe-Net)
1	528.5
2	527.8
3	528.2
4	528.7
5	528.4
6	528.0
7	529.3
8	527.4
9	529.3
10	529.9
11	528.6
12	526.9
13	528.9
14	527.9
15	528.3

Day	Average Daily
	Power Level
	(MWe-Net)
16	529.3
17	526.4
18	525.0
19	523.9
20	529.6
21	529.7
22	530.0
23	530.3
24	529.1
25	528.7
26	529.6
27	489.9
28	527.2
29	
30	
31	

DOCKET NO: 50-0331

DATE: 03/15/94

Unit: Duane Arnold Energy Center

COMPLETED BY: Richard Woodward

TELEPHONE: (319) 851-7318

UNIT SHUTDOWNS AND POWER REDUCTIONS REPORT MONTH: February 1994

(There were no shutdowns or day-to-day power reductions (greater than 20%) in February.)

Date	Type (1)	Duration (Hours)		Licensee Event Report #	System Code (4)	Comp. Code (5)	Cause

1 - F: Forced S: Scheduled

2 - Reason:

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training & License

Examination

F-Administrative

G-Operational Error

(Explain)

H-Other (Explain)

3 - Method:

1-Manual

2-Manual Scram

3-Automatic Scram

4-Continued

5-Reduce ! Load

9-Other (Explain)

4 - Exhibit G-

Instructions for Preparation of Data

Entry Sheets for Licensee Event

Report (LER) File (NUREG-0161)

5 - Exhibit 1

(Same Source)

REFUELING INFORMATION

DOCKET NO: 50-0331

DATE: <u>03/15/94</u>

Unit: Duane Arnold Energy Center

COMPLETED BY: Richard Woodward TELEPHONE: (319) 851-7318

Name of facility.

Duane Arnold Energy Center

Scheduled date for next refueling shutdown.

February 23, 1995

3. Scheduled date for restart following refueling.

April 14 - 19, 1995

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

No

5. Scheduled date(s) for submitting proposed licensing action and supporting information.

Not applicable

 Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures.

No

Current and projected fuel assemblies inventory:

THE REPORT OF THE PROPERTY OF	Number of Fuel Assemblies	Projected date of last refueling that can be discharged
currently installed in reactor core	368	n/a
previously discharged from core to Spent Fuel Storage Pool	1280	n/a
under present physical capacity of Spent Fuel Storage Pool	1898	2001
under planned capacity of Spent Fuel Storage Pool following re-racking (currently under construction)	2411	2007
under Licensed Capacity of Spent Fuel Storage Pool	3152	2014

DOCKET NO.: 50-0331

DATE: 03/15/94

Unit: Duane Arnold Energy Center

COMPLETED BY: Richard Woodward

TELEPHONE: (319) 851-7318

Monthly Operational Overview for February 1994:

As of the end of February, the DAEC has continuously operated 123 days. The only significant power reduction taken during the month was to perform a control rod sequence exchange and turbine valve testing on February 27. Forgone production during these downpowers totaled approximately the equivalent of two hours' generation.

Production and Loss Statistics for February:	Electric Output	Capacity Factor % of 565.7	Equivalent Number of Full-Power
Actual Electric Output	MWe 558.6	MWe 98.6%	Hours 663.6
Weather (gains)/losses	-3.9	-0.5%	-4.6
Turbine Valve testing, Control Rod Sequence Exchange 2/27/94	1.5	0.3%	1.8
Other Capacity MWe Losses (Operating at Average Thermal Power < 1658)	0.8	0.1%	0.9
Efficiency MWe Losses (Avg. Weather Normalized Full-Power-MWe < 565.7)	7.7	1.5%	10.3
Design Electric Output	565.7	100.0%	672.0

On February 10, 1994, during a routine surveillance test performed under extremely cold weather conditions, the "B" Control Building Standby Filter Unit (SFU) was declared inoperable due to the continued tripping of its air intake electric heater. This necessitated entry into a seven day Limiting Condition for Operation (LCO) at 0442. The cause of the tripping was a low heater sheath temperature trip setpoint. A hot water heating coil subsequently froze and ruptured on the "B" SFU, sending water and steam into the downstream filter train and delaying its return to service. At 1517 February 14, 1994 it was determined that a potential common mode failure had existed because the "A" SFU heater also had the same sheath temperature trip setpoint. The inoperability of both SFU trains required entrance into a twelve hour hot shutdown LCO. That LCO was exited when the "A" train trip setpoint was raised and the unit was returned to service at 1814 hours on February 14, 1994. Once repairs to the "B" train were completed, it was also successfully tested and then declared operable. The seven day LCO was exited at 0513 on February 15, 1994. An engineering evaluation will be performed to determine if expected reliability of the SFU system would be significantly enhanced by the elimination or restriction of water interfaces with the system. Additional testing and calibrations will be performed besides the evaluations to complete corrective actions. (LER 94-04 pending)

Licensing Action Summary:

Plant Availability:	100%	Unplanned Auto Scrams (while/Critical) this month:	()
Number of reportable events:	0	Unplanned Auto Scrams (while/Critical) last 12 months:	1