



P.O. Box 300
Seabrook, NH 03874
Telephone (603) 474-9521
Facsimile (603) 474-2987
Ted C. Feigenbaum
Senior Vice President and
Chief Nuclear Officer

NYN- 94027

March 11, 1994

United States Nuclear Regulatory Commission
Washington, DC 20555

Attention: Document Control Desk
Reference: Facility Operating License NPF-86, Docket No. 50-443
Subject: Monthly Operating Report

Gentlemen:

Enclosed please find Monthly Operating Report 94-02. This report addresses the operating and shutdown experience relating to Seabrook Station Unit 1 for the month of February, 1994 and is submitted in accordance with the requirements of Seabrook Station Technical Specification 6.8.1.5.

Very truly yours,

A handwritten signature in cursive script, appearing to read "Ted C. Feigenbaum", is written over a large, faint circular stamp or watermark.

Ted C. Feigenbaum

Enclosure

cc: Mr. Thomas T. Martin
Regional Administrator
United States Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Mr. Albert W. De Agazio, Sr. Project Manager
Project Directorate I-4
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Antone C. Cerne
NRC Senior Resident Inspector
P.O. Box 1149
Seabrook, NH 03874

9403210267 940228
PDR ADDCK 05000443
R PDR

a member of the Northeast Utilities system

JE24

OPERATING DATA REPORT

DOCKET NO. 50-443
 UNIT Seabrook 1
 DATE 03/11/94
 COMPLETED BY P. E. Nardone
 TELEPHONE (603) 474-9521
 Ext. 4074

OPERATING STATUS

1. Unit Name: Seabrook Station Unit 1
2. Reporting Period: FEBRUARY 1994
3. Licensed Thermal Power (Mwt): 3411
4. Nameplate Rating (Gross Mwe): 1197
5. Design Electrical Rating (Net Mwe): 1148
6. Maximum Dependable Capacity (Gross Mwe): 1200
7. Maximum Dependable Capacity (Net Mwe): 1150
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons: Not Applicable

9. Power Level To Which Restricted, If Any: None
10. Reasons For Restrictions, If Any: Not Applicable

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>672.0</u>	<u>1416.0</u>	<u>64609.0</u>
12. Number Of Hours Reactor Was Critical	<u>310.8</u>	<u>896.4</u>	<u>28603.5</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>953.3</u>
14. Hours Generator On-Line	<u>277.1</u>	<u>862.7</u>	<u>26539.9</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
16. Gross Thermal Energy Generated (MWH)	<u>907870</u>	<u>2905635</u>	<u>86338081</u>
17. Gross Elec. Energy Generated (MWH)	<u>313685</u>	<u>1010749</u>	<u>29984492</u>
18. Net Electrical Energy Generated (MWH)	<u>301048</u>	<u>971135</u>	<u>28794753</u>
*19. Unit Service Factor	<u>41.2</u>	<u>60.9</u>	<u>81.3</u>
*20. Unit Availability Factor	<u>41.2</u>	<u>60.9</u>	<u>81.3</u>
*21. Unit Capacity Factor (Using MDC Net)	<u>39.0</u>	<u>59.6</u>	<u>78.0</u>
*22. Unit Capacity Factor (Using DER Net)	<u>39.0</u>	<u>59.7</u>	<u>78.1</u>
*23. Unit Forced Outage Rate	<u>58.8</u>	<u>39.1</u>	<u>7.9</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): <u>REFUELING, 04/16/94, 57 DAYS</u>			
25. If Shut Down At End Of Report Period, Estimated Date Of Startup: <u>Not Applicable</u>			

*NOTE: "Cumulative" values based on total hours starting 08/19/90, date Regular Full Power Operation began.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-443
 UNIT Seabrook 1
 DATE 03/11/94
 COMPLETED BY P. E. Nardone
 TELEPHONE (603) 474-9521
 Ext. 4074

MONTH FEBRUARY, 1994

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>0</u>	17	<u>141</u>
2	<u>0</u>	18	<u>903</u>
3	<u>0</u>	19	<u>1147</u>
4	<u>0</u>	20	<u>1152</u>
5	<u>0</u>	21	<u>1152</u>
6	<u>0</u>	22	<u>1151</u>
7	<u>0</u>	23	<u>1150</u>
8	<u>0</u>	24	<u>1150</u>
9	<u>0</u>	25	<u>1150</u>
10	<u>0</u>	26	<u>1149</u>
11	<u>0</u>	27	<u>1149</u>
12	<u>0</u>	28	<u>1149</u>
13	<u>0</u>		
14	<u>0</u>		
15	<u>0</u>		
16	<u>0</u>		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-443
 UNIT Seabrook 1
 DATE 03/11/94
 COMPLETED BY P. E. Naughton
 TELEPHONE (603) 474-9521
 Ext. 4074

REPORT MONTH FEBRUARY, 1994

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	Cause & Corrective Action to Prevent Recurrence
-----	------	-------------------	---------------------	---------------------	--	-------------------------------	---

94-01	02/01/94	F	394.9	B/A	4	94-001	Automatic trip as a result of decreasing level in SG.
-------	----------	---	-------	-----	---	--------	---

A. This was caused by the slow, full closure of MSIV
 A during the performance of the quarterly 10% partial
 stroke test. See LER 94-001 for information on root
 cause and corrective action.

- | | | | | | |
|---|---------------------------|---|---|---|--|
| 1 | F: Forced
S: Scheduled | 2 | Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain) | 3 | Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Continued from
previous month
5-Power Reduction
(Duration = 0)
9-Other (Explain) |
|---|---------------------------|---|---|---|--|

DOCKET NO. 50-443
UNIT Seabrook 1
DATE 03/11/94
COMPLETED BY P. E. Nardone
TELEPHONE (603) 474-9521
Ext. 4074

REFUELING INFORMATION REQUEST

1. Name of facility: Seabrook Unit 1
2. Scheduled date for next refueling shutdown:
Refueling Outage 3, 04/16/94
3. Scheduled date for restart following refueling:
Refueling Outage 3, 06/11/94
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?
No
5. Scheduled date(s) for submitting licensing action and supporting information:
N/A
6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures:
None
7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool:
(a) In Core: 193 (b) 136
8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies:
Present licensed capacity: 1236
No increase in storage capacity requested or planned.
9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity:
Licensed capacity of 1236 fuel assemblies based on two annual and twelve eighteen-month refuelings with full core offload capability.
The current licensed capacity is adequate until at least the year 2010.