

CAUSTIC FEED DESIGN ANALYSIS  
DESIGN CHANGE 77-9  
CONTAINMENT SPRAY SYSTEM MODIFICATION  
SURRY POWER STATION- UNIT 2

THIS DOCUMENT CONTAINS  
POOR QUALITY PAGES

8006190 550 XA

## INTRODUCTION

The Containment Spray System of Surry Unit No. 2 has been modified in order to provide assurance of meeting site boundary dose limitations set forth in 10CFR part 100. These modifications involved modifications to the caustic addition system and the installation of a new spray ring header within containment along with other related changes. This report involves itself with analyzing the performance of the modified caustic addition system which with the other containment spray modifications will be capable of meeting parameters of spray pH and sump pH.

Part A demonstrates maximum and minimum spray and sump pH values versus time based on calculated data for twelve (12) scenarios utilizing different combinations of two (2) containment spray and four (4) safety injection pumps. As shown by these curves, the spray pH remains within the bounds of 8.5 to 11.0 set forth in the Standard Review Plan 6.5.2. In addition, the ultimate sump pH value is 8.2 which will enable the Recirculation Spray System to remove atmospheric radioactive iodine and prevent it from leaving the sump solution for long term considerations.

Part B of this analysis deals with the determination of Caustic Fluid Flow Rate History (CFFRH) which is derived from calculated head loss values of the caustic addition piping system and Caustic Addition Tank levels for the twelve scenarios discussed in Part A. Two ('') major considerations used during calculations flow rates were:

1. Is a restrictive flow orifice required; and if so, it must be designed to meet flow requirements which yield caustic for a spray pH range of 8.5 - 11.0 for all pumping scenarios.
2. The Caustic Addition Tank must empty completely during each of the pumping scenarios in order to take credit for the entire tank volume for ultimate sump pH considerations.

As shown by the curves of caustic flow for the twelve scenarios, the flow rate in all cases remains within the bounds of a maximum and minimum rate which would result in a spray pH of 8.5 to 11.0.

In conclusion, the new system for caustic addition will be a reliable means of adding sodium hydroxide solution to the containment spray fluid which will provide iodine removal and consequently keep site boundary dose within the limits of 10CFR part 100.

PART A

## PART A

### CONTAINMENT SPRAY SYSTEM - SURVEY #2

#### SPRAY AND SUMP pH vs. TIME HISTORIES

Figures 1-12 demonstrate that spray pH is maintained between 8.5 and 11 during each of twelve(12) scenarios utilizing combinations of four pumps for the following considerations following a design basis accident. The values of spray pH shown in these curves were developed from caustic flow histories presented in Part B. The documents from which these curves are taken are filed under Stone & Webster calculation numbers 12846.07-35 and 57 and 12846.07-pe-037-0.

Figures 1-4 Starting parameters in these scenario will maximize spray pH. (10.75 maximum scenario No. 4)

Figures 5-8 Starting parameters in these scenarios will minimize spray pH. (9.0 minimum, scenario No. 8)

Figures 9-12 Starting parameters are used which will maximize the time required to empty the caustic addition tank.  
Relating to the minimum time to empty for the RWST.  
(3860 sec. CAT vs 3975 RWST, scenario No. 11)


Figure 13 shows sump pH vs. time history after LOCA. This curve, developed from scenario 11, postulates the longest emptying time for the CAT relative to the RWST. As shown by this curve, ultimate sump pH will be 8.2.

**APPENDIX A**

**SCENARIO NO.1 ICS PUMP + IHHST + IHHST WITH MAX SPRAY pH ASSUMPTIONS**

$$\text{Orifice } H_L = 1350 \times 10^{-6} \text{ ft/CPM}^2 (+)$$


$$\text{Orifice } H_L = 1800 \times 10^{-6} \text{ ft/CPM}^2 (x)$$



APPENDIX A  
SCENARIO NO. 2 2 CS PUMPS + 2 LUSI + 2 HHSI WITH MAX SPRAY DH ASSUMPTIONS

$$\text{Orifice } H_L = 1350 \times 10^{-6} \text{ ft/cm}^2 \quad (+)$$

$$\text{Orifice } H_L = 1300 \times 10^{-6} \text{ ft/cm}^2 \quad (x)$$



**APPENDIX A**  
**SCENARIO NO. 3**

ICG PUMP + 2 LHSI + 2 HHSI WITH MAX SPRAY pH ASSUMPTIONS

Orifice  $H_L = 1350 \times 10^{-6}$  ft/ GPM<sup>2</sup> (+)

Orifice  $H_L = 1200 \times 10^{-6}$  ft/GPM<sup>2</sup> (X)




FIGURE  
3


H. E. C. 1980  
J. L. with Gifco

## APPENDIX A

SCENARIO NO. 4: 2CS PUMPS + 1 LHSI + 1 HHSI WITH MAX SPRAY pH ASSUMPTIONS

$$\text{Orifice } H_L = 1350 \times 10^{-6} \text{ Ft}/\text{GPM}^2 \quad (+)$$


$$\text{Orifice } H_L = 1800 \times 10^{-6} \text{ Ft}/\text{GPM}^2 \quad (x)$$



**APPENDIX A**  
**SCENARIO NO. 5: 1 CS PUMP + 1 LHSI + 1 HHSI WITH MIN SPRAY pH ASSUMPTIONS**

Orifice  $H_L = 1350 \times 10^{-6}$  ft/GPM<sup>2</sup> (+)

Orifice  $H_L = 1000 \times 10^{-6}$  ft/GPM<sup>2</sup> (x)



## APPENDIX

SCENARIO NO. 6: 2 CS PUMPS + 2 LHSI + 2 RHSI WITH MIN. SPRAY PH ASSUMPTIONS

Orifice  $H_L = 1350 \times 10^{-6} \text{ ft}/\text{cm}^2$  (+)

Orifice  $H_L = 1800 \times 10^{-6} \text{ ft}/\text{cm}^2$  (X)





FIGURE  
6

## APPENDIX A

SCENARIO NO. 7: 1 CS PUMP + 2 LHST + 2 MHST WITH MIN SPRAY pH ASSUMPTIONS




## APPENDIX A

SCENARIO NO. 8: 2 CS PUMPS + 1 LHST + 1 HHST WITH MIN SPRAY pH ASSUMPTIONS

$$\text{Orifice } H_L = 1350 \times 10^{-6} \text{ ft/GPM}^2 (+)$$


$$\text{Orifice } H_L = 1800 \times 10^{-6} \text{ ft/GPM}^2 (X)$$



**APPENDIX A  
SCENARIO NO. 9: ICS PUMP + 1 LUSI + 1 HRSI WITH MIN SUMP PR ASSUMPTIONS**

Orifice  $H_L = 1350 \times 10^{-6} \text{ ft}/\text{GPM}^2$  (+)


Orifice  $H_L = 1800 \times 10^{-6} \text{ ft}/\text{GPM}^2$  (X)



**FIGURE 9**


APPENDIX A  
SCENARIO NO. 10: 2 CS PUMPS + 2 LHSI + 2 RHSI WITH MIN SUMP pH ASSUMPTIONS

Orifice  $H_L = 1350 \times 10^{-6} \text{ ft}/\text{CPM}^2$  (+)  
Orifice  $H_L = 1800 \times 10^{-6} \text{ ft}/\text{CPM}^2$  (X)



**APPENDIX A**  
**SCENARIO NO. 11: 1 CS PUMP + 2 LHSI + 2 HHSI WITH MIN SUMP PH ASSUMPTIONS**

Orifice  $H_L = 1350 \times 10^{-6} \text{ ft}/\text{GPM}^2$  (+)  
 Orifice  $H_L = 1800 \times 10^{-6} \text{ ft}/\text{GPM}^2$  (x)



APPENDIX A  
SCENARIO NO. 12: 2 CS PUMPS + 1 LIQUI + 1 HSIS WITH MIN SUMP PH ASSUMPTIONS

Orifice  $H_L = 1350 \times 10^{-6} \text{ ft/cm}^2$  (+)

Orifice  $H_L = 1800 \times 10^{-6} \text{ ft/cm}^2$  (x)




FIGURE  
12

CALCULATION No. 12846.07-PE-037-0

Curve pH values vs time after LOCA

time, sec

4000

3500

3000

2500

2000


1500

1000

500

0

FIGURE 13



PART B

CONTAINMENT SPRAY SYSTEM - SURRY #2 CAUSTIC FLUID  
FLOW RATE HISTORY (CFFRH) AND CHEMICAL ADDITION  
TANK (CAT.) DRAWDOWN FOR DESIGN BASIS ACCIDENT SCENARIOS

Part B contains excerpts from Stone & Webster calculation No. 12846.07/35

"Caustic Fluid Flow Rate Histories in the Containment Spray System (Containment Spray pH Analysis"):

Calc. No. 12846.07/35 Page 4 of 26	Objective of Calculation---Page 1
Calc. No. 12846.07/35 Page 10 of 26	CFFRH Requirements ---Page 2
Calc. No. 12846.07/35 Page 12 of 26	System Schematic ---Page 3
Calc. No. 12846.07/35 Page 17 & 18 of 26	Set of Equations ---Page 4-5
Calc. No. 12846.07/35 Page 21-26 of 26	Conclusions ---Page 6-11
Calc. No. 12846.07/35 - Attach 5: Graphical representation of the caustic fluid flow rate history and chemical addition tank drawdown.	---Page 12-36

## CALCULATION SHEET

J.O./E.O./CALCULATION NO.

12846.07 / 85

REVISION

0

PAGE

41/26

AP01061

PREPARED/DATE  
Octor Faheo 5/27/00REVIEWER/CHECKER/DATE  
P. O'NEIL / 3 JUNE 00

INDEPENDENT REVIEWER/DATE

SUBJECT/TITLE

CFFRH in the Containment Spray System

DA CATEGORY/CODE CLASS

5

Objective of Calculation:

To determine the Caustic Fluid Flow Rate History (CFFRH) in the Containment Spray System for a caustic solution concentration of  $17.5\% \pm 0.5\%$ , under the following modes of operation and assumptions (accident scenarios):

SCENARIO NO	PUMPS IN OPERATION			ASSUMPTION		
	CS	LH	HH	MAX SPRAY pH	MIN SPRAY pH	MIN SUMP pH
1	1	1	1	✓		
2	2	2	2	✓		
3	1	2	2	✓		
4	2	1	1	✓		
5	1	1	1		✓	
6	2	2	2		✓	
7	1	2	2		✓	
8	2	1	1		✓	
9	1	1	1			✓
10	2	2	2			✓
11	1	2	2			✓
12	2	1	1			✓

CS = Containment Spray Pumps (s)

LH = Low Head Safety Injection Pumps (s)

HH = High Head Safety Injection Pumps (s)

## CALCULATION SHEET

6.0.1 E.O./CALCULATION NO.		REVISION	PAGE
12846.07 /35		0	10/26
PREPARED/BY	REVIEWER/CHECKER/DATE	INDEPENDENT REVIEWER/DATE	
David Fairley 5/20/80	P. O'NEIL 3 JUNE 80	QA CATERORY/CODE CLASS	

- 4 - CFERH requirements:
- At any time during caustic injection:  
 $\text{Min Allowable Flow Rate} < \text{Predicted Flow Rate} < \text{Max. Allowable Flow Rate}$   
 (Flow Rate corr. to pH=8.5) (Flow Rate corr. to pH=11.0)
  - CAT gets empty before RWST gets empty.
- Note: Max and Min Allowable Flow Rates are determined in Attachment No 1.
- 5 - Determine CFERH for all accident scenarios specified on page 4, with no restrictive orifices, to demonstrate whether or not direct suction flow from the CAT is feasible and whether or not restrictive orifices are required.
- Direct suction flow is not feasible if during caustic injection:
- $\text{Predicted Flow Rate} < \text{Min. Allowable Flow Rate}$   
 Restrictive orifices are required if:
- $\text{Predicted Flow Rate without orifices} > \text{Max Allowable Flow Rate}$

## CALCULATION SHEET

STONE &amp; WEBSTER ENGINEERING CORPORATION

4.0./W.O./CALCULATION NO.

12846.07 / 35

REVISION

0

PAGE

12/25

4501081

PREPARED/DATE

Oscar Faibis 5/29/80

REVIEWER/CHECKER/DATE

P. O'NEIL

3 JUNE 80


SUBJECT/TITLE

CFER214 in the Containment Spray System

INDEPENDENT REVIEWER/DATE

I

QA CATEGORY/CODE CLASS

Direct Suction System Schematic

## CALCULATION SHEET

STONE &amp; WEBSTER ENGINEERING CORPORATION

AB01081	P.O./E.O./CALCULATION NO. 12846.07/35	REVISION 0	PAGE 17/26
PREPARED/DATE Octav Failes 5/29/80	REVIEWER/CHECKER/DATE P. O'NEIL 3 JUNE 80	INDEPENDENT REVIEWER/DATE	
SUBJECT/TITLE CF = FRT in the Containment Quay System		DA CATEGORY/ CODE CLASS	

The set of equations is :

$$Z_{CAT}^{(0)} \rightarrow \text{known}$$

$$Z_A^{(i)} = \frac{1}{\sqrt{K_{3-2A} + x_A}} \sqrt{Z_{CAT}^{(i)} - Z_{2A} - \frac{S_{RWST}}{S_{CAT}} * E_{2A}^{(i)}} \quad (1)$$

$$Z_B^{(i)} = \frac{1}{\sqrt{K_{3-2B} + x_B}} \sqrt{Z_{CAT}^{(i)} - Z_{2B} - \frac{S_{RWST}}{S_{CAT}} * E_{2B}^{(i)}} \quad (2)$$

$$Z_{CAT}^{(i+1)} = Z_{CAT}^{(i)} - 0.0085233 * [Z_A^{(i)} + Z_B^{(i)}] * \Delta t_{min} \quad (3)$$

Notes :

- $K_{3-2A}, K_{3-2B}$  are constant parameters (head loss coef between the CAT and the function Points e.g. without the restrictive orifices -  $\text{ft}/(\text{GPM}^2)$ ); the numerical values of  $K_{3-2A}, K_{3-2B}$  are specified on pages 6 and 8.
- $x_A, x_B$  are constant parameters, (head loss coef through the restrictive orifices); numerical values of  $x_A, x_B$  are selected as described on page 11
- $Z_{2A}, Z_{2B}$  constant numerical values (see page 16) in ft.

## CALCULATION SHEET

STONE &amp; WEBSTER ENGINEERING CORPORATION

J.O./E.O./CALCULATION NO.

12046.07 / 35

REVISION

PAGE

18/26

PREPARED/DATE Oct 20, 1980	REVIEWER/CHECKER/DATE P. O'NEIL 3 JUNE 80	INDEPENDENT REVIEWER/DATE
SUBJECT/TITLE CFERTH in the Containment Spray System	QA CATEGORY/CODE CLASS	

- $S_{RWST}$ ,  $S_{CAT}$  are constant parameters (sp. gr. of the Boric Acid solution and caustic solution); numerical values as specified on pages 6 and 8.
  - $Z_{CAT}^{(0)}$  is a constant parameter (initial elevation of the caustic solution in the CAT); numerical values as specified on pages 5 and 7 in ft.
  - $\Delta t_{min}$  is a constant numerical value (integration time), selected arbitrarily  $1/3$  min., (20sec)
  - $E_{2A}(i)$ ,  $E_{2B}(i)$  are variables (pressure and kinetic energy at the junction points in Ft. of Boric Acid solution).  $E_{2A}(i)$  and  $E_{2B}(i)$  are calculated and analytically expressed in Attachment 1
- ~~~~~

## CALCULATION SHEET

STONE &amp; WEBSTER ENGINEERING CORPORATION

J.O./E.O./CALCULATION NO.

12846.07 / 35

REVISION

0

PAGE

21/26

AB010.B1

PREPARED/DATE Octave Faifer 5/30/80	REVIEWER/CHECKER/DATE P. O'NEIL 3 JUNE 80	INDEPENDENT REVIEWER/DATE
SUBJECT/TITLE CFPRH in the Containment Spray System.	QA CATEGORY/CODE CLASS I	

Conclusions:

- 1 - The "direct suction flow" method for chemical addition is feasible since without any control (orifice) the flow rates from the CAT exceed the max. allowable flow rates (See Attachment No. 5 ,  $x_4 = x_3 = 0$  cases)
- 2 - With an orifice  $x_4 = x_3 = 1575 \times 10^{-6} \text{ ft}^4/\text{GPM}^2$  the flow rates from the CAT can be kept between the min and the max. allowable flow rates, or the pH can be maintained between 8.5 and 11.0 for all accident scenarios analysed. (See Attachment 5)
- 3 - With an orifice  $x_4 = x_3 = 1575 \times 10^{-6} \text{ ft}^4/\text{GPM}^2$  the CAT will empty before the RWST, hence, under any of the accident scenarios analyzed the entire volume of caustic solution in the CAT will be pumped by the containment spray pump into the reactor containment.

Considerations regarding the sensitivity of the calculation and input data.

- 1 - Input data: The calculated flow rates and cat drawdown for each accident scenario represent max or min envelopes rather than the actual flow rates or drawdown which can be expected. All the inputs were analysed and then selected.

## CALCULATION SHEET

STONE &amp; WEBSTER ENGINEERING CORPORATION

ASD1081

S.D./W.G./CALCULATION NO.

12846.07/35

REVISION

0

PAGE

22/26

PREPARED/DATE DeFor Faubus 5/30/80	REVIEWER/CHECKER/DATE P. O'NEIL 3 JUNE 80	INDEPENDENT REVIEWER/DATE
SUBJECT/TITLE CFERH in the Containment Spray System	DA CATEGORY/CODE CLASS	

in such a way to form two sets of constant inputs, one to maximize the flow rates (pH), the other one to minimize the flow rates (pH). The inputs considered parametric in the calculation are as follows:

- The RUST initial elevation, including the instrument error
- The CAT initial elevation, including the instrument error
- Caustic solution concentration
- Caustic solution temperature
- Boric acid solution concentration

The fact that in developing the max or min. envelopes, <sup>all</sup> the parametric values were selected either to minimize or to maximize the results, is a guarantee that sufficient conservatism does exist in the results of the calculation.

## 2- Calculations

There are two parameters, namely the head loss coefficient between the RUST and the Junction Point, and the head loss coefficient between the CAT and the Junction Point which are essential in estimating the CAT flow rates and draw down. These two coefficients were

## CALCULATION SHEET

STONE &amp; WEBSTER ENGINEERING CORPORATION

S.O./W.O. / CALCULATION NO.

12846.07 / 35

REVISION

0

PAGE

23/26

PREPARED/DATE	REVIEWER/CHECKER/DATE	INDEPENDENT REVIEWER/DATE
Octave Fabes 5/30/80	P. O'NEIL 3 JUNE 80	

SUBJECT/TITLE CFFR44 in the Containment Spray System

QA CATEGORY/CODE CLASS I

analytically calculated and then verified by way of a field test (RWST-CAT Drawdown Test 4/30/80 - see Ref. 6). The results of the field test showed that the actual head losses were 2.6% greater than their analytical evaluation. In order to simplify the sensitivity analysis of the head losses, the calculation was performed with head loss coefficients between RWST and Suction Point modified, to include a margin of uncertainty of  $\pm 5\%$ , while the CAT-Suction Point head loss coefficient was kept at its calculated value. However, a sensitivity analysis of the head loss between the CAT and Suction Point shows that while the design orifice head loss coefficient is  $1575 \times 10^{-6}$  ft/gpm<sup>2</sup>, the CFFR44 requirements are met for any coefficient between  $1350 \times 10^{-6}$  ft/gpm<sup>2</sup> and  $1800 \times 10^{-6}$  ft/gpm<sup>2</sup>. The head loss coefficient of the CAT piping system without the restrictive orifice was considered parametric, between a min of  $420 \times 10^{-6}$  ft/gpm<sup>2</sup> and a max of  $520$  ft/gpm<sup>2</sup> (see pages 6 and 8). The total head loss coefficients between the CAT and Suction Point for which the CFFR44 requirements are met

## CALCULATION SHEET

STONE &amp; WEBSTER ENGINEERS INC.

A.9./B.O./CALCULATION NO.

12876.07 /35

REVISION

0

PAGE

24/26

PREPARED/DATE	REVIEWER/CHECKER/DATE	INDEPENDENT REVIEWER/DATE
Octav Faires 6/2/80	P. O'WEIL 25 JUNE 80	
CFFR4 Inlet Containment Spray System	DA CATEGORY/CODE CLASS	

are as follows:

$$\text{Max: } K = 1800 \times 10^{-6} + 520 \times 10^{-6} = 2320 \times 10^{-6} \text{ Ft/Gpm}^2$$

$$\text{Design: } K = 1575 \times 10^{-6} + 470 \times 10^{-6} = 2045 \times 10^{-6} \text{ Ft/Gpm}^2$$

$$\text{Min: } K = 1350 \times 10^{-6} + 420 \times 10^{-6} = 1770 \times 10^{-6} \text{ Ft/Gpm}^2$$

The above coefficients show that the head losses between the CAT and Function Points could vary  $\pm 13\%$  without affecting the CFFR4 requirements.

### 3 - Predicted CFFR4 and CAT drawdown

The calculated caustic flow rates and CAT drawdown are based on the set of equations shown on page 17. The set of equations models the hydraulics of the RWST and CAT drawdowns as a succession of steady state conditions since certain hydraulic parameters change gradually with time. In order to demonstrate that this analytical approach can rigorously model the CAT drawdown, a field test was performed on 4/30/80. The results of this test (see Ref 6) show that from a practical stand point there are no differences between measured and calculated values and therefore the analytical method can accurately model the CAT drawdown. However, the margin of uncertainty is

## CALCULATION SHEET

STONE &amp; WEBSTER ENGINEERING CORPORATION

J.O./W.U./CALCULATION NO.		REVISION	PAGE
10848.07 /35		0	25/26
PREPARED/DATE	REVIEWER/CHECKER/DATE	INDEPENDENT REVIEWER/DATE	
Octavio Faibis 6/2/80	3 JUNE 80		
SUBJECT/TITLE	QA CATEGORY/CODE CLASS		
CFTRH in the Containment Spray System			

of the CAT drawdown measurements was approximately  $\pm 4$  inches (Ref 6) and therefore the same margin of uncertainty can be attributed to the calculated drawdown.

Assuming that a difference between calculated and actual CAT drawdown could exist, a legitimate concern could be derived regarding the capability of the drawdown to empty the CAT before CS pump(s) shutdown. In order to analyze the criticality of this concern, scenario No 11 was selected for testing the sensitivity of the CAT drawdown possible ranges of uncertainty. (Scenario No 11 is the most critical case regarding the CAT drawdown). Under design conditions (orifice head loss coef  $1575 \times 10^{-6}$  ft/Gpm<sup>2</sup>) the CAT is almost empty at 3860 sec after the start of the accident (CAT Elevation 34.1 Ft), approximately 115 sec before the shutdown of the CS pump which occurs at time 3975 sec. If at 3860 sec the CAT is not empty, there are approximately 2 min available to eventually empty the CAT. The drawdown corresponding to an orifice of  $1800 \times 10^{-6}$  ft/Gpm<sup>2</sup> head loss coefficient shows that at 3860 sec the CAT elev is 34.9 Ft, or approximately 9.6 inches above CAT elev of 34.1 Ft and the CAT is empty at

## CALCULATION SHEET

STONE &amp; WEBSTER ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO.

12846.07 / 35

REVISION

0

PAGE

26 / 26

PREPARED/DATE Octav Faires 6/2/80.	REVIEWER/CHECKER/DATE P. O'NEIL 3 JUNE 80	INDEPENDENT REVIEWER/DATE
SUBJECT/TITLE CFF.2H in the Containment Spray System		QA CATEGORY/CODE CLASS 2

Approximately 3980 sec.

This demonstrates that even with a margin of uncertainty of 9.6 inches the CAT drawdown will not be critical, the CAT will empty before CS pump shut down, and the spray pH will be between the two 8.5 and 11.0 limits.

## CALCULATION SHEET

STONE &amp; WEBSTER ENGINEERING CORPORATION

ADN-1-107

A2010.61

J.O./W.O./CALCULATION NO.		REVISION	PAGE
12846.07 /35		0	1/25
PREPARED/DATE	REVIEWER/CHECKER/DATE	INDEPENDENT REVIEWER/DATE	
Oscar Faithes 6/5/80	P. O'NEIL 5 JUNE 80	John Sun 6/10/80	
SUBJECT/TITLE	CFFRH in the Containment Stray, Section I		
			QA CATEGORY/CODE CLASS

Graphical Representation of the Caustic Fluid  
Flow Rate History (CFRH) and  
CAT drawdown:

## 1 - CFFRH - pages 2 - 13

## Legend:

2CAT Max and Min flow rates corresponding  
to pH of 11.0 and 8.5

—○—○ Flow Rate Time History without restriction on pH  
 ——— Design Flow Rate History

•—•—• } Flow Rate Time History for sensitivity analysis  
 —□—□—□ } (Assuming  $\pm 13\%$  fluctuations maintained  
in the caustic line, and reduced reflux)


## 2 - CAT Drawdown - pages 14 - 25

## Legend:

— Design Drawdown

Case No: 12846.07/35

ATTACHMENT NO 5 PG. 2/25  
PREP: P. O'NEIL 2 JUNE 80  
REV: C. DeMonteau 4/5/80




Calc No 12546.07/35

ATTACHMENT NO 5


PREP: P. O'NEIL 2 JUNE 80

REV: C. THOMAS 5/5/80

PG 3/25



Calc. No 12846.07/35 ATTACHMENT NO 5  
PREP. P. O'NEIL : TVNED  
REV C. Leinenweber 6/5/80 P3. 4/25





H-E 1.1 TO TUE CENTILITER  
HARPER & BROTHERS CO.

461510


Calc. #8 12846.07/35

ATTACHMENT N° 5 Pg 5/25  
PREP: P. O'NEIL 2/5/80  
REV: G. Bittner 6/5/80






SCALE: 1/10 12046.07/35 ATTACHMENT NO 5 JUN 1976  
PRED. ONIC, JONES, FIG. 6/25  
REV. C. BANDWICH 6/15/80



CFERH  
NaOH CONC = 17% - 18%

Case #1 12846, 07/35 ATTACHMENT NO 5 Pg. 7/25  
P&G, P. ONTARIO, 3 June 1980  
P.P. C. T. D. D. 6/5/80

Calc. No 12846.07/35

ATTACHMENT NO 5  
PREP: P. O'NEIL SINGAPORE PG. 8/25  
REV: C Rev 15/08

Calc # 2846.07/35

ATTACHMENT NO. 5  
PREP P. O'NEIL 35 JUN 80  
REV C. Tornatore 6/15/80

pg. 9/25

AND CONC = 17% / g.

ASSUMPTIONS

SCENARIO NO. 8: E.C.S + LIHST. LIHST WITH MINQS PH

FLOW RATE: 6000

0

100

200

300

400

500

600

700

800

900

0

TIME = 12000

0

1000

2000

3000


4000

5000

(SANK, pH = 8.5)

Calc 1's 12846.07/35

ATTACHMENT JT IND 5 pg. 10/25  
PREP: P. O'NEIL 3/3/80  
REV: C. Tammone 6/5/80




Calc # 12846.07/35


ATTACHMENT NO 5  
PREP. P. O'NEIL 3/3/80 PG. 11/25  
REV C 6/5/80

NaOH CONC. = 17% - 10%

461510



ATTACHMENT NO 5  
 Calc No 12846.07/35 PREP: P. O'NEIL 3 JUNE 80 PG 12/25  
 R.F.V. C. Lawrence 6/15/80




SCENARIO NO. 12: 205+1HST+1HST WITH MAX SWING

TIME (seconds)

100  
80  
60  
40  
20

FLOWRATE (GPM)



461510

K-E IN K IS TO THE CENTIMETER 40 X 25 CM  
KODAK SAFETY FILM CO.

CFFDN

NIGHT CONG 17% 78%


Date 1/12/86 07/30

ATTACHMENT NO. 5 P. 9. 1/2/85  
PREP: RONI SOROKA REV: C. TIRMAN 1/5/86

461510

4/2/80

REC'D & CREDITED  
P. O. INLET 35000



K-E 1000 2000 3000 4000

461510

PREPARED: C. THOMAS 6/3/80  
CHECKER: P. ONGIL 3 JUN 80

SCENARIO NO. 2 : 2CS + 2LH + 2HI WITH MAX STRAY PH ASSUMPTIONS

CALC 12846.07 / 35  
ATTACH #5 PAGE 15/25

CAT INITIAL ELEVATION 71'-0"

Z

NEW ELEVATION  
39'-0"

Z

CS PUMP SHIFTDOWN  
275 ± 550

4000

3000

2000

1000


0

Z' - Elevation, ft

2-6

PREPARED: C. LEMITHROW 6/3/80  
CHECKER: P. O'NEIL 5 JUNE 80

SCENARIO No. 3: 1CS + 2LH + 2HH WITH MAX SPRAY PH ASSUMPTIONS



K+E 11-10-70 TIME CERTIFIED

461510

REVIEWED: C. E. MURKIN 6/2/80  
CHECKED: F. O'NEIL 5 JUNE 80

SCENARIO No.4 : 2CS + LH + HH WITH MAX SPRAY P/H ASSUMPTIONS

CNC 12.8% 07/35  
ATTACK 25 INCHES

CAT  
SYNTHETIC ELEV 71'-0"



MIN ELEV 34'0"

2

CS PUMP SHUTDOWN  
3150 SEC

0

20

4000

3000

2000

1000

0

28

K-E 100 TO THE FLOOR TEST

461510

INTERIOR C. L. INTERIOR 10/17/86  
CHECKER: D. O'NEIL S. LINE (A)

SCENARIO NO. 5 : 10S + 1 LH + 1 HT WITH MIN SPRAY TH ASSUMPTIONS

CALC 12846.07/35  
ATTACH #5 PAGE 10/25

CAT

INTAKE ELEV 697.4"



Z-CH-ELEVATION, FT

CS PUMP SHUTDOWN  
4600 SEC

K-E 10 X 10 TO TRUE CENTERLINE  
W.M. CO. INC. & FISHER CO.

461510

PREDATOR: C. LENTERMAN 6/3/80  
CHECKER: P. O'NEIL 5/30/80

STANAPIC, NO. 6 - 2.05 + 2LH + 2HH WITH MIN STRAY TH ASSUMPTIONS

CAC 12.846.07/35  
ATTACH #5 PAGE 325

CAT  
WIND ELEV 69° 11'

—

N.C. ELEVATION ↗

M.W. ELEV 34'.0"

CS PUMP SHUTDOWN  
3024 DEG

K-E 1000 TO 1000 CENTRAL 4000

461510

FREIGHT C CARRIER UNITS  
CHECKER: P. O'NEIL 5 JUNE 60

SCENARIO NO. 7 : ICS + 2 LH + 2 HD WITH MIN STRAY TH ASSIGNMENTS

CNC 12896.07/35  
ATTACK #5 MADE 20/25

CAT 3  
INITIAL ELEV 53° - H°

ZAR - ELEVATION, FT

CS PUMP S/HOLDOWN

4/69-388

1000 2000 3000

200

31

1000

K-E INSTRUMENTS INC. 1000 E. 10TH ST., CLEVELAND, OHIO

451510

MESSAGE: C-BENTON, 5/5/80  
CHECKER: P. ONGE 5 JUNE 80

SCENARIO NO. 8: 2CS + ILH + IHH WITH MIN STRAY PH ASSUMPTIONS

CALC /2E% 07/35  
ATTACH # 5 PAGE 2/25

CAT  $\rightarrow$  INITIAL ELEV 39'-0"

$\frac{1}{2}$

MIN ELEV 34'-0"

$\frac{1}{2}$

CG PUMP SHUTDOWN 3210 SEC

3000


2000

1000

0

Z-AT-ELEVATION, FT

32



K-E 100' FLOW CENTERED IN 100' DIA.

461510

PREDICTOR: C. INTERIOR 6/27/80  
CHECKER: P. O'NEIL 5 JUNE 80  
SCENARIO NO. 10: 200' + 214' + 244' WITH MIN SUMP TH ASSUMPTIONS

AC 12846.07/35  
ATTACH #5 PAGE 23/25

CAT INITIAL ELEV 69'-11"

$\Sigma$   
 $\Sigma$

MIN ELEV 34'-0"

$\Sigma$   
 $\Sigma$

CS PUMP SHUT DOWN

2900 500

K-E

461510

RELEASER: C. TERRINGER 07/05/80  
CHECKER: P. GALE 5 JUNE 80

1. 10S + 2 LH + 2 HH With MIN SUMP TH ASSUMPTIONS

Scenari

CALC 120066.07/35  
ATTACH #5 since 2425

CAT  
II  
INITIAL ELEV 69'-11"

MIN ELEV 36'-0"

CS PUMP SHOTDOWN

3975 525

461510

REFERENCE: C. EASTMAN  
COTRACK: P. O. NEIL  
DATE: 5/2/80  
ATTACH: 5

CEMDO NO. 2 : 205 + 1 LH + 1H WITH MIN SWIMMING ASSUMPTIONS

CALC 12846 DT / 36  
ATTACH #5 PAGE 25/25

CAT INITIAL ELEV 69' -1"

MAP ELEV 34' 0"

3105 SEC

C8 PUMP SHUTDOWN

COAST

SWD

2000

1000

0

Zcm - ELEVATION, ft

36