



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640 JACKSON, MISSISSIPPI 39205

NUCLEAR PRODUCTION DEPARTMENT

September 5, 1980

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW
Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Director

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Units 1 and 2
Docket Nos. 50-416/417
File 0260/15525/15526
PRD-80/47, Interim Report #1
Supplier Drawing Revision
Notice Program
AECM-80/207

On August 6, 1980, Mississippi Power & Light notified Mr. M. Hunt of your office of Potentially Reportable Deficiency (PRD) at the Grand Gulf Nuclear Station construction site. The deficiency concerns the inadequate control of Supplier Drawing Revision Notices (SDRN) Program. Attached is an interim report.

We expect to complete our investigation and submit a complete report by January 22, 1981.

Yours truly,

For J. P. McGaughy, Jr.
Assistant Vice President,
Nuclear Production

ATR:lb

cc: Mr. N. L. Stampley
Mr. R. B. McGehee
Mr. T. B. Conner

Mr. Victor Stello, Director ← THIS COPY FOR
Division of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

B019
5/11

8009150 301

Interim Report #1 to PRD-30/47

I. Potential Problem

Inadequate control of the Supplier Drawing Revision Notice (SDRN) Program has caused the status of affected equipment, (incorporation of SDRN's) to be indeterminate.

II. Approach to Resolution of Problem

- A. Perform investigative actions to identify nonconforming conditions; document, evaluate, and disposition each nonconformance.
- B. Review and revise procedural controls established for the SDRN Program.

III. Status of Proposed Resolution

- A. Investigative action to date has resulted in the issuance of 34 nonconformance documents. Evaluation to determine safety implications is in process.
- B. Procedures covering the control of SDRN's have been revised. In addition, a special method has been devised for SDRN review and punch listing to permit system turnover on a case by case basis.

IV. Reasons for Delay of Final Report

Investigative action has not been completed.

V. Projected Completion of Corrective Action and Submittal Date of Complete Report

Corrective Active are expected to be completed by December 18, 1980.
Submittal date of complete report is projected for January 22, 1981.