

Peach Bottom Atomic Power Station

Thermal Mapping Report No. 80-4

For

August 7, 1980

For

Thermal Monitoring Requirements

Units No. 2 and 3

Philadelphia Electric Company

3000167 434

Summary

On August 6 less than three cooling towers were in operation and river flows were less than 15,000 cfs therefore thermal plume mapping was ordered and was performed on August 7th.

The following table lists conditions on August 6, and August 7th.

Date	:	8/6/80	8/7/80
River Flow (cfs)	:	8500	7300
Heat Discharged (BTU/hr)	:	1.15×10^9	3.41×10^9
# of C.W. Pumps Operating	:	4	4
# of Cooling Towers	:	2	3
Temp Discharge Canal °F ⁽¹⁾	:	89	89
Temp State Line °F ⁽²⁾	:	-	82.6
Temp Holtwood Dam °F	:	-	86.9

(1) Bulk temperature of water discharged to Conowingo Pond from discharge canal.

(2) Temperature at State Line.

TABLE
BOAT SURVEY INFORMATION

SURVEY DATE 08/07/80

TIME:

Survey Start (EST)	0700
Status Line (EST)	0800
Survey Finish (EST)	0920

HYDRAULIC DATA:

Pond Elevation Start (Ft.)	106.67
Pond Elevation Finish (Ft.)	107.15
Natural Flow (24 hour ave., CFS)	7,300
Conowingo Inflow (24 hrs. ave., CFS)	10,300
Conowingo Dam Draft (24 hr. ave., CFS)	9,975

PBAPS Power Output:

Unit 2: Thermal (MW)	0
Electrical (MW)	-15.3
Unit 3: Thermal (MW)	3231.9
Electrical (MW)	1028.6

METEOROLOGICAL DATA:

Time (EST)	0645 0700
Air Temperature (°F)	80
Relative Humidity (%)	72
Precipitation (24 hour total, in)	0
Wind Speed (mph)	2
Cloud Cover	Hazy
Location	Boat Sta. # 7
Wind Direction	NW

WATER TEMPERATURE (SURVEY)

PBAPS Discharge	°C, (°F)	
Intake	°C, (°F)	31.7 (89.06)
Δ T	°C, (°F)	28.4 (83.12)
Pond Surface Max.	°C, (°F)	3.3 (5.94)
Min.	°C, (°F)	31.6 (88.8)
Pond Bottom Max.	°C, (°F)	28.2 (82.7)
Min.	°C, (°F)	31.8 (89.2)
No. of C.W. Pumps Operating		4
No. of Cooling Towers Operating		3

FIGURE
HORIZONTAL ISOTHERMIS
CONOWINGO POND
DATE 08-07-80
TIME 0700 - 9200

