

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
1750 Chestnut Street Tower II

October 3, 1980

Mr. James P. O'Reilly, Director  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly: S

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 1 - DOCKET  
NO. 50-259 - FACILITY OPERATING LICENSE DPR-33 - REPORTABLE OCCURRENCE  
REPORT NRC-50-259/8056 REVISION 1

The enclosed report is a supplement to my letter dated August 8, 1980,  
concerning the technical specification limit of 13.28 R<sub>w</sub>/ft for  
linear heat generation rate which was exceeded in one node. This  
report is submitted in accordance with Browns Ferry unit 1 Technical  
Specification 6.7.2.b(2).

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. R. Calhoun  
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)  
Office of Management Information and Program Control  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Director (40)  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Mr. Bill Lavalles  
Nuclear Safety Analysis Center  
Palo Alto, California 94303

Mr. R. F. Sullivan, NRC Inspector, Browns Ferry

A002  
S  
1/1

S 8010070485