

ELECTRICAL PENETRATION PROTECTION POWER CIRCUITS

(PRIMARY AND SECONDARY)

**NORTH ANNA POWER STATION - UNIT 2
VIRGINIA ELECTRIC AND POWER COMPANY**



**STONE & WEBSTER ENGINEERING CORPORATION
BOSTON, MASSACHUSETTS**

8010150594

Page No. **581**

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

Client: **VEPCO** Location: **NA - 1** Date: **1-7-80** (C. E. L. 10/10)

Project or Apparatus: **MANUFACTURING RESTRICTION** Drawn: **1-7-80** by: **[Signature]**

Drawn by: **REV 1 R/W 3-7-80** Checked: **1-7-80** by: **[Signature]**

RLW 2-8-80

POSITION	PENETRATION		LOAD	TIME-CURRENT CURVE		PRIMARY PROTECTIVE DEVICE	NOTES & COMMENTS	SECONDARY PROTECTIVE DEVICE	NOTES & COMMENTS
	TYPE	CONDUCTOR		1000/SEC	FULL LOAD AMPS				
1A-2	Va	1000MCM	Reactor Control Pump (2-RC-P-018)	Va-1	1115/894	Relay 121A0683A	Controls Breaker Positions 25B	Relay 1A068	Controls Breaker Position 25B or 25B1
1B-2	Va	2/C per phase							
1C-2	Va	1000MCM	Reactor Control Pump (2-RC-P-01C)	Va-1	1115/894	Relay 121A0683A	Controls Breaker Positions 25C	Relay 1A068	Controls Breaker Position 25C or 25C1
1D-2	Va	2/C per phase							
1E-2	Vb	1000MCM	Reactor Heat Removal Pp (2-RH-P-01A)	Vb-1	40	Relay 121A0683A	Controls Breaker Positions 25B1A	Relay 1A053A	Control Breaker Position 25B1A
2C-2	IID	2500MCM	Refueling & Maint.	N/R	N/R	Breaker Normally Open		N/R	
2B-2	IID	2/C per phase							
2E-2	IID	2-1 MCM	Welding Survey Pmp. (Inside) (2-WSP-01A)	IID-1	338	Brkr With CG-6 450A Coil LTD-100% Min., Inst - 1200%		Brkr with CG-6 450A Coil LTD-100% Min., Inst - 1200%	
2F1-2	IC	10 AWG	a. Reactor Control Manip. Crane (1-RC-CR-5) b. Fuel Transfer Control Cab (1-FTCR-52) c. RCP Picture Change Motor (1-RC-P-13)	N/R	N/R	Breaker Normally Open		N/R	
3A-2	III	2 & 6 AWG	Full Length Rods - Lifters	III-1	50	Fuse Shevmit 425X50	Typical	Breaker GE THSD 60A	
			Full Length Rods - Grippers	III-2	10	Fuse Bushman FRI-10	Typical	Breaker GE THSD 40A	
3B-2	III	2 & 6 AWG	Full Length Rods - Lifters	III-1	50	Fuse Shevmit 425X50	Typical	Breaker GE THSD 60A	
			Full Length Rods - Grippers	III-2	10	Fuse Bushman FRI-10	Typical	Breaker GE THSD 40A	
3C-2	III	2 & 6 AWG	Full Length Rods - Lifters	III-1	50	Fuse Shevmit 425X50	Typical	Breaker GE THSD 60A	
			Full Length Rods - Grippers	III-2	10	Fuse Bushman FRI-10	Typical	Breaker GE THSD 40A	
3D-2	III	2 & 6 AWG	Full Length Rods - Lifters	III-1	50	Fuse Shevmit 425X50	Typical	Breaker GE THSD 60A	
			Full Length Rods - Grippers	III-2	10	Fuse Bushman FRI-10	Typical	Breaker GE THSD 40A	

Client: VEPCO
Project: Houston Refinery
NA-A
Rev 1: 1/11/80
Rev 2: 1/14/80

DESCRIPTION	TYPE	LOAD	LOCATION	LOAD	TYPE	CONVERT	FULL LOAD AMP	PRIMARY PROTECTIVE DEVICE	NOTES & COMMENTS	NOTES & COMMENTS
48-2	110	2/0	a. 80 Air Machine Fan b. 2-W F-1012 c. Control Box Drive Mech Fan d. 2-W F-178 e. Steam Generator Support Heater (Breaker Box C-1)	110-1 110-2 110-3	110-1 110-2 110-3	110-1 110-2 110-3	20 92 50.2	Breaker with 00-6, 300A coil 125-1005 Min. (or IFCM) Int. 100A Breaker 250-150-2000A with 25-150-MA coil Breaker Weatherhouse 250-1070	See Note 2 ab 2	Breaker with 00-6, 300A coil 125-1005 Min. (or IFCM) Int. 100A Number of TSD 100A Breaker of TSD 100A
48-3	110	2/0	a. Steam Generator Support Heaters (1) Breaker Box C-1 (2) Breaker Box C-2 (3) Breaker Box C-3 b. Control Box Drive Mech Fan (2-W-F-178)	110-1 110-2 110-3	110-1 110-2 110-3	110-1 110-2 110-3	50.2 50.2 92	Breaker Weatherhouse 250-1070 --- 10 --- --- 10 --- --- 10 --- 25-150-MA coil 25-150-MA coil	See Note 2 ab 2	Number of TSD 100A --- 100 --- --- 100 --- Breaker of TSD 100A
58-2	110	4 AWG	Transformer Heaters	110-4	110-4	110-4	60 (Note 3)	Pass Choke Shunt 075-70	Typical	Pass Choke Shunt 075-70
58-3	110	4 AWG	Transformer Heaters Elevator (Note 6)	110-4	110-4	110-4	60 (Note 3)	Pass Choke Shunt 075-70	Typical	Pass Choke Shunt 075-70
58-4	110	4 AWG	Transformer Heaters Elevator (Note 6)	110-4	110-4	110-4	60 (Note 3)	Pass Choke Shunt 075-70	Typical	Pass Choke Shunt 075-70
68-2	10	14 AWG	Transformer Relief Tank (LT-220)	10-3	10-3	10-3	30 (Note 6)	Breaker 250-150-2000A Breaker 250-150-2000A Breaker Weatherhouse 250-1070 Breaker of TSD 50	Note 4: In Transformer Secondary connected cable loop for a series The loop is protected by a 2500-9 50-000A set of TSD 50A (see curve 1000-88-113-2).	Breaker of TSD 50A Breaker of TSD 50A Breaker of TSD 50A Breaker of TSD 50A

NOTE A

Client: **VEPCO**
 Project: **PROTECTOR REFINERY**
 Date: **1-7-80**
 Drawn: **NA**
 Checked: **1-7-80**
 Scale: **1:1**

Sheet No. **1**
 Revision: **REV 1 2-7-80**
REV 2 9-22-80
REV 3 9-22-80

NO.	DESCRIPTION	LOAD	TIME-CURRENT CURVE	FULL LOAD AMP	PRIMARY PROTECTIVE DEVICE	NOTES & COMMENTS	SECONDARY PROTECTIVE DEVICE
118-2	10 450	10 450	10-7 M/R	M/R	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R
119	10 450	10 450	10-10 M/R	-	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R
120	10 450	10 450	10-1 M/R	4-1	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R
121	10 450	10 450	10-1 M/R	14	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R
122	10 450	10 450	10-1 M/R	3-25	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R
123	10 450	10 450	10-1 M/R	4-2	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R
124	10 450	10 450	10-1 M/R	1	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R
125	10 450	10 450	10-1 M/R	3-3	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R
126	10 450	10 450	10-4 M/R	-	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R
127	10 450	10 450	10-4 M/R	-	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R
128	10 450	10 450	10-6 M/R	-	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R
129	10 450	10 450	10-9 M/R	-	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R
130	10 450	10 450	10-7 M/R	-	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R
131	10 450	10 450	10-1 M/R	14	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R
132	10 450	10 450	10-1 M/R	1	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R
133	10 450	10 450	10-1 M/R	3-3	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R
134	10 450	10 450	10-1 M/R	14	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R
135	10 450	10 450	10-1 M/R	2-6	Fuse Branch 100 7A Breaker normally open	Typical	Breaker 100 7A M/R

NOTE 7 - When circuit "7" (elevator space) is utilized, primary and secondary protection is provided by circuit "7" (elevator normal feed)

NOTE 5 - (A. Air ext @ 1700 Amps (or 12-24/7E-8))

See Note 5

STOKES & WAINWATER ENGINEERING CORPORATION
 CALCULATION SHEET
 Project No. 545
 Client: VEICO
 Project: Proctorville Railroad
 Date: 1-7-80
 Drawn: [Signature]
 Checked: [Signature]
 Scale: AS SHOWN
 Notes: REV 2-7-80
KAW 2-6-80

DESCRIPTION	TYPE	LOCATION	TIME-COMPLIANCE	FULL LOAD RPM	PRIMARY PROTECTION DEVICE	NOTES & COMMENTS	SECONDARY PROTECTIVE DEVICE	NOTES & COMMENTS
11B-2	30	10 400	10-1	4.2	Breaker K20-6 30-250A with 22-1/2" SRA OL. bkr. DEL. 29-22-84 Contactor Fuse Bureau AGC 3/4A	See Note 5 ab 4	Breaker Q8 T8D 20A	
11C-2	30	10 400	10-9	-	Breaker K20-6 30-250A with 22-1/2" SRA OL. bkr. & DIL. 29-22-84 Contactor -- 30 --	Typical	Breaker Q8 T8D 20A	
			10-1	2.6	-- 30 --	See Note 5 ab 4	Breaker Q8 T8D 20A	
			10-1	2.1	-- 30 --		Breaker Q8 T8D 20A	
			10-4	-	Fuse Bureau KTI 14		Breaker Q8 T8D 20A	
			10-5	1.85	Breaker Q8 T8 1/4		Breaker Q8 T8D 20A	
			10-2	4	Breaker K20-6 30-250A -- 30 --		Breaker Q8 T8D 20A	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

Project: **VERCO**
 Location: **OSWEGATCHIE TRIBUTION**
 Date: **1-7-80**
 Drawn: **1-7-80**
 Checked: **1-7-80**
 Title: **REV 1 1/2-7-80**
 R.L.O. 2-1-80

EQUIPMENT	DESCRIPTION	TIME CONSUMPT	CIRCUIT	MATERIALS	PROTECTIVE DEVICE	MOUNTING	REMARKS	NOTES & COMMENTS
218-2	114	8 400	114-1	1	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor	See Note 3 ab 4		
			114-1	3-25	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor			
			114-1	3-25	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor			
218-2	114	8 400	114-3	-	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor	See Note 1 ab 2		
			114-3	-	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor			
			114-3	-	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor			
218-2	114	8 400	114-2	26	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor	See Note 1 ab 2		
			114-2	26	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor			
			114-2	26	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor			
218-2	114	8 400	114-3	21	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor	See Note 1 ab 2		
			114-3	21	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor			
			114-3	21	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor			
218-2	114	8 400	114-1	21	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor	See Note 1 ab 2		
			114-1	21	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor			
			114-1	21	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor			
218-2	114	8 400	114-2	92	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor	See Note 2 ab 2		
			114-2	92	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor			
			114-2	92	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor			
218-2	114	8 400	114-3	92	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor	See Note 2 ab 2		
			114-3	92	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor			
			114-3	92	Breaker 225-6 30-250A with 22-10-1-84 0L 114-2 & 211-22-82 Contactor			


SEE NOTE 4 OR 3
 SEE NOTE 4 OR 3
 SEE NOTE 4 OR 3
 SEE NOTE 4 OR 3

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATIONS SHEET
 Project No. **347**
 Date: **SEP 11 1987**
 Location: **VEPCO**
 Station: **Positives**
 Sheet: **1 of 2**
 Title: **NOV 1 1987**
 Scale: **AS SHOWN**

Panel #	Component	Model	Time Current (amps)	Full Load Amps	Primary Protective Device	Setting	Notes & Comments
100-1	100-1	100-1	110-1	200	Breaker 150-150, 80A coil, 120-120V coil, for 20A coil, 120V coil	110-1	Breaker with 150-150 coil, 120-120V coil, for 20A coil, 120V coil
100-2	100-2	100-2	110-2	50	Breaker 100-100, 150-150V coil, 24-33-30 coil, 110-110V coil	110-2	Breaker 100-100, 150-150V coil, 24-33-30 coil, 110-110V coil
100-3	100-3	100-3	110-3	100	Breaker 100-100, 150-150V coil, 24-33-30 coil, 110-110V coil	110-3	Breaker 100-100, 150-150V coil, 24-33-30 coil, 110-110V coil
100-4	100-4	100-4	110-4	200	Breaker 150-150, 80A coil, 120-120V coil, for 20A coil, 120V coil	110-4	Breaker with 150-150 coil, 120-120V coil, for 20A coil, 120V coil
100-5	100-5	100-5	110-5	100	Breaker 100-100, 150-150V coil, 24-33-30 coil, 110-110V coil	110-5	Breaker 100-100, 150-150V coil, 24-33-30 coil, 110-110V coil
100-6	100-6	100-6	110-6	100	Breaker 100-100, 150-150V coil, 24-33-30 coil, 110-110V coil	110-6	Breaker 100-100, 150-150V coil, 24-33-30 coil, 110-110V coil
100-7	100-7	100-7	110-7	100	Breaker 100-100, 150-150V coil, 24-33-30 coil, 110-110V coil	110-7	Breaker 100-100, 150-150V coil, 24-33-30 coil, 110-110V coil
100-8	100-8	100-8	110-8	100	Breaker 100-100, 150-150V coil, 24-33-30 coil, 110-110V coil	110-8	Breaker 100-100, 150-150V coil, 24-33-30 coil, 110-110V coil
100-9	100-9	100-9	110-9	100	Breaker 100-100, 150-150V coil, 24-33-30 coil, 110-110V coil	110-9	Breaker 100-100, 150-150V coil, 24-33-30 coil, 110-110V coil
100-10	100-10	100-10	110-10	100	Breaker 100-100, 150-150V coil, 24-33-30 coil, 110-110V coil	110-10	Breaker 100-100, 150-150V coil, 24-33-30 coil, 110-110V coil

A GE TE-15A
 B GE THED-15A

2- #14 FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



A PRIMARY PROTECTION DEVICE CURVE
 B SECONDARY PROTECTION DEVICE CURVE
 C PENETRATION CURVE (TO 1000 SECONDS BY TEST)
 D PENETRATION CONTINUOUS RATING

NOTE: PER MANUFACTURER, C* CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 and 1000 AMPERES UNTIL IT INTERSECTS "D".
 E MAX. FAULT CURRENT FOR PROTECTIVE


TIME-CURRENT CHARACTERISTIC CURVES
 For Fuse Links in _____
 BASIS FOR DATA Standards _____ Dated _____
 1. Tests made at _____ Volts a-c at _____ p.f., starting at 25C with no initial load
 2. Curves are plotted to _____ Test points so variations should be _____

No. 12050-SK-IB-1
 Date 1-7-80 JLN
 1-7-80 JLN

K-E TIME-CURRENT CHARACTERISTIC 48 5225
 PENETRATION TYPE IB
 1KV / 2PN 2-7-80
 RLW 2-8-80

A GE THQB 1115
 B GF THED-15A

2 - #14 FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



A PRIMARY PROTECTION DEVICE CURVE
 B SECONDARY PROTECTION DEVICE CURVE
 C PENETRATION CURVE (TO 1000 SECONDS BY TEST)
 D PENETRATION CONT. MAX. RATED
 NOTE: PER MANUFACTURER, NO DISCONTINUITY WITH
 SAME SLOPE EXHIBITED BETWEEN 500 AND
 1000 SECONDS UNTIL IT INTERSECTS A, B.
 E MAX. FAULT CURRENT PNE ASYMMETRICAL

TIME-CURRENT CHARACTERISTIC CURVES

For _____ Fuse Links in _____

BASIS FOR DATA Standards _____ Dated _____

1. Tests made at _____ Volts and at _____ p.f., starting at 250 with no initial load

2. Curves are plotted to _____ Test points so variations should be _____


No. 12050-SK-15-2
 Date 1-7-30
 1-7-30

K-E TIME-CURRENT CHARACTERISTIC 48 3258
 KUFFEL & ESSER CO. 4001 1111
 PENETRATION TYPE 1B
 REV 1
 KLV 2-8-30

A GE TQB-5A
B GE TQB-5A

(D)

#14 FEED THRU
1) SINGLE SEAL
2) TWO SEALS



A PRIMARY PROTECTION DEVICE CURVE
B SECONDARY PROTECTION DEVICE CURVE
C PENETRATION CURVE (10000 SECONDS IN TEST)
D PENETRATION CURVE (CONTINUOUS RATING)
NOTE - PER MANUFACTURER, "D" CONTINUES WITH SAME SLOPE ESTABLISHED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "B".
E MAX. FAULT CURRENT RMS, ASYMMETRICAL

TIME-CURRENT CHARACTERISTIC CURVES

For _____ Fuse Links in _____

BASIS FOR DATA Standards _____ Dated _____

1. Tests made at _____ Volts a-c at _____ p-f, starting at 25C with no initial load.

2. Curves are plotted to _____ Test points so variations should be _____

No. 12050-SK-1B-1
Date 1-7-80 JLN
1-7-80 JLN


M-E TIME-CURRENT CHARACTERISTIC KEUPLER & EMMER CO. 48 0258
PENETRATION TYPE IB

REV 1 JLN 2-7-80
JLN 2-8-80

LT-2470
MG-LM200

A NZM-6 30-250
 Z2 X 14 ampe
 Y 20 ampe
 B GE THED -20A

#10 AWG FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



A PRIMARY PROTECTION DEVICE CURVE
 B SECONDARY PROTECTION DEVICE CURVE
 C PENETRATION CURVE (TO 1000 SECONDS BY INT)
 D PENETRATION CONTINUOUS RATING
 E MAX. FAULT CURRENT PER ADVISORY
 NOTE: FOR MANUFACTURER, 70% CONTINUOUS WITH
 SAME SLOPE EXHIBITED BETWEEN 500 AND
 1000 SECONDS UNLESS OTHERWISE NOTED


TIME-CURRENT CHARACTERISTIC CURVES
 For _____ Fuse Links In _____
 BASIS FOR DATA Standards _____ Dated _____
 1. Tests made at _____ Volts a-c ac _____ p-f, starting at 25C with no initial load.
 2. Curves are plotted to _____ Test points so variations should be _____
 No. 12050-CK-10-1
 Date 1-7-80 AN
 1-7-82

K-E TIME-CURRENT CHARACTERISTIC
 HELFELF & OSBER CO. 400-1114
 AR 5259
 PENETRATION TYPE IC

REV 1 7/11/78
 RLW 2-3-80

A NZMG-9 30-500A
 B GE THED-30A

2 - #10 AWG FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



A. PRIMARY PROTECTION DEVICE CURVE
 B. SECONDARY PROTECTION DEVICE CURVE
 C. PENETRATION CURVE (TO 1000 SECONDS BY TEST)
 D. PENETRATION CONTINUOUS RATING
 NOTE: PER MANUFACTURER, 50% CONTINUES WITH
 SAME SLOPE EXHIBITED BETWEEN 500 AND
 1000 SECONDS UNTIL IT INTERSECTS 50%
 E. MAX. FAULT CURRENT RMS ASYMMETRICAL

TIME-CURRENT CHARACTERISTIC CURVES

For _____ Fuse Links in _____

BASIS FOR DATA Standards _____ Date _____

1. Tests made at _____ Volts and at _____ p.f. starting at 230 with no initial load

2. Curves are plotted to _____ Test points so variations should be _____

No. 12050-JK-10-2
 Date 1-2-80 JLN
 1-7-80 JLN


K-E TIME-CURRENT CHARACTERISTIC
 PENETRATION TYPE IC

REV 1 R/W 2-7-80
 K.W. 2-8-80

INCORE DRIVE ASSEMBLIES
 (A THRU E)

A CHASE SHAWMUT OT 15
 B GE THED-20A

#10 AWG FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



A PRIMARY PROTECTION SERVICE CURVE
 B SECONDARY PROTECTION SERVICE CURVE
 C PENETRATION CURVE (TO 1000 SECONDS BY TEST)
 D PENETRATION CONTINUOUS RATING
 NOTE: PER MANUFACTURER, 1/2" CONDUITS WITH
 SAME SLOPE PERMITTED BETWEEN 400 AND
 1000 SECONDS UNLESS OTHERWISE NOTED.
 E MAX. FAULT CURRENT RMS, ASYMPTOTICAL

TIME-CURRENT CHARACTERISTIC CURVES

For _____ Fuse (links) in _____

BASIS FOR DATA Standards _____ Dated _____

1. Tests made at _____ Volts a.c. at _____ pf., starting at 25C with no initial load.

2. Curves are plotted to _____ Test points so variations should be _____

No. 12050-SK-10-3
 Date 1-7-80
 1-1-80


K-E TIME-CURRENT CHARACTERISTIC 49 5255
 KEUFFEL & ESSER CO. NEW YORK
 PENETRATION TYPE IC

REV 1 JPN 2-7-80
 RLW 2-8-80

FLUX MAPPING - DEHUMIDIFIERS

A GE THOR 15A
B GE THOR 20A

#10 AWG FEED THRU
1) SINGLE SEAL
2) TWO SEALS



A PRIMARY PROTECTION DEVICE CURVE
B SECONDARY PROTECTION DEVICE CURVE
C PENETRATION CURVE (TO 10000 SECONDS @ 250A)
D PENETRATION CURVE (RATING)
NOTE: PER MANUFACTURER, "A" CONTINUES WITH
SAME SLOPE EXHIBITED BETWEEN 500 AND
1000 SECONDS UNTIL IT INTERSECTS "D".
E MAX. FAULT CURRENT INS. ASYMMETRICAL

TIME-CURRENT CHARACTERISTIC CURVES

For _____ Fuse Links in _____

BASIS FOR DATA Standards _____ Dated _____

1. Tests made at _____ Volts a-c at _____ p-f, starting at 250 with no initial load

2. Curves are plotted to _____ Test points so variations should be _____

No. 12050-SK-10-4
Date 1-7-80
1-7-80 743


K-E TIME-CURRENT CHARACTERISTIC 48 5238
NEUFEL & ESSER CO. NEW YORK

REV 1 2/7-80
RLW 2-8-80

PENETRATION TYPE IC

A GE TE 15A
B GE TRD-20A

#10 AWG FEED THRU
1) SINGLE SEAL
2) TWO SEALS



- A PRIMARY PROTECTION DEVICE CURVE
- B SECONDARY PROTECTION DEVICE CURVE
- C PENETRATION CURVE (TO 1000 SECONDS BY TEST)
- D PENETRATION CONTINUOUS RATING
- NOTE 1. PER MANUFACTURER, "C" COINCIDES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "D".
- E MAX. FAULT CURRENT RMS. ASYMMETRICAL

TIME-CURRENT CHARACTERISTIC CURVES

For _____ Fuse Links in _____

BASIS FOR DATA Standards _____ Dated _____

1. Tests made at _____ Volts a-c at _____ p-f. starting at 25C with no initial load

2. Curves are plotted to _____ Test points so variations should be _____

No. 12050-SK-IC-5
Date 1-7-80 JLN
1-7-80 JLN


K-E TIME-CURRENT CHARACTERISTIC
PENETRATION TYPE IC 48 5258

REV 1 JLN 2-7-80
RLW 2-8-80

2-1A-D-02A-B
WHITTAKER EXP. JESSEL BOX (JB-6752)

A BUSSMAN AGC 2.5A
 B GE THIED-2GA

#10 AWG FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



TIME-CURRENT CHARACTERISTIC CURVES

For _____ Fuse Links in _____

BASIS FOR DATA Standards _____ Date _____

1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load.

2. Curves are plotted to _____ Test points so variations should be _____

No. 12050-SK-10-6
 Date 1-7-80
 1-7-80 g4c


K-E TIME-CURRENT CHARACTERISTIC
 NEUFEL & ESSER CO. 48 5258
 PENETRATION TYPE IC

REV 1 YPN 2-7-80
 RLW 2-8-80

CONT. RECINC. FAN MOTOR HTRS.

A BRISMAN KAW 7A
 B GE THED-20A

#10 AWG FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



A PRIMARY PROTECTION DEVICE CURVE
 B SECONDARY PROTECTION DEVICE CURVE
 C PENETRATION CURVE (TO 1000 SECONDS BY TEST)
 D PENETRATION CONTINUOUS RATING
 NOTE: FOR MEASUREMENTS, "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "D".
 E MAX. FAULT CURRENT RISE ASYMMETRICAL.

TIME-CURRENT CHARACTERISTIC CURVES

For _____ Fuse Links in _____

BASIS FOR DATA Standards _____ Dated _____

1. Tests made at _____ Volts p-c at _____ p-f, starting at 250 with no initial load

2. Curves are plotted to _____ Test points so variations should be _____

No. 10050-SK-TC-7
 Date 1-7-80
1-7-80


K-E TIME-CURRENT CHARACTERISTIC
 HEFFEL & ESSER CO. 48 525 E
 PENETRATION TYPE IC

REV1 JPH 2-7-80
 RLW 2-8-80

PART LENGTH RODS

A BUSSMAN KTE 1A
 B US 11ED 2CA

#10 AWG FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



TIME-CURRENT CHARACTERISTIC CURVES
 For _____ Fuse Links in _____
 BASIS FOR DATA Standards _____ Date _____
 1. Tests made at _____ Volts a-c at _____ p-f, starting at 25C with no initial load. No. 12050-3K-10-8
 2. Curves are plotted to _____ Test points so variations should be. Date 1-2-80
 1-2-80


K-E TIME-CURRENT CHARACTERISTIC
 KEUFFEL & ESSER CO. 48 5238
 PENETRATION TYPE IC

REV 1 9/17/80
 RLW 2-8-80

RHR PUMP MOTOR HTR.
 RS PUMP MOTOR HTR.

A BUSSMAN AGC 3/4 A
 B GE THED-20A

#10 AWG FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



A PRIMARY PROTECTION DEVICE CURVE
 B SECONDARY PROTECTION DEVICE CURVE
 C PENETRATION CURVE (TO 1000 SECONDS BY TEST)
 D PENETRATION CONTINUOUS RATING
 NOTE: FOR MANUFACTURER, "C" CONTINUES WITH
 SAME SEALS EXHIBITED BETWEEN 500 AND
 1000 SECONDS UNTIL IT INTERSECTS "D"
 E MAX. FAULT CURRENT RMT. ASYMMETRICAL

TIME-CURRENT CHARACTERISTIC CURVES

For _____ Fuse Links in _____

BASIS FOR DATA Standards _____ Dated _____

1. Tests made at _____ Volts a-c at _____ p-f, starting at 25C with no initial load

2. Curves are plotted to _____ Test points so variations should be _____

No. 12050-SK-10-9
 Date 1-7-80
 1-7-80 RLW-3


K-E TIME-CURRENT CHARACTERISTIC
 KUFFEL & ESSER CO. WILMINGTON, DEL.
 PENETRATION TYPE IC

48 5208
 REV 1 9/14 2-7-80
 RLW 2-8-80

FLUX MAPPING - CONTROL POWER

A BRISMAN AGC 6A
 B GE TR02 -20A

#10 AWG FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



TIME-CURRENT CHARACTERISTIC CURVES

For _____ Fuse Links: in _____

BASIS FOR DATA Standards _____ Defect _____

1. Tests made at _____ Volts a-c at _____ p-f., starting at 250 with no initial load

2. Curves are plotted to _____ Test points so variations should be _____

No. 12050-SK-10-10
 Date 1-20-80
 1-2-80 JRS

K-E TIME-CURRENT CHARACTERISTIC
 HELFEL & SIEBEL CO. MADE IN U.S.A.

48 9258


PENETRATION TYPE IC

REV 1 JPPW2-7-80
 RLW 2-8-80

ELEVATOR - CONTROL & BREAK

A NZM-6 50-500A
 22 X 28AMPS
 B GE THRU-35A

#8 AWG FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



A PRIMARY PROTECTION DEVICE CURVE
 B SECONDARY PROTECTION DEVICE CURVE
 C PENETRATION CURVE (TO 1000 SECONDS BY TEST)
 D PENETRATION CONTINUOUS RATING
 NOTE: PER MANUFACTURER, "C" CONTINUES WITH
 SAME SLOPE EXHIBITED BETWEEN 500 AND
 1000 SECONDS UNTIL IT INTERSECTS "D".
 E MAX. FAULT CURRENT RMS. ASYMMETRICAL

TIME-CURRENT CHARACTERISTIC CURVES

For _____ Type Links: _____

Basis for Data Standards _____ Dated _____

1. Tests made at _____ Volts a-c at _____ pf. starting at 25C with no initial load.


2. Curves are plotted to _____ Test points so variation, if could be _____

No. 12050-SK-IIA-1
 Date 1-7-80
 1-2-80

K&E TIME-CURRENT CHARACTERISTIC 48 5258
 PENETRATION TYPE IIA
 REV 1 JAN 2-7-80
 R.L.W. 2-8-80

A NZM-6 50-500A
 22 X 28AMPS
 B GE THED-35A

2-#8 AWG FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



A PRIMARY PROTECTION DEVICE CURVE
 B SECONDARY PROTECTION DEVICE CURVE
 C PENETRATION CURVE (IG 1000 SECONDS BY TEST)
 D PENETRATION CONTINUOUS RATING
 NOTE 1 PER MANUFACTURER, "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 400 AND 1000 SECONDS UNTIL IT INTERSECTS "D".
 E. MAX. FAULT CURRENT RMS ASYMMETRICAL

TIME-CURRENT CHARACTERISTIC CURVES
 For _____ Fuse Links in _____
 BASIS FOR DATA Standards _____ Dated _____
 1. Tests made at _____ Volts a-c at _____ p-f., starting at 250 with no inductor.
 2. Curves are plotted to _____ Test points so variations should be _____
 No. 12050-SK-11A-2
 Date 2-2-80 JLN
 1-7-80 JLN


K&E TIME-CURRENT CHARACTERISTIC REFUEL 3 8888 00 48 9258 PENETRATION TYPE IIA

REV. 1 JPN 2-7-80
 RLW 2-8-80

MOV-2590 THRU 95

A GE THQB 20A
 B GE THED-20A

#8 AWG FEED THRU
 1) SINGLE SEAL
 2) TWO SEAL



A PRIMARY PROTECTION DEVICE CURVE
 B SECONDARY PROTECTION DEVICE CURVE
 C PENETRATION CURVE (TO 1000 SECONDS BY TEST)
 D PENETRATION CONTINUOUS RATING
 NOTE: PER MANUFACTURER, "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "D".
 E MAX. FAULT CURRENT R.M.S. ASYMMETRICAL

TIME-CURRENT CHARACTERISTIC CURVES

For _____ Fuse Links. In _____

BASIS FOR DATA Standards _____ Dated _____


1. Tests made at _____ Volts a-c at _____ a-f, starting at 25C with no initial load

2. Curves are plotted to _____ Test points so variations should be _____

No. 12050-SY-IIA-3
 Date 1-7-80
 1-2-80

M-E TIME-CURRENT CHARACTERISTIC 48 0250
 REV 1 2/27/80
 RLV 2-8-80
 PENETRATION TYPE IIA

#4 AVG F.T.
 1) SINGLE SEAL
 2) TWO SEALS



For Fuse Links, In

BASIS FOR DATA Standards Cited

1. Tests made at Volts \pm 0.1 p.f., starting at 25C with no initial load

2. Curves are plotted to Test points so variations should be

TIME-CURRENT CHARACTERISTIC CURVES

For Fuse Links, In

Cited

1. Tests made at Volts \pm 0.1 p.f., starting at 25C with no initial load

2. Curves are plotted to Test points so variations should be

No. 12050-SK-LIB-1

Date 1-7-80 JLN

17-80 JLN

K-E TIME-CURRENT CHARACTERISTIC

4-15 5-2-88

REV 1 R/W 2-7-80


R/W 2-8-80

PENETRATION TYPE IIB

RECEIPT.

A NZMH-9 50-800A
 B GE THED-45A

#4 AWG FT.
 1) SINGLE SEAL
 2) TWO SEALS



A PRIMARY PROTECTION DEVICE CURVE
 B SECONDARY PROTECTION DEVICE CURVE
 C PENETRATION CURVE (TO 1000 SECONDS BY TEST)
 D PENETRATION CONTINUOUS RATING
 NOTE: PER MANUFACTURER, "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "A".
 E MAX. FAULT CURRENT RMS, ASYMMETRICAL

TIME-CURRENT CHARACTERISTIC CURVES

For _____ Fuse links in _____

BASIS FOR DATA Standards _____ Dated _____

1. Tests made at _____ Volts a-c at _____ p-f, starting at 25C with no initial load.

2. Curves are plotted to _____ Test points so variations should be _____

No. 12050-SK-IIB-2
 Date 1-7-80
 1-7-80 JLN


K-E TIME-CURRENT CHARACTERISTIC
 KEUFFEL & ESSER CO. MAX. 4-11-11
 PENETRATION TYPE IIB

REV 1 JPN 2-7-80
 RLW 2-9-80

ELEVATOR

A GE THED 50
 B GE THED-45A

#4 AWG FT.
 1) SINGLE SEAL
 2) TWO SEALS



A PRIMARY PROTECTION DEVICE CURVE
 B SECONDARY PROTECTION DEVICE CURVE
 C PENETRATION CURVE (TO 1000 SECONDS BY TEST)
 D PENETRATION CONTINUOUS RATING
 NOTE: PER MANUFACTURER, "C" CONTINUES WITH
 SAME SLOPE EXHIBITED BETWEEN 500 AND
 1000 SECONDS UNTIL IT INTERSECTS "D".
 E MAX. FAULT CURRENT RMS, ASYMMETRICAL


TIME-CURRENT CHARACTERISTIC CURVES
 For Fuse Links in _____ Dated _____
 BASIS FOR DATA Standards _____
 1. Tests made at _____ Volts a-c at _____ p-f, starting at 25C with no initial load
 2. Curves are plotted to _____ Test points so variations should be _____
 No. 12050-SK-IIB-3
 Date 1-7-30
 1-7-30

K&E TIME-CURRENT CHARACTERISTIC 48 3256
 KUEPPEL & BERRY CO. WILM. N.J.
 PENETRATION TYPE IIB - LTG PNL 44-2

REV 1 MPN 2-7-30
 RLW 2-8-30

A CHASE SHAWMUT OTS 70
 B CHASE SHAWMUT OTS 70

#4 AWG FT.
 1) SINGLE SEAL
 2) TWO SEALS



A PRIMARY PROTECTION DEVICE CURVE
 B SECONDARY PROTECTION DEVICE CURVE
 C PENETRATION CURVE (TO 1000 SECONDS BY TEST)
 D PENETRATION CONTINUOUS RATING
 NOTE: PER MANUFACTURER, "C" CONTINUES WITH
 SAME SLOPE EXHIBITED BETWEEN 500 AND
 1000 SECONDS UNTIL IT INTERSECTS "D".
 E MAX. FAULT CURRENT RMS. ASYMMETRICAL

TIME-CURRENT CHARACTERISTIC CURVES

For _____ Fuse Links in _____

BASIS FOR DATA Standards _____ Dated _____

1. Tests made at _____ Volts a-c at _____ p-f, starting at 25C with no initial load

2. Curves are plotted to _____ Test points so variations should be _____

No. 12050-SK-IIS-4
 Date 2-7-80
 1-2-80


K-E TIME-CURRENT CHARACTERISTIC
 KEUFFEL & ESSER CO. 48 5258
 PENETRATION TYPE IIS

REV 1 2/11/80
 2-11-80

PRESS. HTRS.
 ST. GEN. SUPP. HTRS. A-1, B-1, A-2,
 B-2 & C-2

A W EHB 3060
 (IN EDMR SECONDARY)
 B GE TRFD-60A
 (IN XFMR SECONDARY)

#4 AWG. F.T.
 1) SINGLE SEAL
 2) TWO SEALS



A PRIMARY PROTECTION DEVICE CURVE
 B SECONDARY PROTECTION DEVICE CURVE
 C PENETRATION CURVE (TO 1000 SECONDS BY TEST)
 D PENETRATION CONTINUOUS RATING
 NOTE: PER MANUFACTURER, "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "B".
 R MAX. FAULT CURRENT RMS. ASYMMETRICAL


TIME-CURRENT CHARACTERISTIC CURVES
 For _____ Fuse Links in _____
 BASIS FOR DATA Standards _____ Dated _____
 1. Tests made at _____ Volts a.c. at _____ p.f., starting at 25C with no initial load
 2. Curves are plotted to _____ Test points so variations should be _____
 No. 12050-SK-IIB-5
 Date 1-7-80
 1-7-80/RLW

K-E TIME-CURRENT CHARACTERISTIC
 KEUFFEL & ESSER CO. 48 5200
 PENETRATION TYPE IIB

REV 1 JAN 2-7-80
 RLW 2-8-80

L70 PNL 19-2

2 - 2/0 FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



- A PRIMARY PROTECTION DEVICE CURVE
 - B SECONDARY PROTECTION DEVICE CURVE
 - C PENETRATION CURVE (TO 1000 SECONDS BY TEST)
 - D PENETRATION CONTINUOUS RATING
- NOTE: PER MANUFACTURER, "C" COINCIDES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "D".
- E MAX. FAULT CURRENT RMS ASYMMETRICAL

TIME-CURRENT CHARACTERISTIC CURVES

For _____ Fuse Links In _____

BASIS FOR DATA Standards _____ Dated _____

1. Tests made at _____ Volts a-c at _____ a-f, starting at 25C with no initial load

2. Curves are plotted to _____ Test points so variations should be _____

No. 12050-SK-IIC-1
 Date 1-7-80
 1-7-80


REV 1 P/W 2-7-80
 JMB 2-8-80

K-E TIME-CURRENT CHARACTERISTIC 48 5258
 REPTED & ISSUED TO: _____

PENETRATION TYPE IIC - 2-HV-F-01A, - B, - C

A NZM-9 130-2000A
 ZL X 105 AMPS
 B GE TRIP LOCK

2/O AWG FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



A PRIMARY PROTECTION DEVICE CURVE
 B SECONDARY PROTECTION DEVICE CURVE
 C PENETRATION CURVE (TO 1000 SECONDS BY TEST)
 D PENETRATION CONTINUOUS RATING
 NOTE: PER MANUFACTURER, "C" CONTINUES WITH
 SAME SLOPE EXHIBITED BETWEEN 500 AND
 1000 SECONDS UNTIL IT INTERSECTS "D".
 E MAX. FAULT CURRENT RMS. ASYMMETRICAL


TIME-CURRENT CHARACTERISTIC CURVES
 For _____ Fuse Links in _____
 BASIS FOR DATA Standards _____ Dated _____
 1. Tests made at _____ Volts a-c at _____ p-f. starting at 25C with no initial load
 2. Curves are plotted to _____ Test points so variations should be _____
 No. 12050-SK-IIC-2
 Date 1-7-80 WLN
 1-7-80 BJA

K-E TIME-CURRENT CHARACTERISTIC 48 5258
 KEUFFEL & ESSER CO. NEW YORK, N.Y.
 PENETRATION TYPE IIC - 2-HV-F-37 SERIES

REV 1 MPW 2-7-80
 RLW 2-8-80

A W EHB-3070 70A
 B GE THED-100A

2/0 FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



TIME-CURRENT CHARACTERISTIC CURVES

For _____ Fuse Links: In _____

BASIS FOR DATA Standards _____ Dated _____

1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load _____

2. Curves are plotted to _____ Test points so variations should be _____

N. 12050-SK-IIC-3
 Date 1-7-80 JPN
 1-7-80 JPN


REV 1 JPN 2-7-80
 RLW 2-8-80

M-E TIME-CURRENT CHARACTERISTIC 48 525B
 KEUFEL & GIBSON CO. 444 N. 114

PENETRATION TYPE IIC - ST. GEN SUPP. HTRS. C-1, A-3, B-3 & C-3

A NZMH-9 50-800A
 B GE THED-100A

2/O FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



TIME-CURRENT CHARACTERISTIC CURVES
 For _____ Fuse Links in _____
 BASIS FOR DATA Standards _____ Dated _____
 1. Tests made at _____ Volts a-c at _____ p-f., starting at 25C with no initial load.
 2. Curves are plotted to _____ Test points so variations should be _____
 No. 12050-SK-IIG-A
 Date 1-7-80
 1-7-80/5/140


NPE TIME-CURRENT CHARACTERISTIC 48 5258
 KUPFEL & ESSER CO. - 1981 - 111A

PENETRATION TYPE IIC - RECEPT LOOPS

REV 1 JPH 2-7-80
 RLW 2-8-80

A NZMH-9 160-2000A
 (SET @ 140)
 (IN XFMR SECONDARY)
 B GE TR20-11CA
 (IN XFMR SECONDARY)

2/0 FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



A PRIMARY PROTECTION DEVICE CURVE
 B SECONDARY PROTECTION DEVICE CURVE
 C PENETRATION CURVE (TO 1000 SECONDS BY TEST)
 D PENETRATION CONTINGENCY RATING
 NOTE: PER MANUFACTURER, 'C' CONTINUES WITH
 SAME SLOPE EXHIBITED BETWEEN 500 AND
 1000 SECONDS UNTIL IT INTERSECTS 'D'.
 E MAX. FAULT CURRENT I_{MS}, ASymMETRICAL

TIME-CURRENT CHARACTERISTIC CURVES

For _____ Fuse Links in _____

BASIS FOR DATA Standards _____ Dated _____

1. Tests made at _____ Volts a-c at _____ p-f, starting at 25C with no initial load

2. Curves are plotted to _____ Test points so variations should be _____


No. 12050-SK-IIC-5
 Date 1-7-80
 1-2-80

K-E TIME-CURRENT CHARACTERISTIC
 KUPPEL & EISNER CO. 48 525 P
 PENETRATION TYPE IIC

REV 1 2/27/80
 RLW 2-8-80

LTC FWLS 21-2, 18-2 & 22-2

2-250 MCM FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



A PRIMARY PROTECTION DEVICE CURVE
 B SECONDARY PROTECTION DEVICE CURVE
 C PENETRATION CURVE (TO 1000 SECONDS BY TEST)
 D PENETRATION CONTINUOUS RATING
 NOTE: PER MANUFACTURER, "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "B".
 E MAX. FAULT CURRENT RMS ASYMMETRICAL

TIME-CURRENT CHARACTERISTIC CURVES
 For Fuse Links in _____
 BASIS FOR DATA Standards _____ Dated _____
 1. Tests made at _____ Volts a-c at _____ p.f. starting at 25C with no initial load
 2. Curves are plotted to _____ Test points so variations should be _____
 No. 12050-3K-IID-1
 Date 1-7-80
 1-7-80


K-E TIME-CURRENT CHARACTERISTIC
 KUFFEL & ESSER CO. NEW YORK
 PENETRATION TYPE IID

REV 1 2/17/80
 JAB 2-8-80

2-RS-P-01A, & B

A NZMH-9 200-2000A
 (SET @ 140)
 (IN XPMR SECONDARY)
 B GE THPA-175A
 (IN XPMR SECONDARY)

250 MCM FEED THRU
 1) SINGLE SEAL
 2) TWO SEALS



A PRIMARY PROTECTION DEVICE CURVE
 B SECONDARY PROTECTION DEVICE CURVE
 C PENETRATION CURVE (TO 7000 SECONDS BY TEST)
 D PENETRATION CONTINUOUS RATING
 NOTE: PER MCM FACTOR, "C" CONTINUES WITH SAME SLOPE EXHIBITED BETWEEN 500 AND 1000 SECONDS UNTIL IT INTERSECTS "D".
 E MAX. FAULT CURRENT RMS, ASYMMETRICAL


TIME-CURRENT CHARACTERISTIC CURVES
 For _____ Fuse Links in _____
 BASIS FOR DATA Standards _____ Dated _____
 1. Tests made at _____ Volts a-c at _____ p-f, starting at 250 with no initial load.
 2. Curves are plotted to _____ Test points so variations should be _____
 No. 12050-SK-IID-2
 Date 1-7-80
 1-7-80

K&E TIME-CURRENT CHARACTERISTIC 48 5200
 KEUFFEL & ESSER CO. INC. - U.S.A.

REV 1 JAN 2-7-80
 RLW 2-8-80

A SHAWMUT FORM 101
AMP TRAP
A 25X50
B GE TH2D-60A

#2 AWG FEED THRU
1) SINGLE SEAL
2) TWO SEALS



TIME-CURRENT CHARACTERISTIC CURVES
For Fuse LINK IN _____
Basis for Data Standards _____ Date _____
1. Tests made at _____ Volts a-c at _____ p.f. starting at 25C with no initial load
2. Curves are plotted to _____ Test points so variations should be _____
No. 12090-3K-11E-1
Date 1-7-80
1-7-80

K-E TIME-CURRENT CHARACTERISTIC 48 5258
PENETRATION TYPE 11E - FULL LENGTH RODS - LIFTERS

REV 1 MPN 2-7-80
RLW 2-8-80