

400 Chestnut Street Tower II

October 16, 1980

Director of Licensing
Attention: Mr. Thomas A. Ippolito, Chief
Operating Reactors Branch No. 2
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr. Ippolito:

In the Matter of the)
Tennessee Valley Authority)

Docket No. 50-259
50-260
50-296

R

We have reviewed the draft data regarding the Effluent and Waste Disposal Semi-Annual Report for year 1978 for the Browns Ferry Nuclear Plant enclosed with the letter from R. A. Hartfield to H. G. Parris dated September 19, 1980. Enclosed is a corrected copy of that data with changes indicated by vertical bars. All other data is correct as reported.

The scope of this request for information was expanded in a telephone discussion with M. R. Beebe on September 30, 1980. Even though TVA's allotted review time was extremely short, the enclosed response also addresses the additional information requested.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills

L. M. Mills, Manager
Nuclear Regulation and Safety

Subscribed and sworn to before
me this 16th day of Oct. 1980.

Paulette H. White
Notary Public

My Commission Expires 9-5-84

Enclosure

B010210 348 R

INSTALLATION BROWN'S FERRY

LOCATION 10 MI NW DECATUR AL

EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT FOR YEAR 1978
SUPPLEMENTAL INFORMATION

UNIT NUMBER 1
TYPE FWP
DOCKET NO. 50-259
COOLING WATER SOURCE TENNESSEE RIVER

LICENSEE TENNESSEE VALLEY AUTHORITY
LICENSED POWER (MWT) 3293.0
INITIAL CRITICALITY 08/17/73

UNIT NUMBER 2
TYPE FWP
DOCKET NO. 50-260
COOLING WATER SOURCE TENNESSEE RIVER

LICENSEE TENNESSEE VALLEY AUTHORITY
LICENSED POWER (MWT) 3293.0
INITIAL CRITICALITY 07/20/74

UNIT NUMBER 3
TYPE FWP
DOCKET NO. 50-296
COOLING WATER SOURCE TENNESSEE RIVER

LICENSEE TENNESSEE VALLEY AUTHORITY
LICENSED POWER (MWT) 3293.0
INITIAL CRITICALITY 08/08/76

MAXIMUM PERMISSIBLE CONCENTRATIONS (MICROCURIES/ML) See Attachment 1

MEASUREMENTS AND APPROXIMATIONS OF TOTAL RADIOACTIVITY See Attachment 2

N/A=NOT APPLICABLE
N/D=NOT DETECTED
N/R=NOT REPORTED

INSTALLATION BROWN'S FERRY

LOCATION 10 MI NW DECATUR AL

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR YEAR 1978
 SUPPLEMENTAL INFORMATION

AVERAGE ENERGY (MEV/DISINTEGRATION)

BETA		GAMMA	
QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
N/A	N/A	N/A	N/A

BATCH RELEASES

A. LIQUID

	QUARTER 1	QUARTER 2
1. NUMBER OF BATCH RELEASES-	123	92
2. TOTAL TIME PERIOD FOR BATCH RELEASE (MIN)-	4.83E 04	3.21E 04
3. MAXIMUM TIME PERIOD FOR A BATCH RELEASE (MIN)-	1.91E 03	1.59E 03
4. AVERAGE TIME PERIOD FOR BATCH RELEASES (MIN)-	3.56E 02	3.56E 02
5. MINIMUM TIME PERIOD FOR A BATCH RELEASE (MIN)-	9.00	35
6. AVERAGE STREAM FLOW DURING PERIODS OF RELEASE OF EFFLUENT INTO A FLOWING STREAM (LTS/MIN)-		

B. GASEOUS

1. NUMBER OF BATCH RELEASES-	NONE	NONE
2. TOTAL TIME PERIOD FOR BATCH RELEASES (MIN)-		
3. MAXIMUM TIME PERIOD FOR A BATCH RELEASE (MIN)-		
4. AVERAGE TIME PERIOD FOR BATCH RELEASES (MIN)-		
5. MINIMUM PERIOD FOR A BATCH RELEASE (MIN)-		

ABNORMAL RELEASES

A. LIQUID

1. NUMBER OF RELEASES	NONE	NONE
2. TOTAL ACTIVITY RELEASED (CURIES)		

B. GASEOUS

1. NUMBER OF RELEASES	NONE	NONE
2. TOTAL ACTIVITY RELEASED (CURIES)		

N/A=NOT APPLICABLE

N/D=NOT DETECTED

N/R=NOT REPORTED

INSTALLATION BROWN'S FERRY

LOCATION 10 MI NW DECATUR AL

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT FOR YEAR 1978
 SUPPLEMENTAL INFORMATION

AVERAGE ENERGY (MEV/DISINTEGRATION)

	BETA		GAMMA	
	QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
	N/A	N/A	N/A	N/A
HATCH RELEASES			QUARTER 3	QUARTER 4
A. LIQUID			3	4
1. NUMBER OF BATCH RELEASES-			73	96
2. TOTAL TIME PERIOD FOR BATCH RELEASE (MIN)-			2.72E 04	3.59E 04
3. MAXIMUM TIME PERIOD FOR A BATCH RELEASE (MIN)-			2.03E 03	1.21E 03
4. AVERAGE TIME PERIOD FOR BATCH RELEASES (MIN)-			3.73E 02	3.74E 02
5. MINIMUM TIME PERIOD FOR A BATCH RELEASE (MIN)-			60	60
6. AVERAGE STREAM FLOW DURING PERIODS OF RELEASE OF EFFLUENT INTO A FLOWING STREAM (LTS/MIN)-				
B. GASEOUS				
1. NUMBER OF BATCH RELEASES-			NONE	NONE
2. TOTAL TIME PERIOD FOR BATCH RELEASES (MIN)-				
3. MAXIMUM TIME PERIOD FOR A BATCH RELEASE (MIN)-				
4. AVERAGE TIME PERIOD FOR BATCH RELEASES (MIN)-				
5. MINIMUM PERIOD FOR A BATCH RELEASE (MIN)-				
AH. NORMAL RELEASES				
A. LIQUID				
1. NUMBER OF RELEASES			1	NONE
2. TOTAL ACTIVITY RELEASED (CURIES)			0.04	
B. GASEOUS				
1. NUMBER OF RELEASES			NONE	NONE
2. TOTAL ACTIVITY RELEASED (CURIES)				

N/A=NOT APPLICABLE

N/D=NOT DETECTED

N/R=NOT REPORTED

INSTALLATION=ROCKWELL'S FERRY

EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT 197A

GASEOUS EFFLUENTS-SUMMATION OF ALL RELEASES

	UNIT	QUARTER 1	QUARTER 2	EST. TOTAL ERROR, %
A. FISSION AND ACTIVATION GASES				
1. TOTAL RELEASE	CI	<1.10E 04	<5.17E 04	
2. AVERAGE RELEASE RATE FOR PERIOD	UCI/SEC	<1.40E 03	<6.58E 03	
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	%	2.85	1.32E 01	
B. IODINES				
1. TOTAL IODINE-131	CI	<2.81E -02	4.34E -02	
2. AVERAGE RELEASE RATE FOR PERIOD	UCI/SEC	<3.57E -03	5.52E -03	
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	%	8.93E -01	1.38E +00	
C. PARTICULATES				
1. PARTICULATES WITH HALF-LIVES > 8 DAYS	CI	<1.01E -02	<2.32E -02	
2. AVERAGE RELEASE RATE FOR PERIOD	UCI/SEC	<1.29E -03	<2.95E -03	
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	%	3.23E -01	7.38E -01	
4. GROSS ALPHA RADIOACTIVITY	CI	<6.66E -07	<6.23E -06	
D. ITRITIUM				
1. TOTAL RELEASE	CI	6.26E 00	1.12E 01	
2. AVERAGE RELEASE RATE FOR PERIOD	UCI/SEC	7.96E -01	1.42E 00	
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	%	1.30	1.52E 00	

N/A=NOT APPLICABLE
N/D=NOT DETECTED
N/R=NOT REPORTED

INSTALLATION-ROCKWELL'S FERRY

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 197P

GASEOUS EFFLUENTS-SUMMATION OF ALL RELEASES

	UNIT	QUARTER 3	QUARTER 4	EST. TOTAL ERROR %
A. FISSION AND ACTIVATION GASES				
1. TOTAL RELEASE	CI	< 9.33E 04	< 1.18E 03	
2. AVERAGE RELEASE RATE FOR PERIOD	UCI/SEC	< 1.19E 04	< 1.50E 02	
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	%	2.37E 01	3.00E -01	
B. IODINES				
1. TOTAL IODINE-131	CI	3.18E -02	< 2.49E -02	
2. AVERAGE RELEASE RATE FOR PERIOD	UCI/SEC	4.05E -03	< 3.17E -03	
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	%	1.01E 00	7.93E -01	
C. PARTICULATES				
1. PARTICULATES WITH HALF-LIVES > 8 DAYS	CI	< 3.23E -02	< 3.31E -02	
2. AVERAGE RELEASE RATE FOR PERIOD	UCI/SEC	< 4.12E -03	< 4.21E -03	
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	%	1.03E 00	1.05E 00	
4. GROSS ALPHA RADIOACTIVITY	CI	< 1.92E -06	< 6.72E -04	
D. TRITIUM				
1. TOTAL RELEASE	CI	6.34E 00	4.98E 00	
2. AVERAGE RELEASE RATE FOR PERIOD	UCI/SEC	8.07E -01	6.34E -01	
3. PERCENT OF TECHNICAL SPECIFICATION LIMIT	%	6.50E -01	7.79E -01	

N/A=NOT APPLICABLE
 N/D=NOT DETECTED
 N/R=NOT REPORTED

INSTALLATION=KROON'S FERRY

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1978

GAS EFFLUENTS ELEVATED RELEASE

NUCLIDES RELEASED	UNIT	CONTINUOUS MODE		BATCH MODE	
		QUARTER	QUARTER	QUARTER	QUARTER
		1	2	1	2
FISSION GASES					
AR-41	CI	<4.08E 00	<3.80E 00		
H-3	CI	7.15E-02	2.53E-01		
KR-85	CI	<1.44E 00	2.87E 00		
KR-85M	CI	<1.48E 01	5.57E 01		
KR-87	CI	<5.93E 00	<8.57E 00		
KR-88	CI	<4.50E 01	<4.90E 01		
XE-133	CI	<4.13E 02	<4.54E 02		
XE-135	CI	<2.17E 00	<3.92E 00		
XE-135M	CI	<7.17E 01	<3.65E 01		
XE-138	CI	<4.97E 02	<2.58E 02		
IODINES					
I-131	CI	<1.55E-02	3.50E-02		
I-133	CI	<5.07E-03	1.06E-02		
I-135	CI	<5.38E-04	4.93E-03		
PARTICULATES					
HA-140	CI	<2.44E-05	<3.16E-05		
CU-64	CI	<1.31E-05	<1.63E-05		
CU-60	CI	<2.76E-05	3.05E-05		
CS-134	CI	<2.89E-05	<6.59E-05		
CS-137	CI	<4.23E-05	<4.16E-05		
FE-59	CI	<3.25E-05	<4.10E-05		
LA-140	CI	<2.44E-05	<3.16E-05		
MN-54	CI	<1.44E-05	<1.58E-05		
NH-95	CI	<1.31E-05	<2.03E-05		
SR-89	CI	6.38E-06	8.42E-06		
SR-90	CI	3.40E-07	1.34E-07		
ZN-65	CI	<3.23E-05	<4.16E-05		
ZR-95	CI	<2.78E-05	<3.55E-05		

INSTALLATION=ROOPNA'S FERRY

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1978

GAS EFFLUENTS ELEVATED RELEASE

NUCLIDES RELEASED	UNIT	CONTINUOUS MODE		BATCH MODE	
		QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4

FISSION GASES

AR-41	CI	1.66E 01	4.72E 01		
H-3	CI	6.88E-01	1.00E 00		
KR-85	CI	6.26E 00	6.71E 00		
KR-85M	CI	1.14E 02	1.73E 03		
KR-87	CI	<9.39E 00	<7.76E 00		
KR-88	CI	1.00E 02	1.29E 02		
XE-133	CI	1.69E 03	1.03E 03		
XE-135	CI	<3.18E 00	<2.98E 00		
XE-135M	CI	<6.50E 01	<3.29E 01		
XE-138	CI	<3.65E 02	<1.42E 02		

IODINES

I-131	CI	3.03E-02	2.70E-02		
I-133	CI	3.92E-03	1.38E-03		
I-135	CI	2.44E-03	<2.98E 00		

PARTICULATES

HA-140	CI	<5.67E-05	<4.24E-05		
CO-58	CI	<4.00E-05	<3.22E-05		
CO-60	CI	4.80E-05	3.37E-05		
CS-134	CI	<3.98E-05	<4.08E-05		
CS-137	CI	<7.03E-05	<5.13E-05		
FE-59	CI	<9.94E-05	<7.87E-05		
LA-140	CI	<3.23E-05	<2.78E-05		
MN-54	CI	<4.56E-05	<3.19E-05		
Nd-95	CI	<6.35E-05	<6.61E-05		
SR-89	CI	1.04E-06	1.67E-05		
SR-90	CI	3.84E-08	4.36E-07		
ZN-65	CI	<6.62E-05	<5.37E-05		
ZR-95	CI	<1.18E-03	<1.04E-03		

INSTALLATION=PROVINTS FERRY

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1978

GAS EFFLUENTS GROUND RELEASE

NUCLIDES RELEASED	UNIT	CONTINUOUS MODE		BATCH MODE	
		QUARTER	QUARTER	QUARTER	QUARTER
		1	2	1	2

FISSION GASES

IAH-41	CI	<6.03E 01	<2.02E 02		
H-3	CI	6.19E 00	1.09E 01		
KR-85	CI	<8.90E 03	<4.54E 04		
KR-PEM	CI	<2.93E 01	<1.54E 02		
KR-87	CI	<7.05E 01	<3.69E 02		
KR-88	CI	<9.15E 01	<5.07E 02		
XE-133	CI	<5.69E 01	<3.72E 02		
XE-135	CI	<2.68E 01	<1.58E 02		
XE-135M	CI	<1.33E 01	<7.50E 02		
XE-138	CI	<5.68E 02	<2.91E 03		

IODINES

I-131	CI	< 1.24E-02	8.39E-03		
I-133	CI	< 1.85E-03	< 8.21E-03		
I-135	CI	<1.28E-02	< 3.61E-02		

PARTICULATES

BA-140	CI	<2.96E-04	< 7.15E-04		
CO-58	CI	<2.61E-04	< 1.30E-03		
CO-60	CI	< 2.40E-03	5.07E-03		
CS-134	CI	<2.55E-04	<6.42E-04		
CS-137	CI	< 1.86E-03	1.65E-03		
FE-59	CI	<3.36E-04	<1.48E-03		
LA-140	CI	<2.96E-04	< 7.15E-04		
MN-54	CI	< 5.72E-04	< 1.26E-03		
NO-95	CI	< 7.16E-04	<2.22E-03		
SR-89	CI	1.07E-05	2.48E-04		
SR-90	CI	2.45E-05	2.01E-04		
ZN-65	CI	<2.11E-03	< 5.23E-03		
ZR-95	CI	<6.54E-04	<2.15E-03		

INSTALLATION=KROONIS FERRY

EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT 1978

GAS EFFLUENTS (GROUND RELEASE

NUCLIDES RELEASED	UNIT	CONTINUOUS MODE		BATCH MODE	
		QUARTER	QUARTER	QUARTER	QUARTER
		3	4	3	4
FISSION GASES					
AR-41	CI	<3.91E-02	<5.08E-01		
H-3	CI	5.65E-00	3.58E-00		
KR-85	CI	<8.35E-04	<2.37E-04		
KR-85M	CI	<2.21E-02	<3.04E-01		
KR-87	CI	<5.62E-02	<3.74E-02		
KR-88	CI	<7.79E-02	<2.17E-02		
XE-133	CI	<5.14E-02	<4.68E-01		
XE-135	CI	<2.65E-02	<5.80E-01		
XE-135M	CI	<1.16E-02	<1.66E-02		
XE-138	CI	<3.50E-03	<8.06E-02		
IODINES					
I-131	CI	1.50E-03	1.31E-03		
I-133	CI	<6.41E-03	<3.19E-03		
I-135	CI	<1.46E-01	<2.46E-02		
PARTICULATES					
BA-140	CI	<2.54E-03	<2.47E-03		
CO-58	CI	<2.33E-03	<2.23E-03		
CO-60	CI	6.86E-04	5.87E-04		
CS-134	CI	<1.62E-03	<1.81E-03		
CS-137	CI	<1.07E-03	<9.34E-04		
FE-59	CI	<4.16E-03	<9.39E-03		
LA-140	CI	<1.76E-03	<1.79E-03		
MN-54	CI	<3.96E-03	<1.30E-02		
NB-95	CI	<2.21E-03	<2.98E-03		
SR-89	CI	6.95E-06	2.81E-05		
SR-90	CI	3.00E-06	1.10E-06		
ZN-65	CI	<2.12E-03	<1.93E-03		
ZR-95	CI	<8.20E-03	<1.17E-02		

INSTALLATION=BROWN'S FERRY

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1978

LIQUID EFFLUENTS

NUCLIDES RELEASED	UNIT	CONTINUOUS MODE		BATCH MODE	
		QUARTER	QUARTER	QUARTER	QUARTER
		1	2	1	2
BA-140	CI	<1.13E-03	<6.80E-04		
Ce-141	CI	<2.00E-03	<1.74E-03		
CO-58	CI	<8.20E-03	<9.56E-03		
CO-59	CI	<5.45E-02	<4.61E-02		
CR-51	CI	1.18E-01	1.67E-01		
CS-134	CI	<4.76E-03	<3.76E-03		
CS-136	CI	<4.58E-03	<2.20E-03		
CS-137	CI	<1.45E-02	<1.26E-02		
FE-59	CI	<4.85E-03	<3.87E-03		
H-3	CI	9.08E 00	6.19E 00		
I-131	CI	<1.68E-02	<1.14E-02		
I-133	CI	<8.85E-03	<5.96E-03		
LA-140	CI	<1.13E-03	<6.80E-04		
MN-54	CI	<1.04E-02	<9.01E-03		
MN-56	CI	<8.61E-04	<4.24E-04		
MO-99	CI	<3.78E-03	<2.31E-03		
NR-24	CI	<1.24E-01	<3.29E-02		
NB-95	CI	<1.79E-02	<1.47E-02		
SR-89	CI	<4.57E-04	<7.25E-05		
SR-90	CI	<2.28E-04	2.35E-05		
TC-99M	CI	<3.78E-03	<2.31E-03		
XL-133	CI	<2.87E-02	<7.71E-02		
XL-135	CI	<2.49E-02	<2.36E-02		
ZN-65	CI	<5.46E-02	<4.14E-02		
ZR-95	CI	<2.29E-02	<2.54E-02		

INSTALLATION-BROWN'S FERRY

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1978

LIQUID EFFLUENTS

NUCLIDES RELEASED	UNIT	CONTINUOUS MODE		BATCH MODE	
		QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
HA-140	CI	<5.15E-04	<6.75E-04		
CE-141	CI	<2.15E-03	<3.85E-03		
CO-58	CI	<8.26E-03	<1.16E-02		
CO-60	CI	<2.98E-02	<1.02E-01		
CR-51	CI	1.21E-01	2.48E-01		
CS-134	CI	<6.91E-03	<1.67E-02		
CS-136	CI	<2.28E-03	<8.59E-03		
CS-137	CI	<1.56E-02	<2.79E-02		
FE-59	CI	<3.51E-03	<6.53E-03		
H-3	CI	6.32E 00	9.21E 00		
I-131	CI	<1.65E-02	<2.66E-02		
I-133	CI	<4.60E-03	<9.83E-02		
LA-140	CI	<5.15E-04	<6.75E-04		
MN-54	CI	<6.43E-03	<1.99E-02		
MN-56	CI	<3.74E-04	<1.26E-03		
MO-99	CI	<1.53E-03	<1.70E-03		
NA-24	CI	<1.19E-02	<4.56E-02		
NB-95	CI	<1.33E-02	<4.33E-02		
SR-89	CI	<1.87E-04	2.93E-04		
SR-90	CI	<1.19E-04	2.94E-04		
TC-99M	CI	<1.53E-03	<1.70E-03		
XE-133	CI	<1.34E-01	<4.96E-02		
XE-135	CI	<6.46E-02	<3.01E-02		
-65	CI	<3.70E-02	<1.14E-01		
ZR-95	CI	<1.33E-02	<4.33E-02		

INSTALLATION=PROSPECTS FERRY

EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT 1978

LIQUID EFFLUENTS-SUMMATION OF ALL RELEASES

	UNIT	QUARTER 1	QUARTER 2	EST. TOTAL ERROR, %
A. FISSION AND ACTIVATION PRODUCTS				
1. TOTAL RELEASE (NOT INCLUDING TRITIUM, GASES, ALPHA)	CI	5.60E 00	2.80E 00	
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	UCI/ML	1.98E -08	2.13E -08	
3. PERCENT OF APPLICABLE LIMIT	%	28	14	
B. TRITIUM				
1. TOTAL RELEASE	CI	9.08E 00	6.19E 00	
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	UCI/ML	3.20E -08	4.05E -08	
3. PERCENT OF APPLICABLE LIMIT	%	1.07E -03	1.35E -03	
C. DISSOLVED AND ENTRAINED GASES				
1. TOTAL RELEASE	CI	< 1.09E -01	< 2.44E -01	
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	UCI/ML	< 3.84E -10	< 1.95E -09	
3. PERCENT OF APPLICABLE LIMIT	%	6.41E -03	3.25E -02	
D. GROSS ALPHA RADIOACTIVITY				
1. TOTAL RELEASE	CI	1.03E -04	< 5.14E -04	
E. VOLUME OF WASTE RELEASED (PRIOR TO DILUTION)				
	LITERS	1.35E 07	8.27E 06	
F. VOLUME OF DILUTION WATER USED DURING PERIOD				
	LITERS	2.84E 11	1.34E 11	

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1974

LIQUID EFFLUENTS-SUMMATION OF ALL RELEASES

	UNIT	QUARTER 3	QUARTER 4	EST. TOTAL ERROR, %
A. FISSION AND ACTIVATION PRODUCTS				
1. TOTAL RELEASE (NOT INCLUDING TRITIUM, GASES, ALPHA)	CI	1.73E 00	3.06E 00	
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	UCI/ML	1.68E -08	1.99E -08	
3. PERCENT OF APPLICABLE LIMIT	%	8.65E 00	1.53E 01	
B. TRITIUM				
1. TOTAL RELEASE	CI	6.32E 00	9.21E 00	
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	UCI/ML	6.08E -08	5.98E -08	
3. PERCENT OF APPLICABLE LIMIT	%	2.03E -03	2.00E -03	
C. DISSOLVED AND ENTRAINED GASES				
1. TOTAL RELEASE	CI	< 2.55E -01	< 3.37E -01	
2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	UCI/ML	< 2.45E -09	< 2.19E -09	
3. PERCENT OF APPLICABLE LIMIT	%	4.08E -02	3.65E -02	
D. GROSS ALPHA RADIOACTIVITY				
1. TOTAL RELEASE	CI	1.16E -05	< 1.87E -02	
E. VOLUME OF WASTE RELEASED (PRIOR TO DILUTION)				
	LITERS	7.03E 06	1.06E 07	
F. VOLUME OF DILUTION WATER USED DURING PERIOD				
	LITERS	1.04E 11	1.54E 11	

ATTACHMENT 1

MAXIMUM PERMISSIBLE CONCENTRATIONS

- a. Fission and Activation Gases: Not Applicable
- b. Iodines: Not Applicable
- c. Particulates, half-lives >8 days: Not Applicable
- d. Liquid effluents: sum of indiv. MPC ratios \leq 1
(ref. 10 CFR 20, Appendix B, note 1)

ATTACHMENT 2

MEASUREMENTS AND APPROXIMATIONS OF TOTAL RADIOACTIVITY

a,b,&c. Fission and Activation Gases, Iodines, Particulates:
Airborne effluent gaseous activity is continuously monitored and recorded; additionally, grab samples are taken and analyzed monthly to determine specific radionuclide activity concentrations. Stack and building vent effluent flow rates are calculated once a shift based on the configuration of operating exhaust fans. The flow rate is consolidated weekly to determine the volume of airborne effluents released from the plant.

Charcoal and particulate samples are taken and analyzed at least weekly to determine specific activity concentrations. The total activity released from the plant is then calculated by taking weekly activity concentration values and multiplying them by the weekly airborne effluent volume.

Allowance is made for a plus or minus one sigma counting error associated with J^2 isotopic analyses.

d. Liquid Effluents

Gross beta, gamma and total γ isotopic activity concentrations are determined on each batch of liquid effluent before release. The total curie content of a released batch is determined by multiplying the highest of the above three activity concentrations by the total volume discharges. The total activity released during a month is then determined by summing the activity content of each batch discharged during the month.

Allowance is made for plus or minus one sigma counting error associated with the total γ isotopic analyses.