

TENNESSEE VALLEY AUTHORITY

CHAATANOOGA, TENNESSEE 37401
1750 Chestnut Street Tower II

October 14, 1980

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 1 - DOCKET
NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 - REPORTABLE OCCURRENCE
REPORT SCRO-50-327/8065 REVISION 1

The enclosed report is a supplement to my letter dated June 23, 1980,
concerning four mechanical penetrations passing through a fire zone
boundary leading into the emergency gas filter treatment system filter
room in the auxiliary building which were discovered to be breached.
This report is submitted in accordance with Sequoyah unit 1 Technical
Specifications 3.7.12 and 6.9.2.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. R. Callahan
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Director (40)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Bill Lavallee
Nuclear Safety Analysis Center
Palo Alto, California 94303

Mr. W. T. Cottle, NRC Inspector, Sequoyah

801021C 669

5

A002
5/11