



**PUBLIC SERVICE COMPANY OF COLORADO**

P. O. BOX 840 · DENVER, COLORADO 80201

OSCAR R. LEE  
VICE PRESIDENT

November 12, 1982  
Fort St. Vrain  
Unit No. 1  
P-82518

Mr. John T. Collins, Regional Administrator  
U. S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76112

SUBJECT: I & E Inspection Report 82-23

Dear Mr. Collins:

This letter is in response to the Notice of Violation resulting from inspections conducted at this facility during the period September 1, 1982, through September 30, 1982. The specific items found in violation and responses are as follows:

Based on the results of an NRC inspection conducted during the period of September 1-30, 1982, and in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C), 47 FR 9987, dated March 9, 1982, the following violation was identified:

Technical Specification 7.4.a, "Procedures, Administrative Controls," states, in part that, "...written procedures shall be established, implemented, and maintained..."

Standard Operating Procedure SOP 62, Revision 24, dated March 22, 1982, Section 2.3.6, Step 2.3.6.5, states, "At the time the release is initiated, visually verify flow through the sight flow indicator to RT-6212 and 6213 and record verification and time in the station log."

Contrary to the above, on September 9, 1982, the NRC inspector determined that the licensee had not recorded the verification as required by SOP 62.

- 1) The corrective steps which have been taken and the results achieved:

The operators were all verbally instructed in the requirement to log the flow verification through RT-6212 and 6213 in their narrative log. The next batch release was made from the reactor building sump on September 27, 1982, and the flow verification was logged properly at that time.

- 2) Corrective steps which will be taken to avoid further violations:


A memo dated November 12, 1982, was sent to all equipment operators and shift supervisors reminding them of the procedural requirements of SOP 62.

- 3) The date when full compliance will be achieved:

Full compliance regarding the above violation was achieved on September 27, 1982, when the sample flow verification was logged as required by the procedure.

Should you have any further questions, please contact Mr. Edwin D. Hill, (303) 571-7436, extension 201.

Very truly yours,

  
Oscar R. Lee

ORL/alk

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter )  
 )  
Public Service Company of Colorado ) Docket No. 50-267  
Fort St. Vrain Unit No. 1 )

AFFIDAVIT

Oscar R. Lee being duly sworn, hereby deposes and says that he is Vice President of Electrical Production of Public Service Company of Colorado; that he is duly authorized to sign and file with the Nuclear Regulatory Commission the attached response to the Notice of Violation identified in NRC Inspection Report 82-23; that he is familiar with the content thereof; and that the matters set forth therein are true and correct to the best of his knowledge, information and belief.




O. R. Lee

Vice President of Electrical Production

STATE OF COLORADO )  
 ) ss  
COUNTY OF DENVER )

Subscribed and sworn to before me, a Notary Public in and for P.S. Co. of Colo.  
on this 17 TH day of NOVEMBER, 1982.



Notary Public

My commission expires OCTOBER 7, 1983