LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[0 1] C T N M S 1 (2) 0 0 - 0 0 0 0 0 - 0 0 (3) 4 1 1 1 1 (4) [ ] (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
[0 1] REPORT SOURCE L (6) 0 5 0 0 0 2 4 5 (7) 1 1 0 6 8 0 (8) 1 1 2 0 8 0 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[0 2] On November 6, 1980 at 0925 hours during performance of Class II Inservice
[0 3] Inspection of the Isolation Condenser System, liquid penetrant examination of the
[0 4] inside diameter of the steam supply piping nozzle -to-isolation condenser vessel
[0 5] weld revealed circumferential cracking on both sides of the weld in the heat
[0 6] affected zone. See attachment.
[0 7]
[0 8]
[0 9]

[0 9] SYSTEM CODE C F (11) — CAUSE CODE X (12) — CAUSE SUBCODE Z (13) — COMPONENT CODE P I P E X X (14) — COMP. SUBCODE D (15) — VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER — EVENT YEAR 8 0 — [—] — SEQUENTIAL REPORT NO. 0 1 9 — [/] — OCCURRENCE CODE 0 1 — REPORT TYPE T — [—] — REVISION NO. 0

ACTION TAKEN B (18) — FUTURE ACTION X (19) — EFFECT ON PLANT Z (20) — SHUTDOWN METHOD Z (21) — HOURS (22) 0 0 0 0 — ATTACHMENT SUBMITTED Y (23) — NPRD-4 FORM SUB. N (24) — PRIME COMP. SUPPLIER N (25) — COMPONENT MANUFACTURER G 0 8 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

[1 0] The cause of weld degradation is not known at the present time. Evaluation is in
[1 1] progress and repairs will be made as necessary. In addition, all supply and return
[1 2] piping welds will be ultrasonically tested. See attachment.
[1 3]
[1 4]

[1 5] FACILITY STATUS H (28) — % POWER 0 0 0 (29) — OTHER STATUS (30) NA — METHOD OF DISCOVERY B (31) — DISCOVERY DESCRIPTION (32) Inservice Inspection

[1 6] ACTIVITY RELEASED Z (33) — CONTENT OF RELEASE Z (34) — AMOUNT OF ACTIVITY (35) NA — LOCATION OF RELEASE (36) NA

[1 7] PERSONNEL EXPOSURES — NUMBER 0 0 0 (37) — TYPE Z (38) — DESCRIPTION (39) NA

[1 8] PERSONNEL INJURIES — NUMBER 0 0 0 (40) — DESCRIPTION (41) NA

[1 9] LOSS OF OR DAMAGE TO FACILITY (42) — TYPE Z — DESCRIPTION NA

[2 0] PUBLICITY — ISSUED N (44) — DESCRIPTION (45) NA

8011250385

NRC USE ONLY