

Tic

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-5001

1981 11 27 11 27  
SHIELDS L. DALTROFF  
VICE PRESIDENT  
ELECTRIC PRODUCTION  
PHILADELPHIA ELECTRIC COMPANY

December 1, 1980

Re: Docket Nos. 50-277  
50-278

IE Bulletin 80-17

Mr. Boyce W. Grier, Director  
Office of Inspection and Enforcement  
Region I  
US Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

Dear Mr. Grier:

This letter concerns the Confirmatory Orders for Peach Bottom Units 2 and 3 sent by Victor Stello to S. L. Daltroff on October 2, 1980 that require certain actions to be completed by December 1, 1980. These actions are restated below.

- III. 1. By December 1, 1980, the licensee shall:
  - a) Install and make operable a system to continuously monitor water levels in all scram discharge volumes (SDV).
  - b) The installed system shall provide for level-indication, with an associated alarm, in the control room, for each SDV. This equipment shall provide sufficient information to the reactor operator such that if water accumulates in either SDV the decision about actions to be taken can be made in a timely fashion from the control room.


THIS DOCUMENT CONTAINS  
POOR QUALITY PAGES

8102080234 Q

This letter is to confirm that as of November 29, 1980 Peach Bottom Units 2 and 3 have operable systems to continuously monitor water level in scram discharge volumes that fulfill the above requirements.

If you have any questions or require additional information, do not hesitate to contact us.

Very truly yours,

A handwritten signature in cursive script, appearing to read "A. J. [unclear]", is written in dark ink on the page.