

JAN 18 1983

50-255

MEMORANDUM FOR: Frank Miraglia, Assistant Director
for Safety Assessment, DL

FROM: L. S. Rubenstein, Assistant Director
for Core and Plant Systems, DSI

SUBJECT: PALISADES TECHNICAL SPECIFICATION CHANGE REQUEST ON
SAFETY INJECTION TANK BORON CONCENTRATION (TAC #49281)

The Reactor Physics Section of the Core Performance Branch has reviewed the Technical Specification changes requested by Consumers Power Company (CP) in the letter from D. J. VandoHalle (CP) to D. M. Crutchfield (IPC) dated December 15, 1982. The proposed changes provide limiting conditions for operation, the surveillance requirements and the basis for a reduction in the required boron concentration in Safety Injection Tank T-82R for the remainder of Cycle 5.

We find the proposed changes acceptable.

Original signed by
L. S. Rubenstein

L. S. Rubenstein, Assistant Director
for Core and Plant Systems, DSI

Enclosure:
As stated

DISTRIBUTION:

cc: R. Mattson
D. Eisenhut
D. Crutchfield
T. Wambach
D. Capra

~~CPB reading~~
CPB reading
LRubenstein
CBerlinger
DFieno
NLauben
LKopp

Contact: L. Kopp
X-20481

8301250195 830118
CP ADOCK 03000255
CF

XA

B/C

DF

C43

OFFICE	DSI:CPB	DSI:RSB	DSI:CPB	DSI:CPB	AG:CPB:DSI	
SURNAME	LKopp;ld	NLauben	DFieno	CBerlinger	LRubenstein	
DATE	1/17/83		1/17/83	1/18/83	1/18/83	