



Carolina Power & Light Company

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429
January 26, 1983

83 JAN 28 P 4 10

FILE: B09-13510A
SERIAL: BSEP/83-203

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street N.W.
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 AND 50-324
LICENSE NOS. DPR-71 AND DPR-62
RESPONSE TO IE BULLETIN 80-13

Dear Mr. O'Reilly:

In response to your letter of April 4, 1980, transmitting IE Bulletin 80-13, Carolina Power and Light Company submits the following information:

The Brunswick Steam Electric Plant Unit No. 1 core spray spargers and in-vessel piping have been visually inspected using Periodic Test 90.1, and no indication of cracking was noted. This inspection was completed on January 15, 1983.

As requested in the bulletin, each unit will be inspected during all future refueling outages until further notice with a follow-up report to be issued within thirty (30) days of the completion of the test.

Very truly yours,

P. W. Howe, Vice President
Brunswick Nuclear Project

RMP/gvc/LETGC1

cc: Mr. R. C. DeYoung

8302150080 830126
PDR ADOCK 05000324
Q PDR

IE11