



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 8, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Fire Doors Blocked Open to
Facilitate Planned
Maintenance
LER 83-006/03 L-0
AECM-83/0087

On January 12, 1983, fire doors OC714 and OCT10 were temporarily blocked open to facilitate planned maintenance in the area. Fire watches were posted in accordance with Technical Specification 3.3.7.9. The event is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 82-006/03 L-0.

Yours truly,

J.P. McGaughey
for J.P. McGaughey

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY

TE 22

8302150083 830208
PDR ADGCK 05000416
S PDR