

APPENDIX A
NOTICE OF VIOLATION

Florida Power Corporation
Crystal River Unit 3

Docket No. 50-302
License No. DPR-72

As a result of the inspection conducted on April 27 - May 25, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified.

Technical Specification 6.11 requires procedures to meet the requirements of 10 CFR, Part 20 be adhered to for all activities involving personnel radiation exposure.

Radiation Protection Procedure, RP-101, Section 4.8.2, requires an individual entering a contaminated area to wear proper clothing necessary for contamination control as specified by a standing radiation work permit (SRWP).

Contrary to the above, on May 5, 1982, two individuals were observed on separate occasions entering a contaminated area without the proper clothing requirements specified on the SRWP.

This is a Severity Level IV Violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Date: JUN 13 1982