NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION
Attachment to AECM-83/0087
Page 1 of 1

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | MSGGS1 (2) | 00-00000-00 (3) | 41111 (4) | (5)
LICENSEE CODE (7–14) LICENSE NUMBER (15–25) LICENSE TYPE (26–30) CAT (57–58)

CON'T
01 | REPORT SOURCE L (6) | 05000416 (7) | 011283 (8) | 020883 (9)
DOCKET NUMBER (60–68) EVENT DATE (69–74) REPORT DATE (75–80)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 Fire doors OC714 and OCT10 were temporarily blocked open to facilitate planned
03 maintenance in the area. Fire watches were posted in accordance with T.S.3.3.7.9.
04 This had no effect on the health and safety of the public and did not constitute a
05 threat to plant safety. This event is being reported pursuant to T.S.6.9.1.13.b.
06
07
08

09 | SYSTEM CODE AB (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE ZZZZZZ (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 83 — SEQUENTIAL REPORT NO. 006 / OCCURRENCE CODE 03 REPORT TYPE L — REVISION NO. 0

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z999 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Fire doors were temporarily blocked open to facilitate planned maintenance activites.
11 They were closed at the completion of work on January 12. The LCO was in effect
12 for eleven hours. All corrective action is considered complete. This is a final
13 report.
14

15 | FACILITY STATUS G (28) | % POWER 000 (29) | OTHER STATUS NA (30) | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION Planned Action (32)

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY NA (35) | LOCATION OF RELEASE NA (36)

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION NA (39)

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION NA (41)

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION NA (43)

20 | PUBLICITY ISSUED N (44) | DESCRIPTION NA (45) | NRC USE ONLY

8302150094 830208
PDR ADOCK 05000416
S PDR

NAME OF PREPARER Original signed by John P. Bailey PHONE

GPO 917-926