



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 8, 1983

JAMES P. MCGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Smoke Detection Zone Alarmed
and Would Not Reset
LER 82-187/99 X-0
AECM-83/0088

On December 29, 1982, with the plant in cold shutdown, the smoke detection zone covering the Auxiliary Building corridors alarmed and would not reset. The zone was deactivated and an hourly fire watch was established in accordance with Technical Specification 3.3.7.9. Attached is Special Report LER 82-187/99 X-0.

Yours truly,

J.P. McGaughy
for J.P. McGaughy

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8302150110 830208
PDR ADOCK 05000416
S PDR

OFFICIAL COPY
IE 22