

APPENDIX B

NOTICE OF DEVIATION

Carolina Power & Light Company
H. B. Robinson 2

Docket No. 50-261
License No. DPR-23

Based on the results of the NRC inspection conducted on October 11 - November 10, 1982, certain of your activities appear to deviate from your commitments to the Commission as indicated below.

CP&L letter GD-28-231, Reactor Vessel Overpressure Protection Request for License Amendment, dated January 25, 1978 committed to installation of a low pressure alarm on the backup nitrogen system for the low temperature overpressure protection system.

Contrary to the above, as of November 1, 1982, a low pressure alarm had not been installed on the backup nitrogen system.