

ATTACHMENT I

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50/395

UNIT V.C. Summer I

DATE 02-10-83

COMPLETED BY G.J. Taylor

TELEPHONE (803) 345-5209

MONTH JANUARY 1983

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>416</u>
2	<u>412</u>
3	<u>419</u>
4	<u>416</u>
5	<u>413</u>
6	<u>416</u>
7	<u>417</u>
8	<u>414</u>
9	<u>413</u>
10	<u>414</u>
11	<u>409</u>
12	<u>409</u>
13	<u>407</u>
14	<u>408</u>
15	<u>411</u>
16	<u>412</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>410</u>
18	<u>169</u>
19	<u>330</u>
20	<u>408</u>
21	<u>412</u>
22	<u>201</u>
23	<u>398</u>
24	<u>411</u>
25	<u>416</u>
26	<u>402</u>
27	<u>402</u>
28	<u>400</u>
29	<u>223</u>
30	<u>390</u>
31	<u>399</u>

ATTACHMENT II
OPERATING DATA REPORT

DOCKET NO. 50/395
 UNIT V.C. Summer I
 DATE 02-10-83
 COMPLETED BY G.J. Taylor
 TELEPHONE (803) 345-5209

OPERATING STATUS

1. REPORTING PERIOD: JANUARY 1983 GROSS HOURS IN REPORTING PERIOD: 744
 2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 2775 MAX. DEPEND. CAPACITY (MWe-Net): N/A
 DESIGN ELECTRICAL RATING (MWe-Net): 900
 3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): N/A (50% MWth)

4. REASONS FOR RESTRICTION (IF ANY):

The operating license allows operations to
 50% MWth for power operations testing.

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL	<u>728.5</u>	<u>728.5</u>	<u>2035.3</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE	<u>710.7</u>	<u>710.7</u>	<u>1472.0</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)	<u>975,351</u>	<u>975,351</u>	<u>1,771,224</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>311,300</u>	<u>311,300</u>	<u>527,517</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>287,476</u>	<u>287,476</u>	<u>478,672</u>
12. REACTOR SERVICE FACTOR	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
13. REACTOR AVAILABILITY FACTOR	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
14. UNIT SERVICE FACTOR	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
15. UNIT AVAILABILITY FACTOR	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
16. UNIT CAPACITY FACTOR (Using MDC)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
18. UNIT FORCED OUTAGE RATE	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):

D-3 Steam Generator Modification -- March 1983 through May 1983

20. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: N/A

21. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):	FORECAST	ACHIEVED
INITIAL CRITICALITY	<u>10-20-82</u>	<u>10-22-82</u>
INITIAL ELECTRICITY	<u>11-17-82</u>	<u>11-16-82</u>
COMMERCIAL OPERATION	<u> </u>	<u> </u>

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50/395

UNIT NAME V.C. Summer I

DATE 02-10-83

COMPLETED BY G.J. Taylor

TELEPHONE (803) 345-5209

REPORT MONTH JANUARY 1983

NO.	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER (2)	CORRECTIVE ACTIONS/COMMENTS
1	830118	F	16.1	A	3	1) Reactor trip due to Hi bearing vibration in turbine, caused by loose connections in turbine supervisory cabinet.
2	830122	F	8.9	B	3	2) Turbine trip, reactor trip while performing a vibration monitoring surveillance.
3	830129	F	8.3	B	2	3) Manual reactor trip due to inadvertantly dropping four (4) control rods (instead of two (2) control rods) while performing Nuclear Instrumentation Negative Rate Reactor Trip Test.

Director, Office of Management and
Program Analysis
Monthly Operating Report
Page 5
February 10, 1983

ATTACHMENT IV
NARRATIVE SUMMARY OF OPERATING EXPERIENCE

Virgil C. Summer Nuclear Station, Unit No. 1, has been in the process of continuing the power ascension test program at a 50% of rated thermal power level.

A reactor trip occurred at 1051 hours January 18, 1983, from a 50% power level. The trip was due to a turbine trip on Hi bearing vibration. An investigation revealed that a spurious trip signal was generated due to loose electrical connections in the turbine supervisory cabinet.

A reactor trip occurred at 1150 hours January 22, 1983, from a 50% power level. The reactor trip was due to a turbine trip while performing a surveillance test on the main turbine control and stop valves.

A reactor trip occurred at 1337 hours January 29, 1983, from a 50% power level. The reactor was tripped manually, when four (4) control rods [instead of two (2)] were inadvertently dropped, while performing a Nuclear Instrumentation Negative Rate Reactor Trip Test.

Virgil C. Summer Nuclear Station is presently operating at a 50% power level and continuing the power ascension test program.