NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | C A S 0 S 3 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 6 2 (7) | 1 2 1 7 8 2 (8) | 0 1 2 8 8 1 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While in Mode 5, Zone 41 (Cable Spreading Room) fire detectors were removed from
03 service to permit repair of cables. Fire watches were established and spray/
04 sprinkler systems remained operable, hence there was no impact on health and
05 safety of plant personnel or the public.
06
07
08

09 SYSTEM CODE A B (11) | CAUSE CODE B (12) | CAUSE SUBCODE C (13) | COMPONENT CODE I N S T R U (14) | COMP. SUBCODE E (15) | VALVE SUBCODE Z (16)

(17) LER RO REPORT NUMBER: EVENT YEAR 8 2 | — | SEQUENTIAL REPORT NO. 0 1 1 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN A (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP SUPPLIER A (25) | COMPONENT MANUFACTURER P 4 3 5 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Cable damaged (minor) during construction activities in area. Cable was replaced.
11 Further corrective action is not deemed necessary.
12
13
14

15 FACILITY STATUS B (28) | % POWER 0 0 0 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) QA Inspection

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A

17 PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) N/A

18 PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) N/A

8302150155 830128
PDR ADOCK 05000362
S PDR

19 LOSS OF OR DAMAGE TO FACILITY (43) TYPE Z (42) | DESCRIPTION N/A

20 PUBLICITY ISSUED N (44) | DESCRIPTION (45) N/A | NRC USE ONLY

NAME OF PREPARER H.B. RAY HB Ray / [illegible] PHONE 714-492-7700