



Omaha Public Power District

1623 HARNEY ■ OMAHA, NEBRASKA 68102 ■ TELEPHONE 536-4000 AREA CODE 402

February 3, 1983
LIC-83-039

Mr. Robert A. Clark, Chief
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Division of Licensing
Operating Reactors Branch No. 3
Washington, D.C. 20555

Reference: Docket No. 50-285

Dear Mr. Clark:

Iodine Spiking Amendment Application

Omaha Public Power District submitted an amendment application dated November 14, 1980 which proposed to revise the Fort Calhoun Station Technical Specifications (TS) to incorporate additional operating limits and surveillance requirements for radioactive iodine in the reactor coolant system. Numerous correspondence and discussions have ensued between the Commission and the District to resolve the Commission's concern regarding the 2.0 $\mu\text{Ci/gm}$ DOSE EQUIVALENT I-131 steady state limit for reactor coolant radioactivity which was requested in the subject application. The District recently agreed to lower this limit to 1.0 $\mu\text{Ci/gm}$, which is the value specified in the Combustion Engineering Standard Technical Specifications. This change should resolve the staff's concerns and the District has revised our amendment application accordingly. Therefore, please find attached revised Attachments A (proposed TS changes) and B (discussion) which replace those sections in the November 14, 1980 application.

Sincerely,

W. C. Jones
Division Manager
Production Operations

WCJ/TLP:jmn

Attachments

cc: LeBoeuf, Lamb, Leiby & MacRae
1333 New Hampshire Avenue, N.W.
Washington, D.C. 20036

Mr. E. G. Tourigny, NRC Project Manager
Mr. L. A. Yandell, NRC Senior Resident Inspector

0001