,	LICENSEE EVENT REPORT Update Report Previous Report Date 1-13-81
	CONTROL BLOCK: [] [] [] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	G A E I H 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5 6 5 15 CAT 58
0 1 7 8	REPORT LL 6 0 5 0 0 0 3 2 1 7 1 2 2 3 8 0 8 0 2 0 3 8 3 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2	While the unit was in steady state operation research for and prepara-
0 3	tion of the Unit 1 five-year ISI report revealed a lack of hard docu-
0 4	mentation proving visual inspection of at least 50% of the Unit 1 Class
0 5	1 valve (greater than 3" in diameter) internals as required by Tech.
06	Specs. 4.6.K. The health and safety of the public were not affected by
0 7	this non-repetitive event.
08	
0 9	SYSTEM CAUSE CAUSE SUBCODE SUB
	17 REPORT NUMBER 8 0 1 24 26 27 28 29 30 31 32
	ACTION FUTURE ACTION ON PLANT SHUTDOWN HOURS 22 ATTACHMENT FORM SUB. SUPPLIER SUPPLIER SUPPLIER MANUFACTURER G 8 Z 19 Z 20 Z 21 0 0 0 0 0 N 23 N 24 Z 25 Z 9 9 9 9 26 33 34 34 35 36 37 40 40 41 23 42 43 43 44 47 47
1 0	Plant procedures did not stress inspection of Class 1 valve (greater
	than 3") internals. All applicable Hatch Unit 1 and 2 procedures current
1 2	ly require inspection of applicable valve internals when disassembled
1 3	for maintenance.
(TI4)	
1 5	FACILITY STATUS OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 DISCOVERY DESCRIPTION 32 B0 B0 B0 B10 B12 B13 Research for ISI Five-Year Report B0
	ACTIVITY CONTENT ELEASED OF RELEASE AMOUNT OF ACTIVITY 35 NA LOCATION OF RELEASE 36 NA NA 80
1 7 8	PERSONNEL EXPOSURES NUMBER 0 0 0 37 Z 38 NA 9 11 12 13
18	PERSONNEL INJURIES NUMBER DESCRIPTION 41 NA
7 8	9 11 12 LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION 43
1 9	Z 42 NA 830203
20	PDR ADOCK 05000321 SSUED DESCRIPTION (45) PDR ADOCK 05000321 PDR 10 10 10 10 10 10 10 10 10 10 10 10 10
	NAME OF PREPARER H. L. Sumner - Supt. Plt. Eng. Serv. 912-367-7851