

RECEIVED
NRC

Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 1703 09 21 12:28

REGION V

January 17, 1983
G01-83-0023

DESIGNATED ORIGINAL

Certified by

Candy Geierle

U.S. Nuclear Regulatory Commission
Region V -
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

Attention: R.H. Engelken

Subject: NUCLEAR PROJECT NO. 1
IE BULLETIN NO. 82-04, DEFICIENCIES IN
PRIMARY CONTAINMENT ELECTRICAL PENETRATION
ASSEMBLIES

Reference: NRC IEB-82-04, dated December 3, 1982

IEB-82-04 is not applicable to the WNP-1/4 Project. All WNP-1/4 electrical penetration assemblies were furnished by Westinghouse Electric Company. The bulletin identified concerns related to electrical penetrations supplied by Bunker Ramo Company.

We consider this item closed.

Bill Root

R.W. Root
Program Director

CAB:cb

cc: G. Valentyeni-UE&C-8U6
A. Medici-UE&C-8U6
KJ Iverson-UE&C-898
FDCC-899
Document Control Desk-Washington, D.C.

1E11

STATE OF WASHINGTON)
COUNTY OF BENTON)

R. W. Root, being first duly sworn, deposes and says: That he is the Program Director, WNP-1/4, for the WASHINGTON PUBLIC POWER SUPPLY SYSTEM, the applicant herein; that he is authorized to submit the foregoing on behalf of said applicant; that he has read the foregoing and knows the contents thereof; and believes the same to be true to the best of his knowledge.

DATED January 17, 1983

R. W. Root
R. W. Root

On this day personally appeared before me R. W. ROOT to me known to be the individual who executed the foregoing instrument and acknowledged that he signed the same as his free act and deed for the uses and purposes therein mentioned.

GIVEN under my hand and seal this 17th day of January, 1983

Lynda R. Powell
Notary Public in and for the State of Washington

Residing at 4. B. Island