.7 77) LICENSEE EVENT REPORT LLLL! (PLEASE PRINT OR TYPE ALL REQUIRED INTORMATION) CONTROL BLOCK 10 15 12 3 0101 - 10101010101- 1010 3 41111111 0 CON'T 15 10 10 13 16 11 10 11 10 7 18 13 10 12 10 3 18 13 10 EVENT DATE 24 75 REPORT DATE 610 0 1 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) With Units 2 and 3 in Mod's 1 and 4, respectively, Train B ammonia analyzer 2/3 0 2 AIT-9782D2 failed to meet the channel functional test as required by Technical 03 Specification Surveillance Requirement 4.3.2.1 and was declared inoperable. There 0 4 was no impact on plant operation or the health and safety of plant personnel or the 0 5 public as a result of this occurrence, since the redundant Train A analyzer 0 6 remained operable throughout the event. 0 7 0 8 SYSTEM COMPONENT CODE CODE CODE 0000 IS RU (16) (13) (12) 0 9 SEQUENTIAL REVISION OCCURRENCE EPORT NO CODE 0 6 EPORT SUPPLIER OMPONENT SUBMITTED (22) HOURS 0 0 0 N (24) 3 (23) A CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) Inoperability of the analyzer was due to a faulty sample cell. The cell was 110 replaced and the analyzer declared operable in accordance with Procedure 111 S023-II-1.15 at 1100 on January 8, 1983. This was an isolated occurrence and 1 2 no further corrective action is planned. 13 1 4 NETHOD OF ACILI OTHER STATUS COVERY DESCRIPTION (32) DISCOVERY Surveillanc AMOUNT OF ACTIVITY 3 LOCATION OF RELEASE (36) NA DESCRIPTION 39 13 DESCRIPTION (41 010 я 11 AAGE TO FACILITY (43) 8302150281 830203 PDR ADOCK 5000361 IOT DESCRIPTION (45) NAC USE ONLY PDR NA Da/ R 71 4 / NAME OF PRESADER