

Schedule of Events

<u>Date</u>	<u>Time</u>	<u>Place</u>	<u>Event/Attendance Required</u>
10/12/93	1300-1600	MNS TR-155	Controller/Evaluator Training
10/14/93	0900-1200	MNS TR-155	Player Training
10/19/93	1300-1500	MNS TR-155	Controller/Evaluator Pre-brief
10/20/93			Annual Exercise
10/20/93	After Drill	MNS TR-155	Player Critique
10/21/93	0900-1200	MNS TR-155	* Controller/Evaluator Critique
10/21/93	1430-	MNS TR-155	NRC Critique

\* Controllers that will need to attend the NRC Critique will be determined at this critique.

9403250092 931231  
PDR ADDCK 05000369  
PDR  
F

250002

7E35

## McGuire Nuclear Station

### I. SCOPE AND OBJECTIVES

#### A. Scope

The 1993 McGuire Nuclear Station annual exercise is designed to meet the exercise requirements of 10CFR50, Appendix E, Section IV.T. The exercise will be conducted on October 20, 1993.

This exercise will involve participation of McGuire Nuclear Station emergency response personnel. The State and Counties will participate by staffing pre-designated relocation shelters and vehicle monitoring and decontamination stations. The Emergency Operations Facility (EOF) will participate.

The Annual Fire Drill and the Annual Medical drill will be part of the annual exercise.

A formal critique including Duke Power and the NRC will be held at 1430, October 21, 1993 at McGuire Nuclear Station. This critique will be closed to the public.

#### B. Exercise Objectives (Duke Power Emergency Organization

##### Emergency Management

1. Demonstrate the ability to declare emergency classifications in accordance to procedures.
2. Demonstrate the ability to notify the States and Counties within fifteen minutes after declaring an emergency or after changing the emergency classification.
3. Demonstrate proper use of the message format and authentication methodology for messages transmitted to States and Counties.
4. Demonstrate the ability to alert, notify, and staff the TSC, OSC, and EOF facilities after declaring an Alert or higher emergency class.
5. Demonstrate precise and clear transfer of responsibility from the Shift Supervisor (Emergency Coordinator) in the Control Room to the Emergency Coordinator in the TSC.

6. Demonstrate the ability to notify the NRC not later than one hour after declaring one of the emergency classes.
7. Demonstrate assembly of station personnel within 30 minutes in a simulated emergency and provide accountability for any not present at the assembly locations.
8. Test communications equipment among on-site emergency facilities including plant extensions and intercoms.
9. Test off-site communications equipment to the County and State warning points, County and State Emergency Operations Centers and to the NRC including the Selective Signal System and the NRC Emergency Notification System.
10. Test the adequacy and operability of emergency equipment/supplies.
11. Evaluate the adequacy of the following assessment tools, as applicable:
  1. Drawings
  2. Data Displays
  3. Maps
12. Demonstrate precise and clear transfer of responsibility from the Emergency Coordinator in the TSC to the Emergency Operations Facility Director.

#### Accident Assessment

13. Demonstrate the ability to transmit data using the "Emergency Operations Facility Data Transmittal System in accordance with procedures and to distribute this data throughout the EOF.
14. Demonstrate the ability to provide data to the TSC and OSC in accordance with station procedures.
15. Demonstrate the ability to locate a simulated, radioactive plume and to measure the off-site radiation levels.
16. Demonstrate adequate radio communications between the off-site monitoring teams and the TSC/EOF.
17. Demonstrate the ability to develop off-site dose

projections in accordance with procedures.

18. Demonstrate the ability to collect soil, water and vegetation samples in accordance with procedures.
19. Demonstrate the ability to continuously monitor and control emergency worker exposure.
20. Demonstrate the ability to determine on-site radiation levels and airborne radioiodine concentrations.

Protective Action Recommendations

21. Demonstrate the ability to provide timely and appropriate protective action recommendations to off-site officials in accordance with station procedures.

Plant Operations

22. Demonstrate the ability to assess the incident and provide mitigation strategies.

Fire Drill

23. Demonstrate proper plant personnel response to a simulated fire emergency and timely backup assistance from the off-site fire support agency.

Medical Drill

24. Demonstrate proper response to a simulated medical emergency involving a contaminated patient in accordance with station procedures.

Other

25. Demonstrate resolution of previous exercise findings (weaknesses, deficiencies) identified by evaluators, QA, or NRC, as applicable.

## CONDUCT OF EXERCISE

### A. Exercise Organization

The Exercise Organization is made up of controllers, evaluators, observers, players and trainees as described below.

#### Controller/Evaluators

Controllers and evaluators are assigned to specific locations and/or groups as described in part B of this section.

Controllers and evaluators are selected based on their expertise or qualifications to evaluate their assigned area.

In many instances, one person may serve in a dual capacity as both controller and evaluator. Duke Power controllers and evaluators will be identified by wearing armbands or tags.

Controllers are responsible for:

- Maintaining action according to the scenario.
- 2) Providing input messages and data.

Controllers will provide simulated plant parameters and information in the form of exercise messages to appropriate players throughout the exercise.

Evaluators are responsible for:

- 1) Observing players as they work in their specialized functions
- 2) Compiling observations and judgments onto the evaluation forms
- 3) Generation "good practices" and or "action items," as appropriate.

Evaluators will observe players response to the messages and data sheets they are given. Each evaluator should generate a chronology of events observed throughout the exercise. Following the exercise, evaluation sheets should be completed and action items and/or good practices developed.

### Observers

Observers from Duke Power, other utilities, and State and local officials may be authorized to observe various aspects of the exercise. Participation will be limited to observing player actions only. Observers should not interact with players during the exercise.

Observers will be identified by wearing armbands or tags.

### Players

Players include Duke Power personnel assigned to perform functions of the Emergency Plan in the Control Room, Technical Support Center, Operational Support Center, Emergency Operations Facility and other Company personnel that may be assigned as players.

The success of the exercise is largely dependent on player reaction and knowledge of the emergency plan and procedures. Some information and situations affecting player reaction will exist at the time the exercise begins (initial conditions). Most of this input, however, will be introduced by controllers throughout the course of the exercise. Players are responsible for initiating actions according to the procedures, responsibilities, and tasks outlined for their particular function in the emergency plan and implementing procedures.

Players should react to scenario information as it is presented to them. During the exercise is not the appropriate time to critique and comment on the scenario data or information. This does not mean, however, that questions cannot be asked of controllers to provide clarification, if needed.

B. Controller/Evaluator Assignments

<u>Function</u>	<u>Number of Controller/Evaluators</u>
Exercise Director	1
Simulator Control Room	3
TSC Overall	1
TSC Radiation Protection	1
TSC Data	1
TSC Off-Site Agency Communications	1
OSC Safety	2
OSC Security	1
OSC Overall	1
OSC Radiation Protection	3
OSC Chemistry	1
OSC Maintenance	2
OSC Instrument and Electrical	3
OSC Operations	3
Off-site Rad. Monitoring	4
EOF Overall	2
EOF Rad. Assessment	2
EOF Accident Assessment	1
Emergency Communications	1
News Group	2

#### C. Exercise Messages and Data

White message sheets with notes to controllers are kept by the controller/evaluators to allow review of those actions that the players should initiate. Colored message sheets without the notes to controllers will be given to the players at the indicated times. Contingency messages will be given to the players, as necessary, to keep the scenario on track or to provide information contingent upon player actions.

The scenario will be driven by the simulator. Operators will receive indications directly from the simulator at the training center. Personnel at other locations will receive simulated plant data either through the data transmittal system (with pre-programmed exercise data) or through other communications. Hardcopy data sheets showing "snapshots" of plant parameters will be printed and given to the players in the simulator area, TSC and OSC if a problem occurs with the simulator.

Off-site and on-site radiological monitoring data will be provided to the players after an actual reading has been made. Radiological and chemistry sample results will be provided after samples are pulled and analyzed. Any exceptions are noted in exercise messages.

#### D. Exercise Rules

1. Initial plant conditions will be given to players prior to the start of the exercise. This information will only be given to those persons that would normally be aware of such information.
2. Controllers will be available in the Technical Support Center, Operational Support Center, Simulator Control Room Emergency Operations Facility and field monitoring vehicles. Controllers will provide message sheets, data sheets, on-site/off-site radiological data, or other information, as appropriate, for players to respond to. Scenario data will only be provided to players after they have gone to the persons or places where that data would be available in an actual emergency.
3. Player response should be real-time, with no simulated actions unless directed otherwise by the controller. Generally, emergency response activities should be performed fully and NOT simulated unless personnel safety, plant safety, or unit operation would be jeopardized.

4. For ALARA reasons, exercise participants should not enter actual high radiation areas. Instead, players should go to the general area and make the controller aware of their intended response.
5. If a procedure must be simulated, it is the player's responsibility to ensure that the controller is fully aware of any actions taken. If information is needed for player response, it is appropriate to ask questions of the controller. **HOWEVER, DO NOT TALK TO CONTROLLERS UNLESS ABSOLUTELY NECESSARY.**
6. Respirators do not have to be worn by exercise participants. Administrative controls for respirator issue, however, will be followed. Radiation Protection will issue a tag to indicate that a respirator is being worn, and tag out the respirator being issued. Air bottles will be real-time (approximately 30 minutes supply per bottle).
7. Anti-C's will be worn by players if required by Radiation Protection practices or procedure. NO exceptions will be allowed unless directed otherwise by the controller.
8. All phone and radio communications required by procedure will be made unless directed otherwise by the controller. Calls generally should not be made to persons, groups or organizations that are not participating in the exercise. Communications should begin and end with the statement "This is a drill."
9. Once Site Assembly has been achieved, those persons not directly participating in the exercise will be told to return to their normal work area.
10. Site evacuation of non-essential personnel, if required, will be simulated.
11. A helicopter for off-site monitoring, if needed, will be simulated.
12. Players will be identified by colored armbands or tags.  
Controllers, evaluators observers, and trainees will be identified by appropriately labelled armbands or tags.

13. Observer participation will be limited to observing player actions only. Observers should not interact with players during the exercise.

### III. CRITIQUE

Critiques should serve as a feedback mechanism to identify and correct faults discovered during the exercise. The discussions held by key players and controller/evaluators during the critiques are often the only opportunity for integrating all comments and developing an accurate overall picture of performance during an exercise. The written logs and comments of each controller/evaluator will provide valuable information for later evaluation. However, each individual is capable of viewing only a small portion of an entire exercise and, in some cases, views only a small portion of a particular task. The critiques serve to clear up misconceptions that may result from limited individual viewpoints, and help participants put all of the comments in perspective.

#### Process

Controller/evaluators should attend the player critique to obtain any information that may have been missed or misunderstood during the exercise in order to provide for a more thorough evaluation.

Immediately following the player critique, the lead controllers (for TSC, OSC, Off-Site, Control Room, and EOF) should meet with the controller/evaluators in their area of evaluation. Each controller/evaluator should complete and sign their evaluation form and generate action items and/or good practices (see sections below instructions). The lead controller should then work with group members to determine if the exercise objectives were adequately met and to ensure action items are written for objectives that were not met. Additional action items may also be generated for areas where improvement is needed. The lead controller should compile all evaluation sheets and action items/good practices for the group. When complete, the group should meet and key players in their area of evaluation to review the items and make adjustments, as necessary, if an item(s) was born out of a misunderstanding or misconception.

After meeting with the player, the lead controller should make a copy of the evaluation sheets and items. The originals should be given to the Exercise Director and the copies should be retained by the lead controllers.

When all lead controllers have completed the above tasks, the controller critique can be held. All controller/evaluators should be present. The Exercise Director will lead the critique with each lead controller presenting information for his/her group. The lead controller should first discuss any

objectives in his/her area that were not met and why. Then, each action item and good practice should be discussed. Each item presented will be open for discussion. Any controller aware of any information that could change or nullify an item should present the information to the group. At the end of the critique, the Exercise Director may ask that certain controllers attend the NRC critique, particularly if significant problems were identified in an area of evaluation.

Key players, in addition to controllers requested by the Exercise Director, should attend the NRC critique. During the critique, the following persons or groups will provide comments.

- A. Emergency Coordinator (Players comments)
- B. Exercise Director (Controller/evaluator comments)
- C. Observers (if any)
- D. NRC

Each item presented will be open for discussion. Any player or controller aware of any information that could change or nullify an item should present the information to the group.

Following the critique, the Exercise Director will combine the critique comments into an action item list. If any questions remain regarding any item identified, the authoring evaluator may be asked to conduct individual interviews with the players involved in order to gather necessary information to complete the item or to determine the root cause. The Station Emergency Planning Manager and/or the Exercise Director may also conduct interviews, as necessary. The individual item will be assigned to appropriate members of the organization for resolution. The Station Emergency Planning Manager will be responsible for follow-up to ensure implementation of corrective measures.

#### Evaluation Forms

Evaluation forms have been developed to allow review of the specific exercise objectives stated in part I of this exercise plan. Where an objective is not rated as having been completed in an adequate manner, the evaluator will elaborate on the back of the sheet and refer to the associated action item(s). Even if an objective is adequately met, the evaluator may make suggestions for improvement.

Outstanding performances should also be recognized where player actions are clearly exemplary.

#### Exercise Good Practice and Action Item Forms

Controller/evaluators are requested to use their written logs

and evaluation sheets to generate action item findings. Using 'Exercise Action Item' forms, complete the 'Findings' section for each identified item. Example action item forms are available to provide guidance for completing these forms.

The finding should state the action, behavior, or conditions observed that were unacceptable or in need of improvement. Ensure appropriate detail is provided in order to adequately describe the item. Names of participants observed should be recorded for future reference.

Lastly, the controller/evaluator's name should be printed on the upper right hand corner of each page. This will enable the Exercise Director to contact the appropriate person if questions arise or additional information is required.

Good practice forms should be used to list outstanding performances observed where the participants actions are clearly exemplary. The controller/evaluator's name should be printed on the upper right hand corner of each page. Example good practice forms are available to provide guidance for completing these forms.

#### Schedule

Player critiques will be held immediately following the exercise on October 20, 1993. The station critique, led by the Exercise Director or Station Emergency Planning Manager will be held at McGuire Nuclear Station in Training Room 155. The EOF critique, led by the EOF Lead Controller or designee, will be held in the EOF.

The controller/evaluator critique, led by the Exercise Director, will be held at 0900 on October 21, 1993, in the McGuire Nuclear Station Administration Building, Room 155.

The NRC critique will be held at 1430 on October 21, 1993 in the McGuire Administration Building, Room 155.

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: Control Room

(CHECK ONE)

EXERCISE OBJECTIVE TO BE REVIEWED      ADEQUATE    INADEQUATE\*

1. Demonstrate the ability to declare emergency classification in accordance with procedures. \_\_\_\_\_
2. Demonstrate the ability to notify the State and Counties within 15 minutes after declaring an emergency or after changing the emergency classification. \_\_\_\_\_
3. Demonstrate the ability to alert, notify, and staff the TSC, and OSC facilities after declaring an Alert or higher emergency classification. \_\_\_\_\_
4. Demonstrate the ability to notify the NRC not later than 1 hour after declaring one of the emergency classes. \_\_\_\_\_
5. Test communications equipment among on-site emergency facilities including plant extensions, and intercoms. \_\_\_\_\_
6. Test off-site communications equipment to the Counties and State warning points, and to the NRC including the Selective Signaling System and the NRC FTS 2000 phone system. \_\_\_\_\_
7. Test the adequacy and operability of emergency equipment/supplies. \_\_\_\_\_
8. Demonstrate precise and clear transfer of responsibility from the Shift Supervisor in the Control Room to the Emergency Coordinator in the TSC. \_\_\_\_\_
9. Demonstrate proper use of the message format and authentication methodology for messages transmitted to State and Counties. \_\_\_\_\_
10. Evaluate the adequacy of the following assessment tools:
  1. Drawings
  2. Data Display Boards
  3. Maps\_\_\_\_\_

EXERCISE OBJECTIVE TO BE REVIEWED

(CHECK ONE)

ADEQUATE    INADEQUATE\*

11. Demonstrate the ability to assess the incident and provide mitigation strategies. \_\_\_\_\_

\* NOTE: Expand on any item(s) marked "Inadequate"

Evaluator Signature \_\_\_\_\_

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: TSC Overall

(CHECK ONE)

EXERCISE OBJECTIVE TO BE REVIEWED    ADEQUATE    INADEQUATE\*

1. Demonstrate the ability to notify the State and Counties within 15 minutes after declaring an emergency or after changing the emergency classification. \_\_\_\_\_
2. Demonstrate the ability to notify the NRC not later than 1 hour after declaring one of the emergency classes. \_\_\_\_\_
3. Demonstrate assembly of station personnel within 30 minutes in a simulated emergency and provide accountability for any not present at the assembly locations. \_\_\_\_\_
4. Test communications equipment among on-site emergency facilities including plant extensions, and intercoms. \_\_\_\_\_
5. Test off-site communications equipment to the Counties and State warning points, and to the NRC including the Selective Signaling System and the NRC FTS 2000 phone system. \_\_\_\_\_
6. Test the adequacy and operability of emergency equipment/supplies. \_\_\_\_\_
7. Demonstrate precise and clear transfer of responsibility from the Emergency Coordinator in the TSC to the ECF Director in the EOF. \_\_\_\_\_
8. Demonstrate proper use of the message format and authentication methodology for messages transmitted to State and Counties. \_\_\_\_\_
9. Evaluate the adequacy of the following assessment tools:
  1. Drawings
  2. Data Display Boards
  3. Maps\_\_\_\_\_

(CHECK ONE)

EXERCISE OBJECTIVE TO BE REVIEWED    ADEQUATE    INADEQUATE\*

10. Demonstrate the ability to transmit data using the Data Transmittal System in accordance with station procedures. \_\_\_\_\_
11. Demonstrate the ability to provide timely and appropriate protective action recommendations to off-site officials in accordance with station procedures. \_\_\_\_\_
12. Demonstrate the ability to assess the incident and provide mitigation strategies. \_\_\_\_\_

\* NOTE: Expand on any item(s) marked "Inadequate"

Evaluator Signature \_\_\_\_\_

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: TSC Radiation Protection

(CHECK ONE)

**EXERCISE OBJECTIVE TO BE REVIEWED**    **ADEQUATE**    **INADEQUATE\***

1. Test Communications equipment among on-site emergency facilities including plant extensions and intercoms. \_\_\_\_\_
2. Test the adequacy and operability of emergency equipment/supplies. \_\_\_\_\_
3. Evaluate the adequacy of the following assessment tools:
  1. Drawings
  2. Data Display Boards
  3. Maps\_\_\_\_\_
4. Demonstrate adequate radio communications between the off-site monitoring teams and the TSC. \_\_\_\_\_
5. Demonstrate the ability to develop off-site dose projections in accordance with procedures. \_\_\_\_\_

\* NOTE: Expand on any item(s) marked "Inadequate"

Evaluator Signature \_\_\_\_\_

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: Plant Data

(CHECK ONE)

**EXERCISE OBJECTIVE TO BE REVIEWED**    ADEQUATE    INADEQUATE\*

1. Demonstrate the ability to transmit  
data using the Emergency Data  
Transmittal System in accordance  
with station procedures

- \* NOTE: Expand on any item(s) marked "Inadequate"

Evaluator Signature \_\_\_\_\_

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: OSC Overall

EXERCISE OBJECTIVE TO BE REVIEWED      (CHECK ONE)      ADEQUATE    INADEQUATE\*

1. Test communications equipment among on-site emergency facilities including plant extensions and intercoms. \_\_\_\_\_
2. Test the adequacy and operability of emergency equipment/supplies. \_\_\_\_\_
3. Evaluate the adequacy of the following assessment tools:
  1. Drawings
  2. Data Display Boards
  3. Maps\_\_\_\_\_
4. Demonstrate the ability to assess the incident and provide mitigation strategies. \_\_\_\_\_

\* NOTE: Expand on any item(s) marked "Inadequate"

Evaluator Signature \_\_\_\_\_

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: OSC Instrument and Electrical

(CHECK ONE)

EXERCISE OBJECTIVE TO BE REVIEWED      ADEQUATE      INADEQUATE\*

1. Test the adequacy and operability of emergency equipment/supplies. \_\_\_\_\_
2. Demonstrate the ability to assess the incident and provide mitigation strategies. \_\_\_\_\_

\* NOTE: Expand on any item(s) marked "Inadequate"

Evaluator Signature \_\_\_\_\_

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: OSC Chemistry

(CHECK ONE)

EXERCISE OBJECTIVE TO BE REVIEWED      ADEQUATE    INADEQUATE\*

1. Test the adequacy and operability of emergency equipment/supplies. \_\_\_\_\_
2. Demonstrate the ability to assess the incident and provide mitigation strategies. \_\_\_\_\_

\* NOTE: Expand on any item(s) marked "Inadequate"

Evaluator Signature \_\_\_\_\_

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: OSC Maintenance

(CHECK ONE)

EXERCISE OBJECTIVE TO BE REVIEWED      ADEQUATE      INADEQUATE\*

1. Test the adequacy and operability of emergency equipment/supplies. \_\_\_\_\_
2. Demonstrate the ability to assess the incident and provide mitigation strategies. \_\_\_\_\_

\* NOTE: Expand on any item(s) marked "Inadequate"

Evaluator Signature \_\_\_\_\_

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: OSC Operations

(CHECK ONE)

EXERCISE OBJECTIVE TO BE REVIEWED      ADEQUATE      INADEQUATE\*

1. Test the adequacy and operability of emergency equipment/supplies \_\_\_\_\_
2. Demonstrate the ability to assess the incident and provide mitigation strategies \_\_\_\_\_

\* NOTE: Expand on any item(s) marked "inadequate"

Evaluator Signature \_\_\_\_\_

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: On-Site Rad. Monitoring

(CHECK ONE)

EXERCISE OBJECTIVE TO BE REVIEWED      ADEQUATE    INADEQUATE\*

1. Test the adequacy and operability of emergency equipment/supplies. \_\_\_\_\_
2. Demonstrate the ability to assess the incident and provide mitigation strategies. \_\_\_\_\_

\* NOTE: Expand on any item(s) marked "Inadequate"

Evaluator Signature \_\_\_\_\_

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: Off-Site Rad. Monitoring

(CHECK ONE)

EXERCISE OBJECTIVE TO BE REVIEWED      ADEQUATE      INADEQUATE\*

1. Test the adequacy and operability of emergency equipment/supplies. \_\_\_\_\_
2. Demonstrate the ability to collect air, soil, water, and vegetation samples in accordance with station procedures. \_\_\_\_\_
3. Demonstrate adequate radio communications between the off-site monitoring teams and the TSC/EOF. \_\_\_\_\_

\* NOTE: Expand on any item(s) marked "Inadequate"

Evaluator Signature \_\_\_\_\_

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: EOF Overall

(CHECK ONE)

**EXERCISE OBJECTIVE TO BE REVIEWED      ADEQUATE      INADEQUATE\***

1. Demonstrate the ability to declare emergency classification in accordance with procedures. \_\_\_\_\_
2. Demonstrate the ability to notify the State and Counties within 15 minutes after declaring an emergency or after changing the emergency classification. \_\_\_\_\_
3. Demonstrate access control to the EOF. \_\_\_\_\_
4. Demonstrate the ability to notify the NRC not later than 1 hour after declaring one of the emergency classes. \_\_\_\_\_
5. Test off-site communications equipment to the Counties and State warning points, and to the NRC including the Selective Signaling System and the NRC FTS 2000 phone system. \_\_\_\_\_
6. Demonstrate adequate radio communications between the State/Counties and the EOF. \_\_\_\_\_
7. Test the adequacy and operability of emergency equipment/supplies. \_\_\_\_\_
8. Demonstrate precise and clear transfer of responsibility from the Emergency Coordinator in the TSC to the EOF Director in the EOF. \_\_\_\_\_
9. Demonstrate proper use of the message format for messages transmitted to State and Counties. \_\_\_\_\_
10. Demonstrate the ability to distribute Data Transmittal System data throughout the EOF according to the Emergency Plan Implementing Procedures. \_\_\_\_\_

(CHECK ONE)  
EXERCISE OBJECTIVE TO BE REVIEWED    ADEQUATE    INADEQUATE\*

11. Evaluate the adequacy of the following assessment tools:  
1. Drawings  
2. Data Display Boards  
3. Maps
12. Demonstrate the ability to provide timely and appropriate protective action recommendations to off-site officials in accordance with station procedures.
13. Demonstrate the ability to assess the incident and provide mitigation strategies.

\* NOTE: Expand on any item(s) marked "Inadequate"

Evaluator Signature \_\_\_\_\_

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: EOF Plant Assessment

(CHECK ONE)

EXERCISE OBJECTIVE TO BE REVIEWED    ADEQUATE    INADEQUATE\*

1. Test the adequacy and operability of emergency equipment/supplies. \_\_\_\_\_
2. Demonstrate the ability to assess the incident and provide mitigation strategies. \_\_\_\_\_
3. Evaluate the adequacy of the following assessment tools:
  1. Drawings
  2. Data Display Boards
  3. Maps\_\_\_\_\_

- \* NOTE: Expand on any item(s) marked "Inadequate"

Evaluator Signature \_\_\_\_\_

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: EOF Radiological Assessment

(CHECK ONE)

EXERCISE OBJECTIVE TO BE REVIEWED      ADEQUATE      INADEQUATE\*

1. Test the adequacy and operability of emergency equipment/supplies. \_\_\_\_\_
2. Demonstrate the ability to collect air, soil, water, and vegetation samples in accordance with station procedures. \_\_\_\_\_
3. Demonstrate adequate radio communications between the off-site monitoring teams and the TSC/EOF. \_\_\_\_\_
4. Evaluate the adequacy of the following assessment tools:
  1. Drawings
  2. Data Display Boards
  3. Maps\_\_\_\_\_
5. Demonstrate the ability to develop off-site dose projections in accordance with procedures. \_\_\_\_\_

\* NOTE: Expand on any item(s) marked "inadequate"

Evaluator Signature \_\_\_\_\_

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: EOF Off-Site Agency Communications

(CHECK ONE)

EXERCISE OBJECTIVE TO BE REVIEWED    ADEQUATE    INADEQUATE\*

1. Demonstrate the ability to notify the State and Counties within 15 minutes after declaring an emergency or after changing the emergency classification.

\* NOTE: Expand on any item(s) marked "Inadequate"

Evaluator Signature \_\_\_\_\_

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: EOF News Group

(CHECK ONE)

**EXERCISE OBJECTIVE TO BE REVIEWED**    **ADEQUATE**    **INADEQUATE\***

1. Demonstrate access control measure to the News Center and the Media Center. \_\_\_\_\_
2. Demonstrate the ability to provide accurate information to the news media in a timely manner and to provide effective rumor control according to the Emergency Plan Implementing Procedures. \_\_\_\_\_

\* NOTE: Expand on any item(s) marked "Inadequate"

Evaluator Signature \_\_\_\_\_

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: Fire Drill

(CHECK ONE)

EXERCISE OBJECTIVE TO BE REVIEWED    ADEQUATE    INADEQUATE\*

1. Demonstrate proper response to a simulated fire emergency and timely backup assistance from the off-site fire support agency. \_\_\_\_\_

\* NOTE: Expand on any item(s) marked "Inadequate"

Evaluator Signature \_\_\_\_\_

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Area of Review: Medical Drill

(CHECK ONE)

EXERCISE OBJECTIVE TO BE REVIEWED    ADEQUATE    INADEQUATE\*

1. Demonstrate proper response to a simulated medical emergency involving a contaminated patient in accordance with station procedures.

\* NOTE: Expand on any item(s) marked "Inadequate"

Evaluator Signature \_\_\_\_\_

Example  
DRILL or EXERCISE GOOD PRACTICE

To: \_\_\_\_\_

Drill or Exercise Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Station: \_\_\_\_\_

Finding: Good recovery action by Operations to start SSF make-up pump for make-ups to the NC system.

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Example

DRILL or EXERCISE GOOD PRACTICE

Drill or Exercise Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Station: \_\_\_\_\_

Finding: Performance did an excellent job of ensuring timely OAC data was delivered to the TSC and CMC with 'normal' data transmittal paths (and improvised paths when problems were encountered).

---

---

DRILL OR EXERCISE GOOD PRACTICE

To: \_\_\_\_\_

Drill or Exercise Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Station: \_\_\_\_\_

Finding: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

DRILL OR EXERCISE GOOD PRACTICE

To: \_\_\_\_\_

Drill or Exercise Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Station: \_\_\_\_\_

Finding: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\* DRILL or EXERCISE GOOD PRACTICE

To: \_\_\_\_\_

Drill or Exercise Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Station: \_\_\_\_\_

Finding: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

DRILL OR EXERCISE GOOD PRACTICE

To: \_\_\_\_\_

Drill or Exercise Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Station: \_\_\_\_\_

Finding: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

DRILL or EXERCISE GOOD PRACTICE

To: \_\_\_\_\_

Drill or Exercise Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Station: \_\_\_\_\_

Finding: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

DRILL OR EXERCISE GOOD PRACTICE

To: \_\_\_\_\_

Drill or Exercise Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Station: \_\_\_\_\_

Finding: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

*Example*

DRILL OR EXERCISE ACTION ITEM

Lead Responsibility: \_\_\_\_\_ Item No. \_\_\_\_\_

Drill or Exercise Date: \_\_\_\_\_ Station: \_\_\_\_\_

Finding: Two and a half (2.5) inch fire hose is not available in the fire brigade locker.  
Hose is stored in outside cabinets, but  
should cabinets become inaccessible, hose  
would not be available.

Target Date for Completion: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

..... FOLLOW-UP .....

Has corrective action been taken? Yes \_\_\_\_\_ No \_\_\_\_\_

If yes, provide a short description of the action taken:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Date Completed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Signed: \_\_\_\_\_

If no, provide a short description of why item has not been completed and establish a new completion date:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

New Completion Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Signed: \_\_\_\_\_

Item Closed:

Date Closed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Signed: \_\_\_\_\_  
(System Emergency Planner)

*Example*  
DRILL OR EXERCISE ACTION ITEM

Lead Responsibility: \_\_\_\_\_ Item No. \_\_\_\_\_

Drill or Exercise Date: \_\_\_\_\_ Station: \_\_\_\_\_

Finding: IAE personnel were dispatched on a Repair & Recovery Team without receiving and passing required training (personnel in question were Buck Rogers and Indiana Jones).

---

---

---

Target Date for Completion: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

..... FOLLOW-UP .....

Has corrective action been taken? Yes \_\_\_\_\_ No \_\_\_\_\_

If yes, provide a short description of the action taken: \_\_\_\_\_

---

---

---

---

---

Date Completed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Signed: \_\_\_\_\_

If no, provide a short description of why item has not been completed and establish a new completion date: \_\_\_\_\_

---

---

---

---

---

New Completion Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Signed: \_\_\_\_\_

Item Closed:

Date Closed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Signed: \_\_\_\_\_

(System Emergency Planner)

## DRILL or EXERCISE ACTION ITEM

Lead Responsibility: \_\_\_\_\_ Item No. \_\_\_\_ / \_\_\_\_ / \_\_\_\_ / \_\_\_\_ / \_\_\_\_

Drill or Exercise Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Station: \_\_\_\_\_

Finding: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Target Date for Completion: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

. . . . . FOLLOW-UP . . . . .

Has corrective action been taken? Yes \_\_\_\_\_ No \_\_\_\_\_

If yes, provide a short description of the action taken: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Date Completed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Signed: \_\_\_\_\_

If no, provide a short description of why item has not been completed  
and establish a new completion date: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

New Completion Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Signed: \_\_\_\_\_

Item Closed:

Date Closed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Signed: \_\_\_\_\_

(System Emergency Planner)

## DRILL OR EXERCISE ACTION ITEM

Lead Responsibility: \_\_\_\_\_ Item No. \_\_\_\_ / \_\_\_\_ / \_\_\_\_ / \_\_\_\_ / \_\_\_\_

Drill or Exercise Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Station: \_\_\_\_\_

Finding: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Target Date for Completion: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

. . . . . FOLLOW-UP . . . . .

Has corrective action been taken? Yes \_\_\_\_\_ No \_\_\_\_\_

If yes, provide a short description of the action taken:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Date Completed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Signed: \_\_\_\_\_

If no, provide a short description of why item has not been completed  
and establish a new completion date:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

New Completion Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Signed: \_\_\_\_\_

Item Closed:

Date Closed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

Signed: \_\_\_\_\_

(System Emergency Planner)

## DRILL or EXERCISE ACTION ITEM

Lead Responsibility: \_\_\_\_\_ Item No. \_\_\_\_ / \_\_\_\_ / \_\_\_\_ / \_\_\_\_ / \_\_\_\_

Drill or Exercise Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Station: \_\_\_\_\_

Finding: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Target Date for Completion: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

. . . . . FOLLOW-UP . . . . .

Has corrective action been taken? Yes \_\_\_\_\_ No \_\_\_\_\_

If yes, provide a short description of the action taken: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Date Completed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Signed: \_\_\_\_\_

If no, provide a short description of why item has not been completed  
and establish a new completion date: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

New Completion Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Signed: \_\_\_\_\_

Item Closed:

Date Closed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

Signed:

(System Emergency Planner)

DRILL OR EXERCISE ACTION ITEM

Lead Responsibility: \_\_\_\_\_ Item No. \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

Drill or Exercise Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Station:

Finding: \_\_\_\_\_

Target Date for Completion:      /      /

## **FOLLOW-UP**

Has corrective action been taken? Yes \_\_\_\_\_ No \_\_\_\_\_

If yes, provide a short description of the action taken:

Date Completed: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_      Signed:

If no, provide a short description of why item has not been completed and establish a new completion date:

New Completion Date: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ Signed:

**Item Closed:**

Date Closed: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

Signed:

(System Emergency Planner)

## DRILL or EXERCISE ACTION ITEM

Lead Responsibility: \_\_\_\_\_ Item No. \_\_\_\_/\_\_\_\_/\_\_\_\_/\_\_\_\_/\_\_\_\_

Drill or Exercise Date: \_\_\_\_/\_\_\_\_/\_\_\_\_ Station: \_\_\_\_\_

Finding: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Target Date for Completion: \_\_\_\_/\_\_\_\_/\_\_\_\_

. . . . . FOLLOW-UP . . . . .

Has corrective action been taken? Yes \_\_\_\_\_ No \_\_\_\_\_

If yes, provide a short description of the action taken: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Date Completed: \_\_\_\_/\_\_\_\_/\_\_\_\_ Signed: \_\_\_\_\_

If no, provide a short description of why item has not been completed  
and establish a new completion date: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

New Completion Date: \_\_\_\_/\_\_\_\_/\_\_\_\_ Signed: \_\_\_\_\_

Item Closed:

Date Closed: \_\_\_\_/\_\_\_\_/\_\_\_\_

Signed: \_\_\_\_\_

(System Emergency Planner)

## DRILL or EXERCISE ACTION ITEM

Lead Responsibility: \_\_\_\_\_ Item No. \_\_\_\_/\_\_\_\_/\_\_\_\_/\_\_\_\_/\_\_\_\_/\_\_\_\_

Drill or Exercise Date: \_\_\_\_/\_\_\_\_/\_\_\_\_ Station: \_\_\_\_\_

Finding: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Target Date for Completion: \_\_\_\_/\_\_\_\_/\_\_\_\_

. . . . . FOLLOW-UP . . . . .

Has corrective action been taken? Yes \_\_\_\_\_ No \_\_\_\_\_

If yes, provide a short description of the action taken: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Date Completed: \_\_\_\_/\_\_\_\_/\_\_\_\_ Signed: \_\_\_\_\_

If no, provide a short description of why item has not been completed  
and establish a new completion date: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

New Completion Date: \_\_\_\_/\_\_\_\_/\_\_\_\_ Signed: \_\_\_\_\_

Item Closed:

Date Closed: \_\_\_\_/\_\_\_\_/\_\_\_\_

Signed: \_\_\_\_\_

(System Emergency Planner)

# MNS ANNUAL EXERCISE

OCT. 20, 1993

0330		SIMULATOR TURNOVER
0345		SIMULATE INJURY TRANSPORT DECLARE NOUE
0515		25 GPM LEAK
0545		75 GPM LEAK
0550		DECLARE ALERT ACTIVATE OSC/TSC/EOF SITE ASSEMBLY
0630		ASSEMBLY COMPLETE TSC/OSC STAFFED & FUNCTIONAL
0645		CONTAMINATED INJURY
0645		EOF STAFFED & FUNCTIONAL
0715		BOMB THREAT CALL
0800		FIRE
0900		500 - 1000 GPM LEAK ON ND Hx
0905		SAFETY INJECTION
0905		LOSS OF SUBCOOLING SITE AREA EMERGENCY
0930		COUNTIES ACTIVATE SIRENS AND EBS
1050		LOSS OF POWER LOSS OF ECCS
1052		D/G TRIPS ON OVERSPEED
1055		VA FILTER BYPASS FAILS
1100		GENERAL EMERGENCY CORE UNCOVERS
1105		RETURN OF OFFSITE POWER
		C O N T I N U E  C O C I D E N T  A C C I D E N T  M I T I G A T I O N
1430		TERMINATE EXERCISE

ALL TIMES ARE APPROXIMATE AND ACTUAL TIMES WILL BE  
DETERMINED BY PLAYER ACTIONS. FIRE AND MEDICAL PORTIONS  
MAY VARY DUE TO AVAILABILITY OF OFFSITE SUPPORT.

CONFIDENTIAL

McGuire Nuclear Station  
Annual Exercise  
Event Sequence  
October 20, 1993

INITIAL CONDITIONS

UNIT 1

100% Power 144 EFPD

"A" D/G - Replacing #14 Cylinder Liner expected complete  
11:00 AM 10/21/93

SM: 589 pcm, Xe: 2774 pcm, SM Eq. Diff 2.90 pcm

NCS [B]: 623 ppm, Pzr [B]: 623 ppm

Controlling procedure: OP/1/A/6100/03 "Controlling  
Procedure for Unit Operation", Enc. 4.1 "Power Increase"  
complete

NOTE FOR TURNOVER: There has been an employee injured  
in the Aux. Eldg. MERT has responded  
and MEDIC is on the scene preparing  
to transport the contaminated  
employee to Carolinas Medical  
Center.

UNIT 2

100 % Power 320 EFPD 130 day continuous run  
D/G 2B in maintenance for PM's on auxiliary pumps

CONFIDENTIAL

McGuire Nuclear Station  
Annual Exercise  
Event Sequence  
October 20, 1993

WEATHER FORECAST

Tuesday 10/19/93

Fair tonight with a slight chance of showers. Clouds will be increasing on Wednesday with a chance of afternoon thunderstorms. Low temperature tonight will be 63 deg. with a high on Wednesday of 82 degrees. Winds from the South at 3-5 mph.

Wednesday 10/20/93

Clouds increasing throughout the day with a chance of afternoon thunderstorms. Temperatures will remain moderate throughout the day with a high of 82 and a low Wednesday night of 62.

CONFIDENTIAL

McGuire Nuclear Station  
Annual Exercise  
Event Sequence  
October 20, 1993

SCENARIO

- 0330 Simulator turnover with normal full power operations.
- 0345 Simulate an ambulance transporting a contaminated medical injury offsite for further care.

PREDICTED RESPONSE

Declare Notification of Unusual Event

Make notifications to State and Counties and NRC

- 0515 The NC System develops a 25 gpm leak.

PREDICTED RESPONSE

Enter AP/1/A/5500/10 Case 2, "NC System Leakage Within Capability of Both NV Pumps".

Perform Enclosure 1 of AP/1/A/5500/10

Enter OP/1/A/6150/04 "Monitor and Control of PRT"

Classify, Notification of Unusual Event

Enter OP/1/A/6300/01 "Turbine Generator Operation"

Enter OP/1/A/6100/03 "Controlling Procedure for Unit Operation"

- 0520 Valve 1NI-173 will not close (mechanically bound)

PREDICTED RESPONSE

Dispatch NLO to close 1EMXA R2A, (MCC breaker for 1NI-173).

Dispatch NLO to close 1EMXB 1-6B (MCC breaker for 1NI-178)

Dispatch NLO to manually close NI-173. (Will not be opened during exercise).

CONFIDENTIAL

McGuire Nuclear Station  
Annual Exercise  
Event Sequence  
October 20, 1993

Dispatch Mechanical, Instrument And Electrical, and Radiation Protection to assist in closing 1NI-173.

0530 Control Room receives notification that the employee sent to Carolinas Medical Center was not contaminated and that events are secured at the hospital.

0545 Leak size increases to 75 gpm.

PREDICTED RESPONSE

Classify, ALERT  
Activate TSC/OSC/EOF  
Conduct Site Assembly  
Enter OP/1/A/6100/02 "Controlling Procedure for Unit Shutdown"

0645 Contaminated medical injury takes place in Waste Shipping ( 2 patients, 1 will go to Carolinas Medical Center as contaminated, the other will be a non-life threatening injury and will be decontaminated prior to leaving the site for further medical care ).

PREDICTED RESPONSE

Request off-site medical assistance

0715 PBX Operator receives a call stating that there is a bomb on one of the main transformers on Unit 1.

PREDICTED RESPONSE

Request off-site assistance from Mecklenburg County Sheriffs Department in locating the bomb.

Dispatch station fire brigade to standby in case of fire.

0800 Fire at the Central Waste Storage. ( A crane is being dismantled at the north end of the Auxiliary Building and has access around the Auxiliary Building and through the North VAP blocked).

CONFIDENTIAL

McGuire Nuclear Station  
Annual Exercise  
Event Sequence  
October 20, 1993

0900      Seals fail on the ND Heat Exchanger to allow a 500-1000 gpm leak to the Auxiliary Building Floor.

PREDICTED RESPONSE

Enter EP/1/A/5000/01, "Safety Injection".

Enter OP/1/A/6200/14 "Refueling Water System"

Enter EP/1/A/5000/08, "Loss of Coolant Accident Outside Containment".

0901      1EMF36 is indicating off scale due to leak to floor

0905      Loss of Subcooling

PREDICTED RESPONSE

Declare Site Area Emergency

Enter EP/1/A/5000/06 "Loss of Emergency Coolant Recirculation".

Enter EP/1/A/5000/14.1 "Response to Imminent Pressurized Thermal Shock Conditions".

Evacuate Site non-essential personnel

0915      Valve 1ND-29 fails intermittent

PREDICTED RESPONSE

Dispatch a NLO, Mechanical, and Instrument and Electrical to manually open

1050      Loss of offsite and onsite power due to direct lightening strike in Switchyard. Loss of ECCS.

PREDICTED RESPONSE

Enter EP/1/A/5000/09 "Loss of All AC Power"

CONFIDENTIAL

McGuire Nuclear Station  
Annual Exercise  
Event Sequence  
October 20, 1993

1052 "B" D/G trips on overspeed

PREDICTED RESPONSE

Dispatch a NLO to investigate (while investigating the NLO will also find the 1A D/G Day Tank level instrument leaking fuel oil on the floor. Approximately 5 gallon has leaked out).

Enter EP/1/A/5000/9.2 "Loss of All AC Power with SI Required"

1055 Bypass on VA Filters fails open

1100 Declare General Emergency based on Loss of Recirculation when needed. Core uncovers.

PREDICTED RESPONSE

Recommend sheltering of persons within the 5 mile radius of the station and monitor EBS for persons within a 10 mile radius of the station.

1105 Return of offsite power

1300 Unit 2 "A" Feedwater Pump "Low Oil Level" alarm due to a leaking flange. (If an NLO is dispatched and arrives within 15 minutes, he/she will be allowed to tighten the flange with no impact on Unit 2. If greater than 15 minutes there will be a successful runback on Unit 2 with messages indicating 100 gallons of oil had leaked onto the floor).

NOTE: During the Site Area Emergency, the State and Counties will be setting up relocation shelters, vehicle decon and monitoring stations and personnel monitoring and decon. There will be simulation of school evacuations. The sirens will sound at Site Area Emergency and be simulated at General Emergency.

CONFIDENTIAL

McGuire Nuclear Station  
Annual Exercise  
Event Sequence  
October 20, 1993

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 5:25

MESSAGE NO. OPS-1

Message for: NLO CHECKING ND HEAT EXCHANGER ROOM

Message:

"A" Heat exchanger room has been checked and there are  
NO leaks

Notes → Controllers:

THIS MESSAGE SHOULD BE GIVEN PRIOR TO THE ND HX LEAK

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 5:30

MESSAGE NO. OPS-2

Message for: NLO

Message:

Power is now on MCC Breaker 1 EMXA R2A.

Notes to Controllers:

CALL SIMULATOR PHONE 5090 PRIOR TO RELEASING THIS MESSAGE.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 5:30

MESSAGE NO. OPS-3

Message for: NLO

Message:

Power is now on 1 EMXB 1-6B.

Notes to Controllers:

CALL SIMULATOR EXT. 5090 PRIOR TO RELEASING THIS MESSAGE.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 5:40

MESSAGE NO. OPS-4

Message for: NLO

Message:

1ND-56 is definitely releasing and is hot and making a lot  
of noise.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 5:45

MESSAGE NO. OPS-5

Message for: NLO

Message:

1ND-61 is relieving.

Notes to Controllers:

GIVE ONLY IF 1ND-30A IS OPEN

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: 5:45

MESSAGE NO. OPS-6

Message for: NLO

Message:

1ND-61 is NOT relieving

Notes to Controllers:

GIVE IF 1ND-30A IS CLOSED

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 5:45

MESSAGE NO. OPS-7

Message for: NLO

Message:

1ND-64 is relieving.

Notes to Controllers:

GIVE ONLY IF 1ND-15B OR 1ND-30A ARE OPEN

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 5:45

MESSAGE NO. OPS-8

Message for: NLO

Message:

1ND-64 is hot but not relieving

Notes to Controllers:

GIVE IF 1ND-15B OR 1ND-30A IS CLOSED

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: 5:45

MESSAGE NO. OPS-9

Message for: NLO

Message:

INI-161 is not relieving

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 5:45

MESSAGE NO. OPS-10

Message for: NLO

Message:

1NS-2 is not relieving

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: 5:45

MESSAGE NO. OPS-11

Message for: NLO

Message:

INS-19 is not relieving

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: 5:45

MESSAGE NO. OPS-12

Message for: NLO

Message:

INV-229 is not relieving

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: 5:45

MESSAGE NO. OPS-13

Message for: NLO

Message:

INI-102 is not relieving

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 5:45

MESSAGE NO. OPS-14

Message for: NLO

Message:

INI-119 is not relieving

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: 5:45

MESSAGE NO. OPS-15

Message for: NLO

Message:

INI-151 is not relieving

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 5:50

MESSAGE NO. OPS-16

Message for: NLO

Message:

1NI-173 will NOT close.

Notes to Controllers:

Follow the NLO to the Change Room and hold the NLO there for 5 minutes after they are dressed out prior to giving this message.

Do NOT allow the NLO to go to shift RP for coverage, however RP information will be provided by you, the controller.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. OPS - 17

Message for: NLO Checking D/G

Message:

You just found a fuel oil leak on the D/G day tank coming from the level instrument inlet. It has leaked approx. 5 gal.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 6:00

MESSAGE NO. OPS-18

Message for: NLO

Message:

OP/1/A/5500/10 Enclosure 1 remaining valves are closed.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 6:40

MESSAGE NO. OPS-19

Message for: NLO

Message:

IAS-11 is OPEN

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx 7:15

MESSAGE NO. OPS-20

Message for: NLO

Message:

Every other cooling group fans on the main step up  
transformers are shut down.

Notes to Controllers:

CALL SIMULATOR EXT. 5090 PRIOR TO RELEASING THIS MESSAGE.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx 7:25

MESSAGE NO. OPS-21

Message for: NLO

Message:

"G" Heater Drain Tank Pumps are shut down.

Notes to Controllers:

Call the Simulator EXT. 5090 prior to releasing this message.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 7:41

MESSAGE NO. OPS-22

Message for: NLO

Message:

"C" Heater Drain Pumps are secured.

Notes to Controllers:

Give this same message one at a time as each is shut down.

Call Simulator EXT. 5090 prior to releasing this message.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 7:45

MESSAGE NO. OPS-23

Message for: NLO

Message:

"C" Heater Drain Pumps are secured.

Notes to Controllers:

Give this same message one at a time as each is shut down.

Call Simulator EXT. 5090 prior to releasing this message.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 7:50

MESSAGE NO. OPS-24

Message for: NLO

Message:

"C" Heater Drain Pumps are secured.

Notes to Controllers:

Give this same message one at a time as each is shut down.

Call Simulator EXT. 5090 p: or to releasing this message.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 7:45

MESSAGE NO. OPS-25

Message for: NLO

Message:

IAS-74 is OPEN

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 7:45

MESSAGE NO. OPS-26

Message for: NLO

Message:

2AS-74 is OPEN

Notes to Controllers:

CONFIDENTIAL

THIS 'S AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 7:45

MESSAGE NO. OPS-27

Message for: NLC

Message:

1AS-253 is OPEN

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 11:10

MESSAGE NO. OPS-28

Message for: NLO

Message:

The MG sets are removed from service.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 11:09

MESSAGE NO. OPS-29

Message for: NLO

Message:

ISP-1 is closed

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 11:09

MESSAGE NO. OPS-30

Message for: NLO

Message:

ISP-2 is closed

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 11:10

MESSAGE NO. OPS-31

Message for: NLO

Message:

Turbine is on turning gear.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 11:15

MESSAGE NO. OPS-32

Message for: NLO

Message:

"A" ND Pump Breaker looks fine.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 11:20

MESSAGE NO. OPS-33

Message for: NLO

Message:

IND-29 will NOT close.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-34

Message for: NLO

Message:

INC-24 is closed.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-35

Message for: NLO GOING TO SSF

Message:

NC Pump Seal Injection is initiated (EP/09 Enc. 3 is complete)

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-36

Message for: NLO GOING TO IETA

Message:

NC Pump Seal Injection is initiated.  
EP/09 Enc. 2 is complete

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. OPS-37

Message for: NLO

Message:

1EVDA BREAKER 6 IS OPEN

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-38

Message for: NLO

Message:

1EVDD BREAKER 8 IS OPEN

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-39

Message for: NLO

Message:

All breakers on 1TA, TB, TC, and TB are OPEN

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. OPS-40

Message for: NLO

Message:

RC Pump Breaker Control Fuses are pulled.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. OPS-41

Message for: NLO

Message:

Breaker 1EMXC 5B is Closed

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. OPS-42

Message for: NLO

Message:

Breaker 1EMXD 5B is closed

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-43

Message for: NLO

Message:

D/G tripped on overspeed.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-44

Message for: NLO

Message:

1KC-21 is open and a solid stream of water is visible in  
the sight glass.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. OPS-45

Message for: NLO

Message:

1KC-21 is closed.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. OPS-46

Message for: NLO

Message:

1KC-6 is unlocked and throttled 1 turn open.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. OPS- 47

Message for: NLO

Message:

1KC-6 is open.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-48

Message for: NLO

Message:

1KC-24 is open and a solid stream of water is visible in  
the sight glass.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93                      Time:

MESSAGE NO. OPS-49

Message for: NLO

Message:

1KC-24 is closed

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. OPS- 50

Message for: NLO

Message:

1KC-9 is unlocked and throttled 1 turn open.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. OPS-51

Message for: NLO

Message:

1KC-9 is open.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. OPS-52

Message for: NLO

Message:

1KC-27 is open and a solid stream of water is visible in  
the sight glass.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. OPS-53

Message for: NLO

Message:

1KC-27 is closed.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. OPS- 54

Message for: NLO

Message:

1KC-12 is unlocked and throttled 1 turn open.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. OPS-55

Message for: NLO

Message:

1KC-12 is open.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. OPS-56

Message for: NLO

Message:

1KC-30 is open and a solid stream of water is visible in  
the sight glass.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-57

Message for: NLO

Message:

1KC-30 is closed.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

D R I L L

Date: 10/20/93 Time:

MESSAGE NO. OPS-58

Message for: NLO

Message:

1KC-15 is unlocked and throttled 1 turn open.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL.

Date: 10/20/93 Time:

MESSAGE NO. OPS-59

Message for: NLO

Message:

1KC-15 is open.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. OPS-60

Message for: NLO

Message:

SSF is secured per EP/1/A/5000/9.2 Enclosure 4

Notes to Controllers:

CALL 5090 PRIOR TO GIVING THIS MESSAGE.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93                          Time:

MESSAGE NO. OPS-61

Message for: NLO

Message:

LG Seal Oil Air Side Back Up Pump is running

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-62

Message for: NLO

Message:

OP/1/B/6300/03 Enclosure 4.3 "Dumping Hydrogen From Generator  
is COMPLETE.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 11:30

MESSAGE NO. OPS-63

Message for: NLO

Message:

MCC Breaker 1EMXA-R1E is Closed.

Notes to Controllers:

Call Simulator Ext. 5090 prior to releasing this message.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 11:45

MESSAGE NO. OPS-64

Message for: NLO

Message:

INV-172 is OPEN.

Notes to Controllers:

Call Simulator Ext. 5090 prior to releasing this message.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 11:45

MESSAGE NO. OPS-65

Message for: NLO

Message:

1INV-174 is OPEN

Notes to Controllers:

Call Simulator Ext. 5090 prior to releasing this message.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 11:45

MESSAGE NO. OPS-66

Message for: NLO

Message:

1NV-176 is Closed.

Notes to Controllers:

Call Simulator Ext. 5090 prior to releasing this message.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx 11:50

MESSAGE NO. OPS-67

Message for: NLO

Message:

Hydrogen Analyzers are in service.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 11:50

MESSAGE NO. OPS-68

Message for: NLO

Message:

Diesel Generators are shut down.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXEFCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-69

Message for: NLO ON UNIT 2 FEEDWATER PUMP

Message:

The flange leak is stopped.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 6:00

MESSAGE NO. IAE-1

Message for: IAE Tech.

Message:

The actuator is removed from 1NI-173.

Notes to Controllers:

This action normally will take 2 - 3 hours. If there are any snubbers or pipe hangers this will delay the job. Any special lifting rigs will require more time.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. IAE-2

Message for: IAE Tech.

Message:

IP/0/A/3207/02E "IR Compensation Check" is complete.

Notes to Controllers:

Give to IAE after entering mode 3 and procedure has been simulated complete.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. IAE-3

Message for: IAE Tech.

Message:

1ND-29 is stuck off seat and will not close.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. IAE-4

Message for: IAE TECH.

Message:

Air is off 1ND-29 and work is complete.  
The valve is intermittent and will NOT close.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. IAE-5

Message for: IAE TECH

Message:

D/G has a faulty 50% switch.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. IAE-6

Message for: IAE TECH

Message:

D/G faulty 50% switch has been replaced.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. IAE-7

Message for: IAE Tech.

Message:

The leaking tubing entrance fitting to the fuel oil day tank level instrument has been repaired.

Notes to Controllers:

Ensure techs go thru appropriate steps of procuring parts and procedures. (QA, etc.)

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 6:00

MESSAGE NO. MNT-1

Message for: Maintenance Tech.

Message:

The valve ( 1NI-173 ) is stuck and you cannot get it to jack closed.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. MNT-2

Message for: MAINTENANCE TECH.

Message:

1ND29 will not jack closed.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. MNT-3

Message for: MAINTENANCE TECH

Message:

Dampers are bound up on the VA Filters and will not open.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. MNT-4

Message for: MAINTENANCE TECH ON FEEDWATER PUMP

Message:

The leaking flange has been retorqued and the leak is stopped.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 6:00

MESSAGE NO. RP-1

Message for: RP Tech

Message:

Rad levels at INI-173 are as found/as posted.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx 10:45

MESSAGE NO. RP-2

Message for: RP Tech.

Message:

Activity levels in Lower Containment are:

Actual (as sample results indicate)

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 10:45

MESSAGE NO. RP-3

Message for: RP Tech.

Message:

Rad levels in Upper Containment are:

ACTUAL (as sample results indicate)

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. CHEM-1

Message for: RDWST SUPV.

Message:

A Crud Burst will not be performed

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. Chem-2

Message for: Radwaste

Message:

PRT is vented per procedure.

Notes to Controllers:

This should be OP/0/A/5200/18

Call Simulator Ext. 5090 prior to releasing this message.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 11:30

MESSAGE NO. Chem - 3

Message for: Chemistry

Message:

Boron sample results are 620 ppm.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. Chem-4 There are 6 copies of this message to hand out

Message for: Radwaste

Message:

PRT is vented per procedure

Notes to Controllers:

Hand out as necessary.

Call Simulator Ext. 5090 prior to releasing these messages.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. Chem-4 There are 6 copies of this message to hand out

Message for: Radwaste

Message:

PRT is vented per procedure

Notes to Controllers:

Hand out as necessary.

Call Simulator Ext. 5090 prior to releasing these messages.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. Chem-4 There are 6 copies of this message to hand out

Message for: Radwaste

Message:

PRT is vented per procedure

Notes to Controllers:

Hand out as necessary.

Call Simulator Ext. 5090 prior to releasing these messages.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. Chem-4 There are 6 copies of this message to hand out

Message for: Radwaste

Message:

PRT is vented per procedure

Notes to Controllers:

Hand out as necessary.

Call Simulator Ext. 5090 prior to releasing these messages.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. Chem-4 There are 6 copies of this message to hand out

Message for: Radwaste

Message:

PRT is vented per procedure

Notes to Controllers:

Hand out as necessary.

Call Simulator Ext. 5090 prior to releasing these messages.

 CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. Chem-4 There are 6 copies of this message to hand out

Message for: Radwaste

Message:

PRT is vented per procedure

 Notes to Controllers:

Hand out as necessary.

Call Simulator Ext. 5090 prior to releasing these messages.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 10:45

MESSAGE NO. CHEM-5

Message for: Radwaste

Message:

WG system is prepared for DEGAS.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 10:45

MESSAGE NO. CHEM-6

Message for: Radwaste

Message:

NM-10 is open

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx: 1045

MESSAGE NO. CHEM-7

Message for: Radwaste

Message:

NM-283 is OPEN.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. CHEM-8

Message for: CHEM TECH.

Message:

Report that NC System Boron is 1300 ppm.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. CHEM-9

Message for: RADWASTE TECH

Message:

The floor drain tank is aligned to the Aux. Floor Drain Tank.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

D R I L L

Date: 10/20/93

Time:

MESSAGE NO. SIMULATOR - 1

Message for: CONTROL ROOM SRO

Message:

Simulate a call to Carolinas Medical Center informing them that an employee is being sent contaminated.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. SIMULATOR-2

Message for: SRO

Message:

When making the NRC Immediate Notification, inform the NRC Duty Officer (Bethesda) that we will be conducting the McGuire Annual Exercise all day. Ask if they wish to continue receiving calls.

Notes to Controllers:

GIVE TO THE SIMULATOR SRO PRIOR TO MAKING THE NRC IMMEDIATE NOTIFICATION.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. SIMULATOR-3

Message for: SRO

Message:

PT/1/A/4600/01 Will not be performed.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. SIMULATOR-4

Message for: SRO

Message:

PT/1/A/4250/01A "Main Steam Isolation Valve Movement Test"  
will not be performed.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. SIMULATOR-5

Message for: SRO

Message:

ALL lockouts are reset.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. SIMULATOR-6

Message for: SRO

Message:

The Core is uncovered. Low Range Level is 60%.

Thermocouples are at 500 deg.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. SIMULATOR-7

Message for: SRO

Message:

The Core is uncovered. Low Range Level is 55%.

Thermocouples are at 700 deg.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. SIMULATOR-8

Message for: SRO

Message:

The Core low range scale is at 50%.

Thermocouples are at 900 deg.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. SIMULATOR-9

Message for: SRO

Message:

Core low range scale is at 45%.

Thermocouples are at 1100 deg.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. SIMULATOR-10

Message for: SRO

Message:

CORE IS UNCOVERED TO 40%

Thermocouples are indicating 1260 deg.

Red path on core cooling SPDS.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. SIMULATOR-11

Message for: SRO

Message:

RVLIS LEVEL IS 35 %

Thermocouples are at 1450 deg.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx 8:00

MESSAGE NO. Fire Brigade - 1

Message for: Fire Brigade Leader

Message:

The Waste Storage Facility is fully engulfed in fire.  
Flammable liquids have run out of the facility and are  
burning outside the truck corridor door.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. Fire Brigade - 2

Message for:

Message:

The fire is now extinguished.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. Emergency Coordinator - 1

Message for: Emergency Coordinator

Message:

Simulate Site Evacuation.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. Emergency Coordinator - 2

Message for: Emergency Coordinator

Message:

THE EXERCISE IS NOW TERMINATED.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. EOF DIRECTOR - 1

Message for: EOF DIRECTOR

Message:

THE EXERCISE IS NOW TERMINATED.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: 0620

MESSAGE NO. SEC - 1

Message for: SECURITY AT VAP OR N. PAP

Message:

The large crane used to change out the NS Heat exchanger has broken down while passing through the VAP. Access through the VAP is blocked until the crane is moved.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. SEC - 2

Message for: SECURITY VAP OR N. PAP

Message:

THE CRANE HAS BEEN MOVED FROM THE VAP AND NORMAL ACCESS IS RESTORED.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: 7:15

MESSAGE NO.

Message for: Irate Employee

Message:

THIS IS A DRILL MESSAGE. I'm tired of you jerks treating me like you have been. I knew you were going to cut out my job so now it's my time to get even with you. I'm tired of it so I put a bomb on one of the main transformers before I left yesterday. There is no use in you looking for it because I hid it and you will never find it. THIS IS A DRILL MESSAGE.

Notes to Controllers:

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 5:25

MESSAGE NO. OPS-1

Message for: NLO CHECKING ND HEAT EXCHANGER ROOM

Message:

"A" Heat exchanger room has been checked and there are  
NO leaks

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 5:30

MESSAGE NO. OPS-2

Message for: NLO

Message:

Power is now on MCC Breaker 1 EMXA R2A.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 5:30

MESSAGE NO. OPS-3

Message for: NLO

Message:

Power is now on 1 EMXB 1-6B.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 5:40

MESSAGE NO. OPS-4

Message for: NLO

Message:

1ND-56 is definitely releasing and is hot and making a lot  
of noise.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10 0/93

Time: Approx. 5:45

MESSAGE : OPS-5

Message 1, r: NLO

Message:

IND-61 is relieving.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 5:45

MESSAGE NO. OPS-6

Message for: NLO

Message:

IND-61 is NOT relieving.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 5:45

MESSAGE NO. OPS-7

Message for: NLO

Message:

1ND-64 is relieving.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: 5:45

MESSAGE NO. OPS-8

Message for: NLO

Message:

IND-64 is hot but not relieving

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 5:45

MESSAGE NO. GPS-9

Message for: NLO

Message:

1NI-161 is not relieving

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: 5:45

MESSAGE NO. OPS-10

Message for: NLO

Message:

INS-2 is not relieving

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 5:45

MESSAGE NO. OPS-11

Message for: NLO

Message:

1NS-19 is not relieving

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: 5:45

MESSAGE NO. OPS-12

Message for: NLO

Message:

1NV-229 is not relieving

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 5:45

MESSAGE NO. OPS-13

Message for: NLO

Message:

INI-102 is not relieving

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 5:45

MESSAGE NO. OPS-14

Message for: NLO

Message:

INI-119 is not relieving

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 5:45

MESSAGE NO. OPS-15

Message for: NLO

Message:

1NI-151 is not relieving

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 5:50

MESSAGE NO. OPS-16

Message for: NLO

Message:

INI-173 will NOT close.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS -17

Message for: NLO Checking D/G

Message:

You just found a fuel oil leak on the D/G day tank coming from the level instrument inlet. It has leaked approx. 5 gal.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 6:00

MESSAGE NO. OPS-18

Message for: NLO

Message:

OP/1/A/5500/10 Enclosure 1 remaining valves are closed.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 6:40

MESSAGE NO. OPS-19

Message for: NLO

Message:

IAS-11 is OPEN

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx 7:15

MESSAGE NO. OPS-20

Message for: NLO

Message:

Every other cooling group fans on the main step up  
transformers are shut down.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx 7:25

MESSAGE NO. OPS-21

Message for: NLO

Message:

"G" Heater Drain Tank Pumps are shut down.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 7:41

MESSAGE NO. OPS-22

Message for: NLO

Message:

"C" Heater Drain Pumps are secured.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 7:45

MESSAGE NO. OPS-23

Message for: NLO

Message:

"C" Heater Drain Pumps are secured.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 7:50

MESSAGE NO. OPS-24

Message for: NLO

Message:

"C" Heater Drain Pumps are secured.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 7:45

MESSAGE NO. OPS-25

Message for: NLO

Message:

IAS-74 is OPEN

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 7:45

MESSAGE NO. OPS-26

Message for: NLO

Message:

2AS-74 is OPEN

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 7:45

MESSAGE NO. OPS-27

Message for: NLO

Message:

IAS-253 is OPEN

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 11:10

MESSAGE NO. OPS-28

Message for: NLO

Message:

The MG sets are removed from service.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 11:09

MESSAGE NO. OPS-29

Message for: NLO

Message:

ISP-1 is closed

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 11:09

MESSAGE NO. OPS-30

Message for: NLO

Message:

ISP-2 is closed

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 11:10

MESSAGE NO. OPS-31

Message for: NLO

Message:

Turbine is on turning gear.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 11:15

MESSAGE NO. OPS-32

Message for: NLO

Message:

"A" ND Pump Breaker looks fine.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 11:20

MESSAGE NO. OPS-33

Message for: NLO

Message:

IND-29 will NOT close.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-34

Message for: NLO

Message:

INC-24 is closed.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-35

Message for: NLO GOING TO SSF

Message:

NC Pump Seal Injection is initiated (EP/09 Enc. 3 is complete)

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. OPS-36

Message for: NLO GOING TO 1ETA

Message:

NC Pump Seal Injection is initiated.  
EP/09 Enc. 2 is complete

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93                      Time:

MESSAGE NO. OPS- 37

Message for: NLO

Message:

1EVDA BREAKER 6 IS OPEN

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. OPS- 38

Message for: NLO

Message:

IEVDD BREAKER 8 IS OPEN

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. OPS-39

Message for: NLO

Message:

All breakers on 1TA, TB, TC, and TB are OPEN

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. OPS- 40

Message for: NLO

Message:

RC Pump Breaker Control Fuses are pulled.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. OPS-41

Message for: NLO

Message:

Breaker 1EMXC 5B is Closed

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. OPS-42

Message for: NLO

Message:

Breaker 1EMXD 5B is closed

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-43

Message for: NLO

Message:

D/G tripped on overspeed.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. OPS-44

Message for: NLO

Message:

1KC-21 is open and a solid stream of water is visible in  
the sight glass.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-45

Message for: NLO

Message:

1KC-21 is closed.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-46

Message for: NLO

Message:

1KC-6 is unlocked and throttled 1 turn open.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. OPS-47

Message for: NLO

Message:

1KC-6 is open.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-48

Message for: NLO

Message:

1KC-24 is open and a solid stream of water is visible in  
the sight glass.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. OPS-49

Message for: NLO

Message:

1KC-24 is closed

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. OPS-50

Message for: NLO

Message:

1KC-9 is unlocked and throttled 1 turn open.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-51

Message for: NLO

Message:

1KC-9 is open.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. OPS-52

Message for: NLC

Message:

1KC-27 is open and a solid stream of water is visible in  
the sight glass.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

D R I L L

Date: 10/20/93

Time:

MESSAGE NO. OPS- 53

Message for: NLO

Message:

1KC-27 is closed.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. OPS- 54

Message for: NLO

Message:

1KC-12 is unlocked and throttled 1 turn open.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. OPS-55

Message for: NLO

Message:

1KC-12 is open.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. OPS-56

Message for: NLO

Message:

1KC-30 is open and a solid stream of water is visible in  
the sight glass.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. OPS-57

Message for: NLO

Message:

1KC-30 is closed.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. OPS-58

Message for: NLO

Message:

1KC-15 is unlocked and throttled 1 turn open.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. OPS-59

Message for: NLO

Message:

1KC-15 is open.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-60

Message for: NLO

Message:

SSF is secured per EP/1/A/5000/9.2 Enclosure 4

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. OPS-61

Message for: NLO

Message:

LG Seal Oil Air Side Back Up Pump is running

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. OPS-62

Message for: NLO

Message:

OP/1/B/6300/03 Enclosure 4.3 "Dumping Hydrogen From Generator  
is COMPLETE.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 11:30

MESSAGE NO. OPS-63

Message for: NLO

Message:

MCC Breaker 1EMXA-R1E is Closed.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 11:45

MESSAGE NO. OPS-64

Message for: NLO

Message:

1NV-172 is OPEN.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 11:45

MESSAGE NO. OPS-65

Message for: NLO

Message:

1NV-174 is OPEN

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 11:45

MESSAGE NO. OPS-66

Message for: NLO

Message:

1NV-176 is Closed.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx 11:50

MESSAGE NO. OPS-67

Message for: NLO

Message:

Hydrogen Analyzers are in service.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 11:50

MESSAGE NO. OPS-68

Message for: NLO

Message:

Diesel Generators are shut down.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. OPS-69

Message for: NLO ON UNIT 2 FEEDWATER PUMP

Message:

The flange leak is stopped.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 6:00

MESSAGE NO. IAE-1

Message for: IAE Tech.

Message:

The actuator is removed from 1NI-173.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. IAE-2

Message for: IAE Tech.

Message:

IP/0/A/3207/02E "IR Compensation Check" is complete.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. IAE-3

Message for: IAE Tech.

Message:

IND-29 is stuck off seat and will not close.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. IAE-4

Message for: IAE TECH.

Message:

Air is off 1ND-29 and work is complete.  
The valve is intermittent and will NOT close.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. IAE-5

Message for: IAE TECH

Message:

D/G has a faulty 50% switch.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. IAE-6

Message for: IAE TECH

Message:

D/G faulty 50% switch has been replaced.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. IAE-7

Message for: IAE Tech.

Message:

The leaking tubing entrance fitting to the fuel oil day tank level instrument has been repaired.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 6:00

MESSAGE NO. MNT-1

Message for: Maintenance Tech.

Message:

The valve ( 1NI-173 ) is stuck and you cannot get it to jack closed.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. MNT-2

Message for: MAINTENANCE TECH.

Message:

1ND29 will not jack closed.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. MNT- 3

Message for: MAINTENANCE TECH

Message:

Dampers are bound up on the VA Filters and will not open.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. MNT-4

Message for: MAINTENANCE TECH ON FEEDWATER PUMP

Message:

The leaking flange has been retorqued and the leak is stopped.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 6:00

MESSAGE NO. RP-1

Message for: RP Tech

Message:

Rad levels at LNI-173 are as found/as posted.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx 10:45

MESSAGE NO. RP-2

Message for: RP Tech.

Message:

Activity levels in Lower Containment are:

ACTUAL (as sample results indicate)

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 10:45

MESSAGE NO. RP-3

Message for: RP Tech.

Message:

Rad levels in Upper Containment are:

ACTUAL (as sample results indicate)

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

D R I L L

Date: 10/20/93 Time:

MESSAGE NO. CHEM -1

Message for: RDWST SUPV.

Message:

A Crud Burst will not be performed

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. Chem-2

Message for: Radwaste

Message:

PRT is vented per procedure.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

D R I L L

Date: 10/20/93

Time: Approx. 11:30

MESSAGE NO. Chem - 3

Message for: Chemistry

Message:

Boron sample results are 620 ppm.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. Chem-4 There are 6 copies of this message to hand out

Message for: Radwaste

Message:

PRT is vented per procedure

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. Chem-4 There are 6 copies of this message to hand out

Message for: Radwaste

Message:

PRT is vented per procedure

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. Chem-4 There are 6 copies of this message to hand out

Message for: Radwaste

Message:

PRT is vented per procedure

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. Chem-4 There are 6 copies of this message to hand out

Message for: Radwaste

Message:

PRT is vented per procedure

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. Chem-4 There are 6 copies of this message to hand out

Message for: Radwaste

Message:

PRT is vented per procedure

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. Chem-4 There are 6 copies of this message to hand out

Message for: Radwaste

Message:

PRT is vented per procedure

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx. 10:45

MESSAGE NO. CHEM-5

Message for: Radwaste

Message:

WG system is prepared for DEGAS.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx. 10:45

MESSAGE NO. CHEM-6

Message for: Radwaste

Message:

NM-10 is open

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: Approx: 1045

MESSAGE NO. CHEM-7

Message for: Radwaste

Message:

NM-283 is OPEN.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. CHEM- 8

Message for: CHEM TECH.

Message:

Report that NC System Boron is 1300 ppm.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. CHEM- 9

Message for: RADWASTE TECH

Message:

The floor drain tank is aligned to the Aux. Floor Drain Tank.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time:

MESSAGE NO. SIMULATOR - 1

Message for: CONTROL ROOM SRO

Message:

Simulate a call to Carolinas Medical Center informing them that an employee is being sent contaminated.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. SIMULATOR-2

Message for: SRO in Simulator

Message:

When making the NRC Immediate Notification, inform the NRC Duty Officer (Bethesda) that we will be conducting the McGuire Annual Exercise all day. Ask if they wish to continue receiving calls.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. SIMULATOR- 3

Message for: SRO

Message:

PT/1/A/4600/01 Will not be performed.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. SIMULATOR- 4

Message for: SRO

Message:

PT/1/A/4250/01A "Main Steam Isolation Valve Movement Test"  
will not be performed.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93                              Time:

MESSAGE NO. SIMULATOR- 5

Message for: SRO

Message:

ALL lockouts are reset.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. SIMULATOR-6

Message for: SRO

Message:

The Core is uncovered. Low Range Level is 60%.

Thermocouples are at 500 deg.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. SIMULATOR-7

Message for: SRO

Message:

The Core is uncovered. Low Range Level is 55%.

Thermocouples are at 700 deg.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. SIMULATOR-8

Message for: SRO

Message:

The Core low range scale is at 50%.

Thermocouples are at 900 deg.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. SIMULATOR-9

Message for: SRO

Message:

Core low range scale is at 45%.

Thermocouples are at 1100 deg.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. SIMULATOR-10

Message for: SRO

Message:

CORE IS UNCOVERED TO 40%

Thermocouples are indicating 1260 deg.

Red path on core cooling SPDS.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. SIMULATOR-11

Message for: SRO

Message:

RVLIS LEVEL IS 35 %

Thermocouples are at 1450 deg.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: Approx 8:00

MESSAGE NO. Fire Brigade - 1

Message for: Fire Brigade Leader

Message:

The Waste Storage Facility is fully engulfed in fire.  
Flammable liquids have run out of the facility and are  
burning outside the truck corridor door.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93 Time:

MESSAGE NO. Fire Brigade - 2

Message for:

Message:

The fire is now extinguished.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time:

MESSAGE NO. Emergency Coordinator - 1

Message for: Emergency Coordinator

Message:

Simulate Site Evacuation.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. Emergency Coordinator - 2

Message for: Emergency Coordinator

Message:

THE EXERCISE IS NOW TERMINATED.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93                              Time:

MESSAGE NO. EOF DIRECTOR - 1

Message for: EOF DIRECTOR

Message:

THE EXERCISE IS NOW TERMINATED.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93

Time: 0620

MESSAGE NO. SEC - 1

Message for: SECURITY AT VAP OR N. PAP

Message:

The large crane used to change out the NS Heat exchanger has broken down while passing through the VAP. Access through the VAP is blocked until the crane is moved.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

DRILL

Date: 10/20/93 Time:

MESSAGE NO. SEC - 2

Message for: SECURITY VAP OR N. PAP

Message:

THE CRANE HAS BEEN MOVED FROM THE VAP AND NORMAL ACCESS IS RESTORED.

CONFIDENTIAL

THIS IS AN EXERCISE MESSAGE

**DRILL**

Date: 10/20/93

Time: 7:15

MESSAGE NO.

Message for: Irate Employee

Message:

THIS IS A DRILL MESSAGE. I'm tired of you jerks treating me like you have been. I knew you were going to cut out my job so now it's my time to get even with you. I'm tired of it so I put a bomb on one of the main transformers before I left yesterday. There is no use in you looking for it because I hid it and you will never find it. THIS IS A DRILL MESSAGE.

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 6:15 AM

Message number: 1

Message for: Rumor control

Message:

Councilman Webb: I know that there is more to the story on the nuclear problem at McGuire than you are printing. What is the real story? Where can I move my family?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 6:30 Am

Message number: 2

Message for: Rumor control

Message:

My husband has been called back to the plant to staff the TSC. I'm scared! What is going on at the plant? Is my husband in any type of danger? I don't even know how to get in touch with him! What number can I call to check with him?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 6:40 Am

Message number: 3

Message for: Rumor control

Message:

This is Helen Everhardt. I live in a small house in Charlotte. I am an elderly person and can not drive. What am I suppose to do? If they evacuate, who's going to take care of me?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 6:45 Am

Message number: 4

Message for: Rumor control

Message:

Hello, I wonder if you would get them to announce over the radio and on television that I would be glad to come and get anyone who needs transportation to an evacuation shelter if they would call me at 882-7543. My name is Charlie Lewis.

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 7:00AM

Message number: 5

Message for: Rumor control

Message:

I know you've had an accident at the nuclear plant. I've been on a tour before and know a lot about nuclear plants. I'll know if you are not telling the public the truth about your problem. Was this accident caused by operator error like at Three Mile Island or is the equipment broken? My name is Bill Hodges.

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 7:05 Am

Message number: 6

Message for: Rumor control

Message:

This is the second time that you've had problems at your plant. People don't realize how serious problems at a nuclear station really are. Is this just like the leak you had before? I know about your steam generator problems. Is this a steam generator problem?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 7:10 Am

Message number: 7

Message for: Rumor control

Message:

Hello, I've been listening to the radio and I hear that there is something wrong at that nuclear plant. I'm scared because I'm the only one at home in my neighborhood. If I leave now, where should I go?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 7:10 Am

Message number: 8

Message for: Rumor control

Message:

This is Martin Smith of Statesville, NC. I just heard that your plant on Lake Wylie has declared an ALERT. What exactly is that? Are we in danger? Does this mean that radiation is leaking out?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 7:15AM

Message number: 9

Message for: Rumor control

Message:

Hi, I have just heard an ambulance go by my house twice. My neighbor said that they said something on the radio about an accident at the nuclear plant. Can you tell me if there is something wrong at the nuclear plant?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 7:18 Am

Message number: 10

Message for: Rumor control

Message:

This is Margie Stock and my husband is a welder at McGuire. I am terrified that he has been hurt. Can you tell me where he is? Can I talk to him? Can you have him call home?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 7:30AM

Message number: 11

Message for: Rumor control

Message:

This is Mark Hodges with Channel 36 television. Is there some where at the station that we can land our station helicopter? One of our reporters has been out of the area and we'd like to get him to the plant as fast as we can.

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 7:35 Am

Message number: 12

Message for: Rumor control

Message:

Hello, I'm George Settle, they just told about the nuclear plant over the radio. They keep talking about a reactor - what is a reactor? What does "control rods" have to do with it? Well, if the reactor gets too hot what is going to keep the plant from melting or burning or whatever it does?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 7:40 Am

Message number: 13

Message for: Rumor control

Message:

I understand that the nuclear station has blown up. Are we going to be seeing any radiation? I know we need to leave town. What is the safest route for us to take?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 7:45 Am

Message number: 14

Message for: Rumor control

Message:

This is Brenda Smith with the Charlotte Observer. I have just come on shift and I understand that there is a problem at one of your nuclear stations. Can you bring me up-to-date?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 7:50 AM

Message number: 15

Message for: Rumor control

Message:

Hello, I get my water from a well on my property. Will the water be affected by the release of the radioactive gases in this area? I just heard them talking about how to store food and I'm wondering about the water.

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 7:55 Am

Message number: 16

Message for: Rumor control

Message:

This is Tim Petty. My wife works at the station and I've heard that you're having a lot of problems. She works in Safety Assurance. I called and she wasn't at her desk. I'm scared that she's been hurt. Can you kind out where she is and tell her to give me a call.

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 8:00 AM

Message number: 17

Message for: Rumor control

Message:

This is WBT-TV. We are receiving your news release about the problem at the station. I feel like it is our duty (since we are and EBS station) to make sure the public stay informed. Do you have 24 hour-a-day coverage? Who do I need to contact? We'd like to do a story at 12 noon, 6 p.m. and 11 p.m. I will also need a statement from a Duke Power representative. Who can help me out?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 8:05 AM

Message number: 18

Message for: Rumor control

Message:

This is Mrs. Jordan, and there are men in white suits out in my neighborhood...what is going on? Do I need to stay inside? Do I need to leave? Do I need to get my dog in the house? I have a garden out in the back, are the plants safe to eat?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 8:10 Am

Message number: 19

Message for: Rumor control

Message:

My husband is an operator at the plant. I've heard there's a problem and want to make sure that he is O.K. Can you transfer me to the control room or can you give me the most up-to-date information?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 8:20Am

Message number: 20

Message for: Rumor control

Message:

I've been listening to the radio and I hear that there is a terrible fire at McGuire. I'm frightened. What do I need to do?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 8:20 Am

Message number: 21

Message for: Rumor control

Message:

Hello, this is Myra Stevens and I live on Highway 73. Close to the nuclear station. As I was taking my kids to school this morning, I noticed alot of people running around at your nuclear station. Is there a problem there? I sure didn't feel good about leaving my children? Are they safe? Am I?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 8:25 AM

Message number: 22

Message for: Rumor control

Message:

Ms. Ashley: I am 73 years old and I don't own a radio or TV.  
How will I get information about the nuclear accident?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 8:26 Am

Message number: 23

Message for: Rumor control

Message:

Hi, I'm Rick Priory. I'm getting alot of questions from people in the General Office and I'm just calling to see what information you are giving out. Should I put a recording on my telephone referring calls to this number? Do you think the situation is improving?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 8:28 AM

Message number: 24

Message for: Rumor control

Message:

This is Mike Easterling of Cornelius. I heard on the radio that you folks had ~~had~~ a fire at McGuire. How serious is it? Is it out? Have there been any injuries?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 8:30 Am

Message number: 25

Message for: Rumor control

Message:

I'm scared. I've heard on my radio there's a problem at the nuke plant. I'm new and have always been concerned about the safety of the plant. I've heard how dangerous plants like this can be. They're just like nuclear bombs. Is this plant going to blow up? What do I need to do?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 8:45 AM

Message number: 26

Message for: Rumor control

Message:

This is Mark Jones. There are all kinds of DUke Power vans driving around. I know there is a problem at your station. Do I need to stay inside? What's going on? Do I need to leave the are? DO I need to put my dog inside? I have a garden out back. Are the plants going to be contaminated?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 8:50 Am

Message number: 27

Message for: Rumor control

Message:

This is Ms. Abrahams. I have a child in elementary school. Have you evacuated any of the schools? What do I need to do?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 8:50 Am

Message number: 28

Message for: Rumor control

Message:

My name is Bill Norton and my wife and I were looking at some property on Lake Norman this morning and noticed that your atomic nuclear plant. Is it safe? How long has it been in the area? Will we be affected by the station if we live so close by?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 8:50Am

Message number: 29

Message for: Rumor control

Message:

Hi. My name is Lynn Morse and I'm on vacation. I was listening to my CB and heard some county officials talking about evacuating

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 8:55 Am

Message number: 30

Message for: Rumor control

Message:

I live alone and have a cat. I know that it is silly but I am very close to my cat. I can't just leave her....If I am evacuated, can I take the cat to the shelter?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 8:55 Am

Message number: 31

Message for: Rumor control

Message:

This is Yvonne Lamb. I'm worried about the problems ~~your~~ having at the nuclear station. Is this like what happened at Three Mile Island? Are we going to have to evacuate? I am six months pregnant. Am I in any special danger?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 8:58 Am

Message number: 32

Message for: Rumor control

Message:

This is Mrs. Hugh Robinson. My son works at your nuclear station as a contractor. I want to speak with him. Can you tell me how to get in touch with him? I know that your workers are trained but he is not a Duke employee -- what will he do?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:00 Am

Message number: 33

Message for: Rumor control

Message:

Hello, I am Maisy Peterson of Westland Hills Rest Home. We have heard there is a bad problem at your nuclear plant. Who will come get us?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:00 AM

Message number: 34

Message for: Rumor control

Message:

You know, after that Three mile Island accident, the public found out that the plant workers were hiding information. How do we know that we're getting the whole story now? What are you trying to hid. Is the public in any type of danger?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:00 Am

Message number: 35

Message for: Rumor control

Message:

I need some information please. I am a realtor in Huntersville and as I was showing some property at Cowans Ford this morning, my client noticed alot of activity at your nuclear station. They were concerned and will not sign on the property until I have information on what is going on and if it is normal. Is it normal? How often do you have problems? How prepared are you to take care of them? Is this plant like that Three Mile Island plant that melted down? Or is it like the one in Russia that killed so many people? (Realtors name is Annette Ramsey)

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:00

Message number: 36

Message for: Rumor control

Message:

Hello, I'm Marion Strock. I'm a county official and I thought I would call this number to see what you all were telling people about that plant. I've been listening to the news but it sounds like they just keep repeating the same thing over and over. What is happening at the plant right now? Are you all leveling with the people? How soon do you think it's going to be before you evacuate all this area? People are calling here and I don't know what to tell them. I think I should just leave so I won't get all these calls.

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:05 AM

Message number: 37

Message for: Rumor control

Message:

This is Alan Moore and I'm handicapped. I know that there is a problem at the station. I kept my emergency planning booklet that you send me in the mail but I haven't sent the little handicapped card back in. What do I do?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:08Am

Message number: 38

Message for: Rumor control

Message:

I've just hear that the same thing that happened in Russia is happening here. You know they didn't tell the Russian people about the situation and many of them died. Why doesn't Duke tell the truth so that we will have the time to get out before we die?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:10 AM

Message number: 39

Message for: Rumor control

Message:

This is H.A. Thompson with WBTV News. We would like to come down to the plant and set up a crew. Will you have someone available to comment?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:15

Message number: 40

Message for: Rumor control

Message:

I'm mad as I can be about this here accident at that nuclear plant. I told the folks when they put that plant here that something like this was going to happen. Everything I've worked for all my life is right here in this area. If something happens to it and I can't live here no longer, I want you to know than I'm going to sue DPC. You can tell Bill Lee that I'm going to get all my neighbors to sue too. It ain't fair for people to lose their homes and everything they've got so that they can put these nuclear plants here. What is your name? Do you work for DPC? Well, you will hear from me if this here thing gets worse.

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:18 Am

Message number: 41

Message for: Rumor control

Message:

This is Elise Summers and my family and I are terrified! We have only been in the area for about 6 months now and don't know where to go or what to do. Help...Explain what we need to do and what is actually going on.

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:20 Am

Message number: 42

Message for: Rumor control

Message:

This is Missy Lee. I am 8 years old and my mommy is at the store. She said she'd be right back. The siren in our neighborhood is going off and my brother, Neil, said to call this number. What are we supposed to do? My brother is old. He is 14. What are we supposed to do? Do you think my mommy has been hurt?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:25 AM

Message number: 43

Message for: Rumor control

Message:

My brother who works at the plant, just called his wife and told her that things at the plant were getting worse. And they just said on the tv that conditions are stable. Who should I believe? I've been calling everyone I know to tell them what my brother said. We're all getting out of here.

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:30 AM

Message number: 44

Message for: Rumor control

Message:

My name is Elizabeth Brown. I know what you are having a melt down at one of your plants. Where is the plant located? What kind of danger is my 5 month old child in? Are we going to get sick?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:35 AM

Message number: 45

Message for: Rumor control

Message:

This is Alan Moore and I am handicapped. I read your brochure but I never sent in a card. What do I do?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:40AM

Message number: 46

Message for: Rumor control

Message:

This is Angie Cosby. I just heard the sirens around the nuclear station go off. Is this a test. You all are always testing those sirens. I didn't get a notice this time...why not?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:45 AM

Message number: 47

Message for: Rumor control

Message:

I understand that you are having major problems at your plant.  
How many people work there? How many have been injured? How  
many have been exposed to radiation?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:48Am

Message number: 48

Message for: Rumor control

Message:

This is Marvin Letterman. My wife is at Eastridge Mall shopping and the sirens have sounded in our neighborhood. Do I need to leave without her? How will she know? She is a heart patient and will need her medication -- how will I get it to her? What if she has a heart attack? Who will take care of her?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:50AM

Message number: 49

Message for: Rumor control

Message:

We are visiting with our cousins here on Lake Norman and they are out on the lake fishing. We heard the sirens and aren't sure what to do. What has happened? What has happened to our cousins out in the boat? How will they get back to us? How long do they have?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:55Am

Message number: 50

Message for: Rumor control

Message:

I work at Nesbitt Lumber Company in Mount Holly and we have heard the sirens go off, but our management says "Keep working". Can you tell us what is going on?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 9:55Am

Message number: 51

Message for: Rumor control

Message:

Hi, this is Mike Whingate. I heard there's a problem at you nuke plant. The siren have been going off and my child's in school. Where do I need to go and pick her up. She's only 8 years old

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 10:00 Am

Message number: 52

Message for: Rumor control

Message:

This is television Channel 36. We would like to go to the plant to get some footage. Is it possible to get into the control room so the public can see the operators at work? Who do we need to talk to?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 10:05AM

Message number: 53

Message for: Rumor control

Message:

Hello. My name is Brad Day. My neighbor just told me that there is a chance that babies will be borne with deformities because of the accident at your nuclear plant. He said that after Chernobyl both animals and humans had more defects. What do you know about that?

Notes:

THIS IS A DRILL MESSAGE

Date: October 25, 1993

Time: 10:10 Am

Message number: 54

Message for: Rumor control

Message:

Hello. I live in Gastonia and I have heard the reports of problems at McGuire but I have not heard the sirens. Aren't they working? What good are they if they can't let us know of these emergencies?

Noies:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 10:15 AM

Message number: 55

Message for: Rumor control

Message:

Mrs. Markam: I have a dog shelter in Lincolnton and I have heard the sirens go off. I read my emergency planning brochure and understand that I cannot take the animals with me. I cannot leave these animals here to die. Who can I call to get help?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 10:20 AM

Message number: 56

Message for: Rumor control

Message:

My husband works at the nuclear station. I am a little worried with all of the problems you're having at the plant. I would like for him to come on home. How can I get in touch with him? His name is Jerry Blue.

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 10:30 Am

Message number: 57

Message for: Rumor control

Message:

Hi, I read in a magazine that they give out iodine tablets around nuclear power plants when an accident occurs. Who is giving them out in my area? I live at Boiling Springs.

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 10:40 Am

Message number: 58

Message for: Rumor control

Message:

Hello, my neighbor just told me that babies will be born with deformities because of this nuclear accident. He said he read it in a magazine recently. He said that after Chernobyl both animals and humans had more birth defects. What do you know about that?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 10:45Am

Message number: 59

Message for: Rumor control

Message:

This is Mason Black of Black's Dairy Farm I am a volunteer fireman and heard that you all were having some problems. What's happening? Are my cows going to be okay? Do you need a volunteer fireman to come in and help out? Do you need for us to help with crowd control?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 10:50 Am

Message number: 60

Message for: Rumor control

Message:

This is Beth Myers of Davidson and I am 7 months pregnant and my husband is working out of town. I remember that they evacuated pregnant women and children at Three Mile Island first. Did they miss me? I am scared and I have no one here. Please help me.

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 11:00 Am

Message number: 61

Message for: Rumor control

Message:

Ms. Markam: Can I take my prize persian cat to the shelter?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 11:05

Message number: 62

Message for: Rumor control

Message:

My name is Bob Adams. I know there is more to the story than what we are been told on the radio and tv. What is the whole/real story? Where should I move my family?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 11:08 Am

Message number: 63

Message for: Rumor control

Message:

Mr. Shelly: I am 90 years old and I have lived through everything from tornados, to hurricane HUGO, to all the wars. I am not going to leave my home. I hear those sirens and I hear the news, but I'm not leaving. I guess this is as good a place as any to die.

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 11:11 AM

Message number: 64

Message for: Rumor control

Message:

My name is Mark Rhinegruger. I just heard about the release of radiation you're having at the plant. What kind of danger are we (the public) in? I'm scared. I heard all kinds of things about radiation.

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 11:20 AM

Message number: 65

Message for: Rumor control

Message:

This is Dan Rather with CBS news. We want to do a live interview with Bill Lee about the accident at McGuire. Wall Street analysts will be offering their opinions

Can you give us your comments or can you get Bill Lee on the line?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 11:30, m

Message number: 66

Message for: Rumor control

Message:

This is Elise Summers and my family and I are terrified. We have only lived here 6 months and we don't have any information about where to go or what to do. What is a General Emergency? What do we do? Is it too late?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 11: 35 Am

Message number: 67

Message for: Rumor control

Message:

Hello, this is Channel 7 in Greenville SC and we would like to put you on the air to explain to our viewers what is exactly happening at McGuire. Are you ready?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 11:40

Message number: 68

Message for: Rumor control

Message:

This is the switchboard I just received a phone call from Mary Evatt. She lives on Ebenezer Road. She says that the siren at the end of the road has not stopped running.

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 11:45 Am

Message number: 69

Message for: Rumor control

Message:

My area has been designated for evacuation. I can't understand your maps (in the booklet you mailed out). They always confuse me. Can you help me out? What am I suppose to take with me and how long will it be before I can retu...?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 11:50 AM

Message number: 70

Message for: Rumor control






Message:

This is Mike Cosar with WBT and we are getting the same information over and over about the problems at the station. We would like to see for ourselves. Can someone meet us at McGuire? Our viewers deserve the truth.

Notes:





# 1

IMAGE EVALUATION  
TEST TARGET (MT-3)





# 1

## IMAGE EVALUATION TEST TARGET (MT-3)



# 1

## IMAGE EVALUATION TEST TARGET (MT-3)







# 1

## IMAGE EVALUATION TEST TARGET (MT-3)



150mm

6"



THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 11:55

Message number: 71

Message for: Rumor control

Message:

Mr. Abrams: I have a child in elementary school in (your county) and we have been ordered to evacuate. What do I do?

Notes:

THIS IS DRILL MESSAGE

Date: October 20, 1993

Time: 12:00 Noon

Message number: 72

Message for: Rumor control

Message:

Tom Meadows here. What is a general emergency? How did you get to that? What is next?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 12:05PM

Message number: 73

Message for: Rumor control

Message:

My name is Jerry Strange and I've studied about nuclear plants in college. Three Mile Island and Chernobyl both had serious problems. I understand the risk but would like to come to the plant to see a recovery team in action.

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 12:10 AM

Message number: 74

Message for: Rumor control

Message:

This is Amanda Brown. Has there been an accident at McGuire? We have heard our sirens here at our lake cabin but have no radio or tv. Do we need to evacuate? Has there been a release of radioactivity? We were out on the boat and had been skiing. Is the water bad in the lake?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 12:15 Pm

Message number: 75

Message for: Rumor control

Message:

This is Jack Horan with the Charlotte Observer. We are covering your problem at McGuire and need some information. How many people work there? How many have been evacuated from the station? How many from the community? What about injuries?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 12: 20 Pm

Message number: 76

Message for: Rumor control

Message:

This is Mr. Steely. I'm 90 years old and don't want to leave my home. I heard those sirens, radio reports and television reports... but don't want to leave my home. I just wanted to let you know that I'm staying!

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 12:25 Pm

Message number: 77

Message for: Rumor control

Message:

My name is Nita Haron. I have a friend that works at the nuclear station. She called and asked me to pick up her chldren from daycare - that there was a big problem at the plant. What is going on? Is it dangerous for me to be out driving? Breathing the air?

Notes:

THIS IS A DRILL MESSAGE

Date: October 20, 1993

Time: 12:30 Pm

Message number: 78

Message for: Rumor control

Message:

My name is Ray Green and I'm with Channel 7 News. Where can I come to get the most up-to-date information about the plant? I'd also like a company spokesperson to speak on the 6:00 News.

Notes:

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date: 10/10/93

Time: 0335

Group: 05 ----- PRIMARY SYSTEM				
1.	A0965 NC LOOP A WIDE RANGE HOT LEG TEMP	616.36	DEG F	
2.	A0971 NCLLOOP B WIDE RANGE HOT LEG TEMP	616.66	DEG F	
3.	A0977 NC LOOP C WIDE RANGE HOT LEG TEMP	616.36	DEG F	
4.	A0983 NC LOOP D WIDE RANGE HOT LEG TEMP	616.36	DEG F	
5.	A1061 NC LOOP A WIE RANGE COLD LEG TEMP	559.38	DEG F	
6.	A1067 NC LOOP B WIDE RANGE COLD LEG TEM	559.42	DEG F	
7.	A1073 NC LOOP C WIDE RANGE COLD LEG TEMP	559.44	DEG F	
8.	A1079 NC LOOP D WIDE RANGE CLLD LEG TEMP	559.42	DEG F	
9.	A0826 NC SYSTEM (HOT LEG) WIDE RANGE PRESS	2248.19	PSIG	
11.	A1124 PZR LEVEL I (HOT CALIBRATED)	61.11	%	
12.	D2803 REACTOR COOLANT PUMP A	ON		
13.	D2804 RACTOR COOLANT PUMP B	ON		
14.	D2805 REACTOR COOLANT PUMP C	ON		
15.	D2806 REACTOR COOLANT PUMP D	ON		
16.	A1177 SOURCE RANG (FLUX) LEVEL CHANNEL 1	0.00	CPS	
17.	A1206 SOURCE RANGE (FLUX) LEVEL CHANNEL2	0.00	CPS	
18.	A0528 PWWER RANGE AVG LEVEL QUADRANT 1 (N-43)	9.12	%	
19.	P1385 REACTOR THERMAL POWER,BEST ESTIMATE	99.09	%	
20.	A0602 CVCS BORON METER (ISOLATED ON Ph. A)	622.89	PPM	
21.	A1312 RVLIS - TRIN A - DYNAMIC HEAD D/P	105.07	%	
22.	A1300 RVLIS - TRAIN A - UPPER RANGE LEVEL	61.33	%	
23.	A1306 VLIS - TRAIN A - LOWER RANGE LEVEL	67.00	%	
24.	P1481 LOWEST NC SYSTEM SUBCOOLING MARGIN	13.81	DEG F	
Group: 10 ----- SECONDARY SYSTEM				
1.	A1004 STEAM GEN A WIDE RANGE LEVEL	63.86	%	
2.	A1005 TTEAM GEN B WIDE RANGE LEVEL	6386	%	
3.	A0970 STEAM GEN C WIDE RANE LEVEL	63.56	%	
4.	A0988 STEAM GEN D WIDE RANGE LEVEL	61.86	%	
5.	A1107 STEAM GENA STEAM (LINE) PRESS I	990.20	PSIG	
6.	A1113 STEAM GEN B STEAM (LINE) PRESS I	990.20	PSIG	
7.	A1119 STEAM GEN C STEAM (LINE) PRESS I	990.21	PSIG	
8.	A1125 STEAM GEN D STEAM (INE) PRESS I	990.19	PSIG	
9.	P1412 TOTAL S/G A (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
10.	P1414 TOTAL S/GB (MAIN) FEEDWATER FLOW 1	3.79	ML/HR	
11.	P1416 TOTAL S/G C (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
12.	P1418 TOTAL S/G D (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
13.	P1208 AUX FEEDWATER FLOW O S/G A	0.0530	MLB/HR	
44.	P1209 AUX FEEDWATER FLOW TO S/G B	0.0530	MLB/HR	
15.	P1210 AUX FEEDWATER FLOW TO S/G C	0.0530	MLB/HR	
16.	P1211 AUX FEEDWATER FLOW TO S/G D	0.0530	MLB/HR	
17.	A1059 STEAM GEN A NARROW RANGE LEVEL IV	66.00	%	
18.	A1065 STEAM GEN B NARROW ANGE LEVEL IV	66.00	%	
19.	A1071 STEAM GEN C NARROW RANGE LEVEL IV	66.00	%	
20.	A1077 STEAM GNN D NARROW RANGE LEVEL IV	66.00	%	
21.	A0736 MAIN STEAM HEADER PRESSURE	975.75	PSIG	

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 2

Date: 10/20/93

Time: 0335

Group: 15	AUXILIARY/INJECTION SYSTEMS		
1. D0970	NV PUMP A (HIGH HEAD SI)	OFF	
2. D0620	NV PUMP B (HIGH HEAD SI)	ON	
3. A0827	BORON INJECTION (HIG HEAD SI) FLOW		0.00 GPM
4. D3574	NI PUMP A (INTERMEDIATE HEAD SI)	OFF	
5. D3576	NI PUMP B INTERMEDIATE HEAD SI)	OFF	
6. D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF	
7. D0968	ND PUMP B (LOW HEAD SI / RHR)	OFF	
8. A0758	CHARGING PUMP DISCHARGE HEADER FLOW		87.37 GPM
9. A0855	(LOW HEAD SI / RHR) ND HX RETURN FLOW		0.00 GPM
10. A0764	LETDOWN H OUTLET FLOW		75.64 GPM
11. D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL	
12. D0402	REFUELING WATER STORAGE TANK LEVEL	NOT LO	
13. D0401	REFUELING WATER STOAGE TANK LEVEL	NOT EMER LO	
Group: 20	CONTAINMENT SYSTEMS		
1. A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)		PSIG
2. A0785	INTER. RANGE CONTAIN. PRESS (-5 TO 20)	0.1610	PSIG
3. A1047	WIDE RANGE CONTAIN. PRESS (-5 TO 60)		PSIG
4. A1228	LOWER CONT AMBIENT AIR TEMP A	110.59	DEG F
5. A1204	UPPER CONT AMBIENT AIR TEMP A	89.98	DE F
6. A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00	FT
7. A0671	CONTAINMENT SUP LEVEL TRAIN B		FT
8. A0848	CONTAINMENT H2 CONCENTRATION TRAIN	0.00	%
9. D3572	NS UMP A (CONTAINMENT SPRAY)	OFF	
10. D3573	NS PUMP B (CONTAINMENT SRAY)	OFF	
Group: 25	RADIATION SYSTEMS		
1. A0115	IEMF48 REACTOR COOLANT MONITOR	51924.98	CPM
2. A0829	1EM551A IN CONTAINMENT HI RANGE RAD MON	8.99	R/HR
3. A0835	1EMF51B IN CONTAINMENT HI RANGE RAD MON	8.99	R/HR
4. A0073	1EMF39H CONTAINMENT GAS HI RANGE	2.00	CPM
5. A0067	1EMF39L CONTAINMENT GAS LO RANGE	28504.94	CPM
6. A0061	1EMF38H CONTAINMENT PARTICULATE H RANGE	5.00	CPM
7. A0055	1EF38L CONTAINMENT PARTICULATE LO RANGE	27029.45	CPM
8. A1009	1EMF36HH UNIT VENT GAS HI HI RANGE	4.00	R/HR
9. A0018	1EMF36H UNIT VENT GAS HI RANGE	11.01	CPM
10. A0012	1EMF36L UNI VENT GAS LO RANGE	465.00	CPM
11. A0019	1EMF35H UNIT VENT PARTICULATE HI RANGE	19.95	CPM
12. A0013	EMF35L UNIT VENT PARTICULATE LO RANGE	310.00	CPM
13. A0049	1EMF37 UNIT VENT IODINE	385.00	CPM
14. A0079	1EMF40 CONTAINMENT IODINE	500.00	CPM
15. A1368	1EMF24 STEMLINE 1A RADIATION MONITOR	0.0110	mR/Hr
16. A1374	1EMF25 STEAMLINE 1B RADIATION ONITOR	0.0110	MR/HR
17. A1380	1EMF26 STEAMLINE 1C RADIATION MONITOR	0.110	MR/HR
18. A1386	1EMF27 STEAMLINE 1DRADIATION MONITOR	0.0110	MR/HR
19. A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE		CPM
Group: 30	ENVIRONMENTAL SYSTEMS		
1. P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)		MPH
2. P0848	LOWER WIND SPEED (15 MINUTE AVERAGE)		MPH
3. P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAG))		DEG C
4. P0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)		DEG
5. P0849	LOWER WIND DIRECTION (15 MIUTE AVERAGE)		DEG
6. P0595	PRECIPITATION IN LAST 15 MIN		IN
7. P0851	AMBIENT AIR TEMPERTURE(15 MINUTE AVERAGE)		DEG C
8. A0863	UNIT VENT STACK FLOW	91647.50	FT3/MN

RDT501

DUKE POWER COMPANY      Unit: MNS 1      Page: 3

Date: 10/20/93      Time: 0335

Group: 35      IN-CORE THERMOCOUPLES

1. A0268	IN-CORE TEMP A10 T/C #2	559.29	DEG F
2. A0166	IN-CORE TEMP J06 T/C #17	558.82	DEG F
3. A0155	IN-CORE TEMP F01 T/C #43	559.73	DEG F
4. A0251	IN-CORETEMP M07 T/C #59	559.13	EG F
5. P0823	5 HIGHEST IN-CORE T/C TEMP ARGIN	-----	DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP	-----	DEG F
7. A1323	IN-CORE TEMP K05 T/C #54	-----	DEG F
8. A1341	IN-CORE TEMP M11 T/C #60	-----	DEG F
9. A1287	IN-CORE TEMP D13 T/C #42	-----	DEGF
10. A1161	IN-CORE TEMP C04 T/C #3	-----	DEG F

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1  
Date: 10/10/93Page: 1  
Time: 0350

Group: 05	----- PRIMARY SYSTEM			
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	616.36	DEG F	
2. A0971	NCLLOOP B WIDE RANGE HOT LEG TEMP	616.66	DEG F	
3. A0977	NC LOOP C WIDE RANGE HOT LEG TEMP	616.36	DEG F	
4. A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	616.36	DEG F	
5. A1061	NC LOOP A WIE RANGE COLD LEG TEMP	559.38	DEG F	
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEM	559.42	DEG F	
7. A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	559.44	DEG F	
8. A1079	NC LOOP D WIDE RANGE CLLD LEG TEMP	559.42	DEG F	
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	2248.19	PSIG	
11. A1124	PZR LEVEL I (HOT CALIBRATED)	61.11	%	
12. D2803	REACTOR COOLANT PUMP A	ON		
13. D2804	RACTOR COOLANT PUMP B	ON		
14. D2305	REACTOR COOLANT PUMP C	ON		
15. D2806	REACTOR COOLANT PUMP D	ON		
16. A1177	SOURCE RANG (FLUX) LEVEL CHANNEL 1	0.00	CPS	
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL2	0.00	CPS	
18. A0628	PWWER RANGE AVG LEVEL QUADRANT 1 (N-43)	9.12	%	
19. P1385	REACTOR THERMAL POWER,BEST ESTIMATE	99.09	%	
20. A0602	CVCS BORON METER (ISOLATED ON Ph. A)	622.89	PPM	
21. A1312	RVLIS - TRIN A - DYNAMIC HEAD D/P	105.07	%	
22. A1300	RVLIS - TRAIN A - UPPER RANGE LEVEL	61.33	%	
23. A1306	VLIS - TRAIN A - LOWER RANGE LEVEL	64.00	%	
24. P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN	13.81	DEG F	
Group: 10	----- SECONDARY SYSTEM			
1. A1004	STEAM GEN A WIDE RANGE LEVEL	63.86	%	
2. A1005	TTEAM GEN B WIDE RANGE LEVEL	63.86	%	
3. A0970	STEAM GEN C WIDE RANE LEVEL	63.86	%	
4. A0988	STEAM GEN D WIDE RANGE LEVEL	63.86	%	
5. A1107	STEAM GENA STEAM (LINE) PRESS I	990.20	PSIG	
6. A1113	STEAM GEN B STEAM (LINE) PRESS I	990.20	PSIG	
7. A1119	STEAM GEN C STEAM (LINE) PRESS I	990.21	PSIG	
8. A1125	STEAM GEN D STEAM (INE) PRESS I	990.19	PSIG	
9. P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
10. P1414	TOTAL S/GB (MAIN) FEEDWATER FLOW 1	3.79	ML/HR	
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
12. P1418	TOTAL S/G D (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
13. P1208	AUX FEEDWATER FLOW O S/G A	0.0530	MLB/HR	
44. P1209	AUX FEEDWATER FLOW TO S/G B	0.0530	MLB/HR	
15. P1210	AUX FEEDWATER FLOW TO S/G C	0.0530	MLB/HR	
16. P1211	AUX FEEDWATER FLOW TO S/G D	0.0530	MLB/HR	
17. A1059	STEAM GEN A NARROW RANGE LEVEL IV	66.00	%	
18. A1065	STEAM GEN B NARROW ANGE LEVEL IV	66.00	%	
19. A1071	STEAM GEN C NARROW RANGE LEVEL IV	66.00	%	
20. A1077	STEAM GNN D NARROW RANGE LEVEL IV	66.00	%	
21. A0736	MAIN STEAM HEADER PRESSURE	975.75	PSIG	

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1 Page: 2  
Date: 10/20/93 Time: 0350

Group: 15		AUXILIARY/INJECTION SYSTEMS	
1.	D0970	NV PUMP A (HIGH HEAD SI)	OFF
2.	D0620	NV PUMP B (HIGH HEAD SI)	ON
3.	A0827	BORON INJECTION (HIG HEAD SI) FLOW	0.00 GPM
4.	D3574	NI PUMP A (INTERMEDIATE HEAD SI)	OFF
5.	D3576	NI PUMP B INTERMEDIATE HEAD SI)	OFF
6.	D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF
7.	D0968	ND PUMP B (LOW HEAD SI / RHR)	OFF
8.	A0758	CHARGING PUMP DISCHARGE HEADER FLOW	87.37 GPM
9.	A0856	(LOW HEAD SI / RHR) ND HX RETURN FLOW	0.00 GPM
10.	A0764	LETDOWN H OUTLET FLOW	75.64 GPM
11.	D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL
12.	D0402	REFUELING WATER STORAGE TANK LEVEL	NOT LO
13.	D0401	REFUELING WATER STOAGE TANK LEVEL	NOT EMER LO
Group: 20		CONTAINMENT SYSTEMS	
1.	A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)	PSIG
2.	A0785	INTER. RANGE CONTAIN. PRESS (-5 TO 20)	0.1610 PSIG
3.	A1047	WIDE RANGE CONTAIN PRESS (-5 TO 60)	PSIG
4.	A1228	LOWER CONT AMBIENT AIR TEMP A	110.59 DEG F
5.	A1204	UPPER CONT AMBIENT AIR TEMP A	89.98 DE F
6.	A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00 FT
7.	A0671	CONTAINMENT SUP LEVEL TRAIN B	FT
8.	A0848	CONTAINMENT H2 CONCENTRATION TRAIN	0.00 %
9.	D3572	NS UMP A (CONTAINMENT SPRAY)	OFF
10.	D3573	NS PUMP B (CONTAINMENT SRAY)	OFF
Group: 25		RADIATION SYSTEMS	
1.	A0115	1EMF48 REACTOR COOLANT MONITOR	51924.98 CPM
2.	A0829	1EM551A IN CONTAINMENT HI RANGE RAD MON	8.99 R/HR
3.	A0835	1EMF51B IN CONTAINMENT HI RANGE RAD MON	8.99 R/HR
4.	A0073	1EMF39H CONTAINMENT GAS HI RANGE	2.00 CPM
5.	A0067	1EMF39L CONTAINMENT GAS LO RANGE	28504.94 CPM
6.	A0061	1EMF38H CONTAINMENT PARTICULATE H RANGE	5.00 CPM
7.	A0055	1EF38L CONTAINMENT PARTICULATE LO RANGE	27029.45 CPM
8.	A1009	1EMF36HH UNIT VENT GAS HI HI RANGE	4.00 R/HR
9.	A0018	1EMF36H UNIT VENT GAS HI RANGE	11.01 CPM
10.	A0012	1EMF36L UNI VENT GAS LO RANGE	465.00 CPM
11.	A0019	1EMF35H UNIT VENT PARTICULATE HI RANGE	19.95 CPM
12.	A0013	EMF35L UNIT VENT PARTICULATE LO RANGE	310.00 CPM
13.	A0049	1EMF37 UNIT VENT IODINE	385.00 CPM
14.	A0079	1EMF40 CONTAINMENT IODINE	500.00 CPM
15.	A1368	1EMF24 STEMLINE 1A RADIATION MONITOR	0.0110 mR/Hr
16.	A1374	1EMF25 STEAMLINE 1B RADIATION ONITOR	0.0110 MR/HR
17.	A1380	1EMF26 STEAMLINE 1C RADIATION MONITOR	0.110 MR/HR
18.	A1386	1EMF27 STEAMLINE 1DRADIATION MONITOR	0.0110 MR/HR
19.	A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE	CPM
Group: 30		ENVIRONMENTAL SYSTEMS	
1.	P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)	MPH
2.	P0848	LOWER WIND SPEED (15 MINUTE AVERAGE)	MPH
3.	P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAG))	DEG C
4.	P0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)	DEG
5.	P0849	LOWER WIND DIRECTION (15 MIUTE AVERAGE)	DEG
6.	P0595	PRECIPITATION IN LAST 15 MIN	IN
7.	P0851	AMBIENT AIR TEMPERTURE(15 MINUTE AVERAGE)	DEG C
8.	A0863	UNIT VENT STACK FLOW	91647.50 FT3/MN

RDT501

DUKE POWER COMPANY

Unit: MNS 1 Page: 3

Date: 10/20/93 Time: 0350

## Group: 35 ----- IN-CORE THERMOCOUPLES

1. A0268	IN-CORE TEMP A10 T/C #2	559.29	DEG F
2. A0166	IN-CORE TEMP J06 T/C #17	558.82	DEG F
3. A0155	IN-CORE TEMP F01 T/C #43	559.73	DEG F
4. A0251	IN-CORETEMP M07 T/C #59	559.13	EG F
5. P0823	5 HIGHEST IN-CORE T/C TEMP ARGIN	-----	DEG F
6. P0828	5 HIGHEST IN-CORE T/C TFMP	-----	DEG F
7. A1323	IN-CORE TEMP K05 T/C #54	-----	DEG F
8. A1341	IN-CORE TEMP M11 T/C #60	-----	DEG F
9. A1287	IN-COR TEMP D13 T/C #42	-----	DEGF
10. A1161	IN-CORE TEMP C04 T/C #3	-----	DEG F

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1  
Date: 10/10/93Page: 1  
Time: 0405

Group: 05	-----	PRIMARY SYSTEM	-----
1.	A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	616.36 DEG F
2.	A0971	NCLLOOP B WIDE RANGE HOT LEG TEMP	616.66 DEG F
3.	A0977	NC LOOP C WIDE RANGE HOT LEG TEMP	616.36 DEG F
4.	A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	616.36 DEG F
5.	A1061	NC LOOP A WIE RANGE COLD LEG TEMP	559.38 DEG F
6.	A1067	NC LOOP B WIDE RANGE COLD LEG TEM	559.42 DEG F
7.	A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	559.44 DEG F
8.	A1079	NC LOOP D WIDE RANGE CLLD LEG TEMP	559.42 DEG F
9.	A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	2248.19 PSIG
11.	A1124	PZR LEVEL I (HOT CALIBRATED)	61.11 %
12.	D2803	REACTOR COOLANT PUMP A	ON
13.	D2804	RACTOR COOLANT PUMP B	ON
14.	D2805	REACTOR COOLANT PUMP C	ON
15.	D2806	REACTOR COOLANT PUMP D	ON
16.	A1177	SOURCE RANG (FLUX) LEVEL CHANNEL 1	0.00 CPS
17.	A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL2	0.00 CPS
18.	A0628	PWWER RANGE AVG LEVEL QUADRANT 1 (N-43)	9.12 %
19.	P1385	REACTOR THERMAL POWER,BEST ESTIMATE	99.09 %
20.	A0602	CVCS BORON METER (ISOLATED ON Ph. A)	622.89 PPM
21.	A1312	RVLIS - TRIN A - DYNAMIC HEAD D/P	105.07 %
22.	A1300	RVLIS - TRAIN A - UPPER RANGE LEVEL	61.33 %
23.	A1306	VLIS - TRAIN A - LOWER RANGE LEVEL	64.00 %
24.	P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN	13.81 DEG F
Group: 10	-----	SECONDARY SYST..	-----
1.	A1004	STEAM GEN A WIDE RANGE LEVEL	63.86 %
2.	A1005	TTEAM GEN B WIDE RANGE LEVEL	63.86 %
3.	A0970	STEAM GEN C WIDE RANE LEVEL	63.86 %
4.	A0988	STEAM GEN D WIDE RANGE LEVEL	63.86 %
5.	A1107	STEAM GENA STEAM (LINE) PRESS I	990.20 PSIG
6.	A1113	STEAM GEN B STEAM (LINE) PRESS I	990.20 PSIG
7.	A1119	STEAM GEN C STEAM (LINE) PRESS I	990.21 PSIG
8.	A1125	STEAM GEN D STEAM (INE) PRESS I	990.19 PSIG
9.	P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	3.79 MLB/HR
10.	P1414	TOTAL S/GB (MAIN) FEEDWATER FLOW 1	3.79 ML/HR
11.	P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1	3.79 MLB/HR
12.	P1418	TOTAL S/G D (MAIN) FEEDWATER FLOW 1	3.79 MLB/HR
13.	P1208	AUX FEEDWATER FLOW O S/G A	0.0530 MLB/HR
44.	P1209	AUX FEEDWATER FLOW TO S/G B	0.0530 MLB/HR
15.	P1210	AUX FEEDWATER FLOW TO S/G C	0.0530 MLB/HR
16.	P1211	AUX FEEDWATER FLOW TO S/G D	0.0530 MLB/HR
17.	A1059	STEAM GEN A NARROW RANGE LEVEL IV	66.00 %
18.	A1065	STEAM GEN B NARROW ANGE LEVEL IV	66.00 %
19.	A1071	STEAM GEN C NARROW RANGE LEVEL IV	66.00 %
20.	A1077	STEAM GNN D NARROW RANGE LEVEL IV	66.00 %
21.	A0736	MAIN STEAM HEADER PRESSURE	975.75 PSIG

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1 Page: 2

Date: 10/20/93 Time: 0405

Group: 15		AUXILIARY/INJECTION SYSTEMS	
1.	D0970	NV PUMP A (HIGH HEAD SI)	OFF
2.	D0620	NV PUMP B (HIGH HEAD SI)	ON
3.	A0827	BORON INJECTION (HIG HEAD SI) FLOW	0.00 GPM
4.	D3574	NI PUMP A (INTERMEDIATE HEAD SI)	OFF
5.	D3576	NI PUMP B INTERMEDIATE HEAD SI)	OFF
6.	D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF
7.	D0968	ND PUMP B (LOW HEAD SI / RHR)	OFF
8.	A0758	CHARGING PUMP DISCHARGE HEADER FLOW	87.37 GPM
9.	A0856	(LOW HEAD SI / RHR) ND HX RETURN FLOW	0.00 GPM
10.	A0764	LETDOWN H OUTLET FLOW	75.64 GPM
11.	D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL
12.	D0402	REFUELING WATER STORAGE TANK LEVEL	NOT LO
13.	D0401	REFUELING WATER STOAGE TANK LEVEL	NOT EMER LO
Group: 20		CONTAINMENT SYSTEMS	
1.	A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)	PSIG
2.	A0785	INTER. RANGE CONTAIN. PRESS (-5 TO 20)	0.1610 PSIG
3.	A1047	WIDE RANGE CONTAIN. PRESS (-5 TO 60)	PSIG
4.	A1228	LOWER CONT AMBIENT AIR TEMP A	110.59 DEG F
5.	A1204	UPPER CONT AMBIENT AIR TEMP A	89.98 DE F
6.	A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00 FT
7.	A0671	CONTAINMENT SUP LEVEL TRAIN B	FT
8.	A0848	CONTAINMENT H2 CONCENTRATION TRAIN	0.00 %
9.	D3572	NS UMP A (CONTAINMENT SPRAY)	OFF
10.	D3573	NS PUMP B (CONTAINMENT SRAY)	OFF
Group: 25		RADIATION SYSTEMS	
1.	A0115	1EMF48 REACTOR COOLANT MONITOR	51924.98 CPM
2.	A0829	1EM551A IN CONTAINMENT HI RANGE RAD MON	8.99 R/HR
3.	A0835	1EMF51B IN CONTAINMENT HI RANGE RAD MON	8.99 R/HR
4.	A0073	1EMF39H CONTAINMENT GAS HI RANGE	2.00 CPM
5.	A0067	1EMF39L CONTAINMENT GAS LO RANGE	28504.94 CPM
6.	A0061	1EMF38H CONTAINMENT PARTICULATE H RANGE	5.00 CPM
7.	A0055	1EF38L CONTAINMENT PARTICULATE LO RANGE	27029.45 CPM
8.	A1009	1EMF36HH UNIT VENT GAS HI HI RANGE	4.00 R/HR
9.	A0018	1EMF36H UNIT VENT GAS HI RANGE	11.01 CPM
10.	A0012	1EMF36L UNI VENT GAS LO RANGE	465.00 CPM
11.	A0019	1EMF35H UNIT VENT PARTICULATE HI RANGE	19.95 CPM
12.	A0013	EMF35L UNIT VENT PARTICULATE LO RANGE	310.00 CPM
13.	A0049	1EMF37 UNIT VENT IODINE	385.00 CPM
14.	A0079	1EMF40 CONTAINMENT IODINE	500.00 CPM
15.	A1368	1EMF24 STEMLINE 1A RADIATION MONITOR	0.0110 mR/Hr
16.	A1374	1EMF25 STEAMLINE 1B RADIATION ONITOR	0.0110 MR/HR
17.	A1380	1EMF26 STEAMLINE 1C RADIATION MONITOR	0.110 MR/HR
18.	A1386	1EMF27 STEAMLINE 1DRADIATION MONITOR	0.0110 MR/HR
19.	A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE	CPN
Group: 30		ENVIRONMENTAL SYSTEMS	
1.	P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)	--- MPH
2.	P0848	LOWER WIND SPEED (15 MINUTE AVERAGE)	--- MPH
3.	P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAG))	--- DEG C
4.	P0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)	--- DEG
5.	P0849	LOWER WIND DIRECTION (15 MIUTE AVERAGE)	--- DEG
6.	P0595	PRECIPITATION IN LAST 15 MIN	--- IN
7.	P0851	AMBIENT AIR TEMPERTURE(15 MINUTE AVERAGE)	--- DEG C
8.	A0863	UNIT VENT STACK FLOW	91647.50 FT3/MN

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date: 10/20/93 Time: 0405

Group: 35	IN-CORE THERMOCOUPLES	
1. A0268	IN-CORE TEMP A10 T/C #2	559.29 DEG F
2. A0166	IN-CORE TEMP J06 T/C #17	558.82 DEG F
3. A0155	IN-CORE TEMP F01 T/C #43	559.73 DEG F
4. A0251	IN-CORETEMP M07 T/C #59	559.13 EG F
5. P0823	5 HIGHEST IN-CORE T/C TEMP ARGIN	----- DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP	----- DEG F
7. A1323	IN-CORE TEMP K05 T/C #54	----- DEG F
8. A1341	IN-CORE TEMP M11 T/C #60	----- DEG F
9. A1287	IN-COR TEMP D13 T/C #42	----- DEGF
10. A1161	IN-CORE TEMP C04 T/C #3	----- DEG F

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date: 10/10/93

Time: 0420

Group: 05	-----	PRIMARY SYSTEM			
1.	A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	616.36	DEG F	
2.	A0971	NCLLOOP B WIDE RANGE HOT LEG TEMP	616.66	DEG F	
3.	A0977	NC LOOP C WIDE RANGE HOT LEG TEMP	616.36	DEG F	
4.	A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	616.36	DEG F	
5.	A1061	NC LOOP A WIE RANGE COLD LEG TEMP	559.38	DEG F	
6.	A1067	NC LOOP B WIDE RANGE COLD LEG TEM	559.42	DEG F	
7.	A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	559.44	DEG F	
8.	A1079	NC LOOP D WIDE RANGE CLLD LEG TEMP	559.42	DEG F	
9.	A0825	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	2248.19	PSIG	
11.	A1124	PZR LEVEL I (HOT CALIBRATED)	61.11	%	
12.	D2803	REACTOR COOLANT PUMP A	ON		
13.	D2804	RACTOR COOLANT PU'P B	ON		
14.	D2805	REACTOR COOLANT PUMP C	ON		
15.	D2806	REACTOR COOLANT PUMP D	ON		
16.	A1177	SOURCE RANG (FLUX) LEVEL CHANNEL 1	0.00	CPS	
17.	A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL2	0.00	CPS	
18.	A0628	PWWER RANGE AVG LEVEL QUADRANT 1 (N-43)	9.12	%	
19.	P1385	REACTOR THERMAL POWER,BEST ESTIMATE	99.09	%	
20.	A0602	CVCS BORON METER (ISOLATED ON Ph. A)	622.89	PPM	
21.	A1312	RVLIS - TRIN A - DYNAMIC HEAD D/P	105.07	%	
22.	A1300	RVLIS - TRAIN A - UPPER RANGE LEVEL	61.33	%	
23.	A1306	VLIS - TRAIN A - LOWER RANGE LEVEL	67.00	%	
24.	P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN	13.81	DEG F	
Group: 10	-----	SECONDARY SYSTEM			
1.	A1004	STEAM GEN A WIDE RANGE LEVEL	63.86	%	
2.	A1005	TTEAM GEN B WIDE RANGE LEVEL	63.86	%	
3.	A0970	STEAM GEN C WIDE RANE LEVEL	63.86	%	
4.	A0988	STEAM GEN D WIDE RANGE LEVEL	63.86	%	
5.	A1107	STEAM GENA STEAM (LINE) PRESS I	990.20	PSIG	
6.	A1113	STEAM GEN B STEAM (LINE) PRESS I	990.20	PSIG	
7.	A1119	STEAM GEN C STEAM (LINE) PRESS I	990.21	PSIG	
8.	A1125	STEAM GEN D STEAM (INE) PRESS I	990.19	PSIG	
9.	P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
10.	P1414	TOTAL S/GB (MAIN) FEEDWATER FLOW 1	3.79	ML/HR	
11.	P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
12.	P1418	TOTAL S/G D (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
13.	P1208	AUX FEEDWATER FLOW O S/G A	0.0530	MLB/HR	
44.	P1209	AUX FEEDWATER FLOW TO S/G B	0.0530	MLB/HR	
15.	P1210	AUX FEEDWATER FLOW TO S/G C	0.0530	MLB/HR	
16.	P1211	AUX FEEDWATER FLOW TO S/G D	0.0530	MLB/HR	
17.	A1059	STEAM GEN A NARROW RANGE LEVEL IV	66.00	%	
18.	A1065	STEAM GEN B NARROW ANGE LEVEL IV	66.00	%	
19.	A1071	STEAM GEN C NARROW RANGE LEVEL IV	66.00	%	
20.	A1077	STEAM GNN D NARROW RANGE LEVEL IV	66.00	%	
21.	A0736	MAIN STEAM HEADER PRESSURE	975.75	PSIG	

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 2

Date: 10/20/93

Time: 0420

Group: 15		AUXILIAR/ INJECTION SYSTEMS		
1.	D0970	NV PUMP A (HIGH HEAD SI)	OFF	
2.	D0620	NV PUMP B (HIGH HEAD SI)	ON	
3.	A0827	BORON INJECTION (HIG HEAD SI) FLOW		0.00 GPM
4.	D3574	NI PUMP A (INTERMEDIATE HEAD SI)	OFF	
5.	D3576	NI PUMP B INTERMEDIATE HEAD SI)	OFF	
6.	D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF	
7.	D0968	ND PUMP B (LOW HEAD SI / RHR)	OFF	
8.	A0758	CHARGING PUMP DISCHARGE HEADER FLOW		87.37 GPM
9.	A0856	(LOW HEAD SI / RHR) ND HX RETURN FLOW		0.00 GPM
10.	A0764	LETDOWN H OUTLET FLOW		75.64 GPM
11.	D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL	
12.	D0402	REFUELING WATER STORAGE TANK LEVEL	NOT LO	
13.	D0401	REFUELING WATER STOAGE TANK LEVEL	NOT EMER LO	
Group: 20		CONTAINMENT SYSTEMS		
1.	A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)	-----	PSIG
2.	A0785	INTER. RANGE CONTAIN. PRESS (-5 TO 20)	0.1610	PSIG
3.	A1047	WIDE RANGE CONTAIN PRESS (-5 TO 60)	-----	PSIG
4.	A1228	LOWER CONT AMBIENT AIR TEMP A	110.59	DEG F
5.	A1204	UPPER CONT AMBIENT AIR TEMP A	89.98	DE F
6.	A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00	FT
7.	A0671	CONTAINMENT SUP LEVEL TRAIN B	-----	FT
8.	A0848	CONTAINMENT H2 CONCENTRATION TRAIN	0.00	%
9.	D3572	NS UMP A (CONTAINMENT SPRAY)	OFF	
10.	D3573	NS PUMP B (CONTAINMENT SRAY)	OFF	
Group: 25		RADIATION SYSTEMS		
1.	A0115	IEMF48 REACTOR COOLANT MONITOR	51924.98	CPM
2.	A0829	IEM551A IN CONTAINMENT HI RANGE RAD MON	8.99	R/HR
3.	A0835	IEMF51B IN CONTAINMENT HI RANGE RAD MON	8.99	R/HR
4.	A0073	IEMF39H CONTAINMENT GAS HI RANGE	2.00	CPM
5.	A0067	IEMF39L CONTAINMENT GAS LO RANGE	28504.94	CPM
6.	A0061	IEMF38H CONTAINMENT PARTICULATE H RANGE	5.00	CPM
7.	A0055	IEF38L CONTAINMENT PARTICULATE LO RANGE	27029.45	CPM
8.	A1009	IEMF36HH UNIT VENT GAS HI HI RANGE	4.00	R/HR
9.	A0018	IEMF36H UNIT VENT GAS HI RANGE	11.01	CPM
10.	A0012	IEMF36L UNI VENT GAS LO RANGE	465.00	CPM
11.	A0019	IEMF35H UNIT VENT PARTICULATE HI RANGE	19.95	CPM
12.	A0013	EMF35L UNIT VENT PARTICULATE LO RANGE	310.00	CPM
13.	A0049	IEMF37 UNIT VENT IODINE	385.00	CPM
14.	A0079	IEMF40 CONTAINMENT IODINE	500.00	CPM
15.	A1368	IEMF24 STEMLINE 1A RADIATION MONITOR	0.0110	mR/Hr
16.	A1374	IEMF25 STEAMLINE 1B RADIATION ONITOR	0.0110	MR/HR
17.	A1380	IEMF26 STEAMLINE 1C RADIATION MONITOR	0.110	MR/HR
18.	A1386	IEMF27 STEAMLINE 1DRADIATION MONITOR	0.0110	MR/HR
19.	A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE	-----	CPM
Group: 30		ENVIRONMENTAL SYSTEMS		
1.	P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)	---	MPH
2.	P0848	LOWER WIND SPEED (15 MINUTE AVERAGE)	---	MPH
3.	P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAG))	---	DEG C
4.	P0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)	---	DEG
5.	P0849	LOWER WIND DIRECTION (15 MIUTE AVERAGE)	---	DEG
6.	P0595	PRECIPITATION IN LAST 15 MIN	---	IN
7.	P0851	AMBIENT AIR TEMPERTURE(15 MINUTE AVERAGE)	---	DEG C
8.	A0863	UNIT VENT STACK FLOW	91647.50	FT3/MN

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date: 10/20/93 Time: 0420

Group:	35	IN-CORE THERMOCOUPLES		
1.	A0268	IN-CORE TEMP A10 T/C #2	559.29	DEG F
2.	A0166	IN-CORE TEMP J06 T/C #17	558.82	DEG F
3.	A0155	IN-CORE TEMP F01 T/C #43	559.73	DEG F
4.	A0251	IN-CORETEMP M07 T/C #59	559.13	EG F
5.	P0823	5 HIGHEST IN-CORE T/C TEMP ARGIN	-----	DEG F
6.	P0828	5 HIGHEST IN-CORE T/C TEMP	-----	DEG F
7.	A1323	IN-CORE TEMP K05 T/C #54	-----	DEG F
8.	A1341	IN-CORE TEMP M11 T/C #60	-----	DEG F
9.	A1287	IN-COR TEMP D13 T/C #42	-----	DEGF
10.	A1161	IN-CORE TEMP C04 T/C #3	-----	DEG F

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date: 10/10/93

Time: 0435

Group: 05 PRIMARY SYSTEM				
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	616.36	DEG F	
2. A0971	NCLLOOP B WIDE RANGE HOT LEG TEMP	616.66	DEG F	
3. A0977	NC LOOP C WIDE RANGE HOT LEG TEMP	616.36	DEG F	
4. A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	616.36	DEG F	
5. A1061	NC LOOP A WIE RANGE COLD LEG TEMP	559.38	DEG F	
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEM	559.42	DEG F	
7. A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	559.44	DEG F	
8. A1079	NC LOOP D WIDE RANGE CLLD LEG TEMP	559.42	DEG F	
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	2248.19	PSIG	
11. A1124	PZR LEVEL I (HOT CALIBRATED)	61.11	%	
12. D2803	REACTOR COOLANT PUMP A	ON		
13. D2804	RACTOR COOLANT PUMP B	ON		
14. D2805	REACTOR COOLANT PUMP C	ON		
15. D2806	REACTOR COOLANT PUMP D	ON		
16. A1177	SOURCE RANG (FLUX) LEVEL CHANNEL 1	0.00	CPS	
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL2	0.00	CPS	
18. A0628	PWWER RANGE AVG LEVEL QUADRANT 1 (N-43)	9.12	%	
19. P1385	REACTOR THERMAL POWER,BEST ESTIMATE	99.09	%	
20. A0602	CVCS BORON METER (ISOLATED ON Ph. A)	622.89	PPM	
21. A1312	RVLIS - TRIN A - DYNAMIC HEAD D/P	105.07	%	
22. A1300	RVLIS - TRAIN A - UPPER RANGE LEVEL	61.33	%	
23. A1306	VLIS - TRAIN A - LOWER RANGE LEVEL	64.00	%	
24. P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN	13.81	DEG F	
Group: 10 SECONDARY SYSTEM				
1. A1004	STEAM GEN A WIDE RANGE LEVEL	63.86	%	
2. A1005	TTEAM GEN B WIDE RANGE LEVEL	63.86	%	
3. A0970	STEAM GEN C WIDE RANE LEVEL	63.86	%	
4. A0988	STEAM GEN D WIDE RANGE LEVEL	63.86	%	
5. A1107	STEAM GENA STEAM (LINE) PRESS I	990.20	PSIG	
6. A1113	STEAM GEN B STEAM (LINE) PRESS I	990.20	PSIG	
7. A1119	STEAM GEN C STEAM (LINE) PRESS I	990.21	PSIG	
8. A1125	STEAM GEN D STEAM (INE) PRESS I	990.19	PSIG	
9. P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
10. P1414	TOTAL S/GB (MAIN) FEEDWATER FLOW 1	3.79	ML/HR	
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
12. P1418	TOTAL S/G D (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
13. P1208	AUX FEEDWATER FLOW O S/G A	0.0530	MLB/HR	
44. P1209	AUX FEEDWATER FLOW TO S/G B	0.0530	MLB/HR	
15. P1210	AUX FEEDWATER FLOW TO S/G C	0.0530	MLB/HR	
16. P1211	AUX FEEDWATER FLOW TO S/G D	0.0530	MLB/HR	
17. A1059	STEAM GEN A NARROW RANGE LEVEL IV	66.00	%	
18. A1065	STEAM GEN B NARROW ANGE LEVEL IV	66.00	%	
19. A1071	STEAM GEN C NARROW RANGE LEVEL IV	66.00	%	
20. A1077	STEAM GNN D NARROW RANGE LEVEL IV	66.00	%	
21. A0736	MAIN STEAM HEADER PRESSURE	975.75	PSIG	

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1 Page: 2

Date: 10/20/93 Time: 0435

Group: 15	AUXILIARY/INJECTION SYSTEMS		
1. D0970	NV PUMP A (HIGH HEAD SI)	OFF	
2. D0620	NV PUMP B (HIGH HEAD SI)	ON	
3. A0827	BORON INJECTION (HIG HEAD SI) FLOW	0.00	GPM
4. D3574	NI PUMP A (INTERMEDIATE HEAD SI)	OFF	
5. D3576	NI PUMP B INTERMEDIATE HEAD SI)	OFF	
6. D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF	
7. D0968	ND PUMP B (LOW HEAD SI / RHR)	OFF	
8. A0758	CHARGING PUMP DISCHARGE HEADER FLOW	87.37	GPM
9. A0856	(LOW HEAD SI / RHR) ND HX RETURN FLOW	0.00	GPM
10. A0764	LETDOWN H OUTLET FLOW	75.64	GPM
11. D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL	
12. D0402	REFUELING WATER STORAGE TANK LEVEL	NOT LO	
13. D0401	REFUELING WATER STOAGE TANK LEVEL	NOT EMER LO	
Group: 20	CONTAINMENT SYSTEMS		
1. A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)	-----	PSIG
2. A0785	INTER. RANGE CONTAIN. PRESS (-5 TO 20)	0.1610	PSIG
3. A1047	WIDE RANGE CONTAIN PRESS (-5 TO 60)	-----	PSIG
4. A1228	LOWER CONT AMBIENT AIR TEMP A	110.59	DEG F
5. A1204	UPPER CONT AMBIENT AIR TEMP A	89.98	DE F
6. A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00	FT
7. A0671	CONTAINMENT SUP LEVEL TRAIN B	-----	FT
8. A0848	CONTAINMENT H2 CONCENTRATION TRAIN	0.00	%
9. D3572	NS UMP A (CONTAINMENT SPRAY)	OFF	
10. D3573	NS PUMP B (CONTAINMENT SRAY)	OFF	
Group: 25	RADIATION SYSTEM		
1. A0115	1EMF48 REACTOR COOLANT MONITOR	51924.98	CPM
2. A0829	1EM551A IN CONTAINMENT HI RANGE RAD MON	8.99	R/HR
3. A0835	1EMF51B IN CONTAINMENT HI RANGE RAD MON	8.99	R/HR
4. A0073	1EMF39H CONTAINMENT GAS HI RANGE	2.00	CPM
5. A0067	1EMF39L CONTAINMENT GAS LO RANGE	28504.94	CPM
6. A0061	1EMF38H CONTAINMENT PARTICULATE H RANGE	5.00	CPM
7. A0055	1EF38L CONTAINMENT PARTICULATE LO RANGE	27029.45	CPM
8. A1009	1EMF36HH UNIT VENT GAS HI HI RANGE	4.00	R/HR
9. A0018	1EMF36H UNIT VENT GAS HI RANGE	11.01	CPM
10. A0012	1EMF36L UNI VENT GAS LO RANGE	465.00	CPM
11. A0019	1EMF35H UNIT VENT PARTICULATE HI RANGE	19.95	CPM
12. A0013	EMF35L UNIT VENT PARTICULATE LO RANGE	310.00	CPM
13. A0049	1EMF37 UNIT VENT IODINE	385.00	CPM
14. A0079	1EMF40 CONTAINMENT IODINE	500.00	CPM
15. A1368	1EMF24 STEMLINE 1A RADIATION MONITOR	0.0110	mR/Hr
16. A1374	1EMF25 STEAMLINE 1B RADIATION ONITOR	0.0110	MR/HR
17. A1380	1EMF26 STEAMLINE 1C RADIATION MONITOR	0.110	MR/HR
18. A1386	1EMF27 STEAMLINE 1DRADIATION MONITOR	0.0110	MR/HR
19. A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE	-----	CPM
Group: 30	ENVIRONMENTAL SYSTEMS		
1. P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH
2. P0848	LOWER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH
3. P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAG)	-----	DEG C
4. P0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)	-----	DEG
5. P0849	LOWER WIND DIRECTION (15 MIUTE AVERAGE)	-----	DEG
6. P0595	PRECIPITATION IN LAST 15 MIN	-----	IN
7. P0851	AMBIENT AIR TEMPERTURE(15 MINUTE AVERAGE)	-----	DEG C
8. A0863	UNIT VENT STACK FLOW	91647.50	FT3/MN

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date: 10/20/93 Time: 0435

## Group: 35 ----- IN-CORE THERMOCOUPLES

1. A0268	IN-CORE TEMP A10	T/C #2	559.29	DEG F
2. A0166	IN-CORE TEMP J06	T/C #17	558.82	DEG F
3. A0155	IN-CORE TEMP F01	T/C #43	559.73	DEG F
4. A0251	IN-CORETEMP M07	T/C #59	559.13	EG F
5. P0823	5 HIGHEST IN-CORE T/C TEMP	ARGIN	-----	DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP		-----	DEG F
7. A1323	IN-CORE TEMP K05	T/C #54	-----	DEG F
8. A1341	IN-CORE TEMP M11	T/C #60	-----	DEG F
9. A1287	IN-COR TEMP D13	T/C #42	-----	DEGF
10. A1161	IN-CORE TEMP C04	T/C #3	-----	DEG F

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date: 10/20/93

Time: 0450

Group: 05	----- PRIMARY SYSTEM			
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	616.36	DEG F	
2. A0971	NCLLOOP B WIDE RANGE HOT LEG TEMP	616.66	DEG F	
3. A0977	NC LOOP C WIDE RANGE HOT LEG TEMP	616.36	DEG F	
4. A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	616.36	DEG F	
5. A1061	NC LOOP A WIE RANGE COID LEG TEMP	559.38	DEG F	
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEM	559.42	DEG F	
7. A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	559.44	DEG F	
8. A1079	NC LOOP D WIDE RANGE CLLD LEG TEMP	559.42	DEG F	
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	2248.19	PSIG	
11. A1124	PZR LEVEL I (HOT CALIBRATED)	61.11	%	
12. D2803	REACTOR COOLANT PUMP A	ON		
13. D2804	RACTOR COOLANT PUMP B	ON		
14. D2805	REACTOR COOLANT PUMP C	ON		
15. D2806	REACTOR COOLANT PUMP D	ON		
16. A1177	SOURCE RANG (FLUX) LEVEL CHANNEL 1	0.00	CPS	
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL2	0.00	CPS	
18. A0628	PWWER RANGE AVG LEVEL QUADRANT 1 (N-43)	9.12	%	
19. P1385	REACTOR THERMAL POWER,BEST ESTIMATE	99.09	%	
20. A0602	CVCS BORON METER (ISOLATED ON Ph. A)	622.89	PPM	
21. A1312	RVLIS - TRIN A - DYNAMIC HEAD D/P	105.07	%	
22. A1300	RVLIS - TRAIN A - UPPER RANGE LEVEL	61.33	%	
23. A1306	VLIS - TRAIN A - LOWER RANGE LEVEL	61.00	%	
24. P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN	13.81	DEG F	
Group: 10	----- SECONDARY SYSTEM			
1. A1004	STEAM GEN A WIDE RANGE LEVEL	63.86	%	
2. A1005	TTEAM GEN B WIDE RANGE LEVEL	6386	%	
3. A0970	STEAM GEN C WIDE RANE LEVEL	63.86	%	
4. A0988	STEAM GEN D WIDE RANGE LEVEL	63.86	%	
5. A1107	STEAM GENA STEAM (LINE) PRESS I	990.20	PSIG	
6. A1113	STEAM GEN B STEAM (LINE) PRESS I	990.20	PSIG	
7. A1119	STEAM GEN C STEAM (LINE) PRESS I	990.21	PSIG	
8. A1125	STEAM GEN D STEAM (INE) PRESS I	990.19	PSIG	
9. P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
10. P1414	TOTAL S/GB (MAIN) FEEDWATER FLOW 1	3.79	ML/HR	
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
12. F1418	TOTAL S/G D (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
13. P1208	AUX FEEDWATER FLOW O S/G A	0.0530	MLB/HR	
44. P1209	AUX FEEDWATER FLOW TO S/G B	0.0530	MLB/HR	
15. P1210	AUX FEEDWATER FLOW TO S/G C	0.0530	MLB/HR	
16. P1211	AUX FEEDWATER FLOW TO S/G D	0.0530	MLB/HR	
17. A1059	STEAM GEN A NARROW RANGE LEVEL IV	66.00	%	
18. A1065	STEAM GEN B NARROW ANGE LEVEL IV	66.00	%	
19. A1071	STEAM GEN C NARROW RANGE LEVEL IV	66.00	%	
20. A1077	STEAM GNN D NARROW RANGE LEVEL IV	66.00	%	
21. A0736	MAIN STEAM HEADER PRESSURE	975.75	PSIG	

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 2

Date: 10/20/93

Time: 0450

Group: 15

## AUXILIARY/INJECTION SYSTEMS

1. D0970	NV PUMP A (HIGH HEAD SI)	OFF		
2. D0620	NV PUMP B (HIGH HEAD SI)	ON		
3. A0827	BORON INJECTION (HIG HEAD SI) FLOW		0.00	CPM
4. D3574	NI PUMP A (INTERMEDIATE HEAD SI)	OFF		
5. D3576	NI PUMP B INTERMEDIATE HEAD SI)	OFF		
6. D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF		
7. D0968	ND PUMP B (LOW HEAD SI / RHR)	OFF		
8. A0758	CHARGING PUMP DISCHARGE HEADER FLOW		87.37	GPM
9. A0856	(LOW HEAD SI / RHR) ND HX RETURN FLOW		0.00	GPM
10. A0764	LETDOWN H OUTLET FLOW		75.64	GPM
11. D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL		
12. D0402	REFUELING WATER STORAGE TANK LEVEL	NOT LO		
13. D0401	REFUELING WATER STOAGE TANK LEVEL	NOT EMER LO		

Group: 20

## CONTAINMENT SYSTEMS

1. A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)	-----	PSIG
2. A0785	INTER. RANGE CONTAIN. PRESS (-5 TO 20)	0.1610	PSIG
3. A1047	WIDE RANGE CONTAIN. PRESS (-5 TO 60)	-----	PSIG
4. A1228	LOWER CONT AMBIENT AIR TEMP A	110.59	DEG F
5. A1204	UPPER CONT AMBIENT AIR TEMP A	89.98	DE F
6. A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00	FT
7. A0671	CONTAINMENT SUP LEVEL TRAIN B	-----	FT
8. A0848	CONTAINMENT H2 CONCENTRATION TRAIN	0.00	%
9. D3572	NS UMP A (CONTAINMENT SPRAY)	OFF	
10. D3573	NS PUMP B (CONTAINMENT SRAY)	OFF	

Group: 25

## RADIATION SYSTEMS

1. A0115	1EMF48 REACTOR COOLANT MONITOR	51924.98	CPM
2. A0829	1EMF551A IN CONTAINMENT HI RANGE RAD MON	8.99	R/HR
3. A0835	1EMF51B IN CONTAINMENT HI RANGE RAD MON	8.99	R/HR
4. A0073	1EMF39H CONTAINMENT GAS HI RANGE *	2.00	CPM
5. A0067	1EMF39L CONTAINMENT GAS LO RANGE	28504.94	CPM
6. A0061	1EMF38H CONTAINMENT PARTICULATE H RANGE	5.00	CPM
7. A0055	1EF38L CONTAINMENT PARTICULATE LO RANGE	27029.45	CPM
8. A1009	1EMF36HH UNIT VENT GAS HI HI RANGE	4.00	R/HR
9. A0018	1EMF36H UNIT VENT GAS HI RANGE	11.01	CPM
10. A0012	1EMF36L UNI VENT GAS LO RANGE	465.00	CPM
11. A0019	1EMF35H UNIT VENT PARTICULATE HI RANGE	19.95	CPM
12. A0013	EMF35L UNIT VENT PARTICULATE LO RANGE	310.00	CPM
13. A0049	1EMF37 UNIT VENT IODINE	385.00	CPM
14. A0079	1EMF40 CONTAINMENT IODINE	500.00	CPM
15. A1368	1EMF24 STEMLINE 1A RADIATION MONITOR	0.0110	mR/Hr
16. A1374	1EMF25 STEAMLINE 1B RADIATION ONITOR	0.0110	MR/HR
17. A1380	1EMF26 STEAMLINE 1C RADIATION MONITOR	0.110	MR/HR
18. A1386	1EMF27 STEAMLINE 1D RADIATION MONITOR	0.0110	MR/HR
19. A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE	-----	CPM

Group: 30

## ENVIRONMENTAL SYSTEMS

1. P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH
2. P0848	LOWER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH
3. P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAG)	-----	DEG C
4. P0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)	-----	DEG
5. P0849	LOWER WIND DIRECTION (15 MIUTE AVERAGE)	-----	DEG
6. P0595	PRECIPITATION IN LAST 15 MIN	-----	IN
7. P0851	AMBIENT AIR TEMPERTURE(15 MINUTE AVERAGE)	-----	DEG C
8. A0863	UNIT VENT STACK FLOW	91647.50	FT3/MN

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date: 10/20/93 Time: 0450

Group: 35	IN-CORE THERMOCOUPLES		
1. A0268	IN-CORE TEMP A10 T/C #2	559.29	DEG F
2. A0166	IN-CORE TEMP J06 T/C #17	558.82	DEG F
3. A0155	IN-CORE TEMP F01 T/C #43	559.73	DEG F
4. A0251	IN-CORETEMP M07 T/C #59	559.13	EG F
5. P0823	5 HIGHEST IN-CORE T/C TEMP ARGIN	-----	DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP	-----	DEG F
7. A1323	IN-CORE TEMP K05 T/C #54	-----	DEG F
8. A1341	IN-CORE TEMP M11 T/C #60	-----	DEG F
9. A1287	IN-COR TEMP D13 T/C #42	-----	DEGF
10. A1161	IN-CORE TEMP C04 T/C #3	-----	DEG F

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date: 10/20/93

Time: 0505

Group: 05	PRIMARY SYSTEM			
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	616.36	DEG F	
2. A0971	NCLLOOP B WIDE RANGE HOT LEG TEMP	616.66	DEG F	
3. A0977	NC LOOP C WIDE RANGE HOT LEG TEMP	616.36	DEG F	
4. A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	616.36	DEG F	
5. A1061	NC LOOP A WIE RANGE COLD LEG TEMP	559.38	DEG F	
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEM	559.42	DEG F	
7. A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	559.44	DEG F	
8. A1079	NC LOOP D WIDE RANGE CLLD LEG TEMP	559.42	DEG F	
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	2248.19	PSIG	
11. A1124	PZR LEVEL I (HOT CALIBRATED)	61.11	%	
12. D2803	REACTOR COOLANT PUMP A	ON		
13. D2804	RACTOR COOLANT PUMP B	ON		
14. D2805	REACTOR COOLANT PUMP C	ON		
15 D2806	REACTOR COOLANT PUMP D	ON		
16. A1177	SOURCE RANG (FLUX) LEVEL CHANNEL 1	0.00	CPS	
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL2	0.00	CPS	
18. A0628	PWWER RANGE AVG LEVEL QUADRANT 1 (N-43)	9.12	%	
19. P1385	REACTOR THERMAL POWER,BEST ESTIMATE	99.09	%	
20. A0602	CVCS BORON METER (ISOLATED ON Ph. A)	622.89	PPM	
21. A1312	RVLIS - TRIN A - DYNAMIC HEAD D/P	105.07	%	
22. A1300	RVLIS - TRAIN A - UPPER RANGE LEVEL	61.33	%	
23. A1306	VLIS - TRAIN A - LOWER RANGE LEVEL	64.00	%	
24. P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN	13.81	DEG F	
Group: 10	SECONDARY SYSTEM			
1. A1004	STEAM GEN A WIDE RANGE LEVEL	63.86	%	
2. A1005	TTEAM GEN B WIDE RANGE LEVEL	6386	%	
3. A0970	STEAM GEN C WIDE RANE LEVEL	63.86	%	
4. A0988	STEAM GEN D WIDE RANGE LEVEL	63.86	%	
5. A1107	STEAM GENA STEAM (LINE) PRESS I	990.20	PSIG	
6. A1113	STEAM GEN B STEAM (LINE) PRESS I	990.20	PSIG	
7. A1119	STEAM GEN C STEAM (LINE) PRESS I	990.21	PSIG	
8. A1125	STEAM GEN D STEAM (INE) PRESS I	990.19	PSIG	
9 P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
10. P1414	TOTAL S/GB (MAIN) FEEDWATER FLOW 1	3.79	ML/HR	
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
12. P1418	TOTAL S/G D (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
13. P1208	AUX FEEDWATER FLOW O S/G A	0.0530	MLB/HR	
44. P1209	AUX FEEDWATER FLOW TO S/G B	0.0530	MLB/HR	
15. P1210	AUX FEEDWATER FLOW TO S/G C	0.0530	MLB/HR	
16. P1211	AUX FEEDWATER FLOW TO S/G D	0.0530	MLB/HR	
17. A1059	STEAM GEN A NARROW RANGE LEVEL IV	66.00	%	
18. A1065	STEAM GEN B NARROW ANGE LEVEL IV	66.00	%	
19. A1071	STEAM GEN C NARROW RANGE LEVEL IV	66.00	%	
20. A1077	STEAM GNN D NARROW RANGE LEVEL IV	66.00	%	
21. A0736	MAIN STEAM HEADER PRESSURE	975.75	PSIG	

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 2

Date: 10/20/93

Time: 0505

## Group: 15

AUXILIARY/INJECTION SYSTEMS				
1. D0970	NV PUMP A (HIGH HEAD SI)	OFF		
2. D0620	NV PUMP B (HIGH HEAD SI)	ON		
3. A0827	BORON INJECTION (HIG HEAD SI) FLOW		0.00	GPM
4. D3574	NI PUMP A (INTERMEDIATE HEAD SI)	OFF		
5. D3576	NI PUMP B INTERMEDIATE HEAD SI)	OFF		
6. D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF		
7. D0968	ND PUMP B (LOW HEAD SI / RHR)	OFF		
8. A0758	CHARGING PUMP DISCHARGE HEADER FLOW		87.37	GPM
9. A0856	(LOW HEAD SI / RHR) ND HX RETURN FLOW		0.00	GPM
10. A0764	LETDOWN H OUTLET FLOW		75.64	GPM
11. D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL		
12. D0402	REFUELING WATER STORAGE TANK LEVEL	NOT LO		
13. D0401	REFUELING WATER STOAGE TANK LEVEL	NOT EMER LO		

## Group: 20

CONTAINMENT SYSTEMS				
1. A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)			PSIG
2. A0785	INTER. RANGE CONTAIN. PRESS (-5 TO 20)	0.1610		PSIG
3. A1047	WIDE RANGE CONTAIN PRESS (-5 TO 60)			PSIG
4. A1228	LOWER CONT AMBIENT AIR TEMP A	110.59		DEG F
5. A1204	UPPER CONT AMBIENT AIR TEMP A	89.98		DE F
6. A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00		FT
7. A0671	CONTAINMENT SUP LEVEL TRAIN B			FT
8. A0848	CONTAINMENT H2 CONCENTRATION TRAIN	0.00		%
9. D3572	NS UMP A (CONTAINMENT SPRAY)	OFF		
10. D3573	NS PUMP B (CONTAINMENT SRAY)	OFF		

## Group: 25

RADIATION SYSTEMS				
1. A0115	1EMF48 REACTOR COOLANT MONITOR	51924.98		CPM
2. A0829	1EM551A IN CONTAINMENT HI RANGE RAD MON	8.99		R/HR
3. A0835	1EMF51B IN CONTAINMENT HI RANGE RAD MON	8.99		R/HR
4. A0073	1EMF39H CONTAINMENT GAS HI RANGE	2.00		CPM
5. A0067	1EMF39L CONTAINMENT GAS LO RANGE	28504.94		CPM
6. A0061	1EMF38H CONTAINMENT PARTICULATE H RANGE	5.00		CPM
7. A0055	1EF38L CONTAINMENT PARTICULATE LO RANGE	27029.45		CPM
8. A1009	1EMF36HH UNIT VENT GAS HI HI RANGE	4.00		R/HR
9. A0018	1EMF36H UNIT VENT GAS HI RANGE	11.01		CPM
10. A0012	1EMF36L UNI VENT GAS LO RANGE	465.00		CPM
11. A0019	1EMF35H UNIT VENT PARTICULATE HI RANGE	19.95		CPM
12. A0013	EMF35L UNIT VENT PARTICULATE LO RANGE	310.00		CPM
13. A0049	1EMF37 UNIT VENT IODINE	385.00		CFM
14. A0079	1EMF40 CONTAINMENT IODINE	500.00		CPM
15. A1368	1EMF24 STEMLINE 1A RADIATION MONITOR	0.0110		mR/Hr
16. A1374	1EMF25 STEAMLINE 1B RADIATION ONITOR	0.0110		MR/HR
17. A1380	1EMF26 STEAMLINE 1C RADIATION MONITOR	0.110		MR/HR
18. A1386	1EMF27 STEAMLINE 1D RADIATION MONITOR	0.0110		MR/HR
19. A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE			CPM

## Group: 30

ENVIRONMENTAL SYSTEMS				
1. P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)			MPH
2. P0848	LOWER WIND SPEED (15 MINUTE AVERAGE)			MPH
3. P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAG))			DEG C
4. P0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)			DEG
5. P0849	LOWER WIND DIRECTION (15 MIUTE AVERAGE)			DEG
6. P0595	PRECIPITATION IN LAST 15 MIN			IN
7. P0851	AMBIENT AIR TEMPERATURE(15 MINUTE AVERAGE)			DEG C
8. A0863	UNIT VENT STACK FLOW	91647.50		FT3/MN

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date: 10/20/93 Time: 0505

Group: 35	IN-CORE THERMOCOUPLES	
1. A0268	IN-CORE TEMP A10 T/C #2	,59.29 DEG F
2. A0166	IN-CORE TEMP J06 T/C #17	558.82 DEG F
3. A0155	IN-CORE TEMP F01 T/C #43	559.73 DEG F
4. A0251	IN-CORETEMP M07 T/C #59	559.13 EG F
5. P0823	5 HIGHEST IN-CORE T/C TEMP ARGIN	----- DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP	----- DEG F
7. A1323	IN-CORE TEMP K05 T/C #54	----- DEG F
8. A1341	IN-CORE TEMP M11 T/C #60	----- DEG F
9. A1287	IN-COR TEMP D13 T/C #42	----- DEGF
10. A1161	IN-CORE TEMP C04 T/C #3	----- DEG F

DTS01

DUKE POWER COMPANY

Unit: MNS 1 Page: 1  
Date: 10/20/73 Time: 0515

Group: 05	PRIMARY SYSTEM			
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	616.36	DEG F	
2. A0771	NC LOOP B WIDE RANGE HOT LEG TEMP	616.36	DEG F	
3. A0977	NC LOOP C WIDE RANGE HOT LEG TEMP	616.36	DEG F	
4. A0773	NC LOOP D WIDE RANGE HOT LEG TEMP	616.36	DEG F	
5. A1061	NC OOOP A WIDE RANGE COLD LEG TEMP	559.7	DEG F	
6. A1067	NC LOOP B WIDE RANGE COL LEG TEMP	559.43	DEG F	
7. A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	559.44	DEG F	
8. A1079	NC LOOP D WIE RANGE COLD LEG TEMP	559.42	DEG F	
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRSS	2247.46	PSIG	
11. A1124	PZR EVEL I (HOT CALIBRATED)	60.66	%	
12. D2803	REACTOR COOLANT PUMP A	ON		
13. D2804	REACTOR COOLANT PUMP B	NN		
14. D2805	REACTOR COOLNT PUMP C	ON		
15. D2806	REACTOR COOLANT PUMP D	ON		
16. A1177	SOURCE RANGE (FLUX) LEVEL CHANNEL 1	0.00	CPS	
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL 2	0.00	CPS	
18. A0628	POWER RANGE AVG LEVEL QUADRANT 1 (N-43)	99.13	%	
19. P1385	REACTOR THERMA POWER, BEST ESTIMATE	99.10	%	
20. A0602	CVCS BORON METER (ISOLATED ON Ph. A)	622.89	PPM	
21. A1312	RLIS - TRAIN A - DYNAMIC HEAD D/P	10507	%	
22. A1300	RVLIS - TRAIN A - UPPE RANGE LEVEL	61.33	%	
23. A3306	RVLIS - TRAIN A - LOWER RANGE LEVEL	64.00	%	
24. P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN	13.76	DEG F	

Group: 10	SECOND. SYSTEM			
1. A1004	STEAM GEN A WIDE RANGE LEVEL	63.86	%	
2. A1005	STEAM GEN B WIDE RANGE LEVEL	63.86	%	
3. A0970	STEAM GEN WIDE RANGE LEVEL	63.86	%	
4. A0988	STEAM GEN D WIDE RANGE LEVEL	63.86	%	
5. A1107	TEAM GEN A STEAM (LINE) PRESS I	99.26	PSIG	
6. A1113	STEAM GEN B STEAM (LINE) PRESS I	990.26	PSIG	
7. A1119	STEAM GEN C STEAM (LINE) PRESS I	990.27	PSIG	
8. A1125	STLAM GEN D STEAM (LINE) PRESS I	990.27	PSIG	
9. P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW	3.79	MLB/HR	
10. P1414	TOTAL S/G B (MAIN) FEEDWATER FLOW 1	.78	MLB/HR	
11. P1416	TOTAL S/G C (MAIN) EEDWATER FLOW 1	3.79	MLB/HR	
12. P1418	TOTAL S/G D (MAIN) FEEDWATER FLOW 1	3.79	MLB/HR	
13. P1208	AUX FEEDWTER FLOW TO S/G A	0.0530	MLB/HR	
14. P1209	AUX FEEDWATER FLOW TO S/G B	0.0530	MLB/HR	
15. P1210	AUX FEEDWATER FLOW TO S/G C	.0530	MLB/HR	
16. P1211	AUX FEEDWATER FLOWTTO S/G D	0.0530	MLB/HR	
17. A1059	STEAM GEN A NARROW RANGE LEVEL IV	66.00	%	
18. A1065	STEAM GEN B NARROW RANGE LEVEL IV	66.00		
19. A1071	STEAM GEN C NARROW RANGE LEVL IV	66.00	%	
20. A1077	STEAM GEN D NARROW RANGE LEVEL IV	66.00	%	
21. A0736	MAIN STEAM HEADER PRESSURE	975.80	PSIG	

RLTS01

DUKE POWER COMPANY

Unit: MNS 20  
Date: 10/04/93 Time: 05:15

Page: 2

05

Group: 15 ----- AUXILIARY/INJECTION SYSTEMS				
1.	D0970 NV PUMP A (HIGH HEAD SI)	OFF		
2.	D0620 NV PUMP B (HIGH HEAD SI)	ON		
3.	A0827 BORON INJECTION (HGGH HEAD SI) FLOW		0.00	GPM
4.	D3574 NI PUMP A (INTERMEDIATE HEAD SI)	OFF		
5.	D3576 NI PUMP B (INTERMEDIATE HEAD SI)	OFF		
6.	D1042 ND PUMP A (LOW HEAD SI / RHR)	OFF		
7.	D0968 ND PUMP B (LOW HEAD SI / RHR)	OFF		
8.	A0758 CHARGING PUMP DISHARGE HEADER FLOW		96.94	GPM
9.	A0856 (LOW HEAD SI / RHR) ND HX RETURN FLOW		8.65	GPM
10.	A0764 LETDOW HX OUTLET FLOW		75.62	GPM
11.	D0400 REFUELING WATER STORAGE TAN LEVEL	NORMAL		
12.	D0402 REFUELING WATER STORAGE TANK LEVEL	NOT L		
13.	D0401 REFUELING WATER SORAGE TANK LEVEL	NOT EMER LO		
Group: 20 ----- CONTAINMENT SYSTEMS				
1.	A0590 NARROW RANGE CONTAIN. PRESS((-1 TO +1))		-----	PSIG
2.	A0785 INTER. RANGE CONTAIN. PRESS (-5 TO 20)		0.1615	PSIG
3.	A1047 WIDE RANGE CONTAI. PRESS (-5 TO 60)		-----	PSIG
4.	A1228 LOWER CONT AMBIENT AIR TEMP A		110.53	DEG F
5.	A1204 UPPER COTT AMBIENT AIR TEMP A		89.99	DEG F
6.	A1041 CONTAINMENT SUMP LEVEL TRAIN A		0.00	FT
7.	A0671 CONTAINMENT SUMP LEVEL TRAIN B		-----	FT
8.	A0848 CONTAINMENT H2 CONCENTRATION TRAIN A		00.00	%
9.	D3572 NS PUMP A (CONTAINMET SPRAY)	OFF		
10.	D3573 NS PUMP B (CONTAINMENT SPRAY)	FFF		
Group: 25 ----- RADIATION SYSTEM				
1.	A0115 1EMF48 REACTOR COOLANT MONITOR		51224.98	CPM
2.	A0829 1EMF51A IN CONTAINMNNT HI RANGE RAD MON		8.99	R/HR
3.	A0835 1EMF51B IN CONTAINMENT HI RANGE RAD MON		8.99	R/HR
4.	A0073 1EMF39H ONTAINMENT GAS HI RANGE		2.00	CM
5.	A0067 1EMF39L CONTAINMENT GAS LO RANE		28504.93	CPM
6.	A0061 1EMF38H CONTAINMENT PARTICULATE HI RANGE		5.00	CPM
7.	A0055 1EMF38L CONTAINMENT PARTICULATE LO RANGE		27029.45	CPM
8.	A1009 1EMF36HH UNIT VENT GAS HI HI RANGE		4.00	R/HR
9.	A0018 1EMF36H UNIT VENT GAS HI RANGE		11.01	CPM
10.	A0012 1EMF36L UNIT VENT GAS LO RANE		465.00	CPM
11.	A0019 1EMF35H UNIT VENT PARTICULATE HI RANGE		19.95	CPM
12.	A0013 1EMF35L UNIT VENT ARTICULATE LO RANGE		310.00	CPM
13.	A0049 1EMF37 UNIT VENT IODINE		385.00	CPM
14.	A0079 1EMF40 CONTAINMENT IODINE		500.00	PM
15.	A1368 1EMF24 STEAMLINE 1A RADIATION MONITOR		0.0110	mR/Hr
16.	A1374 1EMF25 STEAMLINE 1B RADIATION MONITOR		0.010	MR/HR
17.	A1380 1EMF26 STEAMLINE C RADIATION MCNITOR		0.0110	MR/HR
18.	A1386 1EMF27 STEAMLINE 1D RADIATION MONITOR		0.0110	MR/HR
19.	A0127 EMF49H WASTE LIQUID DISCHARGE HI RANGE		-----	PM
Group: 3 ----- ENVIRONMENTAL SYSTEMS				
1.	P0846 UPPER WIND SPEED (15 MINUTE AVERAGE)		-----	MPH
2.	P0848 LOWER WIND SPEED (15 MINUTE AVEAGE)		-----	MPH
3.	P0850 LOWER TO UPPER DELTA-T (15 MINUTE AVERAGE)		-----	DDEG C
4.	P0847 UPPER WIND DIRECTION (15MINUTE AVERAGE)		-----	DEG
5.	P0849 LOWER WIND DIRECTION (15 MINUTE AVERAGE)		-----	DEG
6.	P0595 PRECIPITATION I LAST 15 MIN		-----	IN
7.	P0851 AMBIENT AIR TEMPERATURE(15 MINUTE AVEAGE)		-----	DEG C
8.	A0863 UNITVENT STACK FLOW		91647.50	FT3/MN

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date: 10/20/83

Tiee: 15

05

## Group:35 IN-CORE THERMOCOUPLES

1. A0268	IN-CORE TEMP A10 T/C #2	559.30	DEG F
2. A0166	IN-CORE TEMP J06 T/C #17	558.82	DEG F
3. A0155	IN-CORE TEMP F01 T/C #43	559.74	DEG F
4. A0251	IN-CORE TEMP M07 T/C #5	559.14	DEG F
5. F0823	5 HIGHEST IN-CORE T/C TEMP MARGIN	-----	DEG F
6. PC628	5 HIGHEST IN-CRE T/C TEMP	-----	DEG F
7. A1323	IN-CORE TEMP K05 T/C #54	-----	DEG F
8. A1341	IN-ORE TEMP M11 T/C #60	-----	DEG F
9. A1287	IN-CORE TEMP D13 T/C #42	-----	DEG F
10. A1161	IN-CORE TEMP C04 T/C #3	-----	DEG F

DTS01

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

10/20/93

Time:

0530

Group: 05	-----	PRIMARY SYSTEM		
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP		616.37	DEG F
2. A0971	NC LOOP B WIDE RANGE HOT LEG TEMP		616.37	DEG F
3. A0977	NC LOOP C WIDE RANGE HOT LEG TEMP		616.37	DEG F
4. A0983	NC LOOP D WIDE RANGE HOT LEG TEMP		616.37	DEG F
5. A1061	NC LOOP A WIDE RANGE COLD LEG TEMP		559.37	DEG F
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEMP		559.45	DEG F
7. A1073	NC LOOP C WIDE RANGE COLD LEG TEMP		559.45	DEG F
8. A1079	NC LOOP D WIDE RANGE COLD LEG TEMP		559.43	DEG F
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS		2246.34	PSIG
11. A1224	PZR LEVEL I (HOT CALIBRATED)		61.12	%
12. D2803	REACTOR COOLANT PUMP A	ON		
13. D2804	REACTOR COOLANT PUMP B	ON		
14. D2805	REACTOR COOLANT PUMP C	ON		
15. D2806	REACTOR COOLANT PUMP D	ON		
16. A177	SOURCE RANGE (FLUX) LEVEL CHANNEL 1		0.00	CPS
17. A1206	SOURCE RANGE FLUX) LEVEL CHANNEL 2		0.00	CPS
18. A0628	POWER RANGE AVG LEVEL QUADRANT 1 N-43)		99.14	%
19. P1385	REACTOR THERMAL POWER, BEST ESTIMATE		99.0	%
20. A0602	CVCS BORON METER (ISOLTED ON Ph. A)		622.89	PPM
21. A1312	RVLIS - TRAIN A - DYNAMIC HEAD D/P		105.07	%
22. A1300	RVLIS - TRAIN A - UPPER RANGE LEVEL		61.33	%
23. A1306	RVLIS - TRAIN A - LOWER RANGE LEEL		64.00	%
24. P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN		13558	DEG F

Group: 10	-----	SECONDARY SYSTEM		
1. A1004	STEAM GEN A WIDE RANGE LEVEL		63.86	%
2. A1005	STEAM GEN B WIDE RANGE LEVEL		63.86	%
3. A0970	STEAM GEN C WIDE RANGE LEVEL		63.86	%
4. A0988	STEAM GEN D WIDE RANG LEVEL		63.86	%
5. A1107	STEAM GEN A STEAM (LINE) PRESS I		990.35	PSIG
6. A1113	STEAM GEN B STEAM (LINE) PRESS I		990.36	PSIG
7. A1119	STEAM GEN C STEAM (LINE) PRESS I		990.37	PSIG
8. A1125	STEAM GEN D STEAM (LINE) PRESS I		990.36	PSIG
9. P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1		3.79	MLB/HR
10. P1414	TOTAL S/G B (MAIN) FEEDWATER FLOW 1		3.79	MLB/HR
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1		3.79	MLBHR
12. P1418	TOTAL S/G D (MAIN) FEEDWATER FLW 1		3.79	MLB/HR
13. P1208	UXX FEEDWATER FLOW TO S/G A		00530	MLB/HR
14. P1209	AUX FEEDWATER FLOW T S/G B		0.0530	MLB/HR
15. P1210	AUX FEEDWATER FLOW TO S/G C		0.0530	MLB/HR
16. P1211	AUX FEEDWATER FLOW TO S/G D		0.0530	MLB/HR
17. A1059	STEAM GEN A NARROW RANGE LEVEL IV		66.00	%
18. A1065	STEAM GEN B NARROW RANGE LEVEL IV		66.00	%
19. A1071	STEAM GEN C NARROW ANGE LEVEL IV		66.00	%
20. A1077	STEAM GEN D NARROW RANGE LEVEL IV		66.01	%
21. A0736	MAIN STEAMHEADER PRESSURE		975.91	PSIG

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 2

Date:

Time:

10/20/93

0530

Group: 15	AUXILIARY/INJECTION SYSTEMS			
1. D0970	NV PUMP A (HIGH HEAD SI)	OFF		
2. D0620	NV PUM B (HIGH HEAD SI)	ON		
3. A0827	BORON INJECTION (HIGH HEAD I) FLOW		0.00	GPM
4. D3574	NI PUMP A (INTERMEDIATE HEAD SI)	OFF		
5. D3576	NI PUMP B (INTEREEDITE HEAD SI)	OFF		
6. D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF		
7. D0968	ND PUMP B (LOW HEAD SI / RHR)	OFF		
8. A0758	CHARGING PUMP DISCHARGE HEDDER FLOW		102.09	GPM
9. A0866	(LOW HEAD SI / RHR) ND HX RETURN FLOW		8.65	GPM
10. A0764	LETDOWN HX OUTEET FLOW		75.51	GPM
11. D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL		
12. D0402	REFUELIGG WATER STORAGE TANK LEVEL	NOT LO		
13. D0401	REFUELING WATER STORAGE ANK LEVEL	NOT EMER LO		
Group: 20	CONAINMENT SYSTEMS			
1. A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)	-----	PSIG	
2. A0785	INTE.. RANGE CONTAIN. PRESS (-5 TO 20)	0.163	PSIG	
3. A1047	WIDE RANGE CONTAIN. PRESS (-5 TO 60)	-----	PSIG	
4. A2228	LOWER CONT AMBIENT AIR TEMP A	110.74	DEG F	
5. A1204	UPPER CONT AMIENT AIR TEMP A	90.00	DEG F	
6. A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00	FT	
7. A0671	CONAAINMENT SUMP LEVEL TRAIN B	-----	FT	
8. A0848	CONTAINMENT H2 CONCENTRATION TRAIN A	0.00	%	
9. D3572	NS PUMP A (CONTAINMENT SPRAY)	FF		
10. D3573	NS PUMP B (COTAINMENT SPRAY)	OFF		
Group: 25	RADATION SYSTEMS			
1. A0115	1EMF48 REACTOR COOLANT MONITOR	51924.98	CPM	
2. A0829	1EMF5A IN CONTAINMENT HI RANGE RAD MON	8.99	R/HR	
3. A0835	1EMF51B IN CONTAINMENT HI RANGE RAD MON	8.99	R/HR	
4. A0073	1EMF39H CONTAINMENT GAS HI RANGE	2.00	CPM	
5. A0067	1EMF39L CONTAINENT GAS LO RANGE	28504.85	CPM	
6. A0061	1EMF38H CONTAINMENT PARTICULATE HI RANEE	5.00	CPM	
7. A0055	1EMF38L CONTAINMENT PARTICULATE LO RANGE	27029.45	CPM	
8. A1009	1EMF36HH UNIT VENT GAS HIHI RANGE	4.00	R/HR	
9. A0018	1EMF36H UNIT VENT GAS HI RANGE	11.01	CPM	
10. A0012	1EMF36L UNIT VNT GAS LO RANGE	465.00	CPM	
11. A0019	1EMF35H UNIT VENT PARTICULATE HI RANGE	19.95	CPM	
12. A0013	1EMF35L UNITVENT PARTICULATE LO RANGE	310.00	CPM	
13. A0049	1EMF37 UNIT VENT IODINE	385.00	CPM	
14. A0079	1EMF40 CONTAINMENT IODINE	500.00	CPM	
15. A1368	1EMF24 STEAMIINE 1A RADIATION MONITOR	0.0110	mR/Hr	
16. A1374	1EMF25 STEAMLINE 1B RADIATION MONITOR	0.0110	MR/HR	
17. A1380	1EMF26 STEAMLINE 1C RADIATION MONITOR	0.011	MR/HR	
18. A1386	1EMF27 STEAMLINE 1D RAIATION MONITOR	0.0110	MR/HR	
19. A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE	-----	CPM	
Group: 30	ENVIRONMENTAL SYSTES			
1. P0846	UPER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH	
2. P0848	LOWER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH	
3. P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAGE)	-----	DEG C	
4. P0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)	-----	DEG	
5. P0849	LOWER WIND DIRECTION (15 MINUE AVERAGE)	-----	DEG	
6. P0595	RECIPITATION IN LAST 15 MIN	-----	IN	
7. P0851	AMBIENT AIR TEMPERATUE(15 MINUTE AVERAGE)	-----	DEG C	
8. A0863	UNIT VENT STACK FLOW	91647.50	FT3/MN	

RDT501

DUK POWER COMPANY

Unit: MNS 1

Page: 3

Date:

10/20/93

Time:

0530

## Group: 35 IN-CORE THERMOCOUPES

1. A0268	IIN-CORE TEMP A10	T/C #2	59.29	DEG F
2. A0166	IN-CORE TEMP J06	T/C #17	558.82	DEG F
3. A0155	IN-CORE TEMP F01	T/C #43	559.73	DEG F
4. A0251	IN-CORE TEMP M07	T/C #59	559.14	DG F
5. P0823	5 HIGHEST IN-CORE T/C TEMP MAGIN		-----	DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP		-----	DEG F
7. A1323	IN-CORE TEMP K05	T/C 554	-----	DEG F
8. A1341	IN-CORE TEMP M11	T/C #60	-----	DEG F
9. A1287	IN-CORE TEMP D13	T/C 42	-----	DEG F
10. A1161	IN-CORE TEMP C04	T/C #3	-----	DEG F

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

10/20/93

Time:

0530

Group: 05		PRIMARY SYSTEM			
1.	A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	616.22	DEG F	
2.	A0971	NC LOOP B WIDE RANGE HOT LEG TEMP	616.22	DEG F	
3.	A0977	NNC LOOP C WIDE RANGE HOT LEG TEMP	616.22	DEG F	
4.	A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	616.22	DEG F	
5.	A1061	NC LOOP A WIDE RANGE COLD LEG TEMP	559.31	DEG F	
6.	A1067	NC LOOP B WIDE RANGE COLD LEG TEMP	559.44	DEG F	
7.	A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	559.46	DEG F	
8.	A1079	NC LOOP D WIDE RANGE COLD LEG TEMP	559.44	DEG F	
9.	A0826	NC SYSTEM (HOT LEG WIDE RANGE PRESS)	2253.43	PSIG	
11.	A1124	PZR LEVEL I (HOT CALIBRATED)	60.98	%	
12.	D2803	REACTOR COLANT PUMP A	ON		
13.	D2804	REACTOR COOLANT PUMP B	ON		
14.	D2805	REACTOR COOLANT PUMP C	ON		
15.	D2806	REACTOR COOLANT PUMP D	ON		
16.	A1177	SOURCE RANGE (FLUX) LEVEL CHANNEL 1	0.00	CPS	
17.	A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL 2	0.00	PS	
18.	A0628	POWER RANGE AVG LEVEL QUADRNT 1 (N-43)	98.86	%	
19.	P1385	REACTOR THERMAL POWER, BEST ESTIMATE	99.05	%	
20.	A0602	CVCS BORON METER ISOLATED ON Ph. A)	623.35	PPM	
21.	A1312	RVLIS - TRAIN A - DYNAMIC HEAD D/P	105.06	%	
22.	A1300	RVLIS - TRAIN A - UPPER RANGE LEVEL	61.33	%	
23.	A1306	RVLIS - TRAIN A - LOWER RANGE LEVEL	64.00	%	
24.	P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN	14.34	DEG F	
Group: 10		SECONDARY SYSTEM			
1.	A1004	STEAMGEN A WIDE RANGE LEVEL	63.85	%	
2.	A1005	STEAM GEN B WIDE RANGE LEVLL	63.85	%	
3.	A0970	STEAM GEN C WIDE RANGE LEVEL	63.85	%	
4.	A0988	STEAM GEN D WIDE RANGE LEVEL	63.86	%	
5.	A1107	STEAM GEN A STEAM (LINE) PRESS I	991.45	PSIG	
6.	A1113	STEAM EN B STEAM (LINE) PRESS I	991.8	PSIG	
7.	A1119	STEAM GEN C STEAM (LINE) PESS I	991.02	PSIG	
8.	A1125	STEAM GEN D STEAM (LINE) PRESS I	990.99	PSIG	
9.	P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	3.78	MLB/HR	
10.	P1414	TOTAL S/G B (MAIN) FEEDWATER FLOW	3.78	MLB/HR	
11.	P1416	TOTL S/G C (MAIN) FEEDWATER FLOW 1	3.7	MLB/HR	
12.	P1418	TOTAL S/G D (MAIN) FEEDWTER FLOW 1	3.78	MLB/HR	
13.	P2208	AUX FEEDWATER FLOW TO S/G A	0.0530	MLB/HR	
14.	P1209	AUX FEEDWATERFLOW TO S/G B	0.0530	MLB/HR	
15.	P1210	AUX FEEDWATER FLOW TO S/G C	0.0530	MLB/HR	
16.	P1211	AUXFEEDWATER FLOW TO S/G D	0.0530	MLB/HR	
17.	A1059	STEAM GEN A NARROW RANG LEVEL IV	66.00	%	
18.	A1065	STEAM GEN B NARROW RANGE LEVEL IV	66.00	%	
19.	A1071	STEAM GEN C ARROW RANGE LEVEL IV	66.00	%	
20.	A1077	STEAM GEN D NARROW RANGE LEVEL IV	66.01	%	
21.	A0736	MAN STEAM HEADER PRESSURE	977.2	PSIG	

RDT501

DUKE POWER COMPAY

Unit: MNS 1

Page: 2

Date: 10/10/93

Time:

0545

Group: 15		AUXILIARY/INJECTION SYSTEMS		
1.	D0970	NV PUMP A (HIGH HEAD SI)	OFF	
2.	D0620	NV PUMP B (HIGH HEAD SI)	ON	
3.	A0827	ORON INJECTION (HIGH HEAD SI) FLOW		0.00 GPM
4.	D3574	NI PUMP A (INTERMEDIAE HEAD SI)	OFF	
5.	D3576	NI PUMP B (INTERMEDIATE HEAD SI)	OFF	
6.	D1042	ND PUMP A (LOW HED SI / RHR)	OFF	
7.	D0968	ND PUMP B (LOW HEAD SI / RHR)	OFF	
8.	A0758	HARGING PUMP DISCHARGE HEADER FLOW		123.0 GPM
9.	A0856	(LOW HEAD SI / RHR) ND H RETURN FLOW		9.88 GPM
10.	A0764	LETDOWN HX OUTLET FLOW		75.74 GPM
11.	D0400	REFUELING ATER STORAGE TANK LEVEL	NORMAL	
12.	D0402	REFUELING WATER STORAGE TANK LEEL	NOT LO	
13.	D0401	REFUELING WATER STORAGE TANK LEVEL	NOT EME LO	
Group: 20		CONTAINMENT SYSTEMS		
1.	A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)		PSGG
2.	A0785	INTER. RANGE CONTAIN. PRESS (-5 TO20)	0.1654	PSIG
3.	A1047	WIDE RANGE CONTAIN. PRESS (-5 TO 60)		PSIG
4.	A1228	LOWER CONT AMBIENT AR TEMP A	110.75	DDEG F
5.	A1204	UPPER CONT AMBIENT AIR TEMPAA	90.04	DEG F
6.	A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00	FT
7.	A0671	CONTAINMENT SUMLEVEL TRAIN B		FT
8.	A0848	CONTAINMENT H2 CONCENTRATION TRAIN A	0.00	%
9.	D3572	NS PUMP A (CONTAINMENT SPRAY)	OFF	
10.	D3573	NS PUMP B (CONTAINMENT SPRAY)	OFF	
Group: 25		RADITION SYSTEMS		
1.	A0115	IEMF48 REACTOR COOLANT MONITOR	51924.98	CPM
2.	A0829	IEMF5A IN CONTAINMENT HI RANGE RAD MON	8.97	R/HR
3.	A0835	IEMF51B IN CONTAINMENT HI AANGE RAD MON	8.97	R/HR
4.	A0073	IEMF39H CONTAINMENT GAS HI RANGE	2.00	CPM
5.	A0067	IEMF39L CONTAINMENT GAS LO RANGE	28504.76	CPM
6.	A0061	IEMF38H CONTAINMENT PARTICULATE HI RANGE	5.00	CPM
7.	A0055	IEMF38L CONTAINMENT PARTICULATE LO RANGE	27029.45	CPM
8.	A1009	IEMF36HH UNIT VENT GAS HI HI RANGE	4.00	R/HR
9.	A0118	IEMF36H UNIT VENT GAS HI RANGE	11.01	CPM
10.	A0012	IEMF36L UNIT VENT GAS LO RANGE	465.00	CPM
11.	A0019	IEMF35H UNIT VENT PARTICULATE HI RAGE	19.95	CPM
12.	A0013	IEMF5L UNIT VENT PARTICULATE LO RANGE	310.00	CPM
13.	A0049	IEMF37 UNIT VFNT IODINE	385.00	CPM
14.	A0779	IEMF40 CONTAINMENT IODINE	500.00	CPM
15.	A1368	IEMF24 STEAMLINE A RADIATION MONITOR	0.0110	mR/Hr
16.	A1374	IEMF25 STEAMLINE 1B RADIATION MONITOR	0.0110	MR/HR
17.	A1380	IEMF2 STEAMLINE 1C RADIATION MONITOR	0.0110	MR/HR
18.	A1386	IEMF27 STEAMLINE 1D RADITION MONITOR	0.0110	MR/HR
19.	A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE		CPM
Group: 30		ENVIRONMENTAL SYSTEMS		
1.	P0846	UPPR WIND SPEED (15 MINUTE AVERAGE)		MPH
2.	P0848	LOWER WIND SPEED (5 MINUTE AVERAGE)		MPH
3.	P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAGE)		DEG C
4.	P0847	UPPER WIND DIEECTION (15 MINUTE AVERAGE)		DEG
5.	P0849	LOWER WIND DIRECTION (15 MINUTE VE, AGE)		DEG
6.	P0595	PRCIPITATION IN LAST 15 MIN		IN
7.	P0851	AMBIENT AIR TEMPERATURE(1 MINUTE AVERAGE)		DEG C
8.	00863	UNIT VENT STACK FLOW	91647.50	FT3/MN

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date

Time:

10/20/93 0945

Group: 35	IN-CORE THERMOCOUPLE		
1. A0268	INCORE TEMP A10 T/C #2	559.6	DEG F
2. A0166	IN-CORE TEMP J06 T/C #7	558.79	DEG F
3. A0155	IN-CORE TEMP F01 T/C #43	559.71	DEG F
4. A0251	IN-CORE TEMPM07 T/C #59	559.11	DEG F
5. P0823	5 HIGHEST IN-CORE T/C TEMP MARGIN	-----	DEG F
6. P0828	5 IGHEST IN-CORE T/C TEMP	-----	DEG F
7. A1323	IN-CORE TEMP K05 T/C 54	-----	DEG F
8. A3341	IN-CORE TEMP M11 T/C #60	-----	DEG F
9. A1287	IN-CORE TEMPDD13 T/C #42	-----	DEG
10. A1161	IN-CORE TEMP C04 T/C #3	-----	DEG F

DTS01

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date: 10/20/93

Time: 0800

Group: 05	-----	PRIMARY SYSTEM	-----
1.	A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	616.15 DEG F
2.	A0971	NC LOOP BWIDE RANGE HOT LEG TEMP	616.15 DE F
3.	A0977	NC LOOP C WIDE RANGE HOT LEG TMP	616.15 DEG F
4.	A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	616.15 DEG F
5.	A1061	NC LOOP A WIDE RANGE COLD LEG TEMP	559.66 DEG F
6.	A1067	NC LOOP E WIDE RANGE COLD LEG TEMP	559.77 DEG F
7.	A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	559.78 DE F
8.	A1079	NC LOOP D WIDE RANGE COLD LEGTEMP	559.77 DEG F
9.	A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	250.74 PSIG
11.	A1124	PZR LEVEL I (HOT CAIBRATED)	60.83 %
22.	D2803	REACTOR COOLANT PUMP A	ON
13.	D2804	REACTOR OOLANT PUMP B	ON
14.	D2805	REACTOR COOLANT PUMP C	ON
15.	D2806	REACTOR COOLANT PUMP D	ON
16.	A1177	SOURCE RANGE (FLUX LEVEL CHANNEL 1	0.00 CPS
17.	A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL 2	0.00 CPS
18.	A0628	POWER RAGE AVG LEVEL QUADRANT 1 (N-43)	98.16 %
19.	P1385	REACTOR THERMAL POWER, BEST ETTIMATE	98.11 %
20.	A0602	CVCS BORON METER (ISOLATED ON Ph. A)	623.95 PPM
21.	A1312	RVLIS - TRAIN A - YYNAMIC HEAD D/P	105.00 %
22.	A1300	RVLIS - TRAIN A - UPPER RANGE LEVEL	61.33 %
23.	A1306	RVLIS - TRAINA - LOWER RANGE LEVEL	64.00
24.	P1481	LOWEST NC SYSTEM SUBCOOLING ARGIN	14.35 DEG F
Group: 10	-----	SECONDARY SYSTEM	-----
1.	A1004	STEAM GEN A WIDE RANGE LEVEL	63.83 %
2.	A1005	STEAM GN B WIDE RANGE LEVEL	63.83
3.	A0970	STEAM GEN C WIDE RANGE LEVEL	63.82 %
4.	A0988	SSTEAM GEN D WIDE RANGE LEVEL	63.83 %
5.	A1107	STEAM GEN A STEAM(LINE) PRESS I	994.82 PSIG
6.	A1113	STEAM GEN B STEAM (LINE) PRESS I	994.83 PSIG
7.	A1119	STEAM EN C STEAM (LINE) PRESS I	994.85 PSIG
8.	A1125	STEAM GEN D STEAM (LINE) PRSS I	994.84 PSIG
9.	P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	3.75 MLB/HR
10.	P1414	TOTAL S/G B (MAI) FEEDWATER FLOW 1	3.74 MLB/HR
11.	P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1	3.74 MLB/HR
12.	P1418	TOTAL /G D (MAIN) FEEDWATER FLOW 1	3.75 MMLB/HR
13.	P1208	AUX FEEDWATER FLOW TO S/G A	0.0529 MLB/HR
14.	P1209	AUX FEEDWATER FLOW TO S/G B	0.0529 MLB/HR
15.	P1210	AUX FEEDWATER FLW TO S/G C	0.0529 MLB/HR
16.	P1211	AUX FEEDWATER FLOW TO S/G D	0.0529 MLB/HR
17.	A1059	STEAMGEN A NARROW RANGE LEVEL IV	66.00 %
18.	A1065	STEAM GEN B NARROW RANGE LVVEL IV	66.00 %
19.	A1071	STEAM GEN C NARROW RANGE LEVEL IV	66.00 %
20.	A1077	STEAM GEN D NAROOW RANGE LEVEL IV	66.00 %
	A0736	MAIN STEAM HEADER PRESSURE	980.74 PSIG

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 2

Date:

10/20/93

Time:

0600

Group: 15

## AUXILIARY/INJECTION SYSTEMS

1. D0970	NV PUMP A (HIGH HEAD SI)	OFF		
2. D0620	NV PUMP B (HIGH EEA SI)	ON		
3. A0827	BORON INJECTION (HIGH HEAD SI) FLOW		0.00	GPM
4. D3574	NI PUP A (INTERMEDIATE HEAD SI)	OFF		
5. D3576	NI PUMP B (INTERMEDIATE HED SI)	OFF		
6. D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF		
7. D0968	ND PUMP B (LOW EAD SI / RHR)	OFF		
8. A0758	CHARGING PUMP DISCHARGE HEADER FLOW		122.32	GPM
9. A0856	(LOWHEAD SI / RHR) ND HX RETURN FLOW		0.00	GPM
10. A0764	LETDOWN HX OUTLET FLOW		75.69	GPM
11. D0400	REFUELING WATER STORAGE TANK LEVEL	NOMAL		
12. D0402	REFUELING WATER STORAGE TANK LEVEL	NOT LO		
13. D0401	REFUELING WATER STORAGE TANK LEVEL	NOT EMER LO		

Group: 20

## CONTAINMENT SYSTEMS

1. 00590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)	-----	PSIG
2. A0785	INTER. RANGE OONTAIN. PRESS (-5 TO 20)	0.1668	PSIG
3. A1047	WIDE RANGE CONTAIN. PRESS (-5 T 60)	-----	PSIG
4. A1228	LOWER COT AMBIENT AIR TEMP A	110.8	DEG F
5. A1204	UPPER CONT AMBIENT AIR EMP A	90.07	DEG F
6. A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00	FT
7. A0671	CONTAINMENT UUMP LEVEL TRAIN B	-----	FT
8. A0848	CONTAINMENT H2 CONCENTRATION TRAIN A	0.00	%
9. D3572	NS PUMPAA (CONTAINMENT SPRAY)	OFF	
10. D3573	NS PUMP B (CONTAINMENT SPRA)	OFF	

Group: 25

## RADIATION SYSTEMS

1. A0115	1EMF48 REACTOR COOLANT MONITOR	51924.98	CPM
2. A0829	1EMF51 IN CONTAINMENT HI RANGE RAD MON	8.90	R/HR
3. A0835	1EMF51B IN CONTAINMENT HI RNNGE RAD MON	8.90	R/HR
4. A0073	1EMF39H CONTAINMENT GAS HI RANGE	2.00	CPM
5. A0067	1EMF39L CONTAINMNT GAS LO RANGE	28504.71	CPM
6. A0061	1EMF38H CONTAINMENT PARTICULATE HI RAGE	5.00	CPM
7. A0055	1EMF38 CONTAINMENT PARTICULATE LO RANGE	27029.45	CPM
8. A1009	1EMF36HH UNIT VENT GAS HI I RANGE	4.00	R/HR
9. A0018	1EMF36H UNIT VENT GAS HI RANGE	11.01	CPM
10. A0012	1EMF36L UNIT VENT GAS LO RANGE	465.00	CPM
11. A0019	1EMF35H UNIT VENT PARTICULATE HI RANGE	19.95	CPM
12. A0013	1EMF35L UNIT VENT PARTICULATE LO RANGE	310.00	CPM
13. A0049	1EMF37 UNIT VENT IODINE	385.00	CPM
14. A0079	1EMF40 CONTAINMENT IODINE	500.00	CPM
15. A1368	1EMF24 STEAMLINE11A RADIATION MONITOR	0.0110	mR/Hr
16. A1374	1EMF25 STEAMLINE 1B RADIATION MONITOR	0.0110	MR/HR
17. A1380	1EMF6 STEAMLINE 1C RADIATION MONITOR	0.0110	MR/HR
18. A1386	1EMF27 STEAMLINE 1D RADIATION MONITOR	0.0110	MR/HR
19. A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE	-----	CPM

Group: 30

## ENVIRONMENTAL SYSTEMS

1. P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH
2. P0848	LOWER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH
3. P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAGE)	-----	DEG C
4. P0847	UPPER WIND DIRCTION (15 MINUTE AVERAGE)	-----	DEG
5. P0849	LOWER WIND DIRECTION (15 MINUTE AVERAGE)	-----	DEG
6. P0595	PRECIPITATION IN LAST 55 MIN	-----	IN
7. P0851	AMBIENT AIR TEMPERATURE(15 MINUTE AVERAGE)	-----	DEG C
8. A0863	UNIT VENT STACKFLOW	91647.50	FT3/MN

RDT501

DUKE POWER COMPANY

Unt: MNS 1

Page: 3

Date: 10/20/93

Time: 06:00

Group: 35 IN-CORE THERMOCOUPLES

1. A0268	IN-CORE TEMP A10 T/C#2	559.65	DEG F
2. A0166	N-CORE TEMP J06 T/C #17	559.18	DEG F
3. A0155	IN-CORE TEMPFO1 T/C #43	560.09	DEGF
4. A0251	IN-CORE TEMP M07 T/C #59	559.49	DEG F
5. P0823	HIGHEST IN-CORE T/C TEMP MARGIN	-----	DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP	-----	DEG F
7. A1323	IN-CORE TEMP K05 T/C #54	-----	DEG F
8. A1341	IN-CORE TEPP M11 T/C #60	-----	DEGFF
9. A1287	IN-CORE TEMP D13 T/C #42	-----	DEG F
10. A1161	I-CORE TEMP C04 T/C #3	-----	DEG F

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

Time:

1920/73

0615

Group: 05

	PRIMARY SYSTEM		
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	615.42	DEG F
2. A0971	NC LOOP B WIDE RANGE HOT LEG EMP	615.42	DEG F
3. A0977	C LOOP C WIDE RANGE HOT LEG TEMP	65.42	DEG F
4. A0983	NC LOOP D WIDE RANE HOT LEG TEMP	615.42	DEG F
5. A1061	NC LOOP A WIDE RANGE COLD LEG TEMP	558.76	DEG F
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEMP	559.33	DGG F
7. A1073	NC LOOP C WIDE RANGE COLD LEG EMP	559.28	DEG F
8. A1079	NC LOOP D WIDE RANGE COLD LEG TEMP	559.29	DEG F
9. A0826	NC SYSTEM (HOT LEG WIDE RANGE PRESS)	2185.02	PSIG
11. A1124	PZR LEVEL I (HOT CALIBRATED)	37.51	%
12. D2803	REACTOR COOLANT PUMP A	ON	
13. D2804	REACTOR COOLANT PUMP B	ON	
14. D2805	REACTOR COOLANT PUMP C	ON	
15. D2806	REACTOR COOLANT PMP D	ON	
16. A1177	SOURCE RANGE (FLUX) LEVEL CHANNEL 1	0.00	CPS
17. A1206	SOURCE RAGE (FLUX) LEVEL CHANNEL 2	0.00	CPS
18. A0628	POWER RANGE AVG LEVEL QUADRN 1 (N-43)	97.56	%
19. P1385	REACTOR THERMAL POWER, BEST ESTIMATE	97.72	%
20. A0602	CVCS BORON METER (ISOLATED ON Ph. A)	624.63	PPM
21. A1312	RVLIS - TRAIN A - DYNAMIC HEAD D/P	104.93	%
22. A1300	RVLIS- TRAIN A - UPPER RANGE LEVEL	61.34	%
23. A1306	RVLIS - TRAIN A - LOWER RANGE ELEVEL	64.00	%
24. P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN	10.66	DEG F

Group: 10

	SECONDARY SYSTEM		
1. A1004	STEAMGEN A WIDE RANGE LEVEL	63.86	%
2. A1005	STEAM GEN B WIDE RANGE LEVEL	63.85	%
3. A0970	STEAM GEN C WIDE RANGE LEVEL	63.85	%
4. A0988	STEAM GEN D WIDE RANGE LEVEL	63.86	%
5. A1107	STEAM GEN A STEAM (LINE) PRESS I	991.18	PSIG
6. A1113	STEA GEN B STEAM (LINE) PRESS I	990.86	PSIG
7. A1119	STEAM GEN C STEAM (LINE) PRESS I	991.91	PSIG
8. A1125	STEAM GEN D STEAM (LINE) PRESS I	991.92	PSIG
9. P1412	TOTAL S/G A (MIN) FEEDWATER FLOW 1	3.73	MLB/HR
10. P1414	TOTAL S/G B (MAIN) FEEDWATER FLOW 1	3.73	MLB/HR
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1	3.7	MLB/HR
12. P1418	TOTAL S/G D (MAIN) FEEDWTER FLOW 1	3.73	MLB/HR
13. P1208	AUX FEEDWATER FLOW TO S/G A	0.0530	MLB/HR
14. P1209	AUX FEEDWATERFLOW TO S/G B	0.0530	MLB/HR
15. P1210	AUX FEEDWATER FLOW TO S/G C	0.0530	MLB/HR
16. P1211	AU FEEDWATER FLOW TO S/G D	0.0500	MLB/HR
17. A1059	STEAM GEN A NARROW RANG LEVEL IV	66.07	%
18. A1065	STEAM GEN B NARROW RANGE LEVEL IV	66.03	%
19. A1071	STEAM GEN CNARROW RANGE LEVEL IV	66.03	%
20. A1077	STEAM GEN D NARROW RANGE LEVEL I	66.06	%
21. A0736	MIN STEAM HEADER PRESSURE	976.89	PSIG

RDTSO1

DUKE POWER COMPNY

Unit: MNS 1

Page: 2

Date: 10/20/93 Time: 06:15

Group: 15		AUXILIARY/INJECTION SYSTEMS			
1.	D0970	NV PUMP A (HIGH HEAD SI)	OFF		
2.	D0620	NV PUMP B (HIGH HEAD SI)	ON		
3.	A0827	BORON INJECTION (HIGHHEAD SI) FLOW		0.00	GPM
4.	D3574	NI PUMP A (INTERMEDIAT HEAD SI)	OFF		
5.	D3576	NI PUMP B (INTERMEDIATE HEAD SI)	OFF		
6.	D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF		
7.	D0968	ND PUMP B (LOW HEAD SI / RHR)	OFF		
8.	A0758	CHRGING PUMP DISCHARGE HEADER FLOW		14.59	GPM
9.	A0856	(LOW HEAD SI / RHR) N HX RETURN FLOW		0.00	GPM
10.	A0764	LETDOWN HX OUTLET FLOW		0.00	GPM
11.	D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL		
12.	D0402	REFUELING WATER STORAGE TANK LEEL	NOT LO		
13.	D0401	EEFUELING WATER STORAGE TANK LEVEL	NOT EMERLO		

Group: 20		CONTAINMENT SYSTEMS			
1.	A0590	NARROW RNNGE CONTAIN. PRESS (-1 TO +1)		---	PSIG
2.	A0785	INTER. RANGE CONTAIN. PRESS (-5 TO 20)		01668	PSIG
3.	A1047	WIDE RANGE CONTAIN. RESS (-5 TO 60)		---	PSIG
4.	A1228	LOWER CONT AMBIENT AIR TEMP A		110.70	DEG F
5.	A1204	UPPER CONTAMBIENT AIR TEMP A		90.07	DEG
6.	A1041	CONTAINMENT SUMP LEVEL TRAIN A		0.00	FT
7.	A0671	CONTANIMENT SUMP LEVEL TRAIN B		---	FT
8.	A0848	CONTAINMENT H2 CONCECTRATTON TRAIN A		0.00	%
9.	D3572	NS PUMP A (CONTAINMENT SPRAY)	OFF		
10.	D3573	NS PUMP B (CONTAINMENT SPRAY)	OFF		

Group: 25		RADIATION SYSTEMS			
1.	A0115	IEMF48 REACTOR COOANT MONITOR		51924.98	CPM
2.	A0829	IEMF51A IN CONTAINMENT HI RANGE RAD MON		8.86	R/HR
3.	A0835	IEMF51B IN CONTAINMENT HI RANGE RAD MON		8.86	R/R
4.	A0073	IEMF39H CONTAINMENT GAS HI RAGGE		2.00	CPM
5.	A0067	IEMF39L CONTAINMENT GAS LO RANGE		2504.70	CPM
6.	A0061	IEMF38H CONTAINMEN PARTICULATE HI RANGE		5.00	CPM
7.	A0055	IEMF38L CONTAINMENT PARTICULATE LO RANGE		27029.45	CPM
8.	A1009	IEMF36HHUUNIT VENT GAS HI HI RANGE		4.08	RHR
9.	A0018	IEMF36H UNIT VENT GAS HI RANE		31.62	CPM
10.	A0012	IEMF36L UNIT VENT GAS LO RANGE		158.49	CPM
11.	A0019	IEMF35H UNIT VENT PARTICULATE HI PANGE		20.40	CPM
12.	A0013	IEMF35L UNIT VENT PARTICULATE LO RANGE		417.12	CPM
13.	A0049	IEMF37 NIT VENT IODINE		396.16	CPM
14.	A0079	IEMF40 CONTAINMENT IODINE		500.00	CPM
15.	A1368	IEMF24 STEAMLINE 1A RADIATION MONITOR		0.0110	mR/Hr
16.	A1374	IEMF25 STEAMLINE B RADIATION MONITOR		0.0110	MR/HR
17.	A1380	IEMF26 STEAMLINE 1C RADIATION MONITOR		0.0110	MR/HR
18.	A1386	IEMF27STEAMLINE 1D RADIATION MONITOR		0.0110	MR/HR
19.	A0127	EMF49H WASTE LIQUID DISCHARE HI RANGE		---	CPM

Group: 30		ENVIRONMENTAL SYSTEMS			
1.	P0846	UPPER WIND SPEED (15 MINUTE AVEAAGE)		---	MPH
2.	P0848	LOWER WIND SPEED (15 MINUTE AVERAGE)		---	MPH
3.	P0850	LOWER TO UPPER DELTA-T (15MINUTE AVERAGE)		---	DEG C
4.	P0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)		---	DEG
5.	P0849	LOWER WIND DIRECION (15 MINUTE AVERAGE)		---	DEG
6.	P0595	PRECIPITATION IN LAST 15 MIN		---	IN
7.	P0851	AMBIENTAIR TEMPERATURE(15 MINUTE AVERAGE)		---	DEG C
8.	A0863	UNIT VENT STACK FLOW		91647.50	FT3/MN

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date:

10/20/93

Time:

0615

## Group: 35 IN-CORE THERMOCOUPLES

1. A0268	IN-CORE TEMP A10	T/C #2	559.10	DEG F
2. A0166	IN-CORE TEMP J06	T/C #17	558.62	DEG F
3. A0155	IN-CORE TEMP F01	T/C #43	559.53	DEG F
4. A0551	IN-CORE TEMP M07	T/C #59	55.93	DEG F
5. P0823	5 HIGHEST IN-COE	T/C TEMP MARGIN	-----	DEG F
6. P0828	5 HIGHEST IN-CORE	T/C TEMP	-----	DEG F
7. A1323	IN-CRE TEMP K05	T/C #54	-----	DEG F
8. A1341	IN-CORE TEMP M11	T/C #60	-----	DEG F
9. A1287	IN-CORE TEMP D13	T/C #42	-----	DEG F
10. A1161	IN-CORE TEMP C04	T/C #3	-----	DEG F

DTS01

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date: 10/20/93

Time: 0630

## Group: 05

PRIMARY SYSTEM				
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	612.79	DEG F	
2. A0971	NC LOOP B WIDE RANGE HOT LEG TEMP	612.79	DEG F	
3. A0977	NC LOOP C WIDE RANGE HOT LEG TEMP	612.79	DEG F	
4. A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	612.79	DEG F	
5. A1061	NC LOOP A WIDE RANGE COLD LEG TEMP	559.46	DEG F	
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEMP	559.94	DEG F	
7. A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	559.93	DEG F	
8. A1079	NC LOOP D WIDE RANGE COLD LEG TEMP	559.93	DEG F	
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	2264.50	PSIG	
11. A1124	PZR LEVEL I (HOT CALIBRATED)	48.47	%	
12. D2803	REACTOR COOLANT PUMP A	ON		
13. D2804	REACTOR COOLANT PUMP B	ON		
14. D2805	REACTOR COOLANT PUMP C	ON		
15. D2806	REACTOR COOLANT PUMP D	ON		
16. A1177	SOURCE RANGE (FLUX) LEVEL CHANNEL 1	0.00	CPS	
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL 2	0.00	CPS	
18. A0628	POWER RANGE AVG LEVEL QUADRANT 1 (N-43)	9126	%	
19. P1385	REACTOR THERMAL POWER, BEST ESTIMATE	92.15	%	
20. A0602	CVCS BORON METER (ISOLATED ON Ph. A)	637.46	PPM	
21. A1312	RVLIS - TRAIN A - DYNAMIC HEAD D/P	104.72	%	
22. A1300	RVLIS - TRAIN A - UPPER RANGE LEVEL	61.40	%	
23. A1306	RVLIS - TRAIN A - LOWER RANGE LEVEL	4.00	%	
24. P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN	19.59	DEG F	

## Group: 10

SECONDARY SYSTEM				
1. A1004	STEAM GEN A WIDE RANGE LEVEL	63.23	%	
2. A1005	STEAM GEN B WIDE RANGE LEVEL	63.21	%	
3. A0970	STEAM GEN C WIDE RANGE LEVEL	63.21	%	
4. A0988	STEAM GEN D WIDE RANGE LEVEL	63.23	%	
5. A1107	STEAM GEN A TEAM (LINE) PRESS I	1008.30	PSIG	
6. A1113	STEAM GEN B STEAM (LINE) PRES I	1008.11	PSIG	
7. A1119	STEAM GEN C STEAM (LINE) PRESS I	1008.11	PSIG	
8. A1125	STEAM GEN D STEAM LINE) PRESS I	1008.11	PSIG	
9. P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	3.49	MLB/HR	
10. P1414	TOTAL S/ B (MAIN) FEEDWATER FLOW 1	3.49	MLB/HR	
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1	3.49	MLB/HR	
12. P1418	TOTAL S/G D (MAIN) FEEDWATER FLOW 1	3.48	MLB/HR	
13. P1208	AUX FEEDWATER FLOW TO S/G A	0.0525	MLB/HR	
14. P1209	AUX FEEDWATER FLOW TO S/G B	0.0525	MLB/HR	
15. P1210	AUX FEEDWATER FLOW TO S/G C	0.0526	LB/HR	
16. P1211	AUX FEEDWATER FLOW TO S/G D	0.0525	MLB/HR	
17. A1059	STEAM GEN A NARROW RANGE LEVEL IV	64.29	%	
18. A1065	STEAM GEN B NARROW RANGE LEVEL IV	64.14	%	
19. A1071	STEAM GEN C NARROW RANGE LEVEL IV	64.14	%	
20. A1077	STEAMGEN D NARROW RANGE LEVEL IV	64.21	%	
21. A0736	MAIN STEAM HEADER PRESSURE	996.40	PSIG	

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 2

Date: 10/20/93

Time: 0630

Group: 15

## AUXILIARY/INJECTION SYSTEMS

1. D0970	NV PUMP A (HIGH HEAD SI)	OFF		
2. D0620	NV PUMP B HIGH HEAD SI)	ON		
3. A0827	BORON INJECTION (HIGH HEAD S) FLOW		0.00	GPM
4. D3574	NI PUMP A (INTERMEDIATE HEAD SI)	OFF		
5. D3575	NI PUMP B (INTERMEDIATE HEAD SI)	OFF		
6. D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF		
7. D0968	ND PUM B (LOW HEAD SI / RHR)	OFF		
8. A0758	CHARGING PUMP DISCHARGE HEDER FLOW		131.78	GPM
9. A0856	(LOW HEAD SI / RHR) ND HX RETURN FLOW		0.00	GPM
10. A0764	LETDOWN HX OUTLET LOW		0.00	GPM
11. D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL		
12. D0402	REFUEING WATER STORAGE TANK LEVEL	NOT LO		
13. D0401	REFUELING WATER STORAGE TAK LEVEL	NOT EMER LO		

Group: 20

## CONTAINMENT SYSTEMS

1. A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)	-----	PSIG
2. A0785	INTER RANGE CONTAIN. PRESS (-5 TO 20)	0.1672	PSIG
3. A1047	WIDE RANGE CONTAIN. PRES (-5 TO 60)	-----	PSIG
4. A1228	LOWER CONT AMBIENT AIR TEMP A	110.73	DEG F
5. A1204	UPPER CONT AMBINT AIR TEMP A	90.03	DEG F
6. A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00	FT
7. A0671	CONTAINMENT SUMP LEVEL TRAIN B	-----	FT
8. A0848	CONTAINMENT H2 CONCENTRATIN TRAIN A	0.00	%
9. D3572	NS PUMP A (CONTINMENT SPRAY)	OFF	
10. D3573	NS PUMP B (CONTAINMENT SPRAY)	OFF	

Group: 25

## RADIATION SYTEMS

1. A0115	1EMF48 REACTOR COOLANT MONITOR	51924.98	CPM
2. A0829	1EMF51A IN CONTAINMENT HI RANGE RAD MON	8.28	R/HR
3. A0835	1EMF51B IN CONTAINMENT HI RANGE RADMON	8.28	R/HR
4. A0073	1EMF39H ONTAINMENT GAS HI RANGE	2.00	CPM
5. A0067	1EMF39L CONTAINMENT GAS LORANGE	28504.64	CPM
6. A0061	1EMF38H CONTAINMENT PARTICULATE HI RANGE	5.00	CPM
7. A0055	1EMF38L CONTAIMENT PARTICULATE LO RANGE	27029.45	CPM
8. A1009	1EMF36HH UNIT VENT GAS HI HI RANGE	4.01	R/HR
9. A0018	1EMF66H UNIT VENT GAS HI RANGE	31.62	CPM
10. A0012	1EMF36L UNIT VENT GAS LO RANE	158.49	CPM
11. A0119	1EMF35H UNIT VENT PARTICULATE HI RANGE	20.03	CPM
12. A0013	1EMF35L UNIT VENTPARTICULATE LO RANGE	329.48	CPM
13. A0049	1EMF37 UNIT VENT IODINE	387.03	CPM
14. A0079	1EMF40 CONTAINMENT IODINE	500.01	CPM
15. A1368	1EMF24 STEAMLINE 1A RAIATION MONITOR	0.0110	mR/Hr
16. A1374	1EMF25 STEAMLINE 1B RADIATION MONITOR	0.0110	MR/HR
17. A1380	1EMF26 STEAMLIEE 1C RADIATION MONITOR	0.0110	MR/HR
18. A1386	1EMF27 STEAMLINE 1D RADIATION MONTTOR	0.0110	MR/HR
19. A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE	---	CPM

Group: 30

## ENVIRONMENTAL SYSTEMS

1. P0846	UPPER WIND SEED (15 MINUTE AVERAGE)	-----	MPH
2. P0848	LOWER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH
3. P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAGE)	-----	DEG C
4. P0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)	-----	DEG
5. P0449	LOWER WIND DIRECTION (15 MINUTE AVERAGE)	-----	DEG
6. P0595	PRECIPITATION IN LAST 15 MIN	-----	IN
7. P0851	AMBIENT AIR TEMPERATURE(15 MINUT AVERAGE)	-----	DEG C
8. A0863	UNT VENT STACK FLOW	91647.50	FT3/MN

RDTSO1

DUKE POWER COPANY

Unit: MNS 1

Page: 3

Date: 10/20/93

Time: 0635

Group: 35		IN-CORE THERMOCOUPLES		
1.	A0268	IN-CORE TMP A10 T/C #2	559.69	DEG F
2.	A0166	IN-CORE TEMP J06 T/C #17	559.22	DEG F
3.	A0155	IN-CORE TEMP F01 T/C #43	560.13	DEG F
4.	A0251	IN-CORE TEMP M07 TCC #59	559.53	DEG F
5.	P0823	5 HIGHEST IN-CORE T/C TEMP MARGIN	-----	DEG F
6.	P0828	5 HIGHEST IN-CORE T/C TEM	-----	DEG F
7.	A1323	IN-CORE TEMP K05 T/C #54	-----	DEG F
8.	A1341	IN-CORE TEMP M11 T/C #60	-----	DEG F
9.	A1287	IN-CORE TEMP D13 T/C #42	-----	DEG F
10.	A1161	IN-CORE TEMP C04 T/C #3	-----	DEG F

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date: 10/20/93Time: 0645

Group: 05

PRIMARY SYSTEM		
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	605.92 DEG F
2. A0971	NC LOOP B WIDE RANGE HOT LEG TEMP	60.92 DEG F
3. A0977	NC LOOP C WIDE RANGE HOT LEG TEMP	605.92 DEG F
4. A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	605.91 DEG F
5. A1061	NC LOOP A WIDE RANGE COLD LEG TEMP	558.39 DEG F
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEMP	558.62 DEG F
7. A1073	N LOOP C WIDE RANGE COLD LEG TEMP	58.62 DEG F
8. A1079	NC LOOP D WIDE RANGE COLD LEG TEMP	558.62 DEG F
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	2220.93 PSIG
11. A1124	PZR LEVEL I(HOT CALIBRATED)	55.12 %
12. D2803	REACTOR COOLANT PUMP A	ON
13. D2804	REACTOR COOLANT PUMP B	ON
14. D2805	REACTOR COOLANT PUP C	ON
15. D2806	REACTOR COOLANT PUMP D	ON
16. A1177	SOURCE RNGE (FLUX) LEVEL CHANNEL 1	0.00 CSS
17. A1206	SOURCE R' NGE (FLUX) LEVEL CHANNEL 2	0.00 CPS
18. A0628	POWR RANGE AVG LEVEL QUADRANT 1 (N-43)	80.65 %
19. P1385	REACTOR THERMAL POER, BEST ESTIMATE	81.78 %
20. A0602	CVCS BORON METER (ISOLATED ON Ph. A)	633.40 RPM
21. A1312	RVLIS - TRAIN A - DYNAMIC HEAD D/P	104.49 %
22. A1300	RVLIS - TRAIN A - UPPER RANG LEVEL	61.53 %
23. A1306	RVLIS - TRAIN A - LOWER RANGE LEVEL	4.00 %
24. P1481	LOWEST NC SYSTEM SBCOOLING MARGIN	24.79 DEG F

Group: 10

SECONDARY SYSTEM		
1. A1004	STEAM GEN A WIDE RANGE LEVEL	62.27 %
2. A1005	STEAM GEN B WIDE RANGE LEVEL	62.25 %
3. A0970	STEAM GEN C WIDE RANGE LEVEL	62.25 %
4. A0988	STEAM GEN D WIDE RANGE LEVEL	62.27 %
5. A1107	STEAM GEN STEAM (LINE) PRESS I	1012.73 SIG
6. A1113	STEAM GEN B STEAM (LINE) PRESS I	1012.27 PSIG
7. A1119	STEAM GEN C STEAM (LINE) PRESS I	1013.88 PSIG
8. A1125	STEAM GEN D STEAM(LINE) PRESS I	1013.88 PSIG
9. P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	3.04 MLB/HR
10. P1414	TOTAL S/GB (MAIN) FEEDWATER FLOW 1	3.04 LLB/HR
11. P1416	TOTAL S/G C (MAIN) FEEDWATER LOW 1	3.05 MLB/HR
12. P1418	TOTAL S/G D (MAIN) FEEDWATER FLOW 1	3.06 MLB/HR
13. P1208	AUX FEEDWATER FLO TO S/G A	0.0509 MLB/HR
14. P1209	AUX FEEDWATER FLOW TO S/G B	0.0510 MLB/HR
15. P1210	AUX FEEDATER FLOW TO S/G C	0.0509 MLB/HR
16. P1211	AUX FEEDWATER FLOW TO S/G D	0.0509 MLB/HR
17. A1059	STEAM GEN A NARROW RANGE LEVEL IV	61.20 %
18. A1065	STEAM GEN B NARRO RANGE LEVEL IV	61.11 %
19. A1071	STEAM GEN C NARROW RANGE LEVEL IV	61.10 %
20. A1077	STEAM EN D NARROW RANGE LEVEL IV	61.19 %
21. A0736	MAIN STEAM HEADER PRESSURE	1003.32 PSIG

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 2

Date:

Time:

10/20/93 0645

Group: 15	AUXILIARY/INJECTION SYSTEMS			
1. D0970	NV PUMP A (HIGH HEAD SI)	OFF		
2. D0620	NV PUMPBB (HIGH HEAD SI)	ON		
3. A0827	BORON INJECTION (HIGH HEAD I) FLOW		0.00	GPM
4. D3574	NI PUMP A (INTERMEDIATE HEAD SI)	OFF		
5. D3576	NI PUMP B (INTERMDIATE HEAD SI)	OFF		
6. D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF		
7. D0968	ND PUMP B (LOW HEAD SI / RHR)	OFF		
8. A0758	CHARGING PUMP DISCHARGE HADER FLOW		128.09	GPM
9. A0856	(LOW HEAD SI / RHR) ND HX RETURN FLOW		0.00	GPM
10. A0764	LETDOWN HX OUTLT FLOW		44.39	GPM
11. D0400	REFUELNG WATER STORAGE TANK LEVEL	NORMAL		
12. D0402	REFUELNG WATER STCRAGE TANK LEVEL	NOT LO		
13. D0401	REFUELNG WATER STORAGE TNK LEVEL	NOT EMER LO		

Group: 20	CONTAINMENT SYSTEMS			
1. A0590	NARROW RANGE CONTAIN. PRESS (-1 TO 1)		----	PSIG
2. A0785	INTE. RANGE CONTAIN. PRESS (-5 TO 20)		0.1677	PSIG
3. A1047	WIDE RANGE CONTAIN. PRESS (-5 TO 60)		----	PSIG
4. A1228	LOWER CONT AMBIENT AIR TEMP A		11055	DEG F
5. A1204	UPPER CONT AMBIENT AIR TEMP A		90.05	DEG F
6. A1041	CONTAINMENT UMP LEVEL TRAIN A		0.00	FT
7. A0671	CONTAINMENT SUMP LEVEL TRAIN B		----	FT
8. A0848	CNTAINMENT H2 CONCENTRATION TRAIN A		000	%
9. D3572	NS PUMP A (CONTAINMENT SPRAY)	OFF		
10. D3573	NS PUMP B (CONTAINMENT SPRAY)	OOFF		

Group: 25	RADIATION SYSTEMS			
1. A0115	1EMF48 REACTOR COOLANT MONITOR		51924998	CPM
2. A0829	1EMF51A IN CONTAINMET HI RANGE RAD MON		7.34	R/HR
3. A0835	1EMF51B IN CONTAINMENT HI RANGE RAD MON		7.34	R/HR
4. A0073	1EMF39H CONAINMENT GAS HI RANGE		2.00	CP
5. A0067	1EMF39L CONTAINMENT GAS LO RANE		28504.62	CPM
6. A0061	11EMF38H CONTAINMENT PARTICULATE HI RANGE		5.00	CPM
7. A0055	1EMF38L CONTAINMENT ARTICULATE LO RANGE		27029.45	CPM
8. A1009	1EMF36HH UNIT VENT GAS HI HI RANGE		4.01	R/HR
9. A0018	1EMF36H UIIT VENT GAS HI RANGE		31.62	CPM
10. A0012	1EMF36L UNIT VENT GAS LO RANGE		158.49	CPM
11. A0013	1EMF35H UNIT VENT PARTICULATE HI RANGE		20.03	CPM
12. A0013	1EMF35L UNIT VENT PRATICULATE LO RANGE		329.27	CPM
13. A0049	1EMF37 UNIT VENT IODINE		387.01	CPM
14. A0079	1EMF40 CNTAINMENT IODINE		500.03	CPM
15. A1368	1EMF24 STEAMLINE 1A RADIATIONMONITOR		0.0110	mR/Hr
16. A1374	EMF25 STEAMLINE 1B RADIATION MONITOR		0.0110	MR/HR
17. A1380	1EMF26 STEAMLINE 1CRADIATION MONITOR		0.0110	MR/HR
18. A1386	1EMF27 STEAMLINE 1D RADIATION MONITOR		0.0110	MR/HR
19. A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE		----	CPM

Group: 30	ENVIRONMENTAL SYSTEMS			
1. P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)		----	MPH
2. P0848	LOWER WIND SPEED (15 MINUTE AVERAE)		----	MPH
3. P0850	LOWER TOUUPPER DELTA-T (15 MINUTE AVERAGE)		----	DG C
4. P0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)		----	DEG
5. P0849	LOWER WIND DIRECTION (15 MINUTE AVERAGE)		----	DEG
6. P0595	PRECIPITATION IN LAS 15 MIN		----	IN
7. P0851	AMBIENT AIR TEMPERATURE(15 MINUTE AVERAE)		----	DEG C
8. A0863	UNIT VENT STACK FLOW		91647.50	FT3/MN

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date:

Tie:

10/20/93

0645

Group: 35 IN-CORE THERMOCOUPLES

1. A0268	IN-CORE TEMP A10 T/C #2	558.53	DEG F
2. A0166	IN-CORE TEMP J06 T/C #17	558.06	DEG F
3. A0155	IN-CORETEMP F01 T/C #43	558.96	DE F
4. A0251	IN-CORE TEMP M07 T/C #59	558.35	DEG F
5. P0823	5 HIGHEST IN-CORE T/C TEMP MARGIN	-----	DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP	-----	DEG F
7. A1323	IN-CORE TEMP K05 T/C #54	-----	DEG F
8. A1341	IN-COR TEMP M11 T/C #60	-----	EEG F
9. A1287	IN-CORE TEMP D13 T/C #42	-----	DEG F
10. A1161	IN-CORE TEMP C04 T/C #3	-----	DEG F

DTS01

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

Time:

10/20/93

0700

## Group: 05

PRIMARY SYSTEM		
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	603.97 DEG F
2. A0971	NC LOOP B WIDE RANGE HOT LEG TEMP	603.97 DEG F
3. A0977	NC LOOPC WIDE RANGE HOT LEG TEMP	603.97 DEG F
4. A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	603.97 DEG F
5. A1061	NC LOOP A WIDE RANGE COLD LEG TEMP	556.44 DEG F
6. A1067	NC LOOP B WIDE RANG COLD LEG TEMP	556.66 DEG F
7. A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	556.65 DEG F
8. A1079	NC LOOP D WIDE RANGE COLD LEG TEMP	556.64 DEG F
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	2247.59 PSIG
11. A1124	PZR LEVEL I (HOT CALIBRATED)	52.57 %
12. D2803	REACTOR COOLANT PUMP A	ON
13. D2804	REACTOR COOLANT PUMP B	ON
14. D2805	REACOR COOLANT PUMP C	ON
15. D2806	REACTOR COOLANT PUMP D	ON
16. A1177	SOURCE RANGE (FLUX) LEVEL CHANNEL 1	0.00 CPS
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL 2	0.00 CPS
18. A0628	POWER RANGE AVG LEVEL QUADRANT 1 (N-43)	80.48 %
19. P1385	REACTOR THERMAL POWER, BEST ESTIMATE	81.13 %
20. A0602	CVCS BORON METER (ISOLATD ON Ph. A)	633.07 PPM
21. A1112	RVLIS - TRAIN A - DYNAMIC HEAD D/P	104.67 %
22. A1300	RVLIS - TRAIN - UPPER RANGE LEVEL	61.56 %
23. A1306	RVLIS - TRAIN A - LOWER RANGE LEVEL	64.00 %
24. P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN	28.60 DEG F

## Group: 10

SECONDARY SYSTEM		
1. A1004	STEAM GEN A WIDE RANGE LEVEL	62.38 %
2. A1005	STEAM GEN B WIDE RANGE LEVEL	62.36 %
3. A0970	STEAM GEN C WIDE RANGE LEVEL	62.3 %
4. A0988	STEAM GEN D WIDE RANGE LEVLL	62.38 %
5. A1107	STEAM GEN A STEAM (LINE) PRESS I	995.70 PSIG
6. A1113	STEAM GEN B SEAM (LINE) PRESS I	995.92 PSIG
7. A1119	STEAM GEN C STEAM (LINE) PRESS I	995.92 PSIG
8. A1125	STEAM GEN D STEAM (LINE) PRESS I	995.91 PSIG
9. P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	3.01 MLB/HR
10. P1414	TOTAL S/G B (MAIN) FEEDWATER FLOW 1	3.02 MLB/HR
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1	3.02 MLB/HR
12. P1418	TOTAL S/G D (MAIN) FEEDWATER FLOW 1	3.02 MLB/HR
13. P1208	AUX FEEDWATR FLOW TO S/G A	0.0500 MLB/R
14. P1209	AUX FEEDWATER FLOW TO S/G B	0.0501 MLB/HR
15. P1210	AXX FEEDWATER FLOW TO S/G C	0.500 MLB/HR
16. P1211	AUX FEEDWATER FLOW TO //G D	0.0500 MLB/HR
17. A1059	STEAM GEN A NARROW RANGE LEVEL IV	61.14 %
18. A1065	STEAM GEN BNNARROW RANGE LEVEL IV	61.06 %
19. A1071	STEAM GEN C NARROW RANGE LEVEL IV	61.06 %
20. A1077	TEAM GEN D NARROW RANGE LEVEL IV	6..15 %
21. A0736	MAIN STEAM HEADER PRESURE	986.46 PSIG

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 2

Date: 10/20/93 Time: 0700

Group: 15 ----- AUXILIARY/INJECTION SYSTEMS				
1. D0970	NV PUMP A (HIGH HEAD SI)	ON		
2. D0620	NV PUM B (HIGH HEAD SI)	ON		
3. A0827	BORON INJECTION (HIGH HEAD SI) FLOW		0.00	GPM
4. D3574	NI PUMP A (INTERMEDIATE HEAD SI)	OFF		
5. D3576	NI PUMP B INTERMEDIATE HEAD SI)	OFF		
6. D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF		
7. D0968	NND PUMP B (LOW HEAD SI / RHR)	OFF		
8. A0758	CHARGING PUMP DISCHRGE HEADER FLOW		108.89	GPM
9. A0856	(LOW HEAD SI / RHR) ND HX RETURN FLOW		0.00	GPM
10. A0764	LETDOWN H OUTLET FLOW		35.97	GPM
11. D0400	REFUELING WATER STORAGE TANK LVEL	NORMAL		
12. D0402	REFUELING WATER STORAGE TANK LEVEL	NOT LO		
13. D0401	REFUELING WATER STORGE TANK LEVEL	NOT EMER LO		
Group: 20 ----- CONTAINMENT SYSTEMS				
1. A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)			PSIG
2. A0785	INTER.RRANGE CONTAIN. PRESS (-5 TO 20)		0.1659	PSIG
3. A1047	WIDE RANGE CONTAIN. PRESS (5 TO 60)			PSIG
4. A1228	LOWER CONT AMBIENT AIR TEMP A		110.35	DEG F
5. A1204	UPPER CONT AMBIENT AR TEMP A		89.99	DEG F
6. A1041	CONTAINMENT SUMP LEVEL TRAIN A		0.00	FT
7. A0671	CONTAINMNT SUMP LEVEL TRAIN B			FT
8. A0848	CONTAINMENT H2 CONCENTRATIONTRAIN A		0.00	%
9. D3572	NS PUMP A (CONTAINMENT SPRAY)	OFF		
10. D3573	NS PUMP B (CONTAINMENT SPRAY)	OFF		
Group: 25 ----- RADIATION SYSTEMS				
1. A0115	1EMF48 REACTOR COOLANT MONIOR		51924.98	CPM
2. A0829	1EMF51A IN CONTAINMENT HI RANGE RAD MON		7.33	R/HR
3. A0835	1EMF51B IN CONTAINMENT HI RANGE RAD MON		7.33	R/HR
4. A0073	1EMF39H CONTAINMENT GAS HI RANGE		2.00	CPM
5. A0067	1EMF9L CONTAINMENT GAS LO RANGE		28504.65	CPM
6. A0061	1EMF38H CONTAINMENT PARTIULATE HI RANGE		5.00	CPM
7. A0055	1EMF38L CONTAINMENT PARTICULATE LO RANGE		27029.45	CPM
8. A1009	1EMF36HH UNIT VENT GAS HI HI RANGE		4.01	R/HR
9. A0018	1EMF36H UNIT VENT GAS HI RANGE		31.62	CPM
10. A0012	1EMF36L UNIT VENT GAS LO RANGE		158.9	CPM
11. A0019	1EMF35H UNIT VENT PARTIULATE HI RANGE		20.03	CPM
12. A0013	1EMF35L UNIT VENT PARTICULATE LO RANGE		329.34	CPM
13. A0049	1EMF37 UNIT ENT IODINE		387.02	CPM
14. A0079	1EMF40 CONTAINMENT IODINE		500.03	CPM
15. A1368	1EMF24 STEAMLINE 1A RADIATION MONITOR		0.010	mR/Hr
16. A1374	1EMF25 STEAMLINE 1B RDIACTION MONITOR		0.0110	MR/HR
17. A1380	1EMF26 STEAMLINE 1C RADIATION MONITOR		0.0110	MR/HR
18. A1386	1EMF27 STEALINE 1D RADIATION MONITOR		0.0110	MR/H
19. A0127	EMF49H WASTE LIQUID DISCHARGE HIRANGE			CPM
Group: 30 ----- ENVIRONMENTAL SYSTEMS				
1. P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)			MPH
2. P0848	LOWER WIND PPEED (15 MINUTE AVERAGE)			MPH
3. P0850	LOWER TO UPPER DELTA-T (15 MINUTEAVERAGE)			DEG C
4. P0847	PPER WIND DIRECTION (15 MINUTE AVERAGE)			DEG
5. P0849	LOWER WIND DIRECTION (15 MINUTE AVERAGE)			DEG
6. P0595	PRECIPITATION IN LAST 15 MIN			IN
7. P0851	AMBIENT AIRTEMPERATURE(15 MINUTE AVERAGE)			DEGCC
8. A0863	UNIT VENT STACK FLOW		91647.50	FT3/MN

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date: 10/20/93 Time: 0700

Group: 35	IN-CORE THERMOCOUPLES		
1. A0268	IN-CORE TEMP A10 T/C #2	556.53	DEG F
2. A0166	IN-CORE TEMP J06 T/C #17	556.05	DEG F
3. A0155	IN-CORE TEMP F01 T/C #43	556.96	DEG F
4. A0251	IN-CORE TEMP M07 T/C #59	556.35	DEG F
5. P0823	5 HIGHEST IN-CORE T/C TEMP MARGIN	-----	DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP	-----	DEG F
7. A1323	IN-CORE TEMP K05 T/C #54	-----	DEG F
8. A1341	IN-CORE TEMP M11 T/C #60	-----	DEG F
9. A1287	IN-CORE TEMP D13 T/C #42	-----	DEG F
10. A1161	IN-CORE TEMP C04 T/C #3	-----	DEG

DTS01

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date: 10/20/93

Time: 0715

Group: 05

PRIMARY SYSTEM		
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	597.61 DEG F
2. A0971	NC LOOP B WIDE RNGE HOT LEG TEMP	597.61 DEG F
3. A0977	NC LOOP C WIDE RANGE HOT LEG TEMP	597.61 DEG F
4. A0983	NC LOP D WIDE RANGE HOT LEG TEMP	597.56 DEG F
5. A1061	NC LOOP A WIDE RANGE COLD LEG TEMP	558.22 DEG F
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEMP	558.35 DEG F
7. A1073	NC LOOP C WIDE RNNGE COLD LEG TEMP	558.34 DEG F
8. A1079	NC LOOP D WIDE RANGE COLD LEG TEMP	558.34 DEG F
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	2240.89 PSIG
11. A1124	PZR LEVEL I (HOT CALIBRATED)	49.53 %
12. D2803	REACTOR COOLANT PUMP A	ON
13. D2804	REACTOR COOLANTPUMP B	ON
14. D2805	REACTOR COOLANT PUMP C	ON
15. D2806	REACOR COOLANT PUMP D	ON
16. A1177	SOURCE RANGE (FLUX) LEVEL HANNEL 1	0.00 CPS
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL 2	0.00 CPS
18. A0628	POWER RANGE AVG LEVEL QUADRANT 1 (N-43)	64.84 %
19. P1385	REACTOR THERMAL POWER, BEST ESTIMAT	67.80 %
20. A0602	CVCSBBORON METER (ISOLATED ON Ph. A)	628.2 PPM
21. A1312	RVLIS - TRAIN A - DYNAMI HEAD D/P	103.87 %
22. A3300	RVLIS - TRAIN A - UPPER RANGE LEVEL	61.68 %
23. A1306	RVLIS - TRAIN A- LOWER RANGE LEVEL	63.99 %
24. P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN	36.94 DEG F

Group: 10

SECONDARY SYSTEM		
1. A1004	STEAM GEN A WIDE RANGE LEVEL	60.85 %
2. A1005	STEAM GEN B WIDE RANGE LEVEL	60.82 %
3. A0970	STEAM GEN C WIDE RANGE LEVEL	60.82 %
4. A0988	STAM GEN D WIDE RANGE LEVEL	60.5 %
5. A1107	STEAM GEN A STEAM (LINE PRESS I	1032.52 PSIG
6. A1113	STEAM GEN B STEAM (LINE) PRESS I	1032.41 PSIG
7. A1119	STEAM GEN C TEAM (LINE) PRESS I	1031.26 PSIG
8. A1125	STEAM GEN D STEAM (LINE) PRESS I	1031.26 PSIG
9. P1412	TOAL S/G A (MAIN) FEEDWATER FLOW 1	2.4 MLB/HR
10. P1414	TOTAL S/G B (MAIN) FEEDWTER FLOW 1	2.48 MLB/HR
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1	2.47 MLB/HR
12. P1418	TOTAL S/G D MAIN) FEEDWATEP FLOW 1	2.47 MLB/HR
13. P1208	AUX FEEDWATER FLOW TO S/G A	0.0489 MLB/HR
14. P1209	UX FEEDWATER FLOW TO S/G B	00488 MLB/HR
15. P1210	AUX FEEDWATER FLOW T S/G C	0.0489 MLB/HR
16. P1211	AUX FEEDWATER FLOW TO S/G D	0.0489 MLB/HR
17. A1059	STEAM GEN A NARROW RANGE LEVEL IV	56.60 %
18. A1065	STEAM GEN B NARROW RANGE LEVEL IV	56.39 %
19. A1071	STEAM GEN C NARROW RANGE LEVEL IV	66.38 %
20. A1077	STEAM GEN D NARROW RANE LEVEL IV	56.45 %
21. A0736	MAIN STEAM HEADER PRESSURE	1026.64 PSIG

RDTSO1

DUK POWER COMPANY

Unit: MNS 1

Page: 2

Date: 10/20/93

Time: 0215

Group: 15		AUXILIARY/INJECTION SYSTEMS		
1.	D0970	'VV PUMP A (HIGH HEAD SI)	OFF	
2.	D0620	NV PUMP B (HIGH HEA SI)	ON	
3.	A0827	BORON INJECTION (HIGH HEAD SI) FLOW		0.00 GPM
4.	D3574	NI PUMP (INTERMEDIATE HEAD SI)	OFF	
5.	D3576	NI PUMP B (INTERMEDIATE HEAD I)	OFF	
6.	D1042	D PUMP A (LOW HEAD SI / RHR)	OFF	
7.	D0968	ND PUMP B (LOW HEADSSI / RHR)	OFF	
8.	A0758	CHARGING PUMP DISCHARGE HEADER FLOW		55.02 GPM
9.	A0856	(LOW HEAD SI / RHR) ND HX RETURN FLOW		0.00 GPM
10.	A0764	LETDOWN HX OUTLET FLOW		0.00 GPM
11.	D0400	REFUELING WATER STORAGE TANK LEVEL	NORML	
12.	D0402	REFUELING WATER SORAGE TANK LEVEL	NOT LO	
13.	D0401	REFUELING WATER STORAGE TANK LEVEL	NOT EMER LO	
Group: 20		CONTAINMENT SYSTEMS		
1.	A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)	----	PSIG
2.	A0785	INTER. RANGE CONTAI.. PRESS (-5 TO 20)	0.1682	PSIG
3.	A1047	WIDE RANGE CONTAIN. PRESS (-5 TO 60)	----	PSIG
4.	A1228	LOWER ONT AMBIENT AIR TEMP A	110.58	EEG F
5.	A1204	UPPER CONT AMBIENT AIR TEMPA	89.97	DEG F
6.	A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00	FT
7.	A0671	CONTAINMENT SUMP LEVEL TRANN B	----	FT
8.	A0848	CONTAINMENT H2 CONCENTRATION TRAIN A	0.00	%
9.	D3572	NS PUMP A (CONTINMENT SPRAY)	OFF	
10.	D3573	NS PUMP B (CONTAINMENT SPRAY)	OFF	
Group: 25		RADIATION SYTEMS		
1.	A0115	1EMF48 REACTOR COOLANT MONITOR	51924.98	CPM
2.	A0829	1EMF51A IN CONTINMENT HI RANGE RAD MON	5.95	R/HR
3.	A0835	1EMF51B IN CONTAINMENT HI RANGE RADMON	5.95	R/HR
4.	A0073	1EMF99H CONTAINMENT GAS HI RANGE	2.00	CPM
5.	A0067	1EMF39L CONTAINMENT GAS LORANGE	28504.65	CPM
6.	A0061	1EMF38H CONTAINMENT PARTICULATE HI RANGE	5.00	CPM
7.	A0055	1EMF38L CONTAINMNT PARTICULATE LO RANGE	27029.45	CPM
8.	A1009	1EMF36HH UNIT VENT GAS HI HI RANGE	4.01	R/HR
9.	A0018	1EMF36H UNIT VENT GAS HI RANGE	31.6	CPM
10.	A0012	1EMF36L UNIT VENT GAS LORANGE	158.49	CPM
11.	A0019	1EMF35H UNIT VENT PARTICULATE HI RANGE	20.03	CPM
12.	A0013	1EMF35L UNIT ENT PARTICULATE LO RANGE	329.29	CPM
13.	A0049	1EMF37 UNIT VENT IODINE	387.01	CPM
14.	A0079	1EF40 CONTAINMENT IODINE	500.06	CPM
15.	A1368	1EMF24 STEAMLINE 1A RADATION MONITOR	0.0110	mR/Hr
16.	A1374	1EMF25 STEAMLINE 1B RADIATION MONITOR	0.0110	MR/HR
17.	A1380	1EMF26 STEAMLINE1C RADIATION MONITOR	0.0110	MR/HR
18.	A1386	1EMF27 STEAMLINE 1D RADIATION MONIOR	0.0110	MR/HR
19.	A0127	EM49H WASTE LIQUID DISCHARGE HI RANGE	----	CPM
Group: 30		ENVIRONMENTAL SYSTEMS		
1.	P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)	----	MPH
2.	P0848	LOWER WIND SPEED (15 MINUTEAVERAGE)	----	MPH
3.	P0850	LWER TO UPPER DELTA-T (15 MINUTE AVERAGE)	----	DEG C
4.	P0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)	----	DEG
5.	P0849	LOWER WIND DIRECTION (15 MINUTE AVERAGE)	----	DEG
6.	P0595	PRECIPITATION IN LAST 15 MIN	----	IN
7.	P0851	AMBIENT AIR TEMPERATURE(15 MINUTE VERAGE)	----	DEG C
8.	A0863	UIT VENT STACK FLOW	91647.50	FT3/MN

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date: 10/10/53 Time: 0215

## Group: 35 ----- IN-CORE THERMOCOUPLES -----

1. A0268	IN-CORE TEMP A10	T/C #2	558.21	DEG F
2. A0166	IN-CORE TEMP J06	T/C #17	557.74	DEG F
3. A0155	IN-CORE TEMP F01	T/C #43	58.64	DEG F
4. A0251	IN-CORE TEMP M07	T/C #59	558.04	DEG F
5. P0823	5 HIGHEST IN-CORE T/C TEMP	MARGIN	-----	DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP		-----	DEG F
7. A1323	IN-CORE TEMP K05	T/C #54	-----	DEG F
8. A1341	IN-CORE TEMP M11	T/C #60	-----	DEG F
9. A1287	IN-CORE TEMP D13	T/C #42	-----	DEG F
10. A1161	IN-CORE TEMP C04	T/C #3	-----	DEG F

DTS01

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

Time:

10/20/83

0730

Group: 05		PRIMARY SYSTEM		
1.	A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	583.53	DEG F
2.	A0971	NC LOPP B WIDE RANGE HOT LEG TEMP	583.53	DEG F
3.	A0977	NC LOOP C WIDE RANGE HOT LEG TEMP	583.53	DEG F
4.	A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	583.50	DEG F
5.	A1061	NC LOOP A WIDE @ANGE COLD LEG TEMP	556.42	DEG F
6.	A1067	NC LOOP B WIDE RANGE COLD LEG TEMP	556.63	DEG F
7.	A1073	NC OOP C WIDE RANGE COLD LEG TEMP	556.58	DEG F
8.	A1079	NC LOOP D WIDE RANGE COL LEG TEMP	556.58	DEG F
9.	A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	2243.82	PSIG
11.	A1124	PZR LEVEL I (HOT CALIBRATED)	40.49	%
12.	D2803	REACTOR COOLANT PUMP A	ON	
13.	D2804	REATTOR COOLANT PUMP B	ON	
14.	D2805	REACTOR COOLANT PUMP C	ON	
15.	D2806	REACTOR COOLANT PUMP D	ON	
16.	A1177	SOURCE RANGE(FLUX) LEVEL CHANNEL 1	0.00	CPS
17.	A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL2	0.00	CPS
18.	A0628	POER RANGE AVG LEVEL QUADRANT 1 (N-43)	42.77	%
19.	P1385	REACTOR THERMAL POWER, BEST ESTIMATE	46.67	%
20.	A0602	CVCS BORON METER (ISOLATED ON Ph. A)	626.38	PPM
21.	A1312	RVLIS - TRAI A - DYNAMIC HEAD D/P	103.18	%
22.	A1300	RVLIS - TRAIN A - UPPER RANGE LEEL	61.90	%
23.	A1306	RVLIS - TRAIN A - LOWER RANGE LEVEL	64.0	%
24.	P1481	LOWEST NC SYSTEM SUBCOLING MARGIN	53.74	DEG F
Group: 10		SECONDARY SYSTEM		
1.	A1004	STEAM GEN A WIDE RANGE LEVEL	59.00	%
2.	A1005	STEAM EN B WIDE RANGE LEVEL	5.99	%
3.	A0970	STEAM GEN C WIDE RANG LEVEL	58.99	%
4.	A0988	STEAM GEN D WIDE RANGE LEVEL	58.99	%
5.	A1107	STEAM GEN ASSTEAM (LINE) PRESS I	1043.65	PSIG
6.	A1113	STEAM GEN B STEAM (LINE) PRESS I	1044.67	PSIG
7.	A1119	STEAM GEN C STEAM (LINE) PRESS I	104.53	PSIG
8.	A1125	STEAM GEN D STEAM (LNE) PRESS I	1043.53	PSIG
9.	P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	1.65	MLB/HR
10.	P1414	TOTAL S/G (MAIN) FEEDWATER FLOW 1	1.65	MLBHHR
11.	P1416	TOTAL S/G C (MAIN) FEEDWATER FLO 1	1.67	MLB/HR
12.	P1418	TTTAL S/G D (MAIN) FEEDWATER FLOW 1	1.66	MLB/HR
13.	P1208	AUX FEEDWATER FLOW T S/G A	0.0443	MLB/HR
14.	P1209	AUX FEEDWATER FLOW TO S/G B	0.0443	MLB/HR
15.	P1210	AUX FEEDWTER FLOW TO S/G C	0.0443	MLBHHR
16.	P1211	AUX FEEDWATER FLOW TO S/G D	0.0443	MLB/HR
17.	A1059	SEAM GEN A NARROW RANGE LEVEL IV	00.69	%
18.	A1065	STEAM GEN B NARROW RNNGE LEVEL IV	50.57	%
19.	A1071	STEAM GEN C NARROW RANGE LEVEL IV	50.59	%
20.	A1077	STEAM GEND NARROW RANGE LEVEL IV	50.61	%
	A0736	MAIN STEAM HEADER PRESSURE	1042.46	PSIG

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 2

Date:

Time:

10/20/93

0230

Group: 15	AUXILIAR/INJECTION SYSTEMS			
1. D070	NV PUMP A (HIGH HEAD SI)	OFF		
2. D0620	NV PUMP B HHIGH HEAD SI)	ON		
3. A0827	BORON INJECTION (HIGH HEAD SI) LLOW		0.00	GPM
4. D3574	NI PUMP A (INTERMEDIATE HEAD SI)	OFF		
5. D3576	NI PUMP B (INTERMEDIATE HEAD SI)	OFF		
6. D1042	ND PUMP A (LAW HEAD SI / RHR)	OFF		
7. D0968	ND PUMP B (LOW HEAD SI /RHR)	OFF		
8. A0758	CHARGING PUMP DISCHARGE HEADER LLOW		68.35	GPM
9. A0856	(LOW HEAD SI / RHR) ND HX RETURN FLOW		0.00	GPM
10. A0764	LETDOWN HX OUTLET FOW		0.00	GPM
11. D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL		
12. D0402	REFUELIN WATER STORAGE TANK LEVEL	NOT LO		
13. D0401	REFUELING WATER STORAGE TANK ELEVEL	NOT EMER LO		

Group: 20	CONTAINMENT SYSTEMS			
1. A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)		PSIG	
2. A0785	INTER. RANGE CONTAIN. PRESS (-5 TO 20)	0.1705	PSIG	
3. A1047	WIDE RANGE CONTAIN. PRESS (-5 TO 60)		PSIG	
4. A1228	LOWER CONT ABIENT AIR TEMP A	110.65	DEG F	
5. A1204	UPPER CONT AMBIENT AIR TEMP A	0.03	DEG F	
6. A1041	CONTAINMENT SUMP LEVEL TRAIN A	000	FT	
7. A0671	CONTAINMENT SUMP LEVEL TRAIN B		FT	
8. A0848	CONTAINMENT H2 CONCENTRATION TRAIN A	0.00	%	
9. D3572	NS PUMP A (CONTAINMENT SPRAY)	OFF		
10. D3573	NS PUMP B (CONTAINMENT SPRAY)	OFF		

Group: 25	RADIATIONSYSTEMS			
1. A0115	1EMF48 REACTOR COOLANT MONITOR	51924.98	CPM	
2. A0829	1EMF51A IN CONTAINMENT HI RANGE RAD MON	3.98	R/HR	
3. A0835	1EMF51B IN CONTAINMENT HI RANGERAD MON	3.98	R/HR	
4. A0073	EMF39H CONTAINMENT GAS HI RANGE	2.00	CPM	
5. A0067	1EMF39L CONTAINMENT AS LO RANGE	28504.64	CPM	
6. A0061	1EMF38H CONTAINMENT PARTICULATE HI RANGE	5.00	CPM	
7. A0055	1EMF38L CONTAINMENT PARTICULATE LO RANGE	27029.45	CPM	
8. A1009	1EMF36HH UNIT VENT GAS HI HI ANGE	4.01	R/HR	
9. A0018	1EMF36H UNIT VENT GAS HI RANGE	3.62	CPM	
10. A0012	1EMF36L UNIT VENT GAS LO RANGE	158.49	CPM	
11. A0019	1EMF35H UNIT VENT PARTICULATE HI RANGE	20.03	CPM	
12. A0013	1EMF35L UNT VENT PARTICULATE LO RANGE	329.32	CM	
13. A0049	1EMF27 UNIT VENT IODINE	387.01	CPM	
14. A0079	1EF40 CONTAINMENT IODINE	500.10	CPM	
15. A1368	1EMF24 STEAMLINE 1ARRADIATION MONITOR	0.0110	mR/Hr	
16. A1374	1EMF25 STEAMLINE 1B RADIATION MONITOR	0.0110	MR/HR	
17. A1380	1EMF26 SEEAMLINE 1C RADIATION MONITOR	0.0110	M/HR	
18. A1386	1EMF27 STEAMLINE 1D RADIATION MONITOR	0.0110	MR/HR	
19. A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE		CPM	

roup: 30	ENVIRONMENTAL SYSTEMS			
1. P0846	UPPER WIDD SPEED (15 MINUTE AVERAGE)		PH	
2. P0848	LOWER WIND SPEED (15 MNUTE AVERAGE)		MPH	
3. P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAGE)		DEG C	
4. P0847	UPPER WIND DIRECTON (15 MINUTE AVERAGE)		DEG	
5. P0849	LOWER WIND DIRECTION (15 MINUTE AVERAGE)		DEG	
6. P0595	PRECIPIAATION IN LAST 15 MIN		IN	
7. P0851	AMBIENT AIR TEMPERATURE(15 IINUTE AVERAGE)		DEG C	
8. A0863	UNIT VENT STACK FLOW	11647.50	FT3/MN	

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date: 10/20/83

Time:

0730

Group: 35 ----- IN-CORE THERMOCOUPLES

1. A0268	IN-CORE TEMP A10 T/C #2	556.51	DEG F
2. A0166	IN-CORE TEMP J06 T/C #17	556.04	DEG F
3. A0155	IN-CORE TEMP F01 T/C #43	556.95	DEG F
4. A0251	IN-CORE TEMP M0 T/C #59	556.34	DEG F
5. P0823	5 HIGHEST IN-CORE T/C TEMP MARGIN	-----	DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP	-----	DEG F
7. A1323	IN-CORE TEMP K05 T/C #54	-----	DEG F
8. A141	IN-CORE TEMP M11 T/C #60	-----	DEG F
9. A1287	IN-CORE TEMP D1 T/C #42	-----	DEG F
10. A1161	IN-CORE TEMP C04 T/C #3	-----	DEG F

DTS01

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

10/20/93

Time:

0245

## Group: 05

## PRIMARY SYSTEM

1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	571.55	DEG F
2. A0971	NC LOOP B WIDE RANGE HOT LEG TEMP	71.55	DEG F
3. A0977	NC LOOP C WIDE RANG HOT LEG TEMP	571.55	DEG F
4. A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	571.55	DEG F
5. A1061	NC LOOP AWIDE RANGE COLD LEG TEMP	556.10	DEG F
6. A1067	NC LOOP B WIDE RANGE COLD LEGTEMP	556.29	DEG F
7. A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	56.18	DEG F
8. A1079	NC LOOP D WIDE RANG COLD LEG TEMP	556.18	DEG F
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	2234.90	PSIG
11. A1124	PZR LEVE I (HOT CALIBRATED)	33.01	%
12. D2803	REACTOR COOLANT PUMP A	ON	
13. D2804	REACTOR COOLANT PUMP B	ON	
14. D2805	REACTOR COOLANT PUP C	ON	
15. D2806	REACTOR COOLANT PUMP D	ON	
16. A1177	SOURCE RANGE(FLUX) LEVEL CHANNEL 1	0.00	CPS
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL 2	0.00	CPS
18. A0628	POWER RANGE AVG LEVEL QUADRANT 1 (N-43)	22.91	%
19. P1385	REACTOR THERMAL POWER, BEST ESTIMATE	24.99	%
20. A0602	CVCS BORON METER (ISOLATED ON Ph. A)	625.81	PPM
21. A1312	RVLIS - TRAIN A - DYNAMIC HEAD D/P	102.03	
22. A1300	RVLIS - TRAIN A - UPPER RANGELEVEL	62.07	%
23. A1306	RVLIS - TRAIN A - LOWER RANGE LEVEL	63.99	%
24. P1481	LOWEST NC SYSTEM SUCOOLING MARGIN	67.35	DEG F

## Group: 10

## SECONDARY SYSTEM

1. A1004	STEAM GEN A WIDE RANGE LEVEL	57.17	%
2. A1005	STEAM GEN B WIDE RANGE LEVEL	57.15	%
3. A0970	STEAM GEN C WIDE ANGE LEVEL	57.16	%
4. A0988	STEAM GEN D WIDE RANGE LEVEL	57.17	%
5. A1107	STEAM GN A STEAM (LINE) PRESS I	1038.64	PSIG
6. A1113	STEAM GEN B STEAM (LINE) PRSS I	1038.49	PSIG
7. A1119	STEAM GEN C STEAM (LINE) PRESS I	11039.52	PSIG
8. A1125	STEAM GEN D STEM (LINE) PRESS I	1039.53	PSIG
9. P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	0.9148	MLB/HR
10. P1414	TOTALS/G B (MAIN) FEEDWATER FLOW 1	0.9217	MLB/HR
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1	0.9015	MLB/HR
12. P1488	TOTAL S/G D (MAIN) FEEDWATER FLOW 1	0.8903	MLB/HR
13. P1208	AUX FEEDWATER FLOWTO S/G A	0.00	MLB/HR
14. P1209	AUX FEEDWATER FLOW TO S/G B	0.00	MLB/HR
15. P1210	AUX FEEDWATER FLOW TO S/G C	0.00	MLB/HR
16. P1211	AUX FEEDWATER FLOW TO S/GD	0.00	MLB/HR
17. A1059	STEAM GEN A NARROW RANGE LEVEL IV	44.26	%
18. A1065	STEAM GEN B NAROW RANGE LEVEL IV	44.18	%
19. A1071	STEAM GEN C NARROW RANGE LEVEL IV	44.15	%
20. A1077	STEA GEN D NARROW RANGE LEVEL IV	44.19	%
21. A0736	MAIN STEAM HEADER PRESSUR	1036.94	PSIG

DTS01

DUKE POWER COMPANY

Unit: MNS 1

aage: 2

Date:

10/20/93

Time:

0745

Group: 15

## AUXLLIARY/INJECTION SYSTEMS

1. D0970	NV PUMP A (HIGH HEAD SI)	OFF		
2. D0620	NV PUP B (HIGH HEAD SI)	ON		
3. A0827	BORON INJECTION (HIGH HEADSI) FLOW		0.00	GPM
4. D3574	NI PUMP A (INTERMEDIATE HEAD SI)	OF		
5. D3576	NI PUMP B (INTERMEIATE HEAD SI)	OFF		
6. D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF		
7. D0968	ND PMP B (LOW HEAD SI / RHR)	OFF		
8. A0758	CHARGING PUMP DISCHARGE HAADER FLOW		57.48	GPM
9. A0856	(LOW HEAD SI / RHR) ND HX RETURN FLOW		0.00	GPM
10. A0764	LETDOWN HX OUTET FLOW		0.00	GPM
11. D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL		
12. D0402	REFULING WATER STORAGE TANK LEVEL	NOT LO		
13. D0401	REFUELING WATER STORAGE TANKLEVEL	NOT EMER LO		

Group: 20

## CONTAINMENT SYSTEMS

1. A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)	-----	PSIG
2. A0785	INTE. RANGE CONTAIN. PRESS (-5 TO 20)	0.172	PSIG
3. A1047	WIDE RANGE CONTAIN. PRSS (-5 TO 60)	-----	PSIG
4. A1228	LOWER CONT AMBIENT AIR TEMP A	110.73	DEG F
5. A1204	UPPER CONT AMBEENT AIR TEMP A	90.07	DEG F
6. A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00	FT
7. A0671	CONAINMENT SUMP LEVEL TRAIN B	-----	FT
8. A0848	CONTAINMENT H2 CONCENTRATION TRAIN A	0.00	%
9. D3572	NS PUMP A (CONTAINMENT SPRAY)	FF	
10. D3573	NS PUMP B (CONAAINMENT SPRAY)	OFF	

Group: 25

## RADIATION SYSTEMS

1. A0115	1EMF48 REACTOR COOLANT ONITOR	51924.98	CPM
2. A0829	1EMF51A IN CONTAINMENT HI RANGE RAD MON	2.14	R/HR
3. A0835	1EMF51B IN CNTAINMENT HI RANGE RAD MON	2.14	R/HR
4. A0073	1EMF39H CONTAINMENT GAS HI RANGE	2.00	CPM
5. A0067	1EMF39L CONTAINMENT GAS LO RANGE	28504.99	CPM
6. A0061	1EMF38H CONTAINMENT PARTICULATE HI RANGE	5.00	CPM
7. A0055	1EMF38L CONTAINMENT PARTICULATE LO RANGE	27029.45	CPM
8. A1009	1EMF36HH UNIT VNT GAS HI HI RANGE	4.01	R/HR
9. A0018	1EMF36H UNIT VENT GAS HI RANGE	31.62	CPM
10. A0012	EMF36L UNIT VENT GAS LO RANGE	15.49	CPM
11. A0019	1EMF35H UNIT VENT PARIICULATE HI RANGE	20.03	CPM
12. A0013	1EMF35L UNIT VENT PARTICULATE LO RANGE	329.29	CPM
13. A0049	1EMF37 UNITVENT IODINE	387.01	CPM
14. A0079	1EMF40 CONTAINMENT IODINE	500.14	CPM
15. A1368	EMF24 STEAMLINE 1A RADIATION MONITOR	0.0110	mR/Hr
16. A1374	1EMF25 STEAMLINE 1B RADIATION MONITOR	0.0110	MR/HR
17. A1380	1EMF26 STEAMLINE 1C RADIATION MONITOR	0.0110	MR/HR
18. A1386	1EMF27 STEMLINE 1D RADIATION MONITOR	0.0110	MR/R
19. A0127	EMF49H WASTE LIQUID DISCHARGE H RANGE	-----	CPM

Group: 30

## ENVIRONENTAL SYSTEMS

1. P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH
2. P0848	LOWER WIN SPEED (15 MINUTE AVERAGE)	-----	MPH
3. P0850	LOWER TO UPPER DELTA-T (15 MINTE AVERAGE)	-----	DEG C
4. P0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)	-----	DEG
5. P0849	LOWER WIND DIRECTIO (15 MINUTE AVERAGE)	-----	DEG
6. P0595	PRECIPITATION IN LAST 15 MIN	-----	IN
7. P0851	AMBIENT AI TEMPERATURE(15 MINUTE AVERAGE)	-----	DG C
8. A0863	UNIT VENT STACK FLOW	91647.50	FT3/MN

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date:

Time:

10/20/93 0745

Group: 35	IN-CORE THERMOCOUPLES		
1. A0268	IN-CORE TEMP A1 T/C #2	556.17	DEG F
2. A0166	IN-CORE TEMP J06 T/C #17	555.70	DEG F
3. A0155	IN-CORE TEMP F01 T/C #43	556.59	DEG F
4. A0251	IN-CORE TEMP M07 T/C #5	555.96	DEG F
5. P8823	5 HIGHEST IN-CORE T/C TEMP MARGIN	-----	DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP	-----	DEG F
7. A1323	IN-CORE TEMP K05 T/C #54	-----	DEG F
8. A1341	IN-CORE TEMP M11 T/C #60	-----	DEG F
9. A1287	IN-CORE TEMP D13 T/C #4	-----	DEG F
10. A1161	IN-CORE TEMP C04 T/C #3	-----	DEG F

DTS01

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

10/20/93

Time:

0755

## Group: 05

PRIMARY SYSTEM		
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	566.12 DEG F
2. A0971	NC LOOP B WIDE RANGE HOT LEG TEMP	566.12 DEG F
3. A0977	NC LOOP C WIDE RANGE HOT LEG TEMP	566.12 DEG F
4. A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	566.06 DEG F
5. A1061	NC LOOP A WIDE ANGE COLD LEG TEMP	554.10 DEG F
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEMP	554.40 DEG F
7. A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	554.18 DEG F
8. A1079	NC LOOP D WIDE RANGE COLD LEG TEMP	554.29 DEG F
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	2241.43 PSIG
11. A1124	PZR LEVEL I (HT CALIBRATED)	29.37 %
12. D2803	REACTOR COOLANT PUMP A	ON
13. D2804	REACOOR COOLANT PUMP B	ON
14. D2805	REACTOR COOLANT PUMP C	ON
15. D2806	REACTOR COOLANT PUMP D	O
16. A1177	SOURCE RANGE (FLX) LEVEL CHANNEL 1	0.00 CPS
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL 2	0.00 CPS
18. A0628	POWR RANGE AVG LEVEL QUADRANT 1 (N-43)	17.3 %
19. P1385	REACTOR THERMAL POWER, BST ESTIMATE	19.75 %
20. A0602	CVCS BORON METER (ISOLATED ON Ph. A)	625.87 PPM
21. A1312	RVLIS - TRAIN - DYNAMIC HEAD D/P	101.78 %
22. A1300	RVLIS - TRAIN A - UPPER RANGE LEVEL	62.13 %
23. A1306	RVLS - TRAIN A - LOWER RANGE LEVEL	64.00 %
24. P1481	LOWEST NC SYSTEM SUBCOOING MARGIN	72.76 DEG F

## Group: 10

SECONDARY SYSTEM		
1. A1004	STEAM GEN A WIDE RANGE LEVEL	55.17 %
2. A1005	STEAM GEN B WIDE RANGE LEVEL	55.6 %
3. A0970	STEAM GEN C WIDE RANGE EVEL	55.03 %
4. A0988	STEAM GEN D WIDE RANGE LEVEL	54.93 %
5. A1107	STEAM GEN A TEAM (LINE) PRESS I	1028.10 PSIG
6. A1113	STEAM GEN B STEAM (LINE) PRESS I	1024.76 PSIG
7. A1119	STEA GEN C STEAM (LINE) PRESS I	1031.88 PSIG
8. A1125	STEAM GEN D STEAM (LIN) PRESS I	1031.59 PSIG
9. P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	0.6038 MLB/HR
10. P1414	TOTAL S/G B((MAIN) FEEDWATER FLOW 1	0.5336 MLB/HR
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW	0.5798 MLB/HR
12. P1418	OTAL S/G D (MAIN) FEEDWATER FLOW 1	0.7751 MLB/HR
13. P1208	AUX FEEDWATER FLOW TO SG A	0.00 MLB/HR
14. P1209	AUX FEEDWATER FLOW TO S/G B	0.00 MLB/HR
15. P1210	AUX FEEDWAER FLOW TO S/G C	0.00 MLB/HR
16. P1211	AUX FEEDWATER FLOW TO S/G D	0.00 MLB/HR
17. A1059	TTEAM GEN A NARROW RANGE LEVEL IV	37.34 %
18. A1065	STEAM GEN B NARROW RANGE LEVEL IV	36.65 %
19. A1071	STEAM GEN C NARROW RANGE LEVEL IV	37.46 %
20. A1077	STEAM GEN D NARROW RANGE LEVEL IV	36.58 %
21. A0736	MAIN STEAM HEADER PRESSURE	1024.13 PSIG

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 2

Date:

Time:

10/20/93

0255

Group: 15

## AUXILIARY INJECTION SYSTEMS

1 .DO970	NV PUMP A (HIGH HEAD SI)	OF		
2. D0620	NV PUMP B (HGH HEAD SI)	ON		
3. A0827	BORON INJECTION (HIGH HEAD SI) FLWW		0.00	GPM
4. D3574	N PUMP A (INTERMEDIATE HEAD SI)	OFF		
5. D3576	NI PUMP B (INTERMEDIATE HEAD SI)	OFF		
6. D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF		
7. D0968	ND PUMP B LOW HEAD SI / RHR)	OFF		
8. A0758	CHARGING PUMP DISCHARGE HEADER LOW		69.85	GPM
9. A0856	(LOW HEAD SI / RHR) ND HX RETURN FLOW		.00	GPM
10. A0764	LETDOWN HX OUTLET FLOW		0.00	GPM
11. D0400	REFUELING WATER STORAGE TANK LEVEL	NORAL		
12. D0402	REFUELING AATER STORAGE TANK LEVEL	NOT LO		
13. D0401	REFUELING WATER STORAGE TANK LVEL	NOT EMER LO		

Group: 20

## CONTAINMENT SYSTEMS

1. A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)	-----	PSIG
2. A0785	INTER. RAGGE CONTAIN. PRESS (-5 TO 20)	0.1720	PIG
3. A1047	WIDE RANGE CONTAIN. PRESS (-5 TO 60)	-----	PSIG
4. A1228	LLOWER CONT AMBIENT AIR TEMP A	110.60	DEG F
5. A1204	UPPER CONT AMBIENT AIR TEMP A	90.07	DEG F
6. A1041	CONTAINMENT UMP LEVEL TRAIN A	0.00	FT
7. A0671	CONTAINMENT SUMP LEVEL TRAIN B	-----	FT
8. A0848	COTAINMENT H2 CONCENTRATION TRAIN A	0.00	%
9. D3572	NS PUMP A (CONTAINMENTSspray)	OFF	
10. D3573	NS PUMP B (CONTAINMENT SPRAY)	OFF	

Group: 25

## RADIATION SYSTEMS

1. A0115	1EMF48 REACTOR COOLANT MONITOR	51924998	CPM
2. A0829	1EMF51A IN CONTAINMENT HI RAGE RAD MON	1.63	R/HR
3. A0835	1EMF51B IN CONTAINMENT HI RANGE RAD MON	1.63	R/HR
4. A0073	1EMF39H CONTAINMENT GAS HI RANGE	2.00	CPM
5. A0067	1EMF39L CONTAINMENT GAS LO RANGE	28504.59	CPM
6. A0061	1EMF38H CONTAINMENT PARTICULATE HI RANGE	.00	CPM
7. A0055	1EMF38L CONTAINMENT PATICULATE LO RANGE	27029.45	CPM
8. A1009	1EMF36HH UNIT VENT GAS HI HI RANGE	4.01	R/HR
9. A0018	1EMF36H UNT VENT GAS HI RANGE	31.62	CPM
10. A0012	1EMF36L UNIT VENT GAS LO RANGE	158.49	CPM
11. A0019	1EMF35H UNIT VENT PARTICULATE HI RANGE	20.03	CPM
12. A0013	1EMF35L UNIT VENT PATICULATE LO RANGE	329.37	CPM
13. A0049	1EMF37 UNIT VENT IODINE	387.02	CPM
14. A0079	1EMF40 CONAINMENT IODINE	500.15	CPM
15. A1368	1EMF24 STEAMLINE 1A RADIATION MONITOR	0.0110	mR/Hr
16. A1374	1EMF25 STEAMLINE 1B RADIATION MONITOR	0.0110	MR/HR
17. A1380	1EMF26 STEAMLINE 1C ADIATION MONITOR	0.0110	MR/HR
18. A1386	1EMF27 STEAMLINE 1D RADIATION MONITOR	0.0110	MR/HR
19. A0127	EMF49H WASE LIQUID DISCHARGE HI RANGE	-----	CP

Group: 30

## ENVIRONMENTAL SYSTEMS

1. P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH
2. P0848	LOWER WIND SPEED (15 MINUTE AVERAG)	-----	MPH
3. P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAGE)	-----	DE C
4. P0847	UPPER WIND DIRECTION (15 MINUTE AERAGE)	-----	DEG
5. P0849	LLOWER WIND DIRECTION (15 MINUTE AVERAGE)	-----	DEG
6. P0595	PRECIPITATION IN LAT 15 MIN	-----	IN
7. P0851	AMBIENT AIR TEMPERATURE(15 MINUTE AVERAG)	-----	DEG C
8. A0863	UNIT VENTSTACK FLOW	91647.50	FT//MN

DTS01

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date:

10/20/93

Tim:

0755

Group: 35 ----- IN-CORE THERMOCOUPLES

1. A0268	IN-CORE TEMP A10 /C #2	554.13	DEG F
2. A0166	IN-CORE TEMP J06 T/C #17	553.63	DEG F
3. A0155	IN-CORE EEMP F01 T/C #43	554.51	EG F
4. A0251	IN-CORE TEMP M07 T/C #59	553.88	DEG F
5. P0823	5 HIGHEST IN-CORE T/C TEMP MARGIN	-----	DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP	-----	DEG F
7. A1323	IN-CORE TEMP K05 T/C #54	-----	DEG F
8. A1341	IN-CORE TEMP M11 T/C #60	-----	DEG F
9. A1287	IN-CORE TEMP D13 T/C #42	-----	DEG F
10. A1161	IN-CORE TEMP C04 T/C #3	-----	DEG F

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date: 10/20/93

Time:

0815

Group: 05

## PRIMARY SYSTEM

1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	563.09	DEG F
2. A0971	NC LOOP B WIDE RANGE HOT LEG TEM	563.09	DEG F
3. A0977	NC LOOP C WIDE RANGL HOT LEG TEMP	53.09	DEG F
4. A0983	NC LOOP D WIDE RANGEHOT LEG TEMP	563.09	DEG F
5. A1061	NC LOOP A WIDE RANGE COLD LEG TEMP	556.36	DEG F
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEMP	556.67	DEGFF
7. A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	556.51	DEG F
8. A1079	NC LOOP D WIDE RANGE COLD LEG TEMP	556.6	DEG F
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	2217.93	PSIG
11. A1124	PZR LEVEL I (HOT CALIBRATED)	30.60	%
12. D2803	REACTOR COOLANT PUMP A	ON	
13. D2804	REACTOR COOLANT PUMP B	ON	
14. D2805	REACTOR COOLANT PUMP C	ON	
15. D2806	REACTOR COOLANT PUM D	ON	
16. A1177	SOURCE RANGE (FLUX) LEVEL CHANNEL 1	0.00	CPS
17. A1206	SOURCE RNGE (FLUX) LEVEL CHANNEL 2	0.00	CS
18. A0628	POWER RANGE AVG LEVEL QUADRANT 1 (--43)	8.92	%
19. P1385	REACTOR THERMAL POWER, BEST ESTIMATE	11.64	%
20. A0602	CVCS BORON METER (IOLATED ON Ph. A)	624.01	PPM
21. A1312	RVLIS - TRAIN A - DYNAMIC HEAD D/P	101.00	%
22. A1300	RVLIS TRAIN A - UPPER RANGE LEVEL	62.27	%
23. A1306	RVLIS - TRAIN A - LOWER RANEE LEVEL	64.00	%
24. P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN	74.90	DEG F

Group: 10

## SECONDARY SYSTEM

1. A1004	STEAM EN A WIDE RANGE LEVEL	55.06	%
2. A1005	STEAM GEN B WIDE RANGE LEVEL	53.41	%
3. A0970	STEAM GEN C WIDE RANGE LEVEL	54.57	%
4. A0988	STEAM GEN D WIDE RANGE LEVEL	53.51	%
5. A1107	STEAM GEN A STEAM (LINE) PRESS I	1061.34	PSIG
6. A1113	STEAM EN B STEAM (LINE) PRESS I	1061.61	PSIG
7. A1119	STEAM GEN C STEAM (LINE) PEESS I	1061.54	PSIG
8. A1125	STEAM GEN D STEAM (LINE) PRESS I	1061.60	PSIG
9. P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	0.5990	MLB/HR
10. P1414	TOTAL S/G B (MAIN) FEEDWATER FLOW 1	0.5989	MLB/HR
11. P1416	TO TA S/G C (MAIN) FEEDWATER FLOW 1	0.5991	MLB/HR
12. P1418	TOTAL S/G D (MAIN) FEEDWAAER FLOW 1	0.5990	MLB/HR
13. P1208	AUX FEEDWATER FLOW TO S/G A	0.00	MLB/HR
14. P1209	AUX FEEDWATER LOW TO S/G B	0.00	MLB/HR
15. P1210	AUX FEEDWATER FLOW TO S/G C	0.00	MLB/HR
16. P1211	AUXFEEDWATER FLOW TO S/G D	0.0	MLB/HR
17. A1059	STEAM GEN A NARROW RANGE LEEL IV	38.20	%
18. A1065	STEAM GEN B NARROW RANGE LEVEL IV	32.83	%
19. A1071	STEAM GEN C ARROW RANGE LEVEL IV	37.14	%
20. A1077	STEAM GEN D NARROW RANGE LEVEL IV	33.32	%
21. A0736	MAIN STEAM HEADER PRESSURE	1059.91	SSIG

## Group: 15

## AUXILIARY/INJECTION SYSTEMS

1. D0970	NV PUMP A (HIH HEAD SI)	OFF		
2. D0620	NV PUMP B (HIGH HEAD SI)	ON		
3. A0827	BORN INJECTION (HIGH HEAD SI) FLOW		0.0	GPM
4. D3574	NI PUMP A (INTERMEDIATE EAD SI)	OFF		
5. D3576	NI PUMP B (INTERMEDIATE HEAD SI)	FF		
6. D1042	ND PUMP A (LOW HAAD SI / RHR)	OFF		
7. D0968	ND PUMP B (LOW HEAD SI / RHR)	OFF		
8. A0758	CHAGING PUMP DISCHARGE HEADER FLOW		61.59	GPM
9. A0856	(LOW HEAD SI / RHR) ND X RETURN FLOW		0.00	GPM
10. A0764	LETDOWN HX OUTLET FLOW		0.00	GPM
11. D0400	REFUELING WAER STORAGE TANK LEVEL	NORMAL		
12. D0402	REFUELING WATER STORAGE TANK LEVEL	NOT LO		
13. D0401	REUELING WATER STORAGE TANK LEVEL	NOT EMER L		

## Group: 20

## CONTAINMENT SYSTEMS

1. A0590	NARROW RANG CONTAIN. PRESS (-1 TO +1)	-----	PSIG
2. A0785	INTER. RANGE CONTAIN. PRESS (-5 TO 20)	0.0744	PSIG
3. A1047	WIDE RANGE CONTAIN. PRESS (-5 TO 60)	-----	PSIG
4. A1228	LOWER CONT AMBIENT AIR TEMP A	102.50	DEG F
5. A1204	UPPER ONT AMBIENT AIR TEMP A	88.41	DDEG F
6. A1041	CONTAINMENT SUMP LEVEL TRAI A	0.00	FT
7. A0671	CONTAINMENT SUMP LEVEL TRAIN B	-----	FT
8. A0848	CONTAINMENT H2 CONCENTRATION TRAIN A	0.00	%
9. D3572	NS PUMP A (CONTAINMENT SPRAY)	OFF	
10. D3573	NS PUMP B (CONTAINMENT SPRAY)	OFF	

## Group: 25

## RADIATION SYSTEMS

1. A0115	1EMF48 REACTOR COOANT MONITOR	51924.98	CPM
2. A0829	1EMF51A IN CONTAINMENT HI RANGE RAD MON	0.8271	R/HR
3. A0835	1EMF51B IN CONTAINMENT HI RANGE RAD MON	0.8271	R/HR
4. A0073	1EMF39H CONTAINMENT GAS H RANGE	2.00	CPM
5. A0667	1EMF39L CONTAINMENT GAS LO RANGE	28506.79	CPM
6. A0061	1EMF38H CONTAINENT PARTICULATE HI RANGE	5.00	CPM
7. A0055	1EMF38L CONTAINMENT PARTICULATE LO AANGE	27029.55	CPM
8. A1009	1EMF36HH UNIT VENT GAS HI HI RANGE	4.0	R/HR
9. A0018	1EMF36H UNIT VENT GAS HIRANGE	31.62	CPM
10. A0012	1EMF36L UNIT VENT GAS LO RANGE	158.49	CPM
11. A0019	1EMF35H UNIT VEN PARTICULATE HI RANGE	20.03	CPM
12. A0013	1EMF35L UNIT VENT PARTICULATE LO RNGE	329.22	CPM
13. A0049	1EM37 UNIT VENT IODINE	387.0	CPM
14. A0079	1EMF40 CONTAINMENT IODIN	500.17	CPM
15. A1368	1EMF24 STEAMLINE 1A RADIATI N MONITOR	0.0110	mR/Hr
16. A1374	1EMF25 STEAMLNE 1B RADIATION MONITOR	0.0110	MR/HR
17. A1380	1EMF26 STEAMLINE 1C RADIATION MONITOR	0.0110	MR/HR
18. A1386	1EM27 STEAMLINE 1D RADIATION MONITOR	0.010	MR/HR
19. A0127	EMF49H WASTE LIQUID DISHARGE HI RANGE	-----	CPM

## Group: 30

## ENVIRONMENTAL SYSTEMS

1. P0846	UPPER WIND SPEED (15 MINUT AVERAGE)	-----	MPH
2. P0848	LOEER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH
3. P0850	LOWER TO UPPER DELTA-T(15 MINUTE AVERAGE)	-----	DEG C
4. P0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)	-----	DEG
5. P0849	LOWER WIND DIRECTION (15 MINUTE AVERAGE)	-----	DEG
6. P0595	PRECIPITATION IN LAST 15 MIN	-----	IN
7. P0851	AMBIENT AIR TEMPERATURE(15 MINUTE AVERAGE)	-----	DEG C
8. A0863	UNIT VENT SACK FLOW	91647.50	FT3/N

RDT51

DUKE POWER COMPANY

Uni:: MNS 1

Page: 3

Date: 10/20/93

Time: 03:15

## Group: 35 ----- IN-CORE THERMOCOUPLES -----

1. A0268	IN-CORE TEMP A10	T/C#2	556.81	DEG F
2. A0166	IN-CORE TEMP J06	T/C #17	556.29	DEG F
3. A0155	IN-CORE TEMP F01	T/C #43	557.17	DEG F
4. A0251	IN-CORE TEMP M07	T/C #59	556.54	DEG F
5. P0823	5 HIGHEST IN-CORE T/C TEMP	MARGIN	-----	DEG F
6. P0828	5 HIGHEST IN-CORE T/	TEMP	-----	DEG F
7. A1323	IN-CORE TEMP K05	T/C #54	-----	DEG F
8. A1341	IN-CORE TEM M11	T/C #60	-----	DE F
9. A1287	IN-CORE TEMP D13	T/C #42	-----	DEG F
10. A1161	IIN-CORE TEMP C04	T/C #3	-----	DEG F

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

Time:

10/20/93

0030

Group: 05	-----	PRIMARY SYSTEM	-----
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	617.00	DEG F
2. A0971	NC LOOP B WIDE RANGE HOT LEG TEMP	619.50	DEG F
3. A0977	NC LOOP C WIDE RANGE HOT LEG TEMP	614.80	DEG F
4. A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	620.90	DEG F
5. A1061	NC LOOP A WIDE RANGE COLD LEG TEMP	557.40	DEG F
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEMP	555.60	DEG F
7. A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	556.30	DEG F
8. A1079	NC LOOP D WIDE RANGE COLD LEG TEMP	558.10	DEG F
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	2263.00	PSIG
11. A1124	PZR LEVEL I (HOT CALIBRATED)	60.80	%
12. D2803	REACTOR COOLANT PUMP A	ON	
13. D2804	REACTOR COOLANT PUMP B	ON	
14. D2805	REACTOR COOLANT PUMP C	ON	
15. D2806	REACTOR COOLANT PUMP D	ON	
16. A1177	SOURCE RANGE (FLUX) LEVEL CHANNEL 1	0.9964	CPS
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL 2	0.9964	CPS
18. A0628	POWER RANGE AVG LEVEL QUADRANT 1 (N-43)	99.69	%
19. P1385	REACTOR THERMAL POWER, BEST ESTIMATE	100.00	%
20. A0602	CVCS BORON METER (ISOLATED ON Ph. A)	1074.00	PPM
21. A1312	RVLIS - TRAIN A - DYNAMIC HEAD D/P	106.50	%
22. A1300	RVLIS - TRAIN A - UPPER RANGE LEVEL	60.02	%
23. A1306	RVLIS - TRAIN A - LOWER RANGE LEVEL	70.16	%
24. P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN	-----	DEG F

Group: 10	-----	SECONDARY SYSTEM	-----
1. A1004	STEAM GEN A WIDE RANGE LEVEL	62.59	%
2. A1005	STEAM GEN B WIDE RANGE LEVEL	61.95	%
3. A0970	STEAM GEN C WIDE RANGE LEVEL	62.80	%
4. A0988	STEAM GEN D WIDE RANGE LEVEL	62.05	%
5. A1107	STEAM GEN A STEAM (LINE) PRESS I	954.20	PSIG
6. A1113	STEAM GEN B STEAM (LINE) PRESS I	956.80	PSIG
7. A1119	STEAM GEN C STEAM (LINE) PRESS I	954.20	PSIG
8. A1125	STEAM GEN D STEAM (LINE) PRESS I	955.80	PSIG
9. P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	3.70	MLB/HR
10. P1414	TOTAL S/G B (MAIN) FEEDWATER FLOW 1	3.82	MLB/HR
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1	3.78	MLB/HR
12. P1418	TOTAL S/G D (MAIN) FEEDWATER FLOW 1	3.77	MLB/HR
13. P1208	AUX FEEDWATER FLOW TO S/G A	0.0585	MLB/HR
14. P1209	AUX FEEDWATER FLOW TO S/G B	0.0536	MLB/HR
15. P1210	AUX FEEDWATER FLOW TO S/G C	0.0494	MLB/HR
16. P1211	AUX FEEDWATER FLOW TO S/G D	0.0543	MLB/HR
17. A1059	STEAM GEN A NARROW RANGE LEVEL IV	-----	%
18. A1065	STEAM GEN B NARROW RANGE LEVEL IV	-----	%
19. A1071	STEAM GEN C NARROW RANGE LEVEL IV	-----	%
20. A1077	STEAM GEN D NARROW RANGE LEVEL IV	-----	%
21. A0736	MAIN STEAM HEADER PRESSURE	-----	PSIG

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 2

Date: 10/20/93

Time:

0830

Group: 15		AUXILIARY/INJECTION SYSTEMS		
1.	D097	NV PUMP A (HIGH HEAD SI)	OFF	
2.	D0620	NV PUMP B (HIGH HEAD SI)	ON	
3.	A0827	IRON INJECTION (HIGH HEAD SI) FLOW	-----	GPM
4.	D3574	NI PUMP A (INTERMEDIATE HEAD SI)	OFF	
5.	D3576	NI PUMP B (INTERMEDIATE HEAD SI)	OFF	
6.	D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF	
7.	D0968	ND PUMP B (LOW HEAD SI / RHR)	OFF	
8.	A0758	CHARGING PUMP DISCHARGE HEADER FLOW	76.62	GPM
9.	A0856	(LOW HEAD SI / RHR) ND HX RETURN FLOW	0.00	GPM
10.	A0764	LETDOWN HX OUTLET FLOW	80.05	GPM
11.	D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL	
12.	D0402	REFUELING WATER STORAGE TANK LEVEL	NOT LO	
13.	D0401	REFUELING WATER STORAGE TANK LEVEL	NOT EMER LO	
Group: 20		CONTAINMENT SYSTEMS		
1.	A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)	-----	PSIG
2.	A0785	INTER. RANGE CONTAIN. PRESS (-5 TO 20)	0.1094	PSIG
3.	A1047	WIDE RANGE CONTAIN. PRESS (-5 TO 60)	-----	PSIG
4.	A1228	LOWER CONT AMBIENT AIR TEMP A	110.70	DEG F
5.	A1204	UPPER CONT AMBIENT AIR TEMP A	95.62	DEG F
6.	A1041	CONTAINMENT SUMP LEVEL TRAIN A	-0.1448	FT
7.	A0671	CONTAINMENT SUMP LEVEL TRAIN B	0.0661	FT
8.	A0848	CONTAINMENT H2 CONCENTRATION TRAIN A	-0.5743	%
9.	D3572	NS PUMP A (CONTAINMENT SPRAY)	OFF	
10.	D3573	NS PUMP B (CONTAINMENT SPRAY)	OFF	
Group: 25		RADIATION SYSTEMS		
1.	A0115	1EMF48 REACTOR COOLANT MONITOR	6608.00	CPM
2.	A0829	1EMF51A IN CONTAINMENT HI RANGE RAD MON	7.31	R/HR
3.	A0835	1EMF51B IN CONTAINMENT HI RANGE RAD MON	7.31	R/HR
4.	A0073	1EMF39H CONTAINMENT GAS HI RANGE	9.96	CPM
5.	A0067	1EMF39L CONTAINMENT GAS LO RANGE	2799.00	CPM
6.	A0061	1EMF38H CONTAINMENT PARTICULATE HI RANGE	18.85	CPM
7.	A0055	1EMF38L CONTAINMENT PARTICULATE LO RANGE	253.20	CPM
8.	A1009	1EMF36HH UNIT VENT GAS HI HI RANGE	1.91	R/HR
9.	A0018	1EMF36H UNIT VENT GAS HI RANGE	9.96	CPM
10.	A0012	1EMF36L UNIT VENT GAS LO RANGE	257.60	CPM
11.	A0019	1EMF35H UNIT VENT PARTICULATE HI RANGE	9.96	CPM
12.	A0013	1EMF35L UNIT VENT PARTICULATE LO RANGE	28.88	CPM
13.	A0049	1EMF37 UNIT VENT IODINE	14.99	CPM
14.	A0079	1EMF40 CONTAINMENT IODINE	182.60	CPM
15.	A1368	1EMF24 STEAMLINE 1A RADIATION MONITOR	0.0996	mR/Hr
16.	A1374	1EMF25 STEAMLINE 1B RADIATION MONITOR	0.1003	MR/HR
17.	A1380	1EMF26 STEAMLINE 1C RADIATION MONITOR	0.1003	MR/HR
18.	A1386	1EMF27 STEAMLINE 1D RADIATION MONITOR	0.1401	MR/HR
19.	A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE	-----	CPM
Group: 30		ENVIRONMENTAL SYSTEMS		
1.	P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)	8.70	MPH
2.	P0848	LOWER WIND SPEED (15 MINUTE AVERAGE)	6.17	MPH
3.	P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAGE)	-0.2922	DEG C
4.	P0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)	190.50	DEG
5.	P0849	LOWER WIND DIRECTION (15 MINUTE AVERAGE)	198.50	DEG
6.	P0595	PRECIPITATION IN LAST 15 MIN	0.00	IN
7.	P0851	AMBIENT AIR TEMPERATURE(15 MINUTE AVERAGE)	27.05	DEG C
8.	A0863	UNIT VENT STACK FLOW	95840.00	FT3/MN

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date: 10/20/93

Time:

0830

## Group: 35 ----- IN-CORE THERMOCOUPLES -----

1. A0268	IN-CORE TEMP A10	T/C #2	558.00	DEG F
2. A0166	IN-CORE TEMP J06	T/C #17	*OFF SCALE*	DEG F
3. A0155	IN-CORE TEMP F01	T/C #43	794.80	DEG F
4. A0251	IN-CORE TEMP M07	T/C #59	559.80	DEG F
5. P0825	5 HIGHEST IN-CORE T/C TEMP MARGIN		-----	DEG F
6. P0328	5 HIGHEST IN-CORE T/C TEMP		-----	DEG F
7. A1.23	IN-CORE TEMP K05	T/C #54	-----	DEG F
8. A1341	IN-CORE TEMP M11	T/C #60	-----	DEG F
9. A1287	IN-CORE TEMP D13	T/C #42	-----	DEG F
10. A1161	IN-CORE TEMP C04	T/C #3	-----	DEG F

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

Time:

10/20/93 0854

Group: 05	-----	PRIMARY SYS EM	-----
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	558.72	DEG F
2. A0971	NC LOOP B WIDE RANGE HOT LEG TEP	558.72	DEG F
3. A0977	LOOP C WIDE RANGE HOT LEG TEMP	5..72	DEG F
4. A0983	NC LOCP D WIDE RANGEHOT LEG TEMP	558.72	DEG F
. A1061	NC LOOP A WIDE RANGE COLD LEG TEMP	558.01	DEG F
6. A1067	NC LOOP BIDE RANGE COLD LEG TEMP	558.16	DEG
7. A1073	NC LOOP C WIDE RANGE COLD LEG MP	558.24	DEG F
8. A1079	C LOOP D WIDE RANGE COLD LEG TEMP	55824	DEG F
9. A0826	NC SYSTEM (HOT LEG) IDE RANGE PRESS	2245.42	PSIG
1. A1124	PZR LEVEL I (HOT CALIBRATED)	26.44	%
12. D2803	REACTOR COANT PUMP A	ON	
13. D2804	REACTOR COOLANT PUMP B	ON	
14. D2805	ACTOR COOLANT PUMP C	ON	
15. D2806	REACTOR COOLANT PUM D	ON	
6. A1177	SOURCE RANGE (FLUX) LEVEL CHANNEL 1	29.27	CPS
17. A1206	SOURCE RANE (FLUX) LEVEL CHANNEL 2	33.58	CS
18. A0628	POWER RANGE AVG LEVEL QUADRAN 1 (N-43)	3.739E-08	%
19. P1385	REACTOR THERMAL POWER, BEST ESTIMATE	1.64	%
20. A0602	CVCS BORON METER (IOLATED ON Ph. A)	633.73	PPM
1. A1312	RVLIS - TRAIN A - DYNAMIC HEAD D/P	100.13	%
22. A1300	RVLIS - TRIN A - UPPER RANGE LEVEL	62.33	%
23. A1306	RVLIS - TRAIN A - LOWER RANGELEVEL	64.00	%
24. P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN	81.67	DEG F
Group: 10	-----	SECONDARY SYSTEM	-----
1. A1004	STEAM GE A WIDE RANGE LEVEL	54.88	
2. A1005	STEAM GEN B WIDE RANGE LEVEL	54.87	%
3. A097	STEAM GEN C WIDE RANGE LEVEL	54.88	%
4. A0988	STEAM GEN D WIDE ANGE LEVEL	54.88	%
5. A1107	STEAM GEN A STEAM (LINE) PRESS I	1093.72	PSIG
6. A1113	STEAM G B STEAM (LINE) PRESS I	1093.73	SIG
7. A1119	STEAM GEN C STEAM (LINE) PRS I	1093.74	PSIG
8. A1125	STEAM GEN D STEAM (LINE) PRESS I	1093.74	PSIG
9. P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	0.0881	MLB/HR
10. P1414	TOTAL S/G B (MAIN) FEEDWATER FLOW 1	0.0952	MLB/HR
11. P1416	TOTAL SG C (MAIN) FEEDWATER FLOW 1	0.0921	LB/HR
12. P1418	TOTAL S/G D (MAIN) FEEDWATE FLOW 1	0.0916	MLB/HR
13. P12	AUX FEEDWATER FLOW TO S/G A	0.00	MLB/HR
14. P1209	AUX FEEDWATER FLW TO S/G B	0.00	MLB/HR
5. P1210	AUX FEEDWATER FLOW TO S/G C	0.00	MLB/HR
16. P1211	AUX FEDWATER FLOW TO S/G D	0.00	MLB/HR
17. A1059	STEAM GEN A NARROW RANGE LEEL IV	37.96	%
18. A105	STEAM GEN B NARROW RANGE LEVEL IV	37.92	%
19. A1071	STEAM GEN C NARROW RGGE LEVEL IV	37.95	%
0. A1077	STEAM GEN D NARROW RANGE LEVEL IV	37.94	%
21. A0736	MAIN TEAM HEADER PRESSURE	1093.66	PIG

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 2

Date:

Time:

10/20/93 0859

## Group: 5 ----- AUXILIARY/INJECTION SYSTEMS

1. D0970	NV PUMP A (HIGH HEASI)	OFF
2. D0620	NV PUMP B (HIGH HEAD SI)	ON
3. A0827	BORONINJECTION (HIGH HEAD SI) FLOW	0.00 GPM
4. D3574	NI PUMP A (INTERMEDIATE HEASI)	OFF
5. D366	NI PUMP B (INTERMEDIATE HEAD SI)	OFF
6. D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF
7. D0968	ND PUMP B (LOW HEAD SI / RHR)	OFF
8. A0758	CHARNG PUMP DISCHARGE HEADER FLOW	130.52 GPM
9. A0856	(LOW HEAD SI / RHR) ND HX ETURN FLCW	0.00 GPM
10. A064	LETDOWN HX OUTLET FLOW	45.24 GPM
11. D0400	REFUELING WATER TORAGE TANK LEVEL	NORMAL
12. D0402	REFUELING WATER STORAGE TANK LEVEL	NOT LO
13. D0401	REFULING WATER STORAGE TANK LEVEL	NOT EMER LO

## Group 20 ----- CONTAINMENT SYSTEMS

1. A0590	NARROW RANGEONTAIN. PRESS (-1 TO +1)	-----	PSIG
2. A0785	INTER. RANGE CONTAIN. PRESS (-5 T220)	0.0311	PSIG
3. A1047	WIDERANGE CONTAIN. PRESS (-5 TO 60)	-----	PSIG
4. A1228	LOWER CONT AMBIENT AIR MMP A	102.43	DEG F
5. 1204	UPPER CONT AMBIENT AI TEMP A	85.90	DEG F
6. A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00	FT
7. A0671	CONTAINME SUMP LEVEL TRAIN B	-----	FT
8. A0848	CONTAINMENT H2 CONCENTRATION TRIN A	0.00	%
9. D3572	S PUMP A (CONTAINMENT SPRAY)	OFF	
10. D3573	NS PUMP B (CONTAINME SPRAY)	OFF	

## Group: 25 ----- RADIATION SYSTEMS

1. A0115	1EMF48 REACTOR COOLANT MONITOR	51924.98	CPM
2. A0829	EMF51A IN CONTAINMENT HI RANGE RAD MON	2.00E-04	R/HR
3. A0835	1EMF51B IN CONTAINMENT I RANGE RAD MON	2.002E-04	R/HR
. A0073	1EMF39H CONTAINMENT GAS HI RANGE	2.00	CPM
5. A0067	1EMF39L CONTAINMENT GAS LO RANGE	28507.96	CP
6. A0061	1EMF38H CONTAINMENT PARTICULATE I RANGE	5.00	CPM
7. A0055	1EMF38 CONTAINMENT PARTICULATE LO RANGE	2709.61	CPM
8. A1009	1EMF36HH UNIT VENT S HI HI RANGE	4.01	R/HR
. A0018	1EMF36H UNIT VENT GAS HI RANGE	31.62	CPM
10. A0012	1EMF36L UNI VENT GAS LO RANGE	158.49	CPM
11. A0019	1EMF35H UNIT VENT PARTICULATEHI RANGE	20.03	CPM
12. A0013	1EMF35L UNIT VENT PARTICULATE LO RANGE	32.33	CPM
13. A0049	1EMF37 UNIT VENT IOINE	387.01	CPM
4. A0079	1EMF40 CONTAINMENT IODINE	500.19	CPM
15. A1368	1EMF24 STMMLINE 1A RADIATION MONITOR	0.0110	m/Hr
16. A1374	1EMF25 STEAMLINE 1B RADIATIONMONITOR	0.0110	MR/HR
17. A1380	1EMF26 STEAMLINE 1C RADIATION MONITOR	.0110	MR/HR
18. A1386	1EMF27 STEAMLINE 1D RADIATIONMONITOR	0.0110	MR/HR
9. A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE	-----	CPM

## Group: 30 ----- ENVIRONMENTAL SSTEMS

1. P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH
2. P0848	LOWER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH
3. P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERGE)	-----	DEG C
4. P0847	UPPER WIN DIRECTION (15 MINUTE AVERAGE)	-----	EG
5. P0849	LOWER WIND DIRECTION (15 INUTE AVERAGE)	-----	DEG
6. P059	PRECIPITATION IN LAST 15 MIN	-----	IN
7. P0851	AMBIENT AIR TEMPEATURE(15 MINUTE AVERAGE)	-----	DEG C
. A0863	UNIT VENT STACK FLOW	91647.50	FT3/MN

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date: 10/20/93

Time: 08:59

Group: 35		IN-CORE THERMOUPLES		
1.	A028	IN-CORE TEMP A10 T/C #2	558.03	DEG F
2.	A0166	IN-CORE TEMP J06 T/C #17	557.56	DEG F
3.	A0155	IN-CORE TEMP F01 T/C #43	558.47	DEGF
4.	A0251	IN-CORE TEMP M07 T/C #59	557.87	DEG F
5.	P0823	HIGHEST IN-CORE T/C TEMP MARGIN	-----	DEG F
6.	P0828	5 HIGHEST IN-CORE TC TEMP	-----	DEG F
7.	A1323	IN-CORE TEMP K05 T/C #54	-----	DEG F
8.	A1341	IN-CORE MMP M11 T/C #60	-----	D F
9.	A1287	IN-CORE TEMP D13 T/C #42	-----	DEG F
10.	A1161	IN-CORE TEMP C04 T/C #3	-----	DEG F

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

Time:

10/20/93 0914

Group: 05

## PRIMARY SYSTEM

1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	556.10	DEG F
2. A0971	NC LOOP B WIDE RANGE HOT LEG TEMP	556.00	DEG F
3. A0977	NC LOOP C WIDE RANGE HOT LEGEMP	556.06	DEG F
4. A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	556.03	DEG F
5. A1061	NC LOOP A WIDE RAN COLD LEG TEMP	545.16	DEG F
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEMP	537.65	DEG F
7. A1073	NC LOOPC WIDE RANGE COLD LEG TEMP	536.38	EG F
8. A1079	NC LOOP D WIDE RANGE COLD LE TEMP	537.00	DEG F
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	773.60	PSIG
11. A1124	PZR LEVEL I (HOT CLIBRATED)	0.00	%
12. D2803	REACTOR COOLANT PUMP A	OFF	
13. D2804	REACTOR OLANT PUMP B	OFF	
14. D2805	REACTOR COOLANT PUMP C	OFF	
15. D280	REACTOR COOLANT PUMP D	OFF	
16. A1177	SOURCE RANGE (FLU) LEVEL CHANNEL 1	31.61	CPS
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL 2	32.98	CPS
18. A0628	POWER RNGE AVG LEVEL QUADRANT 1 (N-43)	3.286E-08	
19. P1385	REACTOR THERMAL POWER, BESTESTIMATE	-0.3993	%
20. A060	CVCS BORON METER (ISOLATED ON Ph. A)	1064.33	PPM
21. A1312	RVLIS - TRAIN A DYNAMIC HEAD D/P	18.08	%
22. A1300	RVLIS - TRAIN A - UPPER RANGE LEVEL	93.89	%
23. A1306	RVLIS TRAIN A - LOWER RANGE LEVEL	61.47	%
24. P1481	LOWEST NC SYSTEM SUBCOOLINGAARGIN	-14.91	DEG F

Group: 10

## SECONARY SYSTEM

1. A1004	STEAM GEN A WIDE RANGE LEVEL	55.55	%
2. A1005	STEAMEEN B WIDE RANGE LEVEL	54.16	%
3. A0970	STEAM GEN C WIDE RANGE LEVL	55.51	%
4. A0988	STEAM GEN D WIDE RANGE LEVEL	55.51	%
5. A1107	STEAM GEN A STEM (LINE) PRESS I	1075.11	PSIG
6. A1113	STEAM GEN B STEAM (LINE) PRESS I	1068.33	PSIG
7. A1119	STEAMGEN C STEAM (LINE) PRESS I	1079.86	PSIG
8. A1125	STEAM GEN D STEAM (LINE) EESS I	1079.86	PSIG
9. P112	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	0.1194	MLB/HR
10. P1414	TOTAL S/G B (MAN) FEEDWATER FLOW 1	0.1194	MLB/HR
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1	0.1194	MLB/HR
12. P1418	TOT S/G D (MAIN) FEEDWATER FLOW 1	0.119	MLB/HR
13. P1208	AUX FEEDWATER FLOW TO S/ A	0.1197	MLB/HR
14. P209	AUX FEEDWATER FLOW TO S/G B	0.1197	MLB/HR
15. P1210	AUX FEEDWATER LOW TO S/G C	0.1197	MLB/HR
16. P1211	AUX FEEDWATER FLOW TO S/G D	0.1197	MLB/HR
17. A1059	STE GEN A NARROW RANGE LEVEL IV	40.3	%
18. A1065	STEAM GEN B NARROW RANGELEVEL IV	36.16	%
19. A071	STEAM GEN C NARROW RANGE LEVEL IV	40.50	%
20. A1077	STEAM GEN D NRROW RANGE LEVEL IV	40.55	%
21. A0736	MAIN STEAM HEADER PRESSURE	1068.33	PSIG

RDT501

UUKE POWER COMPANY

Unit: MNS 1

Page: 2

Date:

10/20/93

Time:

0714

Group: 15	AUXILIARY/INJECTION SYSTEMS	
1. D097	NV PUMP A (HIGH HEAD SI)	ON
2. D0620	NV PUMP B (HIGHHEAD SI)	ON
3. A0827	BORON INJECTION (HIGH HEAD SI) FL	585.47 GPM
4. D3574	NIUMP A (INTERMEDIATE HEAD SI)	ON
5. D3576	NI PUMP B (INTERMEDIATEHEAD SI)	ON
6.D1042	ND PUMP A (LOW HEAD SI / RHR)	OF
7. D0968	ND PUMP B (LW HEAD SI / RHR)	ON
8. A0758	CHARGING PUMP DISCHARGE HEADER FW	87.62 GPM
9. A0856	(LOHEAD SI / RHR) ND HX RETURN FLOW	000 GPM
10. A0764	LETDOWN HX OUTLET FLOW	0.00 GPM
11.D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL
12. D0402	REFUELING WEER STORAGE TANK LEVEL	NOT LO
13. D0401	REFUELING WATER STORAGE TANK LEVL	NOT EMER LO
Group: 20	CONTAINMET SYSTEMS	
1A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)	PSIG
2. A0785	INTER. RANG CONTAIN. PRESS (-5 TO 20)	0.0468 PSIG
3. A1047	WIDE RANGE CONTAIN. PRESS (-5 O 60)	----- PSIG
4. A1228	LWER CONT AMBIENT AIR TEMP A	1059 DEG F
5. A1204	UPPER CONT AMBIENT AIR TMP A	86.49 DEG F
6 A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00 FT
7. A0671	CONTAINMEN SUMP LEVEL TRAIN B	----- FT
8. A0848	CONTAINMENT H2 CONCENTRATION TRA A	0.00 %
9. D3572	S PUMP A (CONTAINMENT SPRAY)	OFF
10. D3573	NS PUMP B (CONTAINME SPRAY)	OFF
Group: 25	RADIATION SYSTEMS	
1. A0115	1EMF48 REACTOR COOLANT ONITOR	51924.98 CPM
2. 0829	1EMF51A IN CONTAINMENT HI RANGE RAD MON	2.002E-04 R/HR
3. A0835	1EMF51B IN COTAINMENT HI RANGE RAD MON	2.002E-04 R/HR
4. A0073	1EMF39H CONTAINMENT GA : HI RANGE	2.00 CPM
5. A0067	1MF39L CONTAINMENT GAS LO RANGE	285084 CPM
6. A0061	1EMF38H CONTAINMENT PARTCULATE HI RANGE	5.00 CPM
7A0055	1EMF38L CONTAINMENT PARTICULATE LO RANGE	27029.62 CPM
8. A1009	1EMF36HH UN VENT GAS HI HI RANGE	4.55 R/HR
9. A0018	1EMF36H UNIT VENT GAS HI RANGE	31.62 CPM
10. A0012	MF36L UNIT VENT GAS LO RANGE	158. CPM
11. A0019	1EMF35H UNIT VENT PARCCULATE HI RANGE	22.96 CPM
12.A0013	1EMF35L UNIT VENT PARTICULATE LO RANGE	1031.52 CPM
13. A0049	1EMF37 UNITVENT IODINE	460.16 CPM
14. A0079	1EMF40 CONTAINMENT IODINE	500.19 CPM
15. A1368	EMF24 STEAMLINE 1A RADIATION MONITOR	0.110 mR/Hr
16. A1374	1EMF25 STEAMLINE 1B RAATION MONITOR	0.0110 MR/HR
17 A1380	1EMF26 STEAMLINE 1C RADIATION MONITOR	0.0110 MR/HR
18. A1386	1EMF27 STELINE 1D RADIATION MONITOR	0.0110 MR/R
19. A0127	EMF49H WASTE LIQUID DISCHARGE H RANGE	----- CPM
Group: 30	ENVIROENTAL SYSTEMS	
.. P0846	UPPER WIND SPEED (15 MINUTE AVERAG)	----- MPH
2. P0848	LOWER WINSPEED (15 MINUTE AVERAGE)	----- MPH
3. P0850	LOWER TO UPPER DELTA-T (15 MINTE AVERAGE)	----- DEG C
4. P0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)	----- DEG
5. P0849	LOWER WIND DIRECTIO (15 MINUTE AVERAGE)	----- DEG
6. P0595	PRECIPITATION IN LAST 15 MIN	----- IN
7. P0851	AMBIENT A TEMPERATURE(15 MINUTE AVERAGE)	----- EG C
8. A0863	UNIT VENT STACK FLOW	53418.03 FT3/MN

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Pa:: 3

Date:

Time:

10/20/83 0914

## Group: 35 ----- IN-CORE THERMOCOUPLES

1. A0268	IN-CORE TEMP A10	T/C #2	554.52	DEG F
2. A0166	IN-CORETEMP J06	T/C #17	554.05	EG F
3. A0155	IN-CORE TEMP F01	T/C #43	554.92	DEG F
4. A0251	IN-CORE TEMP M07	T/C #59	554.15	DEG F
5. P0823	5 HIGHEST IN-CORET/C TEMP MARGIN		-----	DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP		-----	DEG F
7. A1323	IN-CORETEMP K05	T/C #54	-----	DEG F
8. A1341	IN-CORE TEMP M11	T/C #60	-----	DEG F
9. A128	IN-CORE TEMP D13	T/C #42	-----	DEG F
10. A1161	IN-CORE TEMP C04	T/C #3	-----	DEG F

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

Time:

10/22/93

0929

## Group: 05

	PRIMARY SYSTEM		
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	525.26	DEG F
2. A0971	C LOOP B WIDE RANGE HOT LEG TEMP	52.66	DEG F
3. A0977	NC LOOP C WIDE RANGE OT LEG TEMP	525.13	DEG F
A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	525.54	DEG F
5. A1061	NC LOOP AIIDE RANGE COLD LEG TEMP	437.49	DEGF
6. A1067	NC LOOP B WIDE RANGE COLD LEG EMP	347.64	DEG F
7. A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	3.17	DEG F
8. A1079	NC LOOP D WIDE RANGCOLD LEG TEMP	335.24	DEG F
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	818.24	PSIG
11. A1124	PZR LEVELI (HOT CALIBRATED)	0.00	%
12. D2803	REACTOR COOLANT PUMP A	OFF	
13. D2804	REACTOR COOLANT PUMP B	OFF	
14. D2805	REACTOR COOLANT PUMP C	OFF	
15. D2806	REACTOR COOLANT PUMP D	OFF	
16. A177	SOURCE RNGE (FLUX) LEVEL CHANNEL 1	20.55	CS
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANEL 2	14.29	CPS
18. A0628	POWER RANGE AVG LEVEL QUADRANT 1 (N-43)	1.95E-08	%
19. P1385	REACTOR THERMAL PORR, BEST ESTIMATE	0.00	%
O. A0602	CVCS BORON METER (ISOLATED ON Ph. A)	1113.62	PPM
21. A1312	RVLIS -RRAIN A - DYNAMIC HEAD D/P	15.96	
22. A1300	RVLIS - TRAIN A - UPPER RANG LEVEL	72.04	%
23. A1306	RVLIS - TRAIN A - LOWER RANGE LEVEL	59.66	%
24. P1481	LOWEST NC SYSTEMSUBCOOLING MARGIN	-18.43	DEG F

## Group: 10

	SECONDARY SYSTEM		
1. A1004	STEAM GEN A WIDE RANGE LEVL	59.16	%
2. A1005	STEAM GEN B WIDE RANGE LEVEL	58.26	%
3. A0970	STEAM GEN C WIDRANGE LEVEL	58.88	%
4. A0988	STEAM GEN D WIDE RANGE LEVEL	58.85	%
5. A1107	STEAMGEN A STEAM (LINE) PRESS I	938.96	PIG
6. A1113	STEAM GEN B STEAM (LINE) PESS I	932.80	PSIG
7. A199	STEAM GEN C STEAM (LINE) PRESS I	950.41	PSIG
8. A1125	STEAM GEN D STEM (LINE) PRESS I	949.51	PSIG
9. P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	6.135E-03	MLB/HR
10. P1414	TOTAL /G B (MAIN) FEEDWATER FLOW 1	9.092E-03	MLB/HR
11. P1416	TOTAL S/G C (MAIN) FEEDWAER FLOW 1	0.00	MLB/HR
12. P118	TOTAL S/G D (MAIN) FEEDWATER FLOW 1	0.00	MLB/HR
13. P1208	AUX FEEDWATER FOW TO S/G A	6.153E-03	MLB/HR
14. P1209	AUX FEEDWATER FLOW TO S/G B	9.106E-03	MLB/HR
15. P1210	AUX EEDWATER FLOW TO S/G C	0.00	MB/HR
16. P1211	AUX FEEDWATER FLOW TO S/G D	0.00	MLB/HR
17. A59	STEAM GEN A NARROW RANGE LEVEL IV	48.63	%
18. A1065	STEAM GEN B NARROW RANGE LEVEL IV	45.52	%
19. A1071	STEAM GEN C NARROW RANGE LEVEL IV	47.95	%
20. A1077	STE GEN D NARROW RANGE LEVEL IV	47.8	%
21. A0736	MAIN STEAM HEADER PRESSU	911.73	PSIG

RDTSO1

DUKE POWER COMPANY

Unit: MN 1

aage: 2

Date:

Time:

10/20/93 0929

Group: 15	AIIILIARY/INJECTION SYSTEMS		
1. D0970	NV PUMP A (HIGH HEAD SI)	ON	
2. D0620	NV PUMP B (HIGH HEAD SI)	ON	
3. A0827	BORON INJECTION (HIGH HEA SI) FLOW	624.84	GPM
4. D74	NI PUMP A (INTERMEDIATE HEAD SI)	ON	
5. D3576	NI PUMP B (INTEMEEDIATE HEAD SI)	ON	
6. D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF	
7. D0968	ND PPP B (LOW HEAD SI / RHR)	ON	
8. A0758	CHARGING PUMP DISCHARGE ADER FLOW	93.27	GPM
9. A856	(LOW HEAD SI / RHR) ND HX RETURN FLOW	0.00	GPM
10. A0764	LETDOWN HX OUTET FLOW	0.00	GPM
11. D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL	
12. D0402	REFLLING WATER STORAGE TANK LEVEL	NOT LO	
13. D0401	REFUELING WATER STORAGE NK LEVEL	NOT EMER LO	
Group: 20	NTAINMENT SYSTEMS		
1. A0590	NARROW RANGE CONTAIN. PRESS (-1 TO+1)	---	PSIG
2. A0785	INTR. RANGE CONTAIN. PRESS (-5 TO 20)	0.100	PSIG
3. A1047	WIDE RANGE CONTAIN. PRSS (-5 TO 60)	---	PSIG
4. 228	LOWER CONT AMBIENT AIR TEMP A	98.40	DEG F
5. A1204	UPPER CONT AMIENT AIR TEMP A	91.48	DEG F
6. A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00	FT
7. A0671	CONAINMENT SUMP LEVEL TRAIN B	---	FT
8. A0848	CONTAINMENT H2 CONCENTRAION TRAIN A	0.00	%
9. 572	NS PUMP A (CONTAINMENT SPRAY)	FF	
10. D3573	NS PUMP B (CONTINMENT SPRAY)	OFF	
Group: 25	RADIATION SYSTEMS		
1. A0115	IEMF48 REACTOR COOLANT NITOR	51924.98	CPM
2. 0829	IEMF51A IN CONTAINMENT HI RANGE RAD MON	1.993E-04	R/HR
3. A0335	IEMF51B IN COTAINMENT HI RANGE RAD MON	1.993E-04	R/HR
4. A0073	IEMF39H CONTAINMENT GAS HI RANGE	2.00	CPM
5. A0067	IEF39L CONTAINMENT GAS LO RANGE	28508.4	CPM
6. A0061	IEMF38H CONTAINMENT PARICULATE HI RANGE	5.00	CPM
7. 0055	IEMF38L CONTAINMENT PARTICULATE LO RANGE	27029.62	CPM
8. A1009	IEMF36HH UNIT VNT GAS HI HI RANGE	4.67	R/HR
9. A0018	IEMF36H UNIT VENT GAS HI RANGE	31.62	CPM
10. A0012	IEMF6L UNIT VENT GAS LO RANGE	158.49	CPM
11. A0019	IEMF35H UNIT VENT PARTIULATE HI RANGE	23.59	CPM
12. A0013	IEMF35L UNIT VENT PARTICULATE LO RANGE	1183.65	CPM
13. A0049	IEMF37 UNIT ENT IODINE	476.01	CPM
14. A0079	IEMF40 CONTAINMENT IODINE	500.19	CPM
15. A1368	IEF24 STEAMLINE 1A RADIATION MONITOR	0.010	mR/Hr
16. A1374	IEMF25 STEAMLINE 1B RAAATION MONITOR	0.0110	MR/HR
17. A1380	IEMF26 STEAMLINE 1C RADIATION MONITOR	0.0110	MR/HR
18. A1386	IEMF27 STEAMLNE 1D RADIATION MONITOR	0.0110	MR/HR
19. A0127	EMF49H WASTE LIQUID DISCHARGE HIRANGE	---	CPM
Group: 30	ENVIRONMTAL SYSTEMS		
1. P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)	---	MPH
2. P0848	LOWER WIND PEED (15 MINUTE AVERAGE)	---	MPH
3. P0850	LOWER TO UPPER DELTA-T (15 MINUE AVERAGE)	---	DEG C
4. P0847	UPER WIND DIRECTION (15 MINUTE AVERAGE)	---	DEG
5. P0849	LOWER WIND DIRECTION (15 MINUTE AVERAGE)	---	DEG
6. P0595	PRECIPITATION IN LAST 15 MIN	---	IN
7. P0851	AMBIENT AIRTEMPERATURE(15 MINUTE AVERAGE)	---	DEGC
8. A0863	UNIT VENT STACK FLOW	53418.03	FT3/MN

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date:

Time:

10/20/93 0929

## Group: 35 IN-CORE THERMOCOUPLES

. A0268	IN-CORE TEMP A10	T/C #2	528.05	DEG F
2. A0166	IN-CORE TEP J06	T/C #17	527.51	DEGF
3. A0155	IN-CORE TEMP F01	T/C #43	528.47	DEG F
4. A0251	NN-CORE TEMP M07	T/C #59	52.91	DEG F
5. P0823	5 HIGHEST IN-CORE T/	TEMP MARGIN	-----	DEG F
P0828	5 HIGHEST IN-CORE T/C TEMP		-----	DEG F
7. A1323	IN-CORE TPP K05	T/C #54	-----	DEG F
8. A1341	IN-CORE TEMP M11	T/C #60	-----	DEG F
9. A1287	N-CORE TEMP D13	T/C #42	-----	DEG F
10. A1161	IN-CORE TEMP C04	T/C #3	-----	DEG F

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

Time:

10/20/93

0945

Group: 05	-----	PRIMARY SYSTEM	-----
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEM	525.26	DEG F
2. A0971	NLLOOP B WIDE RANGE HOT LEG TEMP	5266	DEG F
3. A0977	NC LOOP C WIDE RANGE T LEG TEMP	525.13	DEG F
4 A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	525.54	DEG F
5. A1061	NC LOOP A WIDE RANGE COLD LEG TEMP	437.49	DEG F
6. A1067	NC LOOP B WIDE RANGE COLD LEGEMP	347.64	DEG F
7. A1073	NNC LOOP C WIDE RANGE COLD LEG TEMP	3.17	DEG F
8. A1079	NC LOOP D WIDE RANGE OLD LEG TEMP	335.24	DEG F
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	818.24	PSIG
11. A1124	PZR LEVEL IHNOT CALIBRATED)	0.00	%
12. D2803	REACTOR COOLANT PUMP A	OFF	
13. D280	REACTOR COOLANT PUMP B	OFF	
14. D2805	REACTOR COOLANT PUMP C	OFF	
. D2806	REACTOR COOLANT PUMP D	OFF	
16. A1177	SOURCERANGE (FLUX) LEVEL CHANNEL 1	20.55	CPS
17. A1206	SOURCE RANGE (FLUX) LEVEL CANNEL 2	14.29	CPS
18. A062	POWER RANGE AVG LEVEL QUADRANT 1 (N-43)	1.9E-08	%
19. P1385	REACTOR THERMAL WWER, BEST ESTIMATE	0.00	%
20. A0602	CVCS BORON METER (ISOLATED ON Ph. A)	1113.62	PPM
21. A1312	RVLIS - TRAI A - DYNAMIC HEAD D/P	15.96	%
22. A1300	RVLIS - TRAIN A - UPPER RAEE LEVEL	72.04	%
23. A13	RVLIS - TRAIN A - LOWER RANGE LEVEL	559.66	%
24. P1481	LOWEST NC SYSTEMSUBCOOLING MARGIN	-18.43	DEG F
Group: 10	-----	SECONDARY SYSTEM	-----
1. A1004	STEAM GEN A WIDE RANGE LEVL	59.16	%
2. A105	STEAM GEN B WIDE RANGE LEVEL	58.26	%
3. A0970	STEAM GEN C WIDERANGE LEVEL	58.88	%
4. A0988	STEAM GEN D WIDE RANGE LEVEL	58.85	%
5. A1107	STEAM GEN A STEAM (LINE) PRESS I	938.96	PSIG
6. A1113	STEAM GEN B STEAM (LINE) PESS I	932.80	PSIG
7. A111	STEAM GEN C STEAM (LINE) PRESS I	950.41	PSIG
8. A1125	STEAM GEN D STEM (LINE) PRESS I	949.51	PSIG
9. P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	6.135E-03	MLB/HR
10. P1414	TOTASS/G B (MAIN) FEEDWATER FLOW 1	9.092E-03	MLB/HR
11. P1416	TOTAL S/G C (MAIN) FEEDWAR FLOW 1	0.00	MLB/HF
12. P18	TOTAL S/G D (MAIN) FEEDWATER FLOW 1	0.00	MLB/HR
13. P1208	AUX FEEDWATER OOW TO S/G A	6.153E-03	MLR/HR
4. P1209	AUX FEEDWATER FLOW TO S/G B	9.106E-03	MLB/HR
15. P1210	AUX EEDWATER FLOW TO S/G C	0.0	MLB/HR
16. P1211	AUX FEEDWATER FLOW TO S/D	0.00	MLB/HR
17. A059	STEAM GEN A NARROW RANGE LEVEL IV	48.63	%
18. A1065	STEAM GEN B NARRW RANGE LEVEL IV	45.52	%
19. A1071	STEAM GEN C NAJROW RANGE LEVEL IV	47.95	%
20. A1077	STE GEN D NARROW RANGE LEVEL IV	47.82	%
21. A0736	MAIN STEAM HEADER PRESSURE	911.73	PSIG

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Pe: 2

Date:

Time:

10/20/93 0945

Group: 15	AXILIARY/INJECTION SYSTEMS		
1. D0970	NV PUMP A (HIGH HEAD SI)	ON	
2. D0620	NVPUMP B (HIGH HEAD SI)	ON	
3. A0827	BORON INJECTION (HIGH AAD SI) FLOW	624.84	GPM
4. 3574	NI PUMP A (INTERMEDIATE HEAD SI)	ON	
5. D3576	NI PUMP B (INTERMEIATE HEAD SI)	ON	
6. D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF	
7. D0968	ND PP B (LOW HEAD SI / RHR)	ON	
8. A0758	CHARGING PUMP DISCHARG HEADER FLOW	93.27	GPM
9. A0856	(LOW HEAD SI / RHR) ND HX RETURN FLOW	0.00	GPM
10. A0764	LETDOWN HX OTLET FLOW	0.00	GPM
11. D0400	REFUELING WATER STORAGE TANK LEV	NORMAL	
12. D0402	REFELING WATER STORAGE TANK LEVEL	NOT LO	
13. D0401	R"UELING WATER STORAG TANK LEVEL	NOT EMER LO	
Group: 20	CCONTAINMENT SYSTEMS		
1. A0590	NARROW RANGE CONTAIN. PRESS (-1 +1)	-----	PSIG
2. A0785	INER. RANGE CONTAIN. PRESS (-5 TO 20)	0.104	PSIG
3. A1047	WIDE RANGE CONTAIN. PRESS (-5 TO 60)	-----	PSIG
A1228	LOWER CONT AMBIENT AIR TEMP A	98.40	DEG F
5. A1204	UPPER CONT AMBIENT AIR TEMP A	91.48	DEG F
6. A1041	CONTAINMENT SUMP LEEL TRAIN A	0.00	FT
7. A0671	CONTAINMENT SUMP LEVEL TRAIN B	-----	FT
8. A0848	CONTAINENT H2 CONCENTRATION TRAIN A	0.00	
9. D3572	NS PUMP A (CONTAINMENT SPRAY)	OFF	
10. D357	NS PUMP B (CONTAINMENT SPRAY)	OFF	
roup: 25	RADIATION SYSTEMS		
1. A0115	1EMF48 RACTOR COOLANT MONITOR	51924.98	PPM
2. A0829	1EMF51A IN CONTAINMENT HI RNGE RAD MON	1.993E-04	R/HR
3. A0835	11EMF51B IN NTAINMENT HI RANGE RAD MON	1.993E-04	R/HR
4. A0073	1EMF39H C .INMENT AS HI RANGE	2.00	CPM
5. A0067	1EMF39L C .AINMENT GAS LO RANGE	28508.04	CPM
6. A0061	1EMF38H CTAINMENT PARTICULATE HI RANGE	5.00	CPM
7. A0055	1EMF38L CONTAINMENT PARTICLATE LO RANGE	27029.62	CPM
8. A10	1EMF36HH UNIT VENT GAS HI HI RANGE	4.67	R/HR
9. A0018	1EMF36H UNIT VET GAS HI RANGE	31.62	CPM
10. A0012	1EMF36L UNIT VENT GAS LO RANGE	158.49	CPM
11. A0019	1EMF3H UNIT VENT PARTICULATE HI RANGE	23.59	CPM
12. A0013	1EMF35L UNIT VENT PARTICUTTE LO RANGE	1183.65	CPM
13. A049	1EMF37 UNIT VENT IODINE	476.01	CPM
14. A0079	1EMF40 CONTAINME IODINE	500.19	CPM
15. A1368	1EMF24 STEAMLINE 1A RADIATION MONITOR	0.0110	mR/Hr
16. A1374	1EMF STEAMLINE 1B RADIATION MONITOR	0.0110	MR/HR
17. A1380	1EMF26 STEAMLINE 1C RADIATON MONITOR	0.0110	MR/HR
18. A186	1EMF27 STEAMLINE 1D RADIATION MONITOR	0.0110	MR/HR
19. A0127	EMF49H WASTE LUUID DISCHARGE HI RANGE	-----	CPM
Group: 30	ENVIRONMENTAL SYSTEMS		
1. P0846	UPPER WIND SPEED (5 MINUTE AVERAGE)	-----	MPH
2. 0848	LOWER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH
3. P0850	LOWER TO UPPE DELTA-T (15 MINUTE AVERAGE)	-----	DEG C
4. P0847	UPPER WIND DIRECTION (15 MINUTEVERAGE)	-----	DEG
5. P0849	LOR WIND DIRECTION (15 MINUTE AVERAGE)	-----	DEG
6. P0595	PRECIPITATION IN LAST MIN	-----	IN
7.P0851	AMBIENT AIR TEMPERATURE(15 MINUTE AVERAGE)	-----	DEG C
8. A0863	UNIT VENT STCK FLOW	53418.03	FT3/M

RDT1

DUKE POWER COMPANY

Uni: MNS 1

Page: 3

Date:

10/20/93

Time:

0945

## Group: 35 ----- IN-CORE THERMOCOUPLES

1. A0268	IN-CORE TEMP A10	T/C 2	528.05	DEG F
2. 00166	IN-CORE TEMP J06	T/C #17	527.51	DEG F
3. A0155	IN-CORE TEMPFO1	T/C #43	528.47	DEG F
4. A0251	IN-CORE TEMP M07	T/C #59	527.91	DEG F
5. P0823	511GHEST IN-CORE T/C TEMP	MARGIN	---	DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP		-----	DEG F
7. A323	IN-CORE TEMP K05	T/C #54	-----	DEG F
8. A1341	IN-CORE TEMMM11	T/C #60	-----	DEG F
9. A1287	IN-CORE TEMP D13	T/C #42	-----	DEG F
10. A1161	N-CORE TEMP C04	T/C #3	-----	DEG F

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

Time:

10/20/93

10:10D

Group: 05	-----	PRIMARY SYSTEM	-----
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	428.52	DEG F
2. A0971	NC LOOP B WIDE RANGE HOT LEG TEMP	431.81	DEG F
3. A0977	NC LOOP C WIDE RANGE HOT LEG TEMP	436.30	DEG F
4. A0983	NC LOOP D WIDE RANGE HOT LEGTEMP	435.44	DEG F
5. A161	NC LOOP A WIDE RANGE COLD LEG TEMP	335.34	DEG F
6. A1067	NC LOOP B WIDE NNGE COLD LEG TEMP	270.93	DEG F
7. A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	257.45	DEG F
8. A1079	NC OP D WIDE RANGE COLD LEG TEMP	260.3	DEG F
9. A0826	NC SYSTEM (HOT LEG) WIDEANGE PRESS	292.87	PSIG
11. A124	PZR LEVEL I (HOT CALIBRATED)	0.00	%
12. D2803	REACTOR COOLAN PUMP A	OFF	
13. D2804	REACTOR COOLANT PUMP B	OFF	
14. D2805	REATOR COOLANT PUMP C	OFF	
15. D2806	REACTOR COOLANT PUMP D	OFF	
16. 1177	SOURCE RANGE (FLUX) LEVEL CHANNEL 1	11.26	CPS
17. A1206	SCJRCE RANGE (UX) LEVEL CHANNEL 2	13.77	CPS
18. A0628	POWER RANGE AVG LEVEL QUADRANT 1 -43)	1.130E-08	%
19. P1385	RECTOR THERMAL POWER, BEST ESTIMATE	0.00	%
20. A0602	CVCS BORON METER (ISOLAED ON Ph. A)	1159.58	PPM
21. A132	RVLIS - TRAIN A - DYNAMIC HEAD D/P	13.47	%
22. A1300	RVLIS - TRAINA - UPPER RANGE LEVEL	70.49	%
23. A1306	RVLIS - TRAIN A - LOWER RANGE LEVL	62.30	%
24. P1481	LOEST NC SYSTEM SUBCOOLING MARGIN	-36.8	DEG F
Gro: 10	-----	SECONDARY SYSTEM	-----
1. A1004	STEAM GEN A IDE RANGE LEVEL	59.23	%
2. A1005	STEAM GEN B WIDE RANGE LEVEL	58.35	%
3. A0970	STEM GEN C WIDE RANGE LEV'L	5889	%
4. A0988	STEAM GEN D WIDE RANGE LELL	58.86	%
5.A1107	STEAM GEN A STEAM (LINE) PRESS I	934.04	PSIG
6. A1113	STEAM GEN B EAM (LINE) PRESS I	928.36	PSIG
7. A1119	STEAM GEN C STEAM (LINE) PRESS	948.83	PSIG
8. A1125	TEAM GEN D STEAM (LINE) PRESS I	94.10	PSIG
9. P1412	TOTAL S/G A (MAIN) FEDWATER FLOW 1	0.00	MLB/HR
10.P1414	TOTAL S/G B (MAIN) FEEDWATER FLOW 1	0.00	MLB/HR
11. P1416	TOTAL S/G C(MAIN) FEEDWATER FLOW 1	0.00	MLBHR
12. P1418	TOTAL S/G D (MAIN) FEEDWATER FLW 1	0.00	MLB/HR
13. P1208	UX FEEDWATER FLOW TO S/G A	000	MLB/HR
14. P1209	AUX FEEDWATER FLOW T S/G B	0.00	MLB/HR
15. P1210	AUX FEEDWATER FLOW TO S/G C	0.00	MLB/HR
16. P1211	AUX FEEDWAER FLOW TO S/G D	0.00	MLHHR
17. A1059	STEAM GEN A NARROW RANGE LEVEL IV	48.73	%
18. A1065	STEAM GEN B NARROW RANGE LEVEL IV	5.64	%
19. A1071	STEAM GEN C NARROW RGGE LEVEL IV	47.94	%
20AA1077	STEAM GEN D NARROW RANGE LEVEL IV	47.81	%
21. A0736	MAIN STEAMHEADER PRESSURE	840.82	PSG

RDS01

DUKE POWER COMPANY

Unt: MNS 1

Page: 2

Date:

Time:

12/20/83

1000

## Group: 15 ----- AUXILIARY/INJECTION SYSTEMS

1. D0970	NV PUMP A (HIGH HEAD S)	OFF		
2. D0620	NV PUMP B (HIGH HEAD SI)	ON		
3. A0827	BORON INJTION (HIGH HEAD SI) FLOW		421.25	GP
4. D3574	NI PUMP A (INTERMEDIATE HEAD S)	OFF		
5. D3576	NI PUMP B (INTERMEDIATE HEAD SI)	OFF		
6. D1042	ND PUMP A (LOW HEADI / RHR)	OFF		
. D0968	ND PUMP B (LOW HEAD SI / RHR)	ON		
8. A0758	CHARGING PUMP DISCHARGE HEAD FLOW		63.44	GP
9. A0856	(LOW HEAD SI / RHR) ND HX RETUN FLOW		0.00	GPM
10. A0764	LETDOWN HX OUTLET FLOW		0.00	GPM
11. D0400	REFUELING WATER STOAGE TANK LEVEL	NORMAL		
2. D0402	REFUELING WATER STORAGE TANK LEVEL	NOT LO		
13. D0401	REFUELING WTER STORAGE TANK LEVEL	NOT EMER LO		

## Group: 20 ----- CONTAINMENT SYSTEMS

1. A0590	NARROW RANGE CONTAI. PRESS (-1 TO +1)			PSIG
2. A885	INTER. RANGE CONTAIN. PRESS (-5 TO 20)	-2.960E-03		PSIG
3. A1047	WIDE RANGE CONTAIN. PRESS (-5 TO 60)			PSIG
4. A1228	LOWER CON AMBIENT AJ. TEMP A		94.55	EG F
5. A1204	UPPER CONT AMBIENT AIR TEMP		87.66	DEG F
6. A1041	CONTAINMENT SUMP LVEL TRAIN A		0.00	FT
7. A0671	CONTAINMENT SUR VEL TRAIN B			FT
8. A0848	CONTAINMENT H2 C. ENTRATION TRAIN A		0.00	%
9. D3572	NS PUMP (CONTAINMENT SPRAY)	OFF		
10. D3573	NS PUMP B (CONTAINMENT SPRA)	OFF		

## Group: 25 ----- RADTION SYSTEMS

1. A0115	1EMF48 REACTOR COOLANT MONITOR	51924.98	CPM
2. A0829	1EMF5A IN CONTAINMENT HI RANGE RAD MON	2.002E-04	R/HR
3. A0835	1EMF51B IN CONTAINMENT HI ANGE RAD MON	2.002E-04	R/HR
4. A0073	1EMF39H CONTAINMENT GAS HI RANGE	2.00	CPM
5. A0067	1EMF39L CONTAINMT GAS LO RANGE	28508.04	CPM
6. A0061	1EMF38H CONTAINMENT PARTICULATE HI ANGE	5.00	CPM
7. A0055	1EMF8L CONTAINMENT PARTICULATE LO RANGE	27029.62	CPM
8. A1009	1EMF36HH UNIT VENT GAS HIHI RANGE	4.44	R/HR
9. A18	1EMF36H UNIT VENT GAS HI RANGE	31.62	CPM
10. A0012	1EMF36L UNIT VENTGAS LO RANGE	158.49	CPM
11. A0019	1EMF35H UNIT VENT PARTICULATE HI RANE	22.37	CPM
12. A0013	1EMF35L NIT VENT PARTICULATE LO RANGE	889.7	CPM
13. A0049	1EMF37 UNIT VENT IODINE	445.39	CPM
14. A079	1EMF40 CONTAINMENT IODINE	500.19	CPM
15. A1368	1EMF24 STEAMLNE 1A RADIATION MONITOR	0.0110	mR/Hr
16. A1374	1EMF25 STEAMLINE 1B RADIATION MONIT	0.0110	MR/HR
17. A1380	1EM26 STEAMLINE 1C RADIATION MONITOR	0.010	MR/HR
18. A1386	1EMF27 STEAMLINE 1D RADTION MONITOR	0.0110	MR/HR
19. O127	EMF49H WASTE LIQUID DISCHARGE HI RANGE		CPM

## Group: 30 ----- ENVIRONMENTAL SYSTEM

1. P0846	UPER WIND SPEED (15 MINUTE AVERAGE)		MPH
2. P0848	LOWER WIND SPEED 5 MINUTE AVERAGE)		MPH
3. 0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAGE)		DEG C
4. P0847	UPPER WIND DEECTION (15 MINUTE AVERAGE)		DEG
5. P0849	LOWER WIND DIRECTION (15 MINUTE AERAGE)		DEG
6. P0595	PRCIPITATION IN LAST 15 MIN		IN
7. P0851	AMBIENT AIR TEMPERATURE(5 MINUTE AVERAGE)		DEG C

SA0863 UNIT VENT STACK FLOW

10/20/83 10:00

53418.03 FT3/MN

RDT501

DUKEPOWER COMPANY

Unit: MNS 1

Page: 3

Date: 10/20/93 Time: 10100

Group: 35 IN-CORE THERMOCOUPES

1. A0268	IN-CORE TEMP A10 T/C #2	43.64	DEG F
2. A0166	IN-CORE TEMP J06 T/C#17	439.14	DEG F
3. 0155	IN-CORE TEMP F01 T/C #43	439.95	DEG F
4. A0251	IN-CORE TE M07 T/C #59	439.31	DEGF
5. P0823	5 HIGHEST IN-CORE T/C TEMP MARGN	-----	DEG F
6. P0828	5 IGHEST IN-CORE T/C TEMP	---	DEG F
7. A1323	IN-CORE TEMP K05 T/#54	-----	DEG F
. A1341	IN-CORE TEMP M11 T/C #60	-----	DEG F
9. A1287	IN-CORE TEP D13 T/C #42	-----	DEGF
10. A1161	IN-CORE TEMP C04 T/C #3	-----	DEG F

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

Time:

10/20/93 10:15

Group: 05	-----	PRIMARY SYSTEM			
1. A0965	NC OP A WIDE RANGE HOT LEG TEMP		556.1	DEG F	
2. A0971	NC LOOP B WIDE RANGE HOTLEG TEMP		556.00	DEG F	
3. A977	NC LOOP C WIDE RANGE HOT LEG TEMP		556.06	DEG F	
4. A0983	NC LOOP D WIDERANGE HOT LEG TEMP		556.03	DEG F	
. A1061	NC LOOP A WIDE RANGE COLD LEG TEMP		545.16	DEG F	
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEMP		537.6	DEG F	
7. A1073	NC LOOP C WIDE RANGE COL LEG TEMP		536.38	DEG F	
8. 0079	NC LOOP D WIDE RANGE COLD LEG TEMP		537.00	DEG F	
9. A0826	NC SYSTEM (HO LEG) WIDE RANGE PRESS		1073.60	PSIG	
11. A1124	PZR LEVEL I (HOT CALIBRATED)		0.00	%	
12. D2803	REATOR COOLANT PUMP A	OFF			
13. D2804	REACTOR COOLANT PUMP B	OFF			
14. 2805	REACTOR COOLANT PUMP C	FF			
15. D2806	REACTOR COOLANT UMP D	OFF			
16. A1177	SOURCE RANGE (FLUX) LEVEL CHANNEL		31.61	CPS	
17. A1206	SOUCE RANGE (FLUX) LEVEL CHANNEL 2		32.8	CPS	
18. A0628	POWER RANGE AVG LEVEL QADRANT 1 (N-43)		3.286E-08	%	
19.1385	REACTOR THERMAL POWER, BEST ESTIMATE		-0.3993	%	
20. A0602	CVCS BORON MTER (ISOLATED ON Ph. A)		1064.33	PPM	
21. A1312	RVLIS - TRAIN A - DYNAMIC HEAD D/		18.08	%	
22. A1300	RVSS - TRAIN A - UPPER RANGE LEVEL		939	%	
23. A1306	RVLIS - TRAIN A - LOWERRANGE LEVEL		61.47	%	
24.1481	LOWEST NC SYSTEM SUBCOOLING MARGIN		-14.91	DEG F	
Group: 10	-----	SECONDARY SYSTEM			
1. A1004	SEAM GEN A WIDE RANGE LEVEL		5555	%	
2. A1005	STEAM GEN B WIDE RANGE LEVL		54.16	%	
3AA0970	STEAM GEN C WIDE RANGE LEVEL		55.51	%	
4. A0988	STEAM GEN D IDE RANGE LEVEL		55.51	%	
5. A1107	STEAM GEN A STEAM (LINE) PRESS I		1075.11	PSIG	
6. A1113	STEA GEN B STEAM (LINE) PRESS I		106.33	PSIG	
7. A1119	STEAM GEN C STEAM (LNE) PRESS I		1079.86	PSIG	
. A1125	STEAM GEN D STEAM (LINE) PRESS I		1079.86	PSIG	
9. P1412	TOTAL S/GA (MAIN) FEEDWATER FLOW 1		0.1194	ML/HR	
10. P1414	TOTAL S/G B (MAIN) FEEDWATER FOW 1		0.1194	MLB/HR	
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1		11194	MLB/HR	
12. P1418	TOTAL S/G D (MAIN) EDWATER FLOW 1		0.1194	MLB/HR	
3. P1208	AUX FEEDWATER FLOW TO S/G A		0.1197	MLB/HR	
14. P1209	AUX FEEDWTER FLOW TO S/G B		0.1197	ML/HR	
15. P1210	AUX FEEDWATER FLOW TO S/G C		0.1197	MLB/HR	
16. P1211	AUX FEEDWATER FLOW TO S/G D		.1197	MLB/HR	
17. A1059	STEAM GEN A NARROW ANGE LEVEL IV		40.30	%	
18. A1065	STEAM GEN B NARROW RANGE LEVEL IV		36.16	%	
19. A1071	STEAM GEC NARROW RANGE LEVEL IV		40.50	%	
20. A1077	STEAM GEN D NARROW RANGE LEVEIV		40.55	%	
21. A0736	MAIN STEAM HEADER PRESSURE		168.33	PSIG	

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 2

Date:

Time:

10/20/93

10:15

## Group: 15 ----- AUXILIARY/INJECTION SYSTEMS

1. D0970	NV PUMP (HIGH HEAD SI)	ON		
2. D0620	NV PUMP B (HIGH HEAD SI)	ON		
3. A0827	BORON INJECTION (HIGH HEAD SI) FLOW		885.47	GPM
4. D3574	NI PUMP A (INTERMDIATE HEAD SI)	ON		
5. D3576	NI PUMP B (INTERMEDIATE HEAD SI)	ON		
6. D1042	ND PUMAA (LOW HEAD SI / RHR)	OFF		
7. D0968	ND PUMP B (LCW HEAD SI / RH)	ON		
8. A075	CHARGING PUMP DISCHARGE HEADER FLOW		.62	GPM
9. A0856	(LOW HEAD SI / R) ND HX RETURN FLOW		0.00	GPM
10. A0764	LETDOWN HX OUTLET FLOW		0.00	GPM
11. D0400	REFUELNG WATER STORAGE TANK LEVEL	NORMAL		
12. D0402	REFUELING WATER STORAGE TA LEVEL	NOT LO		
13. D0401	REFUELING WATER STORAGE TANK LEVEL	NOTE MER LO		

## Group: 20 ----- CONTAINMENT SYSTEMS

1. A0590	NARRO RANGE CONTAIN. PRESS (-1 TO +1)	-----	PSIG	
2. A0785	INTER. RANGE CONTAIN. PRES (-5 TO 20)	0.0468	PSIG	
3. A147	WIDE RANGE CONTAIN. PRESS (-5 TO 60)	-----	PSIG	
4. A1228	LOWER CONT AMBINT AIR TEMP A	102.59	DEG F	
5. A1204	UPPER CONT AMBIENT AIR TEMP A	86.49	DEG F	
6. A1041	CONTINMENT SUMP LEVEL TRAIN A	0.00	FT	
7. A0671	CONTAINMENT SUMP LEVEL TRAIN B	-----	FT	
8. A0848	CONTAINMENT H2OONCENTRATION TRAIN A	0.00	%	
9. D3572	NS PUMP A (CONTAINMENT SPRAY)	OFF		
10. D3573	N PUMP B (CONTAINMENT SPRAY)	OFF		

## Group: 25 ----- RADIATION SYSTEMS

1. A0115	1EMF48 REACOR COOLANT MONITOR	51924.98	CPM	
2. A0829	1EMF51A IN CONTAINMENT HI RANGEAD MON	2.002E-04	R/HR	
3. A0835	MMF51B IN CONTAINMENT HI RANGE RAD MON	2.002-04	R/HR	
4. A0073	1EMF39H CONTAINMENT GASII RANGE	2.00	CPM	
5AA0067	1EMF39L CONTAINMENT GAS LO RANGE	28508.04	CPM	
6. A0061	1EMF38H COAINMENT PARTICULATE HI RANGE	5.00	CPM	
7. A0055	1EMF38L CONTAINMENT PARTICULATEOO RANGE	27029.62	CPM	
8. A1009	EMF36HH UNIT VENT GAS HI HI RANGE	4.55	R/HR	
9. A0018	1EMF36H UNIT VENT GAHHI RANGE	31.62	CPM	
1 A0012	1EMF36L UNIT VENT GAS LO RANGE	158.49	CPM	
11. A0019	1EMF35H UNT VENT PARTICULATE HI RANGE	22.96	CP	
12. A0013	1EMF35L UNIT VENT PARTICULATE RANGE	1031.52	CPM	
13. A0049	1EM37 UNIT VENT IODINE	40.16	CPM	
14. A0079	1EMF40 CONTAINMENT IODI	500.19	CPM	
1. A1368	1EMF24 STEAMLINE 1A RADIATION MONITOR	0.0110	mR/Hr	
16. A1374	1EMF25 STAMLINE 1B RADIATION MONITOR	0.0110	MHR	
17. A1380	1EMF26 STEAMLINE 1C RADIATIONMONITOR	0.0110	MR/HR	
18. A1386	1EMF27 STEAMLINE 1D RADIATION MONITOR	.0110	MR/HR	
19. A0127	EMF49H WASTE LIQUIDISCHARGE HI RANGE	-----	CPM	

## Group: 30 ----- ENVIRONMENTAL SYSTEMS

1. P0846	UPPER WIND SPEED (15 MIUTE AVERAGE)	-----	MPH	
2. P0848	LOWER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH	
3. P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAGE)	-----	DEG C	
. P0847	UPPER WIND DIRECTION (15 MINUTE AVERAE)	-----	DEG	
5. P0849	LOWER WID DIRECTION (15 MINUTE AVERAGE)	-----	G	
6. P0595	PRECIPITATION IN LAST 15 MIN	-----	IN	
7. P0851	AMBIENT AIR TEMPERATURE(15 MINUTE AVERAGE)	-----	DEG C	
8. A0863	UNIT VENT STACK FLW	53418.03	FT3/MN	

DTS01

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date:

10/20/83

Time:

10:15

## Group: 35 ----- IN-CORE THERMOCOUPLES

1. A0268	IN-CORE TEMP A10 T/C #2	554.52	DEG F
2. A016	IN-CORE TEMP J06 T/C #17	554.05	DEG F
3. A0155	IN-CORE TEMP F01T/C #43	554.92	DEG F
4. A0251	IN-CORE TEMP M07 T/C #59	554.15	DEG F
5. P0823	5 HIGHEST IN-CORE T/C TEMP MARGIN	-----	DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP	-----	DEG F
7. A133	IN-CORE TEMP K05 T/C #54	-----	DEG F
8. A1341	IN-CORE TEMP M11 T/C #60	-----	DEG F
9. A1287	IN-CORE TEMP D13 T/C #42	-----	DEG F
10. A1161	IN-COREEMP C04 T/C #3	-----	EG F

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

Time:

10/20/93 10:30

## Group: 05 -----

PRIMARY SYSTEM			
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	248.52	DEG F
2. A0971	NC LOOP B WIDE RANGE HOT LEG TEMP	248.33	DEG F
3. A0977	NC LOOP C WIE RANGE HOT LEG TEMP	248.56	DEG F
4. A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	248.52	DEG F
5. A1061	NCLOOP A WIDE RANGE COLD LEG TEMP	265.4	DEG F
6. A1067	NC LOOP B WIDE RANGE COD LEG TEMP	255.16	DEG F
7. A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	25.79	DEG F
8. A1079	NC LOOP D WE RANGE COLD LEG TEMP	207.89	DEG
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PSSS	169.24	PSIG
11. A1124	PZ LEVEL I (HOT CALIBRATED)	10000	%
12. D2803	REACTOR COOLANT PUMP A	OFF	
13D2804	REACTOR COOLANT PUMP B	OFF	
14. D2805	REACTOR COONT PUMP C	OFF	
15. D2806	REACTOR COOLANT PUMP D	OFF	
16. A1177	SURCE RANGE (FLUX) LEVEL CHANNEL 1	9.18	CP
17. A1206	SOURCE RANGE (FLUX) LEL CHANNEL 2	10.62	CPS
18 A0628	POWER RANGE AVG LEVEL QUADRANT 1 (N-43)	8.669E-09	%
19. P1385	REACTOR THMAL POWER, BEST ESTIMATE	0.00	%
20. A0602	JVCS BORON METER (ISOLATED ON Ph. A)	708.15	PPM
21. A1312	RVL1- TRAIN A - DYNAMIC HEAD D/P	.98	%
22. A1300	RVLIS - TRAIN A - UER RANGE LEVEL	95.08	%
3. A1306	RVLIS - TRAIN A - LOWER RANGE LEVEL	64.00	%
24. P1481	LOWEST NCSYSTEM SUBCOOLING MARGIN	92.93	D F

## Group: 10 -----

SECONDARY SYSTEM			
1. A1004	STEAM GEN A WIDE RANGE LEVEL	58.04	%
. A1005	STEAM GEN B WIDE RANGE LEVEL	57.03	%
3. A0970	STEAM GENC WIDE RANGE LEVEL	58.02	%
4. A0988	STEAM GEN D WIDE RANGE LEVEL	58.13	%
5. A1107	STEAM GEN A STEAM (LINE) PRESS I	41.10	PSIG
6. A1113	STEAM GEN B STEAM (LE) PRESS I	837.40	PSIG
A1119	STEAM GEN C STEAM (LINE) PRESS I	857.11	PSIG
8. A1125	STEAM GEND STEAM (LINE) PRESS I	838.05	PIG
9. P1412	TOTAL S/G A (MAIN) FEEDWATER LOW 1	0.00	MLB/HR
10. P1414	TOTAL S/G B (MAIN) FEEDWATER FLOW 1	0.00	MLB/HR
11. P1416	TOTAL S/G C (MAIN)EEEDWATER FLOW 1	0.00	MLB/HR
2. P1418	TOTAL S/G D (MAIN) FEEDWATER FLOW 1	0.00	MLB/HR
13. P1208	AUX FEEDATER FLOW TO S/G A	0.00	MB/HR
14. P1209	AUX FEEDWATER FLOW TO S/G B	0.00	MLB/HR
15. "10	AUX FEEDWATER FLOW TO S/G C	0.00	MLB/HR
16. .	AUX FEEDWATER FLOWTO S/G D	0.00	MLB/HR
7. A.	STEAM GEN A NARROW RANGE LEVEL IV	42.49	%
18. A1065	STEAM G B NARROW RANGE LEVEL IV	39.03	%
19. A1071	STEAM GEN C NARROW RANGE LEVEL	42.78	%
20. A107	STEAM GEN D NARROW RANGE LEVEL IV	42.67	%
21. A0736	MAIN STEAM HEADER PESSURE	780.73	PSIG

RDTSO1

LORE POWER COMPANY

Unit: MN 1

Page: 2

Date: 10/10/83 Time: 10:30

Group: 15 ----- AUXILIARY/INJECTION SYSTEMS				
1. D0970	NV PUMP A (HIGH HEAD SI)	ON		
2. D062	NV PUMP B (HIGH HEAD SI)	OFF		
3. A0827	BORON INJECTION HIGH HEAD SI) FLOW		433.49	GPM
4. D3574	NI PUMP A (INTERMEDIATE HEAD SI)	OFF		
5. D3576	NI PUMP B (INTERMEDIATE HEAD SI)	OFF		
6. D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF		
7. D098	ND PUMP B (LOW HEAD SI / RHR)	ON		
8. A0758	CHARGING PUMP DCHARGE HEADER FLOW		63.68	GPM
9. A0856	(LOW HEAD SI / RHR) ND HX RETURN FLO		0.00	GPM
10. A0764	LETDON HX OUTLET FLOW		0.00	GPM
11. D0400	REFUELING WATER STORAGE TK LEVEL	NORMAL		
12. D02	REFUELING WATER STORAGE TANK LEVEL	NOT O		
13. D0401	REFUELING WATERSTORAGE TANK LEVEL	NOT EMER LO		
Group: 20 ----- CONTAINMENT SYSTEMS				
1. A0590	NARROW RANGE CONTAIN. RESS (-1 TO +1)			PSIG
2. 785	INTER. RANGE CONTAIN. PRESS (-5 TO 20)	-0.1849		PSIG
3. A107	WIDE RANGE CONTAIN. PRESS (-5 TO 60)			PSIG
4. A1228	LOWER CONT AMBIET AIR TEMP A		88.14	DEG F
5. A1204	UPPER CONT AMBIET AIR TEMP A		80.41	DEG F
6. A1041	CONTAINMENT SUMP LEVEL TRAIN A		0.00	FT
7. A0671	CONTAINMENT SUMP LEVEL TRAN B			FT
8. A0848	CONTAINMENT H2 CONCENTRATION TRAIN A		0.00	%
9. D3572	NS PUMP A (CONTINMENT SPRAY)	OFF		
10. D3573	NS PUMP B (CONTAINMENT SPRAY)	OFF		
Group: 25 ----- RADIATION SYTEMS				
1. A015	1EMF48 REACTOR COOLANT MONITOR	51924.98		CPM
2. A0829	1EMF51A IN CONAINMENT HI RANGE RAD MON	2.021E-04		R/HR
3. A0835	1EMF51B IN CONTAINMENT HI RANGE RAD MON	2.021E-04		R/HR
4. A0073	1EMF9H CONTAINMENT GAS HI RANGE		2.0	CPM
5. A0067	1EMF39L CONTAINMENT GAS L RANGE	28507.98		CPM
6. A061	1EMF38U CONTAINMENT PARTICULATE HI RANGE		5.00	CPM
7. A0055	1EMF38L CONTAMENT PARTICULATE LO RANGE	27029.62		CPM
8. A1009	1EMF36HH UNIT VENT GAS HI HI RANGE		4.95	R/HR
9. A0018	1EM66H UNIT VENT GAS HI RANGE		16.4	CPM
10. A0012	1EMF36L UNIT VENT GAS LO RANGE	1.140E+09		CPM
11. 019	1EMF35H UNIT VENT PARTICULATE HI RANGE		25.13	CPM
12. A0013	1EMF35L UNIT ENT PARTICULATE LO RANGE	1554.24		CPM
13. A0049	1EMF37 UNIT VENT IODINE		514.61	CPM
14. A0079	1EM40 CONTAINMENT IODINE		500.	CPM
15. A1368	1EMF24 STEAMLINE 1A RADATION MONITOR		0.0110	mR/Hr
16. 1374	1EMF25 STEAMLINE 1B RADIATION MONITOR		0.0110	MR/HR
17. A1380	1EMF26 STEAMLNE 1C RADIATION MONITOR		0.0110	MR/HR
18. A1386	1EMF27 STEAMLINE 1D RADIATION MONOR		0.0110	MR/HR
19. A0127	EM99H WASTE LIQUID DISCHARGE HI RANGE			CPM
Grop: 30 ----- ENVIRONMENTAL SYSTEMS				
1. P0846	UPPER WIND SPDD (15 MINUTE AVERAGE)			MPH
2. P0848	LOWER WIND SPEED (15 MINUT AVERAGE)			MPH
3. P0850	LWER TO UPPER DELTA-T (15 MINUTE AVERAGE)			DEG C
4. P0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)			DEG
5 P0849	LOWER WIND DIRECTION (15 MINUTE AVERAGE)			DEG
6. P0595	PRECIPITATIN IN LAST 15 MIN			IN
7. P0851	AMBIENT AIR TEMPERATURE(15 MINUTEVERAGE)			DEG C
8. A0863	UIT VENT STACK FLOW	534103		FT3/MN

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date:

Time:

10/20/93 12:32

Group	35	IN-CORE THERMOCOUPLES		
1.	A0268	IN-CORE TEMP A0 T/C #2	282.75	DEG F
2.	A0166	IN-CORE TEMP J06 T/C #17	282.20	DEG F
3.	A0155	N-CORE TEMP F01 T/C #43	283.02	DEG
4.	A0251	IN-CORE TEMP M07 T/C #59	282.34	DEG F
5.	P0823	5 HIGHEST IN-CORE T/C TEMP MARGIN	-----	DEG F
6.	P0828	5 HIGHEST IN-CORE T/TTEMP	-----	DEG F
7.	A1323	IN-CORE TEMP O5 T/C #54	-----	DEG F
8.	A1341	IN-CORE TEMP M11 T/C #60	-----	DEG F
9.	A1287	INCORE TEMP D13 T/C #42	-----	DEG F
10.	A1161	IN-CORE TEMP C04 T/C #3	-----	DEG F

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date: 08/04/93

Time:

10/20/93 10:45

Group: 05	-----	PRIMARY SYSTEM	-----
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	252.03	DEG F
2. A0971	NC LOOP B WIDE RANGE HOT LEG TEMP	253.59	DEG F
3. A0977	NC LOOP C WIDE RANGE HOT LEG TEMP	252.99	DEG F
4. A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	253.14	DEG F
5. A1061	NC LOOP A WIDE RANGE COLD EG TEMP	233.93	DEG F
6. A177	NC LOOP B WIDE RANGE COLD LEG TEMP	256.63	DEG F
7. A1073	NC LOOP C WIDE RANGE COLD LEG TEMP	215.27	DEG F
8. A1079	NC LOOP D WIDE RANGE COLD LEG TEMP	212.29	DEG F
9. A0826	NC STEM (HOT LEG) WIDE RANGE PRESS	192.16	PSIG
11. A1124	PZR LEVEL I (HOT CALIBRAT)	100.00	%
12. D233	REACTOR COOLANT PUMP A	OF	
13. D2804	REACTOR COOLANT UMP B	OFF	
14. D2805	REACTOR COOLANT PUMP C	OFF	
15. D2806	REACOR COOLANT PUMP D	OFF	
16. A1177	SOURCE RANGE (FLUX) LEVECCHANNEL 1	5.53	CPS
17. A006	SOURCE RANGE (FLUX) LEVEL CHANNEL 2	5.54	CPS
18. A0628	POWER RANGE AVG LEVEL QUADRANT 1 (N-43)	8.608E-09	%
19. P1385	REACTOR THERMAL POWER, BEST ESTIMATE	0.00	%
20. A0602	CVCBBORON METER (ISOLATED ON Ph. A)	710.3	PPM
21. A1312	RVLIS - TRAIN A - DYNAMIC HEAD D/P	7.05	%
22. A13	RVLIS - TRAIN A - UPPER RANGE LEVEL	96.78	%
23. A1306	RVLIS - TRAIN - LOWER RANGE LEVEL	64.01	%
24. P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN	100.25	DEG F
Group: 10	-----	SECONDARY SYST	-----
1. A104	STEAM GEN A WIDE RANGE LEVEL	58.34	%
2. A1005	STEAM GEN B WDE RANGE LEVEL	57.29	%
3. A0970	STEAM GEN C WIDE RANGE LEVEL	58.33	%
4. A0988	STM GEN D WIDE RANGE LEVEL	58.3	%
5. A1107	STEAM GEN A STEAM (LINE PRESS I	793.29	PSIG
6. 1113	STEAM GEN B STEAM (LINE) PRESS I	785.72	PSIG
7. A1119	STEAM GEN C TEAM (LINE) PRESS I	807.43	PSIG
8. A1125	STEAM GEN D STEAM (LINE) PRESS I	790.46	PSIG
9. P1412	TOAL S/G A (MAIN) FEEDWATER FLOW 1	00	MLB/HR
10. P1414	TOTAL S/G B (MAIN) FEEWATER FLOW 1	0.00	MLB/HR
11.P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1	0.00	MLB/
12. P1418	TOTAL S/G D(MAIN) FEEDWATER FLOW 1	0.00	MLB/HR
13. P1208	AUX FEEDWATER FLOW TO S/G A	0.00	MLB/HR
14. P1209	AUX EEDWATER FLOW TO S/G B	0.00	MLB/HR
15. P1210	AUX FEEDWATER FLOW TO//G C	0.00	MLB/HR
16 P1211	AUX FEEDWATER FLOW TO S/G D	0.00	MLB/HR
17. A1059	STEAM GEN A NARRW RANGE LEVEL IV	42.30	%
18. A1065	STEAM GEN B NARROW RANGE LEVEL IV	38.59	%
19. A1071	STAM GEN C NARROW RANGE LEVEL IV	4.60	%
20. A1077	STEAM GEN D NARROW RAGE LEVEL IV	42.50	%
21 A0736	MAIN STEAM HEADER PRESSURE	710.08	PSIG

RDTSO1

DUKE POWECOMPANY

Unit: MNS 1

Page: 2

Date: 10/20/93 Time: 10:45

Group: 15 ----- AUXILIARY/INJECTION SYSTEMS	
1. D0970	N PUMP A (HIGH HEAD SI) ON
2. D0620	NV PUMP B (HIGH HEAD SI) OFF
3. A027	BORON INJECTION (HIGH HEAD SI) FLOW 443.33 GPM
4. D3574	NI PUMP A (INTERMEDIATE HEAD SI) OFF
5. D3576	NI PUMP B (INTERMEDIATE HEAD SI) OFF
6. D1042	PUMP A (LOW HEAD SI / RHR) OFF
7. D0968	ND PUMP B (LOW HEAD I / RHR) ON
8. A0758	CHARGNG PUMP DISCHARGE HEADER FLOW 49.6 GPM
9. A0856	(LOW HEAD SI / RHR) ND HX ETURN FLOW 0.00 GPM
10. A764	LETDOWN HX OUTLET FLOW 0.00 GPM
11. D0400	REFUELING WATE STORAGE TANK LEVEL NORMAL
12. D0402	REFUELING WATER STORAGE TANK LEVEL NOT LO
13. D0401	REFLING WATER STORAGE TANK LEVEL NOT EMER LO
Group: 20 ----- CONTAINMENT SYSTEMS	
1. A0590	NARROW RANGE NNTAIN. PRESS (-1 TO +1) ----- PSIG
2. A0785	INTER. RANGE CONTAIN. PRESS (-5 TO 20) -0.2167 PSIG
3. A1047	WID RANGE CONTAIN. PRESS (-5 TO 60) ----- PSIG
4. A1228	LOWER CONT AMBIENT AIR MMP A 87.54 DEG F
5. 204	UPPER CONT AMBIENT AIR TEMP A 78.81 DEG F
6. A1041	CONTAINMENT SUMP LEVEL TRAIN A 0.00 FT
7. A0671	CONTAINMENT SUMP LEVEL TRAIN B ----- FT
8. A0848	COTAINMENT H2 CONCENTRATION TRAIN A 0.00 %
9. D3572	NS PUMP A (CONTAINMENT PRAY) OFF
10. 573	NS PUMP B (CONTAINMENT SPRAY) FF
Group: 25 ----- RADIATION SYSTEMS	
1. A0115	1F48 REACTOR COOLANT MONITOR 519248 CPM
2. A0829	1EMF51A IN CONTAINMENTHI RANGE RAD MON 2.021E-04 R/HR
3. A0835	1EMF51B IN CONTAINMENT HI RANGE RAD MON 2.021E-04 R/HR
4. A0073	1EMF39H CONTNNMENT GAS HI RANGE 2.00 CPM
5. A0067	1EMF39L CONTAINMENT GAS LO RANGE 28507.98 CPM
6. A0061	1MF38H CONTAINMENT PARTICULATE HI RANGE 5.0 CPM
7. A0055	1EMF38L CONTAINMENT PARICULATE LO RANGE 27029.62 CPM
8. 1009	1EMF36HH UNIT VENT GAS HI HI RANGE 4.98 R/HR
9. A0018	1EMF36H UNI VENT GAS HI RANGE 16.60 CPM
10. A0012	1EMF36L UNIT VENT GAS LO RANGE 1.172E+09 CPM
11. A0019	MMF35H UNIT VENT PARTICULATE HI RANGE 258 CPM
12. A0013	1EMF35L UNIT VENT PARICULATE LO RANGE 1589.17 CPM
13 A0049	1EMF37 UNIT VENT IODINE 518.25 CPM
14. A0079	1EMF40 CONTINMENT IODINE 500.19 CPM
15. A1368	1EMF24 STEAMLINE 1A RADIATION MOITOR 0.0110 mR/Hr
16. A1374	EMF25 STEAMLINE 1B RADIATION MONITOR 0.010 MR/HR
17. A1380	1EMF26 STEAMLINE 1C RADATION MONITOR 0.0110 MR/HR
18 A1386	1EMF27 STEAMLINE 1D RADIATION MONITOR 0.0110 MR/HR
19. A0127	EMF49H WAS LIQUID DISCHARGE HI RANGE ----- CPM
Group: 30 ----- ENVIRONMENTAL SYSTEMS	
1. P0846	UPPER WIND SPEED (15 MINUTE AVERAGE) ----- MPH
P0848	LOWER WIND SPEED (15 MINUTE AVERAGE) ----- MPH
3. P0850	LOWER TO UPER DELTA-T (15 MINUTE AVERAGE) ----- DEG C
4. P0847	UPPER WIND DIRECTION (15 MINTE AVERAGE) ----- DEG
5. P0849	LWER WIND DIRECTION (15 MINUTE AVERAGE) ----- DEG
6. P0595	PRECIPITATION IN LAST 15 MIN ----- IN
7. P0851	AMBIENT AIR TEMPERATURE(15 MINUTE AVERAG ----- DEG C
8. A0863	UNIT VENT STACK FLOW 53418.03 FT/MN

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date: 10/20/93

Time: 10:45

Group: 35	IN-CORE THERMOCOUPLES		
1. A0268	IN-CORE TEMP A10 T/C #2	253.22	DEG F
2. A0166	-CORE TEMP J06 T/C #17	252.5	DEG F
3. A0155	IN-CORE TEMP F01 T/C #	253.59	DEG F
4. A0251	IN-CORE TEMP M07 T/C #59	252.84	DEG F
5. P0823	5 HIGHEST -CORE T/C TEMP MARGIN	-----	DEG
6. P0828	5 HIGHEST IN-CORE T/C TEMP	-----	DEG F
7. A1323	N-CORE TEMP K05 T/C #54	-----	DEG F
8. A1341	IN-CORE TEMP M11 T/C#60	-----	DEG F
9. A1287	IN-CORE TEMP D13 T/C #42	-----	DEG F
10. A1161	IN-CORE TE C04 T/C #3	-----	DEG

RDTSO1

DUKE POWER COMPANY

Unit: F'S 1

Page: 1

Date: 10/20/93 Time: 11:00

Group: 05	-----	PRIMARY SYSTEM	-----
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	243.33	DEG F
2. A0971	NC LOOP WIDE RANGE HOT LEG TEMP	243.38	DEG F
3. A0977	NC LOOP C WIDE RANGE HOT LE TEMP	243.38	DEG F
4. A098	NC LOOP D WIDE RANGE HOT LEG TEMP	2243.25	DEG F
5. A1061	NC LOOP A WIDE RAE COLD LEG TEMP	232.22	DEG F
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEMP	242.80	DEG F
7. A1073	NC LOOC WIDE RANGE COLD LEG TEMP	208.30	DEG F
8. A1079	NC LOOP D WIDE RANGE COLD LG TEMP	212.95	DEG F
9. A08	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	189.94	PSIG
11. A1124	PZR LEVEL I (HOTCALIBRATED)	100.00	%
12. D2803	REACTOR COOLANT PUMP A	OFF	
13. D2804	REACTO COOLANT PUMP B	OFF	
14. D2805	REACTOR COOLANT PUMP C	OFF	
15. D286	REACTOR COOLANT PUMP D	OFF	
16. A1177	SOURCE RANGE (FLX) LEVEL CHANNEL 1	7.87	CPS
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL 2	7.10	CPS
18. A0628	POWERAANGE AVG LEVEL QUADRANT 1 (N-43)	8.399E-09	%
19. P1385	REACTOR THERMAL POWEF, BESESTIMATE	0.00	%
20. A062	CVCS BORON METER (ISOLATED ON Ph. A)	712.59	PPM
21. A1312	RVLIS - TRAIN - DYNAMIC HEAD D/P	6.86	%
22. A1300	RVLIS - TRAIN A - UPPER RANGE LEVEL	96.82	%
23. A1306	RVLIS - TRAIN A - LOWER RANGE LEVEL	64.00	%
24. P1481	LOWEST NC SYSTEM SUBCOOLIG MARGIN	110.16	DEG F

## Group: 10 ----- SOONDARY SYSTEM -----

1. A1004	STEAM GEN A WIDE RANGE LEVEL	58.58	%
2. A1005	STEAM GEN B WIDE RANGE LEVEL	57.47	%
3. A0970	STEAM GEN C WIDE RANGE LEEL	58.61	%
4. A988	STEAM GEN D WIDE RANGE LEVEL	58.57	%
5. A1107	STEAM GEN A STAM (LINE) PRESS I	757.18	PSIG
6. A1113	STEAM GEN B STEAM (LINE) PRESS I	756.83	PSIG
7. A1119	STEAM GEN C STEAM (LINE) PRESS I	764.9	PSIG
8. A1125	STEAM GEN D STEAM (LINE)PRESS I	774.66	PSIG
9. P12	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	0.00	MLB/HR
10. P1414	TOTAL S/G B (MAI) FEEDWATER FLOW 1	0.00	MLB/HR
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW	0.00	MLB/HR
12. P1418	TOTL S/G D (MAIN) FEEDWATER FLOW 1	0.0	MLB/HR
13. P1208	AUX FEEDWATER FLOW TO S/G A	0.00	MLB/HR
14. 209	AUX FEEDWATER FLOW TO S/G B	0.00	MLB/HR
15. P1210	AUX FEEDWATER LOW TO S/G C	0.00	MLB/R
16. P1211	AUX FEEDWATER FLOW TO S/G D	0.00	MLB/HR
17. A1059	STEAM GEN A NARROW RANGE LEVEL IV	4.17	%
18. A1065	STEAM GEN B NARROW RNGE LEVEL IV	38.44	%
1. A1071	STEAM GEN C NARROW RANGE LEVEL IV	42.44	%
20. A1077	STEAM GEN NARROW RANGE LEVEL IV	42.57	%
21. A0736	MAIN STEAM HEADER PRESSURE	640.97	PSIG

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page:

Date: 10/20/93 Time: 11:00

Group: 15 ----- AUXILIARY INJECTION SYSTEMS			
1. D0970	NV PUMP A (HIGH HEAD SI)	ON	
2. D0620	NV PUMP B (HIGH HEAD SI)	OFF	
3. A0827	BORON INJECTION (HIGH HEAD SI) FOW		453.79 GPM
4. D3574	N PUMP A (INTERMEDIATE HEAD SI)	OFF	
5. D3576	NI PUMP B (INTERMEDIATE EAD SI)	OFF	
6DD1042	ND PUMP A (LOW HEAD SI / RHR)	OFF	
7. D0968	ND PUMP B (LOW HEA SI / RHR)	ON	
8. A0758	CHARGING PUMP DISCHARGE HEADER FOW		36.28 GPM
9. A0856	(OW HEAD SI / RHR) ND HX RETURN FLOW		00 GPM
10. A0764	LETDOWN HX OUTLET FLO		0.00 GPM
11 D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL	
12. D0402	REFUELING WTER STORAGE TANK LEVEL	NOT LO	
13. D0401	REFUELING WATER STORAGE TANK LEE:	NOT EMER LO	

Group: 20 ----- CONTAINNT SYSTEMS			
. A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)	-----	PSIG
2. A0785	INTER. RANE CONTAIN. PRESS (-5 TO 20)	-0.2328	PSI
3. A1047	WIDE RANGE CONTAIN. PRESS (-TO 60)	-----	PSIG
4. A1228	OWER CONT AMBIENT AIR TEMP A	.08	DEG F
5. A1204	UPER CONT AMBIENT AIR TEMP A	78.7	DEG F
6. A1041	CONTAINMENT SUMP LEVEL RAIN A	0.00	FT
7.0671	CONTAINMENT SUMP LEVEL TRAIN B	-----	FT
8. A0848	CONTAINMENT2 CONCENTRATION TRAIN A	0.00	%
9. D3572	NS PUMP A (CONTAINMENT SPRAY)	OFF	
10. D3573	S PUMP B (CONTAINMENT SPRAY)	OFF	

Gup: 25 ----- RADIATION SYSTEMS			
1. A0115	1EMF48 REATOR COOLANT MONITOR	51924.98	CPM
2. A0829	1EMF51A IN CONTAINMENT HI RANGERAD MON	2.031E-04	R/HR
3. A0835	EMF51B IN CONTAINMENT HI RANGE RAD MON	2.03E-04	R/HR
4. A0073	1EMF39H CONTAINMENT G HI RANGE	2.00	CPM
. A0067	1EMF39L CONTAINMENT GAS LO RANGE	28507.98	CPM
6. A0061	1EMF38H CTTAINMENT PARTICULATE HI RANGE	5.00	CFM
7. A0055	1EMF38L CONTAINMENT PARTICULAT LO RANGE	27029.62	CPM
8. A1009	1EMF36HH UNIT VENT GAS HI HI RANGE	496	R/HR
9. A0u18	1EMF36H UNIT VENT GA HI RANGE	16.50	CPM
.. A0012	1EMF36L UNIT VENT GAS LO RANGE	1.151E+09	CPM
11. A0019	1EMF35H UNI VENT PARTICULATE HI RANGE	25.18	CP
12. A0013	1EMF35L UNIT VENT PARTICULATE O RANGE	1565.81	CPM
13. A0049	1EMF37 UNIT VENT IODE	515.81	CPM
1 A0079	1EMF40 CONTAINMENT IODINE	500.19	CPM
15. A1368	1EMF24 STEMLINE 1A RADIATION MONITOR	0.0110	mRr
16. A1374	1EMF25 STEAMLINE 1B RADIATION ONITOR	0.0110	MR/HR
17. A1380	1EMF26 STEAMLINE 1C RADIATION MONITOR	0110	MR/HR
18. A1386	1EMF27 STEAMLINE 1D RADIATION MONITOR	0.0110	MR/HR
9. A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE	-----	CPM

Group: 30 ----- ENVIRONMENTAL STTEMS			
1. P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH
2. P0848	LOWER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH
. P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAGE)	-----	DEG C
4. P0847	UPPER WDD DIRECTION (15 MINUTE AVERAGE)	-----	GG
5. P0849	LOWER WIND DIRECTION (15 MNUTE AVERAGE)	-----	DEG
6. P0595	PRECIPITATION IN LAST 15 MIN	-----	IN
7. P0851	AMBIENT AIR TEMPERURE(15 MINUTE AVERAGE)	-----	DEG C
8. A0863	UNIT VENT STACK FLOW	53418.03	FT3/MN

RDTSO1

UKE POWER COMPANY

Unit: MNS 1

Page: 3

Date: 10/20/93 Time: 11:00

Group: 35	IN-CORE THERMOCUPLES	
1. A026	IN-CORE TEMP A10 T/C #2	247.57 DEG F
2. A0166	IN-CORE TEMP J06 /C #17	247.08 DEG F
3. A0155	IN-CORE TEMP F01 T/C #43	247.98 DEG F
4. A0251	IN-CORETEMP M07 T/C #59	247.36 DE F
5. P0823	5 HIGHEST IN-CORE T/C TEMP RGIN	----- DEG F
6. P082	5 HIGHEST IN-CORE T/C TEMP	----- DEG F
7. A1323	IN-CORE TEMP K05 T/C #54	----- DEG F
8. A1341	IN-CORE TEMP M11 T/C #60	----- DEG F
9. A1287	IN-CO TEMP D13 T/C #42	----- DEG F
10. A1161	IN-CORE TEMP C04 T/C #3	----- DEG F

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date: 10/20/93

Time: 11:15

## Group: 05

PRIMARY SYSTEM		
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	239.31 DEG F
2. A0971	NC LP B WIDE RANGE HOT LEG TEMP	247.43 DEG F
3. A0977	NC LOOP C WIDE RANGE HOT G TEMP	248.69 DEG F
4. A03	NC LOOP D WIDE RANGE HOT LEG TEMP	247.29 DEG F
5. A1061	NC LOOP A WIDE ANGE COLD LEG TEMP	231.74 DEG F
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEMP	234.68 DEG F
7. A1073	NC LPP C WIDE RANGE COLD LEG TEMP	232.8 DEG F
8. A1079	NC LOOP D WIDE RANGE COLDLEG TEMP	235.60 DEG F
9. 826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	106.12 PSIG
11. A1124	PZR LEVEL I (HOT CALIBRATED)	100.00 %
12. D2803	REACTOR COOLANT PUMP A	OFF
13. D2804	REATOR COOLANT PUMP B	OFF
14. D2805	REACTOR COOLANT PUMP C	OFF
15. D286	REACTOR COOLANT PUMP D	FF
16. A1177	SOURCE RANGE FLUX) LEVEL CHANNEL 1	6.99 CPS
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL	8.26 CPS
18. A0628	PORR RANGE AVG LEVEL QUADRANT 1 (N-43)	8.343E-9 %
19. P1385	REACTOR THERMAL POWER, EST ESTIMATE	0.00 %
20. 0602	CVCS BORON METER (ISOLATED ON Ph. A)	714.73 PPM
21. A1312	RVLIS - TRAI A - DYNAMIC HEAD D/P	6.90 %
22. A1300	RVLIS - TRAIN A - UPPER RANGE LEVL	89.03 %
23. A1306	RVL - TRAIN A - LOWER RANGE LEVEL	640 %
24. P1481	LOWEST NC SYSTEM SUBCOING MARGIN	46.45 DEG F

## Group: 10

SECONDARY SYSTEM		
1. A1004	STEAM GEN A WIDE RANGE LEVEL	58.83 %
2. A1005	STAM GEN B WIDE RANGE LEVEL	5771 %
3. A0970	STEAM GEN C WIDE RANGE EVEL	58.91 %
4.A0988	STEAM GEN D WIDE RANGE LEVEL	58.89 %
5. A1107	STEAM GEN ATEAM (LINE) PRESS I	716.04 PSI
6. A1113	STEAM GEN B STEAM (LINE) PRESS	704.83 PSIG
7. A1119	TEAM GEN C STEAM (LINE) PRESS I	71550 PSIG
8. A1125	STEAM GEN D STEAM (LINE PRESS I	723.68 PSIG
P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	0.00 MLB/HR
10. P1414	TOTAL S/G B (MIN) FEEDWATER FLOW 1	0.00 MLBHR
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLO11	0.00 MLB/HR
12. P1418	OTAL S/G D (MAIN) FEEDWATER FLOW 1	0.00 MLB/HR
13. P1208	AUX FEEDWATER FLOW T S/G A	0.00 MLB/HR
1. P1209	AUX FEEDWATER FLOW TO S/G B	0.00 MLB/HR
15. P1210	AUX FEEDWER FLOW TO S/G C	0.00 MLHR
16. P1211	AUX FEEDWATER FLOW TO S/G D	0.00 MLB/HR
17. A1059	STEAM GEN A NARROW RANGE LEVEL IV	4.00 %
18. A1065	STEAM GEN B NARROW RNGE LEVEL IV	37.96 %
. A1071	STEAM GEN C NARROW RANGE LEVEL IV	42.23 %
20. A1077	STEAM GEND NARROW RANGE LEVEL IV	42.36 %
21. A0736	MAIN STEAM HEADER PRESSURE	572.57 PSIG

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 2

Date: 10/20/93

Time: 11:15

Group: 15		AUXILIA/INJECTION SYSTEMS			
1.	D0970	NV PUMP A (HIGH HEAD SI)	ON		
2.	D0620	NV PUMP B(HIGH HEAD SI)	OFF		
3.	A0827	BORON INJECTION (HIGH HEAD SI FLOW		463.08	GPM
4.	D3574	NI PUMP A (INTERMEDIATE HEAD SI)	OFF		
5.	D3576	NI PUMP B (INTERMEDIATE HEAD SI)	OFF		
6.	D1042	ND PUMP A (LOW HEAD SI / RHR)	OFF		
7.	D0968	ND PUMP B LOW HEAD SI / RHR)	OFF		
8.	A0758	CHARGING PUMP DISCHARGE HEADE FLOW		34.10	GPM
9.	A0856	(LOW HEAD SI / RHR) ND HX RETURN FLOW		0.00	GPM
10.	A0764	LETDOWN HX OUTLET OOW		0.00	GPM
11.	D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL		
12.	D0402	REFUELIN WATER STORAGE TANK LEVEL	NOT LO		
13.	D0401	REFUELING WATER STORAGE TANKEEVEL	NOT EMER LO		
Group: 20		CONTANMENT SYSTEMS			
1.	A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)			PSIG
2.	A0785	INTER. ANGE CONTAIN. PRESS (-5 TO 20)	-0.2432		SIG
3.	A1047	WIDE RANGE CONTAIN. PRESS-5 TO 60)			PSIG
4.	A1228	LOWER CONT AMBIENT AIR TEMP A	86.86		DEG F
5.	A1204	UPPER CONT AMBIEN AIR TEMP A	77.58		DEG F
6.	A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00		FT
7.	A0671	CONTAINMENT SUMP LEVEL TRAIN B			FT
8.	A0848	OONTAINMENT H2 CONCENTRATION TRAIN A	0.00		%
9.	D3572	NS PUMP A (CONTAINMT SPRAY)	OFF		
..	D3573	NS PUMP B (CONTAINMENT SPRAY)	OFF		
Group: 25		RADIATION SYSTEMS			
1.	A0115	1EMF48 REACTOR COOLANT MONITOR	519.98		CPM
2.	A0829	1EMF51A IN CONTAINMNT HI RANGE RAD MON	2.031E-04		R/HR
3	A0835	1EMF51B IN CONTAINMENT HI RANGE RAD MON	2.031E-04		R/HR
4.	A0073	1EMF39H CONTNNMENT GAS HI RANGE	2.00		CP
5.	A0067	1EMF39L CONTAINMENT GAS LO RAGE	28507.98		CPM
6.	A0061	EMF38H CONTAINMENT PARTICULATE HI RANGE	5.00		CPM
7.	A0055	1EMF38L CONTAINMENTPARTICULATE LO RANGE	27029.62		CPM
8.	A1009	1EMF36HH UNIT VENT GAS HI HI RANGE	4.86		R/HR
9.	A0018	1EMF36HUNIT VENT GAS HI RANGE	15.91		PM
10.	A0012	1EMF36L UNIT VENT GAS LO RAE	1.026E+09		CPM
11.	A0019	1EMF35H UNIT VENT PARTICULATE HI RANGE	24.62		CPM
12.	A0013	1EMF35L UNIT VENTPARTICULATE LO RANGE	1430.21		CPM
13.	A0049	1EMF37 UNIT VENT IODINE	501.69		CPM
14.	A0079	1EMF40 CTAINMENT IODINE	500.19		PPM
15.	A1368	1EMF24 STEAMLINE 1A RADIATIN MONITOR	0.0110		mR/Hr
16.	A137	1EMF25 STEAMLINE 1B RADIATION MONITOR	0.0110		MR/HR
17.	A1380	1EMF26 STEAMLINE C RADIATION MONITOR	0.0110		MR/HR
8.	A1386	1EMF27 STEAMLINE 1D RADIATION MONITOR	0.0110		MR/HR
19.	A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE			CPM
Group: 3		ENVIRONMENTAL SYSTEMS			
1.	P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)			MPH
2.	P0848	LOWER WIND SPEED (15 MINUTE AVEAGE)			MPH
3.	P0850	LOWER O UPPER DELTA-T (15 MINUTE AVERAGE)			DEG C
4.	P0847	UPPER WIND DIRECTION (15INUTE AVERAGE)			DEG
5.	P08	LOWER WIND DIRECTION (15 MINUTE AVERAGE)			DEG
6.	P0595	PRECIPITATION IN LA 15 MIN			IN
7.	P0851	AMBIENT AIR TEMPERATURE(15 MINUTE AVERAGE)			DEG C
8.	A0863	UNIT VNT STACK FLOW	53418.03		FT3/MN

DTS01

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date: 10/20/93 Time: 11:15

## Group: 5 ----- IN-CORE THERMOCOUPLES -----

1. A0268	IN-CORE TEMP A10 T/C #2	238.68	DEG F
. A0166	IN-CORE TEMP J06 T/C #17	238.21	DEG F
3. A0155	IN-CORE TEMP F01 T/C #43	239.10	DEG F
4. A0251	IN-CORE TEMP M07 T/C #59	238.47	DEG F
5. P03	5 HIGHEST IN-CORE T/C TEMP MARGIN	-----	DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP	-----	DEG F
7. A1323	IN-CORE TEMP K05 T/C #54	-----	DEG F
8. 1341	IN-CORE TEMP M11 T/C #60	-----	DEG F
9. A1287	IN-CORE TEMP D13 T/C #42	-----	DEG F
10. A1161	IN-CORE TEMP C04 T/C #3	-----	DEG F

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

Time:

10/24/93 11:30

## Group: 05

	PRIMARY SYSTEM		
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	279.81	DEG F
2. A0971	NC LOOP B WIDE RANGE HOT LEG TEMP	280.12	DEG F
3. A0977	NC LOOP C WIDERANGE HOT LEG TEMP	280.26	DEG F
4. A0983	NC LOOP D WIDE RANGE HOT LEG TEMP	280.28	DEG F
5. A1061	NC OOP A WIDE RANGE COLD LEG TEMP	276.	DEG F
6. A1067	NC LOOP B WIDE RANGE CO LEG TEMP	267.50	DEG F
7. 1073	NC LOOP C WIDE RANGE COLD LEG TEMP	248.45	DEG F
8. A1079	NC LOOP D WIDE RANGE COLD LEG TEMP	237.01	DEG F
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRES	50.39	PSIG
11. A1124	PZ LEVEL I (HOT CALIBRATED)	88.	%
12. D2803	REACTOR COOLANT PUMP A	OFF	
13. 2804	REACTOR COOLANT PUMP B	FF	
14. D2805	REACTOR COOLANPUMP C	OFF	
15. D2806	REACTOR COOLANT PUMP D	OFF	
16. A1177	SORCE RANGE (FLUX) LEVEL CHANNEL 1	10.	CPS
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL 2	8.45	CPS
18. 0628	POWER RANGE AVG LEVEL QUADRANT 1 (N-43)	8.707E-09	%
19. P1385	REACTOR THERAL POWER, BEST ESTIMATE	0.00	%
20. A0602	CVCS BORON METER (ISOLATED ON Ph A)	716.94	PPM
21. A1312	LIS - TRAIN A - DYNAMIC HEAD D/P	113	%
22. A1300	RVLIS - TRAIN A - UPPR RANGE LEVEL	71.72	%
23. A1306	RVLIS - TRAIN A - LOWER RANGE LEVEL	64.00	%
24. P1481	LOWEST NC SSTEM SUBCOOLING MARGIN	-29.21	DEG F

## Group: 10

	SECONDARY SYSTEM		
1. A1004	STEAM GEN A WIDE RAN LEVEL	59.01	%
2 A1005	STEAM GEN B WIDE RANGE LEVEL	57.88	%
3. A0970	STEAM GEN C WIDE RANGE LEVEL	59.10	%
4. A0988	STEAM GEN D WIDE RANGE LEVEL	59.08	%
5. A1107	TTEAM GEN A STEAM (LINE) PRESS I	69.25	PSIG
6. A1113	STEAM GEN B STEAM (LNE) PRESS I	671.38	PSIG
7. A1119	EEAM GEN C STEAM (LINE) PRESS I	686.01	PSIG
8. A1125	STEAM GEN D SEAM (LINE) PRESS I	693.93	PSG
9. P1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	0.00	MLB/HR
10. P1414	TOTAL S/G B (MAIN) FEEDWATER FLOW 1	0.00	MLB/HR
11. P1416	TOTAL S/G C (MAIN) EEDWATER FLOW 1	0.00	MLB/HR
12.P1418	TOTAL S/G D (MAIN) FEEDWATER FLOW 1	0.00	MLB/HR
13. P1208	AUX FEEDWAR FLOW TO S/G A	0.00	MB/HR
14. P1209	AUX FEEDWATER FLOW TO S/G B	0.00	MLB/HR
15. P1210	AUX FEEDWATER FLOW TO S/G C	0.0	MLB/HR
16. P1211	AUX FEEDWATER FLOW TOS/G D	0.00	MLB/HR
.. A1059	STEAM GEN A NARROW RANGE LEVEL IV	41.91	%
18. A1065	STEAM GEN B NARROW RANGE LEVEL IV	37.65	
19. A1071	STEAM GEN C NARROW RANGE LEVEL I	42.11	%
20. A1077	STEAM GEN D NARROW RANGE LEVEL IV	42.23	%
21. A0736	MAIN STEAM HEADER PESSURE	504.66	

DTS01

DUKE POWER COMPANY

Unit: MNS

Page: 2

Date:

10/29/93

Time:

11:30

Group: 15	AUXILIARY/INJECTION SYSTEMS			
1. D0970	NV PUMP A (HIGH HEAD SI)	OFF		
2. D0620	NV PUMP B (HIGH HEAD SI)	OFF		
3. A0827	BORON INJECTION (GH HEAD SI) FLOW		0.00	GPM
4. D3574	NI PUMP A (INTERMEDIATE HEAD SI)	OFF		
5. D3576	NI PUMP B NNTERMEDIATE HEAD SI)	OFF		
6. D1042	ND PUMP A (LOW HEAD SI / RHR	OFF		
7. D0968	ND PUMP B (LOW HEAD SI / RHR)	OFF		
8. A0758	CHARGING PUM DISCHARGE HEADER FLOW		0.00	GPM
9. A0856	(LOW HEAD SI / RHR) ND HX RETURN FLOW		0.00	GPM
10. A0764	LETDOWN HX OUTLET FLO		0.00	GPM
11 D0400	REFUELING WATER STORAGE TANK LEVEL	NORMAL		
12. D0402	REFUELING WATER STORAGE TANK LEVEL	NOT LO		
13. D0401	REFUELING WATER STORAGE TANK LVEL	EMER LO		
Group: 20	CONTAINMENT SYSTEMS			
.. A0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)	-----	PSIG	
2. A0785	INTER. RAN CONTAIN. PRESS (-5 TO 20)	-0.2316	PSG	
3. A1047	WIDE RANGE CONTAIN. PRESS (- TO 60)	-----	PSIG	
4. A1228	LOWER CONT AMBIENT AIR TEMP A	88.02	DEG F	
5. A1204	UPPER CONT AMBIENT IR TEMP A	77.61	DEG F	
. A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00	FT	
7. A0671	CONTAINMEN SUMP LEVEL TRAIN B	-----	F	
8. A0848	CONTAINMENT H2 CONCENTRATION AAIN A	0.00	%	
9. D3572	NS PUMP A (CONTAINMENT SPRAY)	OFF		
10. D3573	NS PUMP B (CONTAINMNT SPRAY)	OFF		
Group: 25	RADIATION SYSTEMS			
1. A0115	1EMF48 REACTOR COOLANT MONITO	5924.98	CPM	
2. A0829	1EMF51A IN CONTAINNNT HI RANGE RAD MON	2.021E-04	R/HR	
3. A0835	1EMF51B IN CONTAINMENT HI RANGE RAD MON	2.021E-04	R/HR	
4. A0073	1EMF39HONTAINMENT GAS HI RANGE	2.00	C	
5. A0067	1EMF39L CONTAINMENT GAS LO RNGE	28507.98	CPM	
6. A0061	1EMF38H CONTAINMENT PARTICULATE HI RANGE	5.00	CPM	
7. A0055	1EMF38L CONTAINMEN PARTICULATE LO RANGE	27029.62	CPM	
8. A1009	1EMF36HH UNIT VENT GAS HI HI RANGE	4.75	R/HR	
9. A0018	1EMF36H UN VENT GAS HI RANGE	15.29	PM	
10. A0012	1EMF36L UNIT VENT GAS LO RAGE	8.975E+08	CPM	
11. A001	1EMF35H UNIT VENT PARTICULATE HI RANGE	24.03	CPM	
12. A0013	1EMF35L UNIT VENPARTICULATE LO RANGE	1289.15	CPM	
13. A0049	1EMF37 UNIT VENT IODINE	487.00	CPM	
14. A0079	1EMF40CONTAINMENT IODINE	500.19	CPM	
15. A1368	1EMF24 STEAMLINE 1A RADIATION MONITOR	0.0110	m/Hr	
16. A1374	1EMF25 STEAMLINE 1B RADIATION ONITOR	0.0110	MR/HR	
17. A1380	1EMF26 STEAMLINE 1C RADIATION MONITOR	.0110	MR/HR	
18. A1386	1EMF27 STEAMLINE 1D RADIATION MONITOR	0.0110	MR/HR	
9. A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE	-----	CPM	
Group: 30	ENVIRONMENTAL STEMS			
1. P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH	
2. P0848	LOWER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH	
3. P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAE)	-----	DEG C	
4. P0847	UPPER WD DIRECTION (15 MINUTE AVERAGE)	-----	DE	
5. P0849	LOWER WIND DIRECTION (15 MUUTE AVERAGE)	-----	DEG	
6. P0595	PRECIPITATION IN LAST 15 MIN	-----	IN	
7. P0851	AMBIENT AIR TEMPERTURE(15 MINUTE AVERAGE)	-----	DEG C	
8AA0863	UNIT VENT STACK FLOW	53418.03	FT3/MN	

RDT501

UKE POWER COMPANY

Unit: MNS 1

Page: 3

Date:

Time:

10/20/93 11:30

## Group: 35 ----- IN-CORE THERMOUPLES -----

1. A026	IN-CORE TEMP A10	T/C #2	177.17	DEG F
2. A0166	IN-CORE TEMP J06	T/C #17	177.09	DEG F
3. A0155	IN-CORE TEMP F01	T/C #43	178.18	DEG F
4. A0251	IN-CORE TEMP M07	T/C #59	177.96	DEGF
5. P0823	5 HIGHEST IN-CORE T/C TEMP	ARGIN	-----	DEG F
6. P082	5 HIGHEST IN-CORE T/C TEMP		-----	DEG F
7. A1323	IN-CORE TEMP K05TT	C #54	-----	DEG F
8. A1341	IN-CORE TEMP M11	T/C #60	-----	DEG F
9. A1287	IN-CORE TEMP D13	T/C #42	-----	DEG F
10. A1161	IN-CORE TEMP C04	T/C #3	-----	DEG F

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

Time: 11:45

10/20/93

Group: 05

## PRIMARY SYSTEM

1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	287.67	DEG F
2. A0971	NC LOOP WIDE RANGE HOT LEG TEMP	287.67	DG F
3. A0977	NC LOOP C WIDE RANGE HOT LEG EMP	287.67	DEG F
4. A0983	C LOOP D WIDE RANGE HOT LEG TEMP	77.76	DEG F
5. A1061	NC LOOP A WIDE RAN COLD LEG TEMP	287.66	DEG F
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEMP	287.89	DEG F
7. A1073	NC LOOP WIDE RANGE COLD LEG TEMP	287.75	DG F
8. A1079	NC LOOP D WIDE RANGE COLD LEGTEMP	287.84	DEG F
9. A0826	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	47.69	PSIG
11. A1124	PZR LEVEL I (HOT LIBRATED)	28.59	%
12. D2803	REACTOR COOLANT PUMP A	OFF	
13. D2804	REACTORCOOLANT PUMP B	OFF	
14. D2805	REACTOR COOLANT PUMP C	OFF	
15. D280	REACTOR COOLANT PUMP D	OFF	
16. A1177	SOURCE RANGE (FLU) LEVEL CHANNEL 1	9.55	CPS
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL 2	5.86	CPS
18. A0628	POWER NNGE AVG LEVEL QUADRANT 1 (N-43)	8.490E-09	%
19. P135	REACTOR THERMAL POWER, BEST ESTIMATE	0.0	%
20. A062	CVCS BORON METER (ISOLATED ON Ph. A)	718.95	PPM
21. A1312	RVLIS - TRAIN A DYNAMIC HEAD D/P	5.10	%
2. A1300	RVLIS - TRAIN A - UPPER RANGE LEVEL	68.00	%
23. A1306	RVLIS- TRAIN A - LOWER RANGE LEVEL	55.36	%
24. P1481	LOWEST NC SYSTEM SUBL COOLING MARGIN	-36.37	DEG F

Group: 10

## SONDARY SYSTEM

1. A1004	STEAM GEN A WIDE RANGE LEVEL	59.12	%
2. A1005	STEAM GEN B WIDE RANGE LEVEL	58.01	%
3. A0970	STEAM GEN C WIDE RANGE LEEL	59.21	%
4. A88	STEAM GEN D WIDE RANGE LEVEL	59.33	%
5. A1107	STEAM GEN A STAM (LINE) PRESS I	673.16	PSIG
6. A1113	STEAM GEN B STEAM (LINE) PRESS I	643.40	PSIG
7. A1119	STEAM GEN C STEAM (LINE) PRESS I	670.9	PSIG
8. A1125	STEAM GEN D STEAM (LINEPRESS I	654.76	PSIG
9. P412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	0.00	MLB/HR
10. P1414	TOTAL S/G B (MAIN) FEDWATER FLOW 1	0.00	MLB/H
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1	0.00	MLB/HR
12. P1418	TOLL S/G D (MAIN) FEEDWATER FLOW 1	0.	MLB/HR
13. P1208	AUX FEEDWATER FLOW TO SG A	0.00	MLB/HR
14. 1209	AUX FEEDWATER FLOW TO S/G B	0.00	MLB/HR
15. P1210	AUX FEEDWATERFLOW TO S/G C	0.00	MLB/H
16. P1211	AUX FEEDWATER FLOW TO S/G D	0.00	MLB/HR
17. A1059	STAM GEN A NARROW RANGE LEVEL IV	41.8	%
18. A1065	STEAM GEN B NARROW RANGE VEL IV	37.38	%
19.1071	STEAM GEN C NARROW RANGE LEVEL IV	42.07	%
20. A1077	STEAM GEN D NRROW RANGE LEVEL IV	42.07	%
21. A0736	MAIN STEAM HEADER PRESSURE	438.34	PSIG

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 2

Date:

Time:

10/20/93

11:45

Group: 15	AUXILIARY/INJECTION SYSTEMS			
1. D970	NV PUMP A (HIGH HEAD SI)	FF		
2. D0620	NV PUMP B (HIH HEAD SI)	OFF		
3. A0827	BORON INJECTION (HIGH HEAD SI) FLO		0.00	GPM
4. D3574	NI PUM A (INTERMEDIATE HEAD SI)	OFF		
5. D3576	NI PUMP B (INTERMEDIAT HEAD SI)	OFF		
6.1042	ND PUMP A (LOW HEAD SI / RHR)	OFF		
7. D0968	ND PUMP B (LW HEAD SI / RHR)	OFF		
8. A0758	CHARGING PUMP DISCHARGE HEADER FW		0.00	GPM
9. A0856	(OW HEAD SI / RHR) ND HX RETURN FLOW		0.00	GPM
10. A0764	LETDOWN HX OUTLET FLOW		0.00	GPM
11.D0400	REFUELING WATER STORAGE TANK LEVEL	NNORMAL		
12. D0402	REFUELING WAER STORAGE TANK LEVEL	LO		
13. D0401	REFUELING WATER STORAGE TANK LEVL	EMER LO		
Group: 20	CONTAINMNT SYSTEMS			
1. 0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)			PSIG
2. A0785	INTER. RANGCONTAIN. PRESS (-5 TO 20)	-0.2142		PSIG
3. A1047	WIDE RANGE CONTAIN. PRESS (-50 60)			PSIG
4. A1228	WWER CONT AMBIENT AIR TEMP A	8.16		DEG F
5. A1204	UPPER CONT AMBIENT AIREMP A	78.04		DEG F
A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00		FT
7. A0671	CONTAINMEN SUMP LEVEL TRAIN B			FT
8. A0848	CONTAINMENT H2 CONCENTRATION TIIN A	0.00		%
9. D3572	S PUMP A (CONTAINMENT SPRAY)	OFF		
10. D3573	NS PUMP B (CONTAINMENT RRAY)	OFF		
Group: 25	RADIATION SYSTEMS			
1. A0115	1EMF48 REACTOR COOLANT MONITO	51924.98		CPM
2. A0829	1EF51A IN CONTAINMENT HI RANGE RAD MON	2.01E-04		R/HR
3. A0835	1EMF51B IN CONTAINMNT HI RANGE RAD MON	2.021E-04		R/HR
4. A0073	1EMF39H CONTAINMENT GAS HI RANGE	2.00		CPM
5. A0067	1EMF39L NTAINMENT GAS LO RANGE	28507.98		CM
6. A0061	1EMF38H CONTAINMENT PARTICULAE HI RANGE	5.00		CPM
7. A0055	1EMF38L CONTAINMENT PARTICULATE LO RANGE	2029.62		CPM
8. A1009	1EMF36HH UNIT VENTGAS HI HI RANGE	4.27		R/HR
9. A0018	1EMF36H UNIT VENT GAS HI RANGE	12.52		CPM
10. A0012	1EMF36LNNIT VENT GAS LO RANGE	3.171E+08		M
11. A0019	1EMF35H UNIT VENT PARTICULAT HI RANGE	21.39		CPM
12. A0013	1EMF35LUNIT VENT PARTICULATE LO RANGE	655.97		CPM
13. A0049	1EMF37 UNIT VENT IDINE	421.04		CPM
4. A0079	1EMF40 CONTAINMENT IODINE	500.19		CPM
15. A1368	1EMF24 STEMLINE 1A RADIATION MONITOR	0.0110		R/Hr
16. A1374	1EMF25 STEAMLINE 1B RADIATI MONITOR	0.0110		MR/HR
17. A138	1EMF26 STEAMLINE 1C RADIATION MONITOR	00.0110		MR/HR
18. A1386	1EMF27 STEAMLINE 1D RIIATION MONITOR	0.0110		MR/HR
19. A0127	EMF49H WASTE LIQUID DISCHARGE HI RANGE			CPM
Group: 30	ENVIRONMENTAL YSTEMS			
1. P084	UPPER WIND SPEED (15 MINUTE AVERAGE)			MPH
2. P0848	LOWER WIND SPEED (15 MINUTE AVERAGE)			MPH
3. P0850	LOWER TO UPPER DELTA-T (15 MINUTE AVERAE)			DEG C
4. P0847	UPPER IND DIRECTION (15 MINUTE AVERAGE)			DEG
5. P0849	LOWER WIND DIRECTION (15 MIUTE AVERAGE)			DEG
6. P055	PRECIPITATION IN LAST 15 MIN		IN	
7. P0851	AMBIENT AIR TEMPERATURE(15 MINUTE AVERAGE)			DEG
8. A0863	UNIT VENT STACK FLOW	53418.03		FT3/MN

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 3

Date:

Time:

10/20/93

11:45

Group: 35	IN-CORE THERMOCOUPLES	
1. A08	IN-CORE TEMP A10 T/C #2	286.95 DEG F
2. A0166	IN-CORE TMP J06 T/C #17	286.37 DEG F
3. A0155	IN-CORE TEMP F01 T/C #43	287.15 DEG F
4. A0251	IN-CORE TEMP M07 T/C #59	26.43 DEG F
5. P0823	5 HIGHEST IN-CORE T/ TEMP MARGIN	----- DEG F
6. P088	5 HIGHEST IN-CORE T/C TEMP	----- DEG F
7. A1323	IN-CORE TMP K05 T/C #54	----- DEG F
8. A1341	IN-CORE TEMP M11 T/C #60	----- DEG F
9. A1287	IN-CORE TEMP D13 T/C #42	----- DEG F
10. A1161	IN-CORE TEMP C04 TC #3	----- DEG F

RDT01

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date:

10/20/93

Time:

12:00

Group: 05	-----	PRIMARY SYSTEM		
1.	A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	250.74	DEG F
2.	A0971	NC LOOP B WIDE RANE HOT LEG TEMP	264.54	DEG F
3.	A0977	NC LOOP C WIDE RANGE HOT LEG TEMP	270.97	DEG F
4.	A0983	NC LOOP D IDE RANGE HOT LEG TEMP	286.59	DEG F
5.	A1061	NC LOOP A WIDE RANGE COLD LE TEMP	195.54	DEG F
6.	A1067	N LOOP B WIDE RANGE COLD LEG TEMP	182.33	DEG F
7.	A1073	NC LOOP C WIDE RANGCCOLD LEG TEMP	180.34	DEG F
.	A1079	NC LOOP D WIDE RANGE COLD LEG TEMP	228.28	DEG F
9.	A0826	NC SYSTM (HOT LEG) WIDE RANGE PRESS	6.22	IIG
11.	A1124	PZR LEVEL I (HOT CALIBRATE)	0.00	%
12.	D28	REACTOR COOLANT PUMP A	OFF	
13.	D2804	REACTOR CCOLANT UMP B	OFF	
14.	D2805	REACTOR COOLANT PUMP C	OFF	
15.	D2806	REACT COOLANT PUMP D	OFF	
16.	A1177	SOURCE RANGE (FLUX) LEVEL HANNEL 1	8.88	CPS
17.	A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL 2	6.01	CPS
18.	A0628	POWER RANGE AVGEVEL QUADRANT 1 (N-43)	6.744E-09	%
19.	P1385	REACTOR THERMAL POWER, BEST ESTIMATE	0.00	%
20.	A0602	CVCS RON METER (ISOLATED ON Ph. A)	720.68	PPM
21.	A1312	RVLIS - TRAIN A - DYNAMICHEAD D/P	0.00	%
22.	A1300	RVLIS - TRAIN A - UPPER RANGE LEVEL	64.76	%
23.	A1306	RVLIS - TRAIN A- LOWER RANGE LEVEL	26.41	%
24.	P1481	LOWEST NC SYSTEM SUBCOOLING MARGIN	-36.76	DEG F
Group: 10	-----	SECONDARY SYTEM		
1.	A104	STEAM GEN A WIDE RANGE LEVEL	60.18	%
2.	A1005	STEAM GEN B WIDE ANGE LEVEL	58.91	%
3.	A0970	STEAM GEN C WIDE RANGE LEVEL	60.48	%
4.	A0988	STEA GEN D WIDE RANGE LEVEL	60.94	%
5.	A1107	STEAM GEN A STEAM (LINE) RESS I	322.28	PSIG
6.	A113	STEAM GEN B STEAM (LINE) PRESS I	320.10	PSIG
7.	A1119	STEAM GEN C STAM (LINE) PRESS I	329.79	PSIG
8.	A1125	STEAM GEN D STEAM (LINE) PRESS I	332.92	PSIG
9.	P1412	TOTL S/G A (MAIN) FEEDWATER FLOW 1	0.0	MLB/HR
10.	P1414	TOTAL S/G B (MAIN) FEEDWTER FLOW 1	0.00	MLB/HR
11.	416	TOTAL S/G C (MAIN) FEEDWATER FLOW 1	0.00	MLB/HR
12.	P1418	TOTAL S/G D (MIN) FEEDWATER FLOW 1	0.00	MLB/HR
13.	P1208	AUX FEEDWATER FLOW TO S/G A	0.00	MLB/HR
14.	P1209	AUX FEEDWATERFLOW TO S/G B	0.0	MLB/HR
15.	P1210	AUX FEEDWATER FLOW TO SG C	0.00	MLB/HR
16.	1211	AUX FEEDWATER FLOW TO S/G D	0.00	MLB/HR
17.	A1059	STEAM GEN A NRROW RANGE LEVEL IV	34.74	%
18.	A1055	STEAM GEN B NARROW RANGE LEVEL IV	30.34	%
19.	A1071	STAM GEN C NARROW RANGE LEVEL IV	35.0	%
20.	A1077	STEAM GEN D NARROW RANGLLEVEL IV	37.38	%
21.	A0736	MAIN STEAM HEADER PRESSURE	46.74	PSIG

RDTSO1

DUKE WER COMPANY

Unit: MNS 1

Page: 2

Date:

10/20/93

Time:

12:00

Group: 15	AUXILIARY/INJECTION SYSTEMS			
1. D0970	NVUUMP A (HIGH HEAD SI)	ON		
2. D0620	NV PUMP B (HIGH HEAD SI)	ON		
3. 0827	BORON INJECTION (HIGH HEAD SI) FLOW	767.86	GPM	
4. D3574	NI PUMP A (IERMEDIATE HEAD SI)	OFF		
5. D3576	NI PUMP B (INTERMEDIATE HEAD SI)	OFF		
6. D1042	NPPUMP A (LOW HEAD SI / RHR)	OFF		
7. D0968	ND PUMP B (LOW HEAD SI/ RHR)	OFF		
8.A0758	CHARGING PUMP DISCHARGE HEADER FLOW	42.08	GPM	
9. A0856	(LOW HEAD S / RHR) ND HX RETURN FLOW	0.00	GPM	
10. A0764	LETDOWN HX OUTLET FLOW	0.00	GPM	
11. D0400	RFUELING WATER STORAGE TANK LEVEL	NORMAL		
12. D0402	REFUELING WATER STORAE TANK LEVEL	LO		
13 D0401	REFUELING WATER STORAGE TANK LEVEL	EER LO		
Group: 20	CONTAINMENT SYSTEM			
1. A0590	ARROW RANGE CONTAIN. PRESS (-1 TO +1)	---	PSIG	
2. A0785	INTER. RANGE CONTAIN.PRESS (-5 TO 20)	1.26	PSIG	
A1047	WIDE RANGE CONTAI PRESS (-5 TO 60)	---	PSIG	
4. A1228	LOWER CNT AMBIENT AIR TEMP A	143.55	DEG F	
5. A1204	UPPER CNT AMBIENT AIR TEMP A	86.44	DEG F	
6. A1041	CONTAINMENT SUMP LEVEL TRAIA	0.00	FT	
7. A067	CONTAINMENT SUMP LEVEL TRAIN B	---	FT	
8. A0848	CONTAINMENT H2 CONCNTRATION TRAIN A	0.00	%	
9. D3572	NS PUMP A (CONTAINMENT SPRAY)	OFF		
10. D3573	NS PUMBB (CONTAINMENT SPRAY)	OFF		
Group: 2	RADIATION SYSTEMS			
.. A0115	1EMF48 REACTOR COLANT MONITOR	51924.98	CPM	
2. A0829	1EMF51A IN CONTAINMENT HI RANGE RAD M	0.8633	R/HR	
3. A0835	1EMF51 IN CONTAINMENT HI RANGE RAD MON	0.8633	R/HR	
4. A0073	1EMF39H CONTAINMENT GAS HI ANGE	2.00	CPM	
5. A00	1EMF39L CONTAINMENT GAS LO RANGE	8507.98	CPM	
6. A0061	1EMF38H CONTAINMNT PARTICULATE HI RANGE	5.00	CPM	
7. A0055	1EMF38L CONTAINMENT PARTICULATE LO RNGE	27029.62	CPM	
8. A1009	1EMF3HH UNIT VENT GAS HI HI RANGE	4.18	R/HR	
9. A0018	1EMF36H UNIT VENT GAS HI RNGE	12.00	CPM	
10. A001	1EMF36L UNIT VENT GAS LO RANGE	.094E+08	CPM	
11. A0019	1EMF35H UNIT VET PARTICULATE HI RANGE	20.90	CPM	
12. A0013	1EMF35L UNIT VENT PARTICULATE LO RAGE	538.52	CPM	
13. A0049	1EMF UNIT VENT IODINE	408.80	CPM	
14. A0079	1EMF40 CONTAINMENT IODINE	500.19	CPM	
15. A68	1EMF24 STEAMLINE 1A RADIATION MONITOR	0.0110	mR/Hr	
16. A1374	1EMF25 STEAMLIE 1B RADIATION MONITOR	0.0110	MR/HR	
17. A1380	1EMF26 STEAMLINE 1C RADIATION MONIT	0.0110	MR/HR	
18. A1386	1EMF7 STEAMLINE 1D RADIATION MONITOR	0.011	MR/HR	
19. A0127	EMF49H WASTE LIQUID DISCARGE HI RANGE	---	CPM	
Group: 30	ENVIRONMENTAL SYSTEMS			
1. P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)	---	MPH	
2. P0848	LOWR WIND SPEED (15 MINUTE AVERAGE)	---	MPH	
3. P0850	LOWER TO UPPER DELTA-T 5 MINUTE AVERAGE)	---	DEC C	
4. 0847	UPPER WIND DIRECTION (15 MINUTE AVERAGE)	---	DEG	
5. P0849	LOWER WIND DEECTION (15 MINUTE AVERAGE)	---	DEG	
6. P0595	PRECIPITATION IN LAST 15 MIN	---	IN	
7. P0851	AMIENT AIR TEMPERATURE(15 MINUTE AVERAGE)	---	DEG C	
8. A0863	UNIT VENT STACK FLOW	53418.03	FT3/MN	

RDT501

DUKE POWER COMPANY

Unit: MNS 1 Page: 3

Date: 10/20/93 Time: 12:00

Group: 35 IN-CORE THERMOCOUPLES

1. A0268	IN-CORE TEMP A10 T/C #2	269.28	DEG F
2. A0166	I-CORE TEMP J06 T/C #17	2616	DEG F
3. A0155	IN-CORE TEMP F01 T/C443	268.65	DEG F
4. 2251	IN-CORE TEMP M07 T/C #59	267.72	DEG F
5. P0823	5 HIGHEST I-CORE T/C TEMP MARGIN	-----	DEGF
6. P0828	5 HIGHEST IN-CORE T/C TEMP	-----	DEG F
7. A1323	--CORE TEMP K05 T/C #54	-----	DEG F
8. A1341	IN-CORE TEMP M11 T/#60	-----	DEG F
. A1287	IN-CORE TEMP D13 T/C #42	-----	DEG F
10. A1161	IN-CORE TE C04 T/C #3	-----	DEGF

RDTSO1

DUKE POWER COMPANY

Unit: MNS 1

Page: 1

Date: *10/20/93*

Time: 12:15

Group: 05

PRIMARY SYSTEM				
1. A0965	NC LOOP A WIDE RANGE HOT LEG TEMP	203.40	DEG F	
2. A0971	NC LOO B WIDE RANGE HOT LEG TEMP	204.58	DEG F	
3. A0977	NC LOOP C WIDE RANGE HOT LEGTEMP	202.50	DEG F	
4. A098	NC LOOP D WIDE RANGE HOT LEG TEMP	204.64	DEG F	
5. A1061	NC LOOP A WIDE RAGE COLD LEG TEMP	203.18	DEG F	
6. A1067	NC LOOP B WIDE RANGE COLD LEG TEMP	204.46	DEG F	
7. A1073	NC LO C WIDE RANGE COLD LEG TEMP	204.70	DEG F	
8. A1079	NC LOOP D WIDE RANGE COLD EG TEMP	203.41	DEG F	
9. A086	NC SYSTEM (HOT LEG) WIDE RANGE PRESS	0.00	PSIG	
11. A1124	PZR LEVEL I (HOTCALIBRATED)	0.00	%	
12. D2803	REACTOR COOLANT PUMP A	OFF		
13. D2804	REACTORCOOLANT PUMP B	OFF		
14. D2805	REACTOR COOLANT PUMP C	OFF		
15. D280	REACTOR COOLANT PUMP D	OF		
16. A1177	SOURCE RANGE (FXX) LEVEL CHANNEL 1	5.41	CPS	
17. A1206	SOURCE RANGE (FLUX) LEVEL CHANNEL 2	8.44	CPS	
18. A0628	POWERRANGE AVG LEVEL QUADRANT 1 (N-43)	6.626E-09	%	
19. P1385	REACTOP THERMAL POWER, BET ESTIMATE	0.00	%	
20. A02	CVCS BORON METER (ISOLATED ON Ph. A)	721.38	PPM	
21. A1312	RVLIS - TRAIN - DYNAMIC HEAD D/P	0.00	%	
22. A1300	RVLIS - TRAIN A - UPPER RANGE LEVEL	65.49	%	
23. A1306	RVLIS- TRAIN A - LOWER RANGE LEVEL	9.81	%	
24. P1481	LOWEST NC SYSTEM SUBCOOLNG MARGIN	6.32	DEG F	

Group: 10

SECNDARY SYSTEM				
1. A1004	STEAM GEN A WIDE RANGE LEVEL	63.83	%	
2. A1005	STEM GEN B WIDE RANGE LEVEL	62.88	%	
3. A0970	STEAM GEN C WIDE RANGE LVEL	64.49	%	
4. A988	STEAM GEN D WIDE RANGE LEVEL	64.52	%	
5. A1107	STEAM GEN A STAM (LINE) PRESS I	193.09	PSIG	
6. A1113	STEAM GEN B STEAM (LINE) PRESS I	140.46	PSIG	
7. A1119	STEAM GEN C STEAM (LINE) PRESS I	138.7	PSIG	
8. A1125	STEAM GEN D STEAM (LINE)PRESS I	205.74	PSIG	
9. 1412	TOTAL S/G A (MAIN) FEEDWATER FLOW 1	0.1523	MLB/HR	
10. P1414	TOTAL S/G B (AIN) FEEDWATER FLOW 1	0.1575	MLB/HR	
11. P1416	TOTAL S/G C (MAIN) FEEDWATER FLOW	0.1577	MLB/HR	
12. P1418	TOTL S/G D (MAIN) FEEDWATER FLOW 1	0.15	MLB/HR	
13. P1208	AUX FEEDWATER FLOW TO S A	0.1486	MLB/HR	
14. 1209	AUX FEEDWATER FLOW TO S/G B	0.1547	MLB/HR	
15. P1210	AUX FEEDWATERFLOW TO S/G C	0.1549	MLB/HR	
16. P1211	AUX FEEDWATER FLOW TO S/G D	0.1480	MLB/HR	
17. A1059	STAM GEN A NARROW RANGE LEVEL IV	425	%	
18. A1065	STEAM GEN B NARROW RANGE EVEL IV	35.69	%	
19. A071	STEAM GEN C NARROW RANGE LEVEL IV	40.96	%	
20. A1077	STEAM GEN D RRROW RANGE LEVEL IV	44.74	%	
21. A0736	MAIN STEAM HEADER PRESSURE	198.27	PSIG	

RDTSO1

UKE POWER COMPANY

Unit: MNS 1

Page: 2

Date:

Time:

10/18/93 12:15

## Group: 15 ----- AUXILIARY/INJECTION SYSTEMS

1. D097	NV PUMP A (HIGH HEAD SI)	OF		
2. D0620	NV PUMP B (HIGHEAD SI)	ON		
3. A0827	BORON INJECTION (HIGH HEAD SI) FLOW		476.32	GPM
4. D3574	NI PMP A (INTERMEDIATE HEAD SI)	OFF		
5. D3576	NI PUMP B (INTERMEDIATE AAD SI)	OFF		
6. D142	ND PUMP A (LOW HEAD SI / RHR)	OF		
7. D0968	ND PUMP B (LOW HAD SI / RHR)	OFF		
8. A0758	CHARGING PUMP DISCHARGE HEADER FLOW		26.29	GPM
9. A0856	(LOHHEAD SI / RHR) ND HX RETURN FLOW		0.0	GPM
10. A0764	LETDOWN HX OUTLET FLOW		0.00	GPM
11. D000	REFUELING WATER STORAGE TANK LEVEL	NORML		
12. D0402	REFUELING WATE STORAGE TANK LEVEL	LO		
13. D0401	REFUELING WATER STORAGE TANK LEVEL	EMER LO		

## Group: 20 ----- CONTAINME SYSTEMS

1. 0590	NARROW RANGE CONTAIN. PRESS (-1 TO +1)	-----	PSIG	
2. A0785	INTER. RANGE ONTAIN. PRESS (-5 TO 20)	-0.2350	PSIG	
3. A1047	WIDE RANGE CONTAIN. PRESS (-5 T 60)	-----	PSIG	
4. A1228	LWER CONT AMBIENT AIR TEMP A	7958	DEG F	
5. A1204	UPPER CONT AMBIENT AIRTEMP A	82.51	DEG F	
6A1041	CONTAINMENT SUMP LEVEL TRAIN A	0.00	FT	
7. A0671	CONTINMENT SUMP LEVEL TRAIN B	-----	FT	
8. A0848	CONTAINMENT H2 CONCENTRATON TRAIN A	0.00	%	
9. D372	NS PUMP A (CONTAINMENT SPRAY)	O		
10. D3573	NS PUMP B (CONINMENT SPRAY)	OFF		

## Group: 25 ----- RADIATION SYSTEMS

1. A0115	1EMF48 REACTOR COOLANT MONITR	51924.98	CPM	
2. A829	1EMF51A IN CONTAINMENT HI RANGE RAD MON	0.0473	R/HR	
3. A0835	1EMF51B IN CONAINMENT HI RANGE RAD MON	0.0473	R/HR	
4. A0073	1EMF39H CONTAINMENT GAS HI RANGE	2.00	CPM	
5. A0067	1EM39L CONTAINMENT GAS LO RANGE	28507.9	CPM	
6. A0061	1EMF32H CONTAINMENT PARTIULATE HI RANGE	5.00	CPM	
7. A055	1EMF38L CONTAINMENT PARTICULATE LO RANGE	27029.62	CPM	
8. A1009	1EMF36HH UNIT VENT GAS HI HI PANGE	4.24	R/HR	
9. A0018	1EMF36H UNIT VENT GAS HI RANGE	12.38	CPM	
10. A0012	1EM36L UNIT VENT GAS LO RANGE	2.890E-0	CPM	
11. A0019	1EMF35H UNIT VENT PARTICLATE HI RANGE	21.26	CPM	
12. A013	1EMF35L UNIT VENT PARTICULATE LO RANGE	625.30	CPM	
13. A0049	1EMF37 UNIT VENTIODINE	417.84	CPM	
14. A0079	1EMF40 CONTAINMENT IODINE	500.19	CPM	
15. A1368	1EF24 STEAMLINE 1A RADIATION MONITOR	0.000	mR/Hr	
16. A1374	1EMF25 STEAMLINE 1B RAIATION MONITOR	0.0110	MR/HR	
17. A1380	1EMF26 STEAMLINE 1C RADIATION MONITOR	0.0110	MR/HR	
18. A1386	1EMF27 STEAMINE 1D RADIATION MONITOR	0.0110	MR/HR	
19. A0127	EMF49H WASTE LIQUID DISCHARGE HIAANGE	-----	CPM	

## Group: 30 ----- ENVIRONMNENTAL SYSTEMS

1 P0846	UPPER WIND SPEED (15 MINUTE AVERAGE)	-----	MPH	
2. P0848	LOWER WINDPPEED (15 MINUTE AVERAGE)	-----	MPH	
3. P0850	LOWER TO UPPER DELTA-T (15 MINUE AVERAGE)	-----	DEG C	
4. P0847	PPER WIND DIRECTION (15 MINUTE AVERAGE)	-----	DEG	
5. P0849	LOWER WIND DIRECTION (15 MINUTE AVERAGE)	-----	DEG	
. P0595	PRECIPITATION IN LAST 15 MIN	-----	IN	
7. P0851	AMBIENT AI TEMPERATURE(15 MINUTE AVERAGE)	-----	DEG	
8. A0863	UNIT VENT STACK FLOW	53418.03	FT3/MN	

RDT501

DUKE POWER COMPANY

Unit: MNS 1

Page 3

Date:

10/20/93

Time: 12:15

Group: 35	IN-CORE THERMOCOUPLES		
.. A0268	IN-CORE TEMP A10 T/C #2	238.12	DEG F
2. A0166	IN-CORE TMP J06 T/C #17	237.65	DEG F
3. A0155	IN-CORE TEMP F01 T/C #43	238.56	DEG F
4. A0251	NN-CORE TEMP M07 T/C #59	37.96	DEG F
5. P0823	5 HIGHEST IN-CORE /C TEMP MARGIN	-----	DEG F
6. P0828	5 HIGHEST IN-CORE T/C TEMP	-----	DEG F
7. A1323	IN-CORE EMP K05 T/C #54	-----	GG F
8. A1341	IN-CORE TEMP M11 T/C #60	-----	DEG F
9. A1287	IN-CORE TEMP D13 T/C #42	-----	DEG F
10. A1161	IN-CORE TEMP C04 //C #3	-----	DEG F

Containment

CONTAINMENT		ml/hr	Expected Values		Drill Values			cpm	Atmos	Rx Bldg
39 (L) CP	6.39E-18		Cont							
39 (R) CP	5.56E-14		Q1	LeakRate	EMF 39(L)	EMF 39(R)	EMF 39(L)	EMF 39(R)	EMF 40	psig
5:00 AM	3.86E-06	1.12E-08	1.05E+04	5.77E+07	6.64E+03	3.50E+04	1.00E+01	6.00E+02	0.15	
5:15	1.29E-05	3.75E-08	1.05E+04	1.92E+09	2.21E+04	3.50E+04	1.00E+01	6.00E+02	0.15	
5:30	5.58E-05	1.62E-07	1.05E+04	8.34E+08	9.59E+04	3.50E+04	1.00E+01	6.00E+02	0.15	
5:45	5.79E-05	1.69E-07	1.05E+04	8.66E+08	9.96E+04	3.50E+04	1.00E+01	6.00E+02	0.15	
6:00	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.15	
6:15	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.15	
6:30	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.15	
6:45	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
7:00	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
7:15	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
7:30	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
7:45	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
8:00	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
8:15	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
8:30	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
8:45	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
9:00	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
9:15	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
9:30	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
9:45	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
10:00	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
10:15	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
10:30	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
10:45	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
11:00	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
11:15	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
11:30	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
11:45	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
12:00	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
12:15	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
12:30	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
12:45	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
13:00	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16	
13:15	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	1.00E+05	1.15E+01	1.00E+04		
13:30	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	3.00E+06		
13:45	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	offscale		
14:00	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	offscale		
14:15	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	offscale		
14:30	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	offscale		
14:45	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	offscale		
15:00	5.84E-05	1.70E-07	1.05E+04	8.73E+08	1.00E+05	offscale	2.30E+03	offscale		
15:15	5.84E-05	1.70E-07	8.00E+04	1.14E+08	1.31E+04	offscale	2.30E+03	offscale		
15:30	5.84E-05	1.70E-07	5.82E+04	1.57E+08	1.80E+04	offscale	2.30E+03	offscale		
15:45	5.84E-05	1.70E-07	3.17E+04	2.88E+08	3.31E+04	offscale	2.30E+03	offscale		
16:00	5.84E-05	1.70E-07	3.17E+04	2.88E+08	3.31E+04	offscale	2.30E+03	offscale		

## Containment

Event	TIME	Upper WS	Lower WS	Upper WD	Lower WD	Ambient	Delta T	EMF35
		MPH	MPH	(from)	(from)	Deg. C	Deg. C	cpsi
	5:00 AM	4.70	2.68	184	204	22.66	1.14	3.00E+01
	5:15	5.98	3.96	162	156	23.11	0.46	4.50E+01
	5:30	6.18	5.16	166	176	22.93	0.19	5.00E+01
	5:45	5.45	3.29	191	173	22.64	-0.15	7.50E+01
	6:00	3.57	2.15	178	168	22.48	-0.08	9.00E+01
	6:15	2.64	2.33	184	179	22.00	0.25	1.10E+02
	6:30	2.47	2.83	162	194	22.02	0.41	1.40E+02
	6:45	2.64	2.69	196	171	23.00	0.06	1.65E+02
	7:00	1.47	1.77	190	116	23.01	0.25	1.85E+02
	7:15	0.85	2.11	177	178	22.08	1.28	2.10E+02
	7:30	1.25	1.71	154	179	22.57	0.74	2.35E+02
	7:45	3.11	2.68	183	177	23.18	0.23	2.87E+02
	8:00	2.28	2.31	181	178	23.63	-0.13	3.10E+02
	8:15	2.18	2.12	203	181	23.83	-0.26	3.45E+02
	8:30	1.75	1.68	169	198	24.47	-0.33	4.05E+02
	8:45	2.47	2.34	166	178	25.40	-0.39	6.15E+02
SI	9:00	2.20	2.04	180	179	25.83	-0.43	6.50E+02
	9:15	2.76	2.05	181	179	25.93	-0.49	7.50E+03
	9:30	3.07	3.06	179	175	26.16	-0.33	1.70E+03
	9:45	3.34	3.21	180	173	26.42	-0.43	2.23E+03
	10:00	3.87	3.84	172	165	26.78	-0.51	2.75E+03
	10:15	4.62	3.98	176	177	27.10	-0.60	3.00E+03
	10:30	4.57	3.76	173	180	27.44	-0.76	3.50E+03
	10:45	4.72	4.34	169	178	27.68	-0.86	3.75E+03
	11:00	3.88	3.65	177	179	28.06	-0.7	4.10E+03
	11:15	4.38	4.16	181	177	28.43	-0.76	4.40E+03
	11:30	5.20	5.01	180	178	29.01	-0.89	4.89E+03
	11:45	5.40	4.92	178	181	29.41	-0.92	5.32E+03
	12:00	4.61	4.68	178	183	29.76	-0.91	5.78E+03
	12:15	5.19	5.24	180	178	30.26	-0.82	6.47E+03
	12:30	5.35	4.92	181	179	30.47	-0.91	7.15E+03
	12:45	6.25	3.75	183	179	30.62	-0.90	7.84E+03
	13:00	4.93	3.79	176	176	30.63	-0.85	8.53E+03
	13:15	5.34	3.12	174	166	31.17	-0.99	9.22E+03
	13:30	5.36	4.37	175	167	31.46	-1.02	9.90E+03
	13:45	5.18	4.36	175	180	31.50	-0.90	1.06E+04
	14:00	5.11	4.96	185	177	31.81	-1.00	1.13E+04
	14:15	5.76	3.56	188	183	31.95	-1.07	1.20E+04
	14:30	5.56	4.11	171	174	32.24	-1.11	1.27E+04
	14:45	5.22	3.06	182	165	32.17	-0.94	9.20E+05
	15:00	4.41	4.78	176	182	32.23	-0.83	offscale
	15:15	4.69	5.08	174	166	32.54	-0.86	offscale
	15:30	4.59	5.31	191	181	32.70	-0.98	offscale
	15:45	4.81	4.79	175	168	32.79	-0.85	offscale
	16:00	4.78	4.62	235	240	33.13	-0.65	offscale

**Containment**

EMF36L cpm	EMF36H cpm	EMF36HH R/hr	EMF37L cpm	EMF38 cpm	EMF39L cpm	EMF39H cpm	EMF51A R/hr	EMF51B R/hr
4.50E+01	1.50E+01	1.50E+00	6.00E+01	2.00E+03	3.54E+04	5.00E+10	7.00E+00	7.00E+00
1.50E+02	1.50E+01	1.50E+00	6.50E+01	2.00E+03	2.06E+05	2.91E+01	7.00E+00	7.00E+00
6.50E+02	1.50E+01	1.50E+00	1.20E+02	2.00E+03	5.47E+05	7.72E+01	7.00E+00	7.00E+00
6.75E+02	1.50E+01	1.50E+00	1.25E+02	2.00E+03	1.06E+06	1.49E+02	7.00E+00	7.00E+00
6.80E+02	1.50E+01	1.50E+00	1.30E+02	2.00E+03	1.57E+06	2.22E+02	7.00E+00	7.00E+00
6.80E+02	1.50E+01	1.50E+00	2.25E+02	2.00E+03	2.08E+06	2.94E+02	7.00E+00	7.00E+00
6.80E+02	1.50E+01	1.50E+00	2.50E+02	2.00E+03	2.59E+06	3.66E+02	7.00E+00	7.00E+00
6.80E+02	1.50E+01	1.50E+00	3.00E+01	2.00E+03	3.10E+06	4.38E+02	7.00E+00	7.00E+00
6.80E+02	1.50E+01	1.50E+00	3.00E+01	2.00E+03	3.61E+06	5.11E+02	7.00E+00	7.00E+00
6.80E+02	1.50E+01	1.50E+00	3.00E+01	2.00E+03	4.13E+06	5.83E+02	7.00E+00	7.00E+00
6.80E+02	1.50E+01	1.50E+00	3.00E+01	2.00E+03	4.64E+06	6.55E+02	7.00E+00	7.00E+00
6.80E+02	1.50E+01	1.50E+00	3.00E+01	2.00E+03	5.15E+06	7.27E+02	7.00E+00	7.00E+00
6.80E+02	1.50E+01	1.50E+00	3.00E+01	2.00E+03	5.66E+06	7.99E+02	7.00E+00	7.00E+00
6.80E+02	1.50E+01	1.50E+00	3.00E+01	2.00E+03	6.17E+06	8.72E+02	7.00E+00	7.00E+00
6.80E+02	1.50E+01	1.50E+00	3.00E+01	2.00E+03	6.68E+06	9.44E+02	7.00E+00	7.00E+00
6.80E+02	1.50E+01	1.50E+00	3.00E+01	2.00E+03	7.19E+06	1.02E+03	7.00E+00	7.00E+00
6.80E+02	1.50E+01	1.50E+00	3.00E+01	2.00E+03	4.13E+07	5.83E+03	7.00E+00	7.00E+00
5.06E+05	5.82E+01	1.50E+00	3.00E+01	2.00E+03	1.09E+08	1.55E+04	7.00E+00	7.00E+00
2.17E+05	2.50E+01	1.50E+00	3.00E+01	2.00E+03	1.78E+08	2.51E+04	7.00E+00	7.00E+00
1.06E+05	1.22E+01	1.50E+00	3.00E+01	2.00E+03	2.46E+08	3.47E+04	7.00E+00	7.00E+00
1.06E+05	1.22E+01	1.50E+00	3.00E+01	2.00E+03	3.14E+08	4.43E+04	7.00E+00	7.00E+00
1.06E+05	1.22E+01	1.50E+00	3.00E+01	2.00E+03	3.82E+08	5.40E+04	7.00E+00	7.00E+00
1.06E+05	1.22E+01	1.50E+00	3.00E+01	2.00E+03	4.50E+08	6.36E+04	7.00E+00	7.00E+00
1.06E+05	1.22E+01	1.50E+00	3.00E+01	2.00E+03	5.19E+08	7.32E+04	7.00E+00	7.00E+00
2.17E+05	2.50E+02	1.50E+00	3.00E+01	2.00E+03	5.87E+08	8.29E+04	8.00E+03	7.00E+00
1.04E+06	1.20E+02	1.50E+00	3.00E+01	2.00E+03	6.55E+08	9.25E+04	4.20E+04	1.90E+01
2.61E+07	3.00E+03	1.50E+00	3.00E+01	2.00E+03	7.23E+08	1.02E+05	4.30E+04	5.18E+01
2.61E+07	3.00E+03	1.50E+00	3.00E+01	2.00E+03	7.91E+08	1.12E+05	4.40E+04	1.41E+02
2.61E+07	3.00E+03	1.50E+00	3.00E+01	2.00E+03	8.59E+08	1.21E+05	4.50E+04	3.83E+02
2.61E+07	3.00E+03	1.50E+00	3.00E+01	2.00E+03	9.28E+08	1.31E+05	3.50E+04	1.04E+03
1.30E+07	1.50E+03	1.50E+00	3.00E+01	2.00E+03	9.96E+08	1.41E+05	3.00E+04	2.83E+03
1.30E+07	1.50E+03	1.50E+00	3.00E+01	2.00E+03	1.06E+09	1.50E+05	2.80E+04	7.71E+03
1.30E+07	1.50E+03	1.50E+00	3.00E+01	6.00E+02	1.13E+09	1.60E+05	2.80E+04	1.40E+04
1.30E+07	1.50E+03	1.50E+00	4.10E+01	6.00E+02	1.20E+09	1.70E+05	2.30E+04	1.30E+04
1.30E+06	1.50E+02	1.50E+00	4.10E+01	6.00E+02	1.27E+09	1.79E+05	1.10E+03	1.30E+03
1.30E+06	1.50E+02	1.50E+00	4.10E+01	6.00E+02	1.34E+09	1.89E+05	1.10E+03	1.30E+03
1.30E+06	1.50E+02	1.50E+00	4.10E+01	6.00E+02	1.40E+09	1.98E+05	1.00E+03	1.20E+03
1.30E+06	1.50E+02	1.50E+00	4.10E+01	6.00E+02	1.47E+09	2.08E+05	1.00E+03	1.20E+03
1.30E+05	1.50E+01	1.50E+00	7.40E+03	5.40E+04	1.54E+09	2.18E+05	9.50E+02	1.60E+03
1.30E+05	1.50E+01	1.50E+00	9.90E+03	9.76E+05	1.61E+09	2.27E+05	8.50E+02	1.10E+03
1.30E+05	1.50E+01	1.50E+00	1.20E+04	6.12E+06	1.68E+09	2.37E+05	7.40E+02	1.10E+03
1.30E+05	1.50E+01	1.50E+00	1.40E+04	9.90E+09	1.75E+09	2.47E+05	6.50E+02	1.10E+03
1.30E+04	1.50E+00	1.50E+00	1.80E+04	9.90E+09	1.81E+09	2.56E+05	6.00E+02	1.00E+03
1.30E+04	1.50E+00	1.50E+00	3.00E+04	9.90E+09	1.88E+09	2.66E+05	5.75E+02	1.00E+03
1.30E+04	1.50E+00	1.50E+00	5.00E+04	9.90E+09	1.95E+09	2.75E+05	5.55E+02	9.00E+02

UNIT	VENT							
		X/Q	5.50E-05	36 (L) CF	1.09E-11	36(HH) CF	2.36E-04	
Xe DCF	33.6	I/Xe Ratio	2.91E-05	I/Xe Ratio	1.00E-02	2.91E-03		
CF DCF	2.26E+06	36(H) CF	9.44E-08	37 (H/L) CF	2.35E-10			
EMF	(cpm)	(cpm)	(cfm)	(Ci/sec)	R/Hr at site Boundary			In Field
	EMF 36(L)	EMF 36(H)	Vent Flow	QNG	QI	Nob Gas	Chld Thy	SBDR
5:00 AM	4.50E+01	1.50E+01	1.05E+05	5.13E-05	1.49E-09	9.48E-08	1.86E-07	0.00
5:15	1.50E+02	1.73E-02	1.05E+05	1.71E-04	4.98E-09	3.16E-07	6.19E-07	0.00
5:30	6.50E+02	7.48E-02	1.05E+05	7.41E-04	2.16E-08	1.37E-06	2.68E-06	0.01
5:45	6.75E+02	7.77E-02	1.05E+05	7.70E-04	2.24E-08	1.42E-06	2.78E-06	0.01
6:00	6.80E+02	7.82E-02	1.05E+05	7.75E-04	2.26E-08	1.43E-06	2.80E-06	0.01
6:15	6.80E+02	7.82E-02	1.05E+05	7.75E-04	2.26E-08	1.43E-06	2.80E-06	0.01
6:30	6.80E+02	7.82E-02	1.05E+05	7.75E-04	2.26E-08	1.43E-06	2.80E-06	0.01
6:45	6.80E+02	7.82E-02	1.05E+05	7.75E-04	2.26E-08	1.43E-06	2.80E-06	0.01
7:00	6.80E+02	7.82E-02	1.05E+05	7.75E-04	2.26E-08	1.43E-06	2.80E-06	0.01
7:15	6.80E+02	7.82E-02	1.05E+05	7.75E-04	2.26E-08	1.43E-06	2.80E-06	0.01
7:30	6.80E+02	7.82E-02	1.05E+05	7.75E-04	2.26E-08	1.43E-06	2.80E-06	0.01
7:45	6.80E+02	7.82E-02	1.05E+05	7.75E-04	2.26E-08	1.43E-06	2.80E-06	0.01
8:00	6.80E+02	7.82E-02	1.05E+05	7.75E-04	2.26E-08	1.43E-06	2.80E-06	0.01
8:15	6.80E+02	7.82E-02	1.05E+05	7.75E-04	2.26E-08	1.43E-06	2.80E-06	0.01
8:30	6.80E+02	7.82E-02	1.05E+05	7.75E-04	2.26E-08	1.43E-06	2.80E-06	0.01
8:45	6.80E+02	7.82E-02	1.05E+05	7.75E-04	2.26E-08	1.43E-06	2.80E-06	0.01
9:00	6.80E+02	7.82E-02	5.30E+04	3.91E-04	1.14E-08	7.23E-07	1.42E-06	0.01
9:15	5.06E+05	5.82E+01	5.30E+04	1.25E-01	1.45E-06	2.31E-04	1.81E-04	2.31
9:30	2.17E+05	2.50E+01	5.30E+04	1.25E-01	1.45E-07	2.31E-04	1.81E-05	2.31
10:15	1.06E+05	1.22E+01	5.30E+04	6.12E-02	7.12E-08	1.13E-04	8.85E-06	1.13
10:30	1.06E+05	1.22E+01	5.30E+04	6.12E-02	7.12E-08	1.13E-04	8.85E-06	1.13
10:45	1.06E+05	1.22E+01	5.30E+04	6.12E-02	7.12E-08	1.13E-04	8.85E-06	1.13
11:00	2.17E+06	2.50E+02	5.30E+04	1.25E+00	1.45E-04	2.31E-03	1.81E-02	23.10
11:15	1.04E+06	1.20E+02	5.30E+04	6.00E-01	6.00E-03	1.11E-03	7.46E-01	11.09
11:30	2.61E+07	3.00E+03	5.30E+04	1.50E+01	1.50E-01	2.77E-02	1.86E+01	277.20
11:45	2.61E+07	3.00E+03	5.30E+04	1.50E+01	1.50E-01	2.77E-02	1.86E+01	277.20
12:00	2.61E+07	3.00E+03	5.30E+04	1.50E+01	1.50E-01	2.77E-02	1.86E+01	277.20
12:15	2.61E+07	3.00E+03	5.30E+04	1.50E+01	1.50E-01	2.77E-02	1.86E+01	277.20
12:30	1.30E+07	1.50E+03	5.30E+04	7.50E+00	7.50E-02	1.39E-02	9.32E+00	138.60
12:45	1.30E+07	1.50E+03	5.30E+04	7.50E+00	7.50E-02	1.39E-02	9.32E+00	138.60
13:00	1.30E+07	1.50E+03	5.30E+04	7.50E+00	7.50E-02	1.39E-02	9.32E+00	138.60
13:15	1.30E+07	1.50E+03	5.30E+04	7.50E+00	7.50E-02	1.39E-02	9.32E+00	138.60
13:30	1.30E+06	1.50E+02	5.30E+04	7.50E-01	7.50E-03	1.39E-03	9.32E-01	13.86
13:45	1.30E+06	1.50E+02	5.30E+04	7.50E-01	7.50E-03	1.39E-03	9.32E-01	13.86
14:00	1.30E+06	1.50E+02	5.30E+04	7.50E-01	7.50E-03	1.39E-03	9.32E-01	13.86
14:15	1.30E+06	1.50E+02	5.30E+04	7.50E-01	7.50E-03	1.39E-03	9.32E-01	13.86
14:30	1.30E+05	1.50E+01	5.30E+04	7.50E-02	7.50E-04	1.39E-04	9.32E-02	1.39
14:45	1.30E+05	1.50E+01	5.30E+04	7.50E-02	7.50E-04	1.39E-04	9.32E-02	1.39
15:00	1.30E+05	1.50E+01	5.30E+04	7.50E-02	7.50E-04	1.39E-04	9.32E-02	1.39
15:15	1.30E+05	1.50E+01	5.30E+04	7.50E-02	7.50E-04	1.39E-04	9.32E-02	1.39
15:30	1.30E+04	1.50E+00	5.30E+04	7.50E-03	7.50E-05	1.39E-05	9.32E-03	0.14
15:45	1.30E+04	1.50E+00	5.30E+04	7.50E-03	7.50E-05	1.39E-05	9.32E-03	0.14
16:00	1.30E+04	1.50E+00	5.30E+04	7.50E-03	7.50E-05	1.39E-05	9.32E-03	0.14

UNIT VENT				
	EMF 36HH (HH)	EMF 37 cpm/min	EMF 37 reading	UV- Iodine uCi/ml
5:00 AM	1.50E+00	0	3.00E+01	4.50E+01
5:15	1.50E+00	0	3.00E+01	1.50E+02
5:30	1.50E+00	2	3.00E+01	6.50E+02
5:45	1.50E+00	2	3.00E+01	6.75E+02
6:00	1.50E+00	2	3.00E+01	6.80E+02
6:15	1.50E+00	2	3.00E+01	6.80E+02
6:30	1.50E+00	2	3.00E+01	6.80E+02
6:45	1.50E+00	2	3.00E+01	6.80E+02
7:00	1.50E+00	2	3.00E+01	6.80E+02
7:15	1.50E+00	2	3.00E+01	6.80E+02
7:30	1.50E+00	2	3.00E+01	6.80E+02
7:45	1.50E+00	2	3.00E+01	6.80E+02
8:00	1.50E+00	2	3.00E+01	6.80E+02
8:15	1.50E+00	2	3.00E+01	6.80E+02
8:30	1.50E+00	2	3.00E+01	6.80E+02
8:45	1.50E+00	2	3.00E+01	6.80E+02
9:00	1.50E+00	2	3.00E+01	7.28E-05
9:15	1.50E+00	2.47E+02	4.65E+06	7.28E-05
9:30	1.50E+00	2.47E+01	4.73E+06	1.28E-06
9:45	1.50E+00	1.21E+01	4.81E+06	1.28E-06
10:00	1.50E+00	1.21E+01	4.89E+06	1.28E-06
10:15	1.50E+00	1.21E+01	4.97E+06	1.28E-06
10:30	1.50E+00	1.21E+01	5.06E+06	1.28E-06
10:45	1.50E+00	1.21E+01	5.14E+06	1.28E-06
11:00	1.50E+00	2.47E+04	3.88E+08	6.00E-03
11:15	1.50E+00	1.02E+06	7.71E+08	6.00E-03
11:30	1.50E+00	2.55E+07	1.15E+09	6.00E-03
11:45	1.50E+00	2.55E+07	1.54E+09	6.00E-03
12:00	1.50E+00	2.55E+07	1.73E+09	3.00E-03
12:15	1.50E+00	2.55E+07	1.92E+09	3.00E-03
12:30	1.50E+00	1.28E+07	2.11E+09	3.00E-03
12:45	1.50E+00	1.28E+07	2.30E+09	3.00E-03
13:00	1.50E+00	1.28E+07	2.31E+09	9.99E-05
13:15	1.50E+00	1.28E+07	2.32E+09	9.99E-05
13:30	1.50E+00	1.28E+06	2.32E+09	9.99E-05
13:45	1.50E+00	1.28E+06	2.33E+09	9.99E-05
14:00	1.50E+00	1.28E+06	2.33E+09	9.99E-05
14:15	1.50E+00	1.28E+06	2.34E+09	9.99E-05
14:30	1.50E+00	1.28E+05	4.25E+05	9.99E-05
14:45	1.50E+00	1.28E+05	4.25E+05	9.99E-05
15:00	1.50E+00	1.28E+05	1.70E+05	4.00E-05
15:15	1.50E+00	1.28E+05	1.70E+05	4.00E-05
15:30	1.50E+00	1.28E+04	1.70E+05	4.00E-05
15:45	1.50E+00	1.28E+04	1.70E+05	4.00E-05
16:00	1.50E+00	1.28E+04	1.70E+05	4.00E-05

## In-plant Area/process Radiation Monitors

10 of 10



EMF	TIME				TIME				TIME			UNITS	Location
	9:15	9:30	9:45	10:00	10:15	10:30	10:45	11:00	11:15	11:30			
1	5	5	5	5	5	5	5	10	15	25	mR/hr	695' Aux Bldg	
2	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.28	mR/hr	716' Aux Bldg	
3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	mR/hr	716' Aux Bldg	
4	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	mR/hr	716' Aux Bldg	
5*	1	1	1	1	1	1	1	1	1	1	mR/hr	NM Lab	
6	2	2	2	2	2	2	2	2	2	2	mR/hr	733' Aux Bldg	
7	2	2	2	2	2	2	2	2	2	2	mR/hr	733' Aux Bldg	
8	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	1.1	1.2	mR/hr	733' Aux Bldg	
9	3	3	3	3	3	3	3	3	3	3	mR/hr	Incore Rm- Rx	
10	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	mR/hr	750' Aux Bldg	
11	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	mR/hr	Waste Drumming	
12	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	mR/hr	Control Rm	
13	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	mR/hr	775' Lab	
14	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	mR/hr	760' RW Dock	
15	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	mR/hr	Hot Mach Shop	
16	1.20E+02	1.25E+02	1.30E+02	1.35E+02	1.40E+02	1.50E+02	1.65E+02	1.70E+02	1.80E+02	1.90E+02	mR/hr	Rx Refuel Br	
17	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	mR/hr	SPP Refuel Br	
18	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	R/hr	HC Filt - A	
19	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	R/hr	HC Filt - B	
20	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	mR/hr	New Fuel-767'	
21	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	mR/hr	New Fuel-767'	
22	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	mR/hr	TSC-767'	
23	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	2.5	11	mR/hr	767' AuxBldg	
24	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	mR/hr	S/G -A	
25	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	mR/hr	S/G -B	
26	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	mR/hr	S/G -C	
27	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	mR/hr	S/G -D	
28	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	mR/hr	Diesel Gen	

EMF	TIME					TIME					UNITS	Location
	11:45	1200	1215	1230	1245	1300	1315	1330	1345			
1	150	175	225	275	300	450	625	700	867	mR/hr	695' Aux Bldg	
2	1	2	3	4	5	6	7	7.5	8	mR/hr	716' Aux Bldg	
3	0.2	0.2	0.2	0.2	5	12	12	12	12	mR/hr	716' Aux Bldg	
4	5	5.5	6	6.5	7	7	7	7	7	mR/hr	716' Aux Bldg	
5*	1 *	2 *	3 *	4 *	5 *	5 *	5 *	5 *	5 *	mR/hr	NN Lab	
6	4	5	7	7	7	7	7	7	7	mR/hr	733' Aux Bldg	
7	2	2	2	2	2	2	2	2	2	mR/hr	733' Aux Bldg	
8	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2	2.1	mR/hr	733' Aux Bldg	
9	3	3	3	3	3	3	3	3	3	mR/hr	Incore Rm- Rx	
10	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	mR/hr	750' Aux Bldg	
11	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	mR/hr	Waste Drumming	
12	0.25	0.25	0.3	0.3	0.35	0.4	0.4	0.45	0.5	mR/hr	Control Rm	
13	0.1	0.1	0.1	0.1	1.5	2	2	2.5	3	mR/hr	775' Lab	
14	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	mR/hr	760' RW Dock	
15	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	mR/hr	Hot Mach Shop	
16	2.00E+02	2.20E+02	2.30E+02	2.50E+02	2.70E+02	3.00E+02	4.00E+02	4.50E+02	6.00E+02	mR/hr	Rx Refuel Br	
17	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	mR/hr	SFP Refuel Br	
18	4	4.4	4.8	5.3	6.2	6.4	6.5	6.8	7.1	R/hr	HC Filt - A	
19	3.1	4	4.2	4.5	5.1	5.6	6.2	6.3	6.4	R/hr	HC Filt - B	
20	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	mR/hr	New Fuel-767*	
21	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	mR/hr	New Fuel-767*	
22	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	mR/hr	TSC-767*	
23	22	25	150	175	225	275	300	450	625	mR/hr	767' AuxBldg	
24	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	mR/hr	S/G -A	
25	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	mR/hr	S/G -B	
26	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	mR/hr	S/G -C	
27	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	mR/hr	S/G -D	
28	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	mR/hr	Diesel Gen	



	TIME		TIME		TIME	
	5:00	5:15	5:30	5:45	6:00	6:15
EMP						
31	500	500	500	500	500	500
32	3.00E+02	3.00E+02	3.00E+02	3.00E+02	3.00E+02	3.00E+02
33	125	130	120	120	130	125
34	6.00E+03	6.00E+03	6.00E+03	6.00E+03	6.00E+03	6.00E+03
35	3.00E+01	4.50E+01	7.50E+01	9.00E+01	3.00E+02	3.00E+02
36						
37						
38	600	600	600	600	600	600
39						
40						
	<b>See other pages for data in shaded areas</b>					
41	100	115	120	150	250	500
42	100	100	100	100	100	100
43 AkB	80	80	80	80	80	80
44	5.00E+03	5.00E+03	5.00E+03	5.00E+03	5.00E+03	5.00E+03
45 AkB	150	150	150	150	150	150
46 AkB	1.60E+05	1.60E+05	1.60E+05	1.60E+05	1.60E+05	1.60E+05
47	5.53E+04	7.03E+04	7.54E+04	7.52E+04	7.39E+04	7.27E+04
48	5.70E+04	5.70E+04	5.70E+04	5.70E+04	5.70E+04	5.70E+04
49L	3.40E+03	3.40E+03	3.40E+03	3.40E+03	3.40E+03	3.40E+03
49H	10	10	10	10	10	10
50	6.00E+02	1.00E+03	1.20E+03	1.20E+03	1.20E+03	1.20E+03
51 AkB						
52	1.00E-01	1.00E-01	1.00E-01	2.00E-01	2.50E-01	3.00E-01
53	60	60	60	60	60	60
54 AkB	0.2	0.2	0.2	0.2	0.2	0.2

**See other pages for data in shaded areas**

R/hr

No

Rad/Wt. V

CPM/Time

TSC

7.33<sup>10</sup>Boron CPM

RC

WR

RC  
WR/Hr

							TIME
28P	7:15	7:30	7:45	8:00	8:15	8:30	8:45
31	500	500	500	500	500	500	500
32	3.00E+02						
33	135	130	125	125	130	120	130
34	6.00E+03						
35	3.00E+02						
36							cps; R/hr
37							UV Gas
38	600	600	600	600	600	600	UV 12
39							RX Part
40							RX Gun
41	1000	1000	1000	1000	1000	1000	RX 12
42	100	100	100	100	100	100	RX Vent
43 ASB	80	80	80	80	80	80	SFP Vent
44	5.00E+03	5.00E+03	5.00E+03	5.00E+03	5.00E+03	5.00E+03	CR vent
45 ASB	150	150	150	150	150	150	WINDT
46 ASB	1.60E+05	1.60E+05	1.60E+05	1.60E+05	1.60E+05	1.60E+05	RW
47	6.77E+04	6.62E+04	6.53E+04	6.39E+04	6.26E+04	6.12E+04	KC
48	5.70E+04	5.70E+04	5.70E+04	5.70E+04	5.70E+04	5.70E+04	733 Boston REPO
49L	3.40E+03	3.40E+03	3.40E+03	3.40E+03	3.40E+03	3.40E+03	REC
49R	10	10	10	10	10	10	REC
50	1.20E+03	1.20E+03	1.20E+03	1.20E+03	1.20E+03	1.20E+03	REC
51 ASB							R/hr
52	3.50E-01	3.50E-01	3.50E-01	3.50E-01	3.50E-01	3.50E-01	Radon V
53	60	60	60	60	60	60	CFM/hr
54 ASB	0.2	0.2	0.2	0.2	0.2	0.2	TSC

10



		TIME									
EMP	11:45	1200	1215	1230	1245	1300	1315	1330	1345		WC
31	500	500	500	500	500	500	500	500	500	cps	S/G Blowdown
32	3.00E+02	cps	CSE								
33	120	130	125	130	125	130	135	130	125	cps	S/G Sample
34	6.00E+03	cps									
35	1.11E+04	1.40E+04	2.13E+04	2.50E+04	2.78E+04	2.92E+04	3.70E+04	5.60E+04	9.20E+05	cps	UV Part.
36										cps; R/Hr	UV Gas
37										cps	UV 12
38	B40	8.00E+02	cps	Rx Part.							
39										cps	Rx Gas
40										cps	Rx 12
41	1000	1000	1000	1000	1000	1000	1000	1000	1000	cps	AB Vent
42	100	100	100	100	100	100	100	100	100	cps	SFP Vent
43 A&B	130	150	180	360	420	600	720	1620	1600	cps	CR Vent
44	5.00E+03	cps	VOC/VOC								
45 A&B	150	150	150	150	150	150	150	150	150	cps	RH
46&B	1.60E+05	cps	WC								
47	7.00E+03	cps	733 Baro. Recv								
48	3.00E+05	5.20E+05	5.70E+04	cps	WC						
49L	8.50E+04	cps	WL								
49R	10	10	10	10	10	10	10	10	10	cps	WL
50	3.89E+03	cps	WL								
51 A&B										R/Hr	Rx
52	4.00E-01	cps	RadNet. V								
53	60	60	60	60	60	60	60	60	60	cps	ORP/Wire
54 A&B	0.25	0.25	0.3	0.3	0.35	0.4	0.4	0.45	0.5	ms/hr	TSC

See OTHER pages for data in shaded areas

	TIME			TIME		TIME	
3MP	1400	1415	1430	1445	1500	1515	1530
31	500	500	500	500	500	500	500
32	3.00E+02						
33	125	135	130	120	125	135	135
34	6.00E+03						
35	offscale						
36							
37							
38	6.25E+02	offscale	offscale	offscale	offscale	offscale	offscale
39							
40							
41	1000	1000	1000	1000	1000	1000	1000
42	100	100	100	100	100	100	100
43 A&B	1800	1800	1800	1800	1800	1800	1800
44	offscale						
45 A&B	150	150	150	150	150	150	150
46 A&B	1.60E+05						
47	7.00E+03						
48	5.70E+04						
49A	8.50E+04						
49B	10	10	10	10	10	10	10
50	3.89E+03						
51 A&B	3						
52	4.00E-01						
53	60	60	60	60	60	60	60
54 A&B	0.5	0.5	0.5	0.5	0.5	0.5	0.5
						RJ/Hr	RJ/Hr
						CPS	Radiation V
						CPS	CPS/Sec
						MR/HR	WEC

Some entries are new for data in shaded areas.

CONTAINMENT		Expected Response Use these for Drill							
		QNG	QI	LeakRate	EMF 39(L)	EMF 39(H)	EMF 39(L)	EMF 39(H)	EMF 40
5:00 AM		3.86E-06	1.12393E-08	1.05E+04	5.77E+07	6.64E+03	3.50E+04	1.00E+01	6.00E+02
5:15		1.29E-05	3.74644E-08	1.05E+04	1.92E+08	2.21E+04	3.50E+04	1.00E+01	6.00E+02
5:30		5.58E-05	1.62346E-07	1.05E+04	8.34E+08	9.59E+04	3.50E+04	1.00E+01	6.00E+02
5:45		5.79E-05	1.6859E-07	1.05E+04	8.66E+08	9.96E+04	3.50E+04	1.00E+01	6.00E+02
6:00		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
6:15		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
6:30		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
6:45		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
7:00		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
7:15		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
7:30		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
7:45		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
8:00		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
8:15		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
8:30		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
8:45		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
9:00		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
9:15		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
9:30		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
9:45		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
10:00		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
10:15		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
10:30		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
10:45		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
11:00		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
11:15		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
11:30		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
11:45		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
12:00		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
12:15		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
12:30		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
12:45		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
13:00		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02
13:15		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	1.00E+05	1.15E+01	1.00E+04
13:30		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	3.00E+06
13:45		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	offscale
14:00		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	offscale
14:15		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	offscale
14:30		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	offscale
14:45		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	offscale
15:00		5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	offscale	2.30E+03	offscale
15:15		5.84E-05	1.69838E-07	8.00E+04	1.14E+08	1.31E+04	offscale	2.30E+03	offscale
15:30		5.84E-05	1.69838E-07	5.82E+04	1.57E+08	1.80E+04	offscale	2.30E+03	offscale
15:45		5.84E-05	1.69838E-07	3.17E+04	2.98E+08	3.31E+04	offscale	2.30E+03	offscale
16:00		5.84E-05	1.69838E-07	3.17E+04	2.88E+08	3.31E+04	offscale	2.30E+03	offscale

RX Nohleg's IRDICE

CONTINUITY

(L) 6.39E-18

(H) 5.56E-14

Expected Response these for Drill


psig

↓

	QNG	QI	LeakRate	MF 39(L)	tMF 39(H)	EMF 39(L)	MF 39(H)	EMF 40	Cont. Pz
#####	3.86E-06	1.12393E-08	1.05E+04	5.77E+07	6.64E+03	3.50E+04	1.00E+01	6.00E+02	0.15
5:15	1.29E-05	3.74644E-08	1.05E+04	1.92E+08	2.21E+04	3.50E+04	1.00E+01	6.00E+02	0.15
5:30	5.58E-05	1.62346E-07	1.05E+04	8.34E+08	9.59E+04	3.50E+04	1.00E+01	6.00E+02	0.15
5:45	5.79E-05	1.6859E-07	1.05E+04	8.66E+08	9.96E+04	3.50E+04	1.00E+01	6.00E+02	0.15
6:00	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.15
6:15	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.15
6:30	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.15
6:45	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16
7:00	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16
7:15	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16
7:30	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16
7:45	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16
8:00	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16
8:15	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16
8:30	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.16
8:45	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
9:00	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
9:15	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
9:30	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
9:45	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
00	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
10:15	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
10:30	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
10:45	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
11:00	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
11:15	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
11:30	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
11:45	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
12:00	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
12:15	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
12:30	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
12:45	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
13:00	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	3.50E+04	1.00E+01	6.00E+02	0.00
13:15	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	1.00E+05	1.15E+01	1.00E+04	0.18
13:30	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	3.00E+06	0.30
13:45	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	offscale	0.30
14:00	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	offscale	0.30
14:15	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	offscale	0.30
14:30	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	offscale	1.00
14:45	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	2.00E+05	2.30E+01	offscale	2.00
15:00	5.84E-05	1.69838E-07	1.05E+04	8.73E+08	1.00E+05	offscale	2.30E+03	offscale	3.00
15:15	5.84E-05	1.69838E-07	8.00E+04	1.14E+08	1.31E+04	offscale	2.30E+03	offscale	7.00
15:30	5.84E-05	1.69838E-07	5.82E+04	1.57E+08	1.80E+04	offscale	1.30E+03	offscale	5.00
15:45	5.84E-05	1.69838E-07	3.17E+04	2.88E+08	3.31E+04	offscale	2.30E+03	offscale	2.00
16:00	5.84E-05	1.69838E-07	3.17E+04	2.88E+08	3.31E+04	offscale	2.30E+03	offscale	2.00

DUKE POWER COMPANY  
McGUIRE NUCLEAR STATION  
FIGURE i-1

10 MILE EPZ



Total Release for Off Site Data

TOTAL RELEASE (FOR OFF SITE DATA)				UNIT VENT				0.5 MILE	
TIME	CONTAINMENT		(Ci/sec)	UNIT VENT		TOTAL RELEASE		X/Q=	9.50E-05
	Xe-133 eq.	I-131 eq.		Xe-133 eq.	I-131 eq.	Xe-133 eq.	I-131 eq.	Whole body	Thyroid
5:00 AM	3.88E-06	1.12E-08	5.13E-05	1.49E-09	5.52E-05	1.27E-08	1.76E-04	2.73E-03	
5:15	1.29E-05	3.75E-08	1.71E-04	4.98E-09	1.84E-04	4.24E-08	5.87E-04	9.11E-03	
5:30	5.58E-05	1.62E-07	7.41E-04	2.16E-08	7.97E-04	1.84E-07	2.54E-03	3.95E-02	
5:45	5.79E-05	1.69E-07	7.70E-04	2.24E-08	8.28E-04	1.91E-07	2.64E-03	4.10E-02	
6:00	5.84E-05	1.70E-07	7.75E-04	2.26E-08	8.34E-04	1.92E-07	2.66E-03	4.13E-02	
6:15	5.84E-05	1.70E-07	7.75E-04	2.26E-08	8.34E-04	1.92E-07	2.66E-03	4.13E-02	
6:30	5.84E-05	1.70E-07	7.75E-04	2.26E-08	8.34E-04	1.92E-07	2.66E-03	4.13E-02	
6:45	5.84E-05	1.70E-07	7.75E-04	2.26E-08	8.34E-04	1.92E-07	2.66E-03	4.13E-02	
7:00	5.84E-05	1.70E-07	7.75E-04	2.26E-08	8.34E-04	1.92E-07	2.66E-03	4.13E-02	
7:15	5.84E-05	1.70E-07	7.75E-04	2.26E-08	8.34E-04	1.92E-07	2.66E-03	4.13E-02	
7:30	5.84E-05	1.70E-07	7.75E-04	2.26E-08	8.34E-04	1.92E-07	2.66E-03	4.13E-02	
7:45	5.84E-05	1.70E-07	7.75E-04	2.26E-08	8.34E-04	1.92E-07	2.66E-03	4.13E-02	
8:00	5.84E-05	1.70E-07	7.75E-04	2.26E-08	8.34E-04	1.92E-07	2.66E-03	4.13E-02	
8:15	5.84E-05	1.70E-07	7.75E-04	2.26E-08	8.34E-04	1.92E-07	2.66E-03	4.13E-02	
8:30	5.84E-05	1.70E-07	7.75E-04	2.26E-08	8.34E-04	1.92E-07	2.66E-03	4.13E-02	
8:45	5.84E-05	1.70E-07	7.75E-04	2.26E-08	8.34E-04	1.92E-07	2.66E-03	4.13E-02	
9:00	5.84E-05	1.70E-07	3.91E-04	1.14E-08	4.50E-04	1.81E-07	1.44E-03	3.89E-02	
9:15	5.84E-05	1.70E-07	1.25E-01	1.45E-06	1.25E-01	1.62E-06	3.99E-01	3.49E-01	
9:30	5.84E-05	1.70E-07	1.25E-01	1.45E-07	1.25E-01	3.15E-07	3.99E-01	6.77E-02	
9:45	5.84E-05	1.70E-07	6.12E-02	7.12E-08	6.13E-02	2.41E-07	1.96E-01	5.18E-02	
10:00	5.84E-05	1.70E-07	6.12E-02	7.12E-08	6.13E-02	2.41E-07	1.96E-01	5.18E-02	
10:15	5.84E-05	1.70E-07	6.12E-02	7.12E-08	6.13E-02	2.41E-07	1.96E-01	5.18E-02	
10:30	5.84E-05	1.70E-07	6.12E-02	7.12E-08	6.13E-02	2.41E-07	1.96E-01	5.18E-02	
10:45	5.84E-05	1.70E-07	6.12E-02	7.12E-08	6.13E-02	2.41E-07	1.96E-01	5.18E-02	
11:00	5.84E-05	1.70E-07	1.25E+00	1.45E-04	1.25E+00	1.45E-04	3.99E+00	3.13E+01	
11:15	5.84E-05	1.70E-07	6.00E-01	6.00E-03	6.00E-01	6.00E-03	1.92E+00	1.29E+03	
11:30	5.84E-05	1.70E-07	1.50E+01	1.50E-01	1.50E+01	1.50E-01	4.79E+01	3.22E+04	
11:45	5.84E-05	1.70E-07	1.50E+01	1.50E-01	1.50E+01	1.50E-01	4.79E+01	3.22E+04	
12:00	5.84E-05	1.70E-07	1.50E+01	1.50E-01	1.50E+01	1.50E-01	4.79E+01	3.22E+04	
12:15	5.84E-05	1.70E-07	1.50E+01	1.50E-01	1.50E+01	1.50E-01	4.79E+01	3.22E+04	
12:30	5.84E-05	1.70E-07	7.50E+00	7.50E-02	7.50E+00	7.50E-02	2.39E+01	1.61E+04	
12:45	5.84E-05	1.70E-07	7.50E+00	7.50E-02	7.50E+00	7.50E-02	2.39E+01	1.61E+04	
13:00	5.84E-05	1.70E-07	7.50E+00	7.50E-02	7.50E+00	7.50E-02	2.39E+01	1.61E+04	
13:15	5.84E-05	1.70E-07	7.50E+00	7.50E-02	7.50E+00	7.50E-02	2.39E+01	1.61E+04	
13:30	5.84E-05	1.70E-07	7.50E-01	7.50E-03	7.50E-01	7.50E-03	2.39E+00	1.61E+03	
13:45	5.84E-05	1.70E-07	7.50E-01	7.50E-03	7.50E-01	7.50E-03	2.39E+00	1.61E+03	
14:00	5.84E-05	1.70E-07	7.50E-01	7.50E-03	7.50E-01	7.50E-03	2.39E+00	1.61E+03	
14:15	5.84E-05	1.70E-07	7.50E-01	7.50E-03	7.50E-01	7.50E-03	2.39E+00	1.61E+03	
14:30	5.84E-05	1.70E-07	7.50E-02	7.50E-04	7.51E-02	7.50E-04	2.40E-01	1.61E+02	
14:45	5.84E-05	1.70E-07	7.50E-02	7.50E-04	7.51E-02	7.50E-04	2.40E-01	1.61E+02	
15:00	5.84E-05	1.70E-07	7.50E-02	7.50E-04	7.51E-02	7.50E-04	2.40E-01	1.61E+02	
15:15	5.84E-05	1.70E-07	7.50E-02	7.50E-04	7.51E-02	7.50E-04	2.40E-01	1.61E+02	
15:30	5.84E-05	1.70E-07	7.50E-03	7.50E-05	7.56E-03	7.52E-05	2.41E-02	1.61E+01	
15:45	5.84E-05	1.70E-07	7.50E-03	7.50E-05	7.56E-03	7.52E-05	2.41E-02	1.61E+01	
16:00	5.84E-05	1.70E-07	7.50E-03	7.50E-05	7.56E-03	7.52E-05	2.41E-02	1.61E+01	

The plume has not yet reached the shaded areas - do not give out this data.

Total Release for Off Site Data

TIME	1 MILE		2 MILES		3 MILES		4 MILES	
	X/Q=	Whole body (mRem/hr)						
5:00 AM	6.49E-05	1.01E-03	2.22E-05	3.45E-04	3.11E-05	4.82E-04	7.88E-06	1.22E-04
5:15	2.16E-04	3.34E-03	7.42E-05	1.15E-03	1.04E-04	1.61E-03	2.63E-05	4.08E-04
5:30	9.37E-04	1.45E-02	3.21E-04	4.99E-03	4.49E-04	6.96E-03	1.14E-04	1.77E-03
5:45	9.73E-04	1.51E-02	3.34E-04	5.18E-03	4.66E-04	7.23E-03	1.18E-04	1.83E-03
6:00	9.81E-04	1.52E-02	3.36E-04	5.22E-03	4.69E-04	7.28E-03	1.19E-04	1.85E-03
6:15	9.81E-04	1.52E-02	3.36E-04	5.22E-03	4.69E-04	7.28E-03	1.19E-04	1.85E-03
6:30	9.81E-04	1.52E-02	3.36E-04	5.22E-03	4.69E-04	7.28E-03	1.19E-04	1.85E-03
6:45	9.81E-04	1.52E-02	3.36E-04	5.22E-03	4.69E-04	7.28E-03	1.19E-04	1.85E-03
7:00	9.81E-04	1.52E-02	3.36E-04	5.22E-03	4.69E-04	7.28E-03	1.19E-04	1.85E-03
7:15	9.81E-04	1.52E-02	3.36E-04	5.22E-03	4.69E-04	7.28E-03	1.19E-04	1.85E-03
7:30	9.81E-04	1.52E-02	3.36E-04	5.22E-03	4.69E-04	7.28E-03	1.19E-04	1.85E-03
7:45	9.81E-04	1.52E-02	3.36E-04	5.22E-03	4.69E-04	7.28E-03	1.19E-04	1.85E-03
8:00	9.81E-04	1.52E-02	3.36E-04	5.22E-03	4.69E-04	7.28E-03	1.19E-04	1.85E-03
8:15	9.81E-04	1.52E-02	3.36E-04	5.22E-03	4.69E-04	7.28E-03	1.19E-04	1.85E-03
8:30	9.81E-04	1.52E-02	3.36E-04	5.22E-03	4.69E-04	7.28E-03	1.19E-04	1.85E-03
8:45	9.81E-04	1.52E-02	3.36E-04	5.22E-03	4.69E-04	7.28E-03	1.19E-04	1.85E-03
9:00	5.29E-04	1.43E-02	1.81E-04	4.91E-03	2.53E-04	6.86E-03	6.42E-05	1.74E-03
9:15	1.47E-01	1.28E-01	5.04E-02	4.40E-02	7.04E-02	6.15E-02	1.79E-02	1.56E-02
9:30	1.47E-01	2.49E-02	5.04E-02	8.55E-03	7.04E-02	1.19E-02	1.79E-02	3.03E-03
9:45	7.20E-02	1.91E-02	2.47E-02	6.54E-03	3.45E-02	9.12E-03	6.75E-03	2.32E-03
10:00	7.20E-02	1.91E-02	2.47E-02	6.54E-03	3.45E-02	9.12E-03	6.75E-03	2.32E-03
10:15	7.20E-02	1.91E-02	2.47E-02	6.54E-03	3.45E-02	9.12E-03	6.75E-03	2.32E-03
10:30	7.20E-02	1.91E-02	2.47E-02	6.54E-03	3.45E-02	9.12E-03	6.75E-03	2.32E-03
10:45	7.20E-02	1.91E-02	2.47E-02	6.54E-03	3.45E-02	9.12E-03	6.75E-03	2.32E-03
11:00	1.47E+00	1.15E+01	5.04E-01	3.95E+00	7.04E-01	5.51E+00	1.79E-01	1.40E+00
11:15	7.06E-01	4.75E+02	2.42E-01	1.63E+02	3.38E-01	2.27E+02	6.57E-02	5.76E+01
11:30	1.76E+01	1.19E+04	6.05E+00	4.07E+03	8.44E+00	5.68E+03	2.14E+00	1.44E+03
11:45	1.76E+01	1.19E+04	6.05E+00	4.07E+03	8.44E+00	5.68E+03	2.14E+00	1.44E+03
12:00	1.76E+01	1.19E+04	6.05E+00	4.07E+03	8.44E+00	5.68E+03	2.14E+00	1.44E+03
12:15	1.76E+01	1.19E+04	6.05E+00	4.07E+03	8.44E+00	5.68E+03	2.14E+00	1.44E+03
12:30	8.82E+00	5.93E+03	3.02E+00	2.03E+03	4.22E+00	2.84E+03	1.07E+00	7.20E+02
12:45	8.82E+00	5.93E+03	3.02E+00	2.03E+03	4.22E+00	2.84E+03	1.07E+00	7.20E+02
13:00	8.82E+00	5.93E+03	3.02E+00	2.03E+03	4.22E+00	2.84E+03	1.07E+00	7.20E+02
13:15	8.82E+00	5.93E+03	3.02E+00	2.03E+03	4.22E+00	2.84E+03	1.07E+00	7.20E+02
13:30	8.82E-01	5.93E+02	3.02E-01	2.03E+02	4.22E-01	2.84E+02	1.07E-01	7.20E+01
13:45	8.82E-01	5.93E+02	3.02E-01	2.03E+02	4.22E-01	2.84E+02	1.07E-01	7.20E+01
14:00	8.82E-01	5.93E+02	3.02E-01	2.03E+02	4.22E-01	2.84E+02	1.07E-01	7.20E+01
14:15	8.82E-01	5.93E+02	3.02E-01	2.03E+02	4.22E-01	2.84E+02	1.07E-01	7.20E+01
14:30	8.83E-02	5.93E+01	3.03E-02	2.03E+01	4.22E-02	2.84E+01	1.07E-02	7.21E+00
14:45	8.83E-02	5.93E+01	3.03E-02	2.03E+01	4.22E-02	2.84E+01	1.07E-02	7.21E+00
15:00	8.83E-02	5.93E+01	3.03E-02	2.03E+01	4.22E-02	2.84E+01	1.07E-02	7.21E+00
15:15	8.83E-02	5.93E+01	3.03E-02	2.03E+01	4.22E-02	2.84E+01	1.07E-02	7.21E+00
15:30	8.89E-03	5.95E+00	3.05E-03	2.04E+00	4.25E-03	2.85E+00	1.08E-03	7.22E-01
15:45	8.89E-03	5.95E+00	3.05E-03	2.04E+00	4.25E-03	2.85E+00	1.08E-03	7.22E-01
16:00	8.89E-03	5.95E+00	3.05E-03	2.04E+00	4.25E-03	2.85E+00	1.08E-03	7.22E-01

The plume has not yet reached the shaded areas - do not give out this data.

Total Release for Off Site Data

TIME	5 MILES		6 MILES		7 MILES		8 MILES	
	X/Q=	3.00E-06	X/Q=	2.30E-06	X/Q=	1.83E-06	X/Q=	1.50E-06
	Whole body	(mRem/hr)	Thyroid	(mRem/hr)	Whole body	(mRem/hr)	Thyroid	(mRem/hr)
5:00 AM	5.56E-06	8.63E-05	4.26E-06	6.62E-05	3.38E-06	5.25E-05	2.78E-06	4.32E-05
5:15	1.85E-05	2.88E-04	1.42E-05	2.21E-04	1.13E-05	1.75E-04	9.27E-06	1.44E-04
5:30	6.03E-05	1.25E-03	6.16E-05	9.56E-04	4.89E-05	7.59E-04	4.02E-05	6.23E-04
5:45	8.34E-05	1.29E-03	6.40E-05	9.93E-04	5.08E-05	7.88E-04	4.17E-05	6.47E-04
6:00	8.40E-05	1.30E-03	6.44E-05	1.00E-03	5.11E-05	7.94E-04	4.20E-05	6.52E-04
6:15	8.40E-05	1.30E-03	6.44E-05	1.00E-03	5.11E-05	7.94E-04	4.20E-05	6.52E-04
6:30	8.40E-05	1.30E-03	6.44E-05	1.00E-03	5.11E-05	7.94E-04	4.20E-05	6.52E-04
6:45	8.40E-05	1.30E-03	6.44E-05	1.00E-03	5.11E-05	7.94E-04	4.20E-05	6.52E-04
7:00	8.40E-05	1.30E-03	6.44E-05	1.00E-03	5.11E-05	7.94E-04	4.20E-05	6.52E-04
7:15	8.40E-05	1.30E-03	6.44E-05	1.00E-03	5.11E-05	7.94E-04	4.20E-05	6.52E-04
7:30	8.40E-05	1.30E-03	6.44E-05	1.00E-03	5.11E-05	7.94E-04	4.20E-05	6.52E-04
7:45	8.40E-05	1.30E-03	6.44E-05	1.00E-03	5.11E-05	7.94E-04	4.20E-05	6.52E-04
8:00	8.40E-05	1.30E-03	6.44E-05	1.00E-03	5.11E-05	7.94E-04	4.20E-05	6.52E-04
8:15	8.40E-05	1.30E-03	6.44E-05	1.00E-03	5.11E-05	7.94E-04	4.20E-05	6.52E-04
8:30	8.40E-05	1.30E-03	6.44E-05	1.00E-03	5.11E-05	7.94E-04	4.20E-05	6.52E-04
8:45	8.40E-05	1.30E-03	6.44E-05	1.00E-03	5.11E-05	7.94E-04	4.20E-05	6.52E-04
9:00	4.53E-05	1.23E-03	3.48E-05	9.42E-04	2.76E-05	7.47E-04	2.27E-05	6.14E-04
9:15	1.26E-02	1.10E-02	9.56E-03	8.44E-03	7.67E-03	6.70E-03	6.30E-03	5.51E-03
9:30	1.26E-02	2.14E-03	9.56E-03	1.64E-03	7.67E-03	1.30E-03	6.30E-03	1.07E-03
9:45	6.17E-03	1.63E-03	4.73E-03	1.25E-03	3.76E-03	9.94E-04	3.09E-03	8.17E-04
10:00	6.17E-03	1.63E-03	4.73E-03	1.25E-03	3.76E-03	9.94E-04	3.09E-03	8.17E-04
10:15	6.17E-03	1.63E-03	4.73E-03	1.25E-03	3.76E-03	9.94E-04	3.09E-03	8.17E-04
10:30	6.17E-03	1.63E-03	4.73E-03	1.25E-03	3.76E-03	9.94E-04	3.09E-03	8.17E-04
10:45	6.17E-03	1.63E-03	4.73E-03	1.25E-03	3.76E-03	9.94E-04	3.09E-03	8.17E-04
11:00	1.26E-01	9.87E-01	9.66E-02	7.57E-01	7.67E-02	6.00E-01	6.30E-02	4.94E-01
11:15	6.05E-02	4.07E+01	4.64E-02	3.12E+01	3.68E-02	2.47E+01	3.02E-02	2.03E+01
11:30	1.51E+00	1.02E+03	1.16E+00	7.80E+02	9.20E-01	6.19E+02	7.56E-01	5.09E+02
11:45	1.51E+00	1.02E+03	1.16E+00	7.80E+02	9.20E-01	6.19E+02	7.56E-01	5.09E+02
12:00	1.51E+00	1.02E+03	1.16E+00	7.80E+02	9.20E-01	6.19E+02	7.56E-01	5.09E+02
12:15	1.51E+00	1.02E+03	1.16E+00	7.80E+02	9.20E-01	6.19E+02	7.56E-01	5.09E+02
12:30	7.56E-01	5.09E+02	5.80E-01	3.90E+02	4.60E-01	3.09E+02	3.78E-01	2.54E+02
12:45	7.56E-01	5.09E+02	5.80E-01	3.90E+02	4.60E-01	3.09E+02	3.78E-01	2.54E+02
13:00	7.56E-01	5.09E+02	5.80E-01	3.90E+02	4.60E-01	3.09E+02	3.78E-01	2.54E+02
13:15	7.56E-01	5.09E+02	5.80E-01	3.90E+02	4.60E-01	3.09E+02	3.78E-01	2.54E+02
13:30	7.56E-02	5.09E+01	5.80E-02	3.90E+01	4.60E-02	3.09E+01	3.78E-02	2.54E+01
13:45	7.56E-02	5.09E+01	5.80E-02	3.90E+01	4.60E-02	3.09E+01	3.78E-02	2.54E+01
14:00	7.56E-02	5.09E+01	5.80E-02	3.90E+01	4.60E-02	3.09E+01	3.78E-02	2.54E+01
14:15	7.56E-02	5.09E+01	5.80E-02	3.90E+01	4.60E-02	3.09E+01	3.78E-02	2.54E+01
14:30	7.57E-03	5.09E+00	5.80E-03	3.90E+00	4.60E-03	3.09E+00	3.78E-03	2.54E+00
14:45	7.57E-03	5.09E+00	5.80E-03	3.90E+00	4.60E-03	3.09E+00	3.78E-03	2.54E+00
15:00	7.57E-03	5.09E+00	5.80E-03	3.90E+00	4.60E-03	3.09E+00	3.78E-03	2.54E+00
15:15	7.57E-03	5.09E+00	5.80E-03	3.90E+00	4.60E-03	3.09E+00	3.78E-03	2.54E+00
15:30	7.62E-04	5.10E-01	5.84E-04	3.91E-01	4.63E-04	3.10E-01	3.81E-04	2.55E-01
15:45	7.62E-04	5.10E-01	5.84E-04	3.91E-01	4.63E-04	3.10E-01	3.81E-04	2.55E-01
16:00	7.62E-04	5.10E-01	5.84E-04	3.91E-01	4.63E-04	3.10E-01	3.81E-04	2.55E-01

The plume has not yet reached the shaded areas - do not give out this data.

Total Release for Off Site Data

TIME	9 MILES		10 MILES	
	X/Q=	1.25E-06	X/Q=	1.08E-06
	Whole body (mRem/hr)	Thyroid (mRem/hr)	Whole body (mRem/hr)	Thyroid (mRem/hr)
5:00 AM	2.32E-06	3.60E-05	1.99E-06	3.09E-05
5:15	7.72E-06	1.20E-04	6.64E-06	1.03E-04
5:30	3.35E-05	5.20E-04	2.88E-05	4.47E-04
5:45	3.48E-05	5.40E-04	2.99E-05	4.64E-04
6:00	3.50E-05	5.44E-04	3.01E-05	4.67E-04
6:15	3.50E-05	5.44E-04	3.01E-05	4.67E-04
6:30	3.50E-05	5.44E-04	3.01E-05	4.67E-04
6:45	3.50E-05	5.44E-04	3.01E-05	4.67E-04
7:00	3.50E-05	5.44E-04	3.01E-05	4.67E-04
7:15	3.50E-05	5.44E-04	3.01E-05	4.67E-04
7:30	3.50E-05	5.44E-04	3.01E-05	4.67E-04
7:45	3.50E-05	5.44E-04	3.01E-05	4.67E-04
8:00	3.50E-05	5.44E-04	3.01E-05	4.67E-04
8:15	3.50E-05	5.44E-04	3.01E-05	4.67E-04
8:30	3.50E-05	5.44E-04	3.01E-05	4.67E-04
8:45	3.50E-05	5.44E-04	3.01E-05	4.67E-04
9:00	1.89E-05	5.12E-04	1.62E-05	4.40E-04
9:15	5.25E-03	4.59E-03	4.52E-03	3.95E-03
9:30	5.25E-03	8.91E-04	4.52E-03	7.66E-04
9:45	2.57E-03	6.81E-04	2.21E-03	5.86E-04
10:00	2.57E-03	6.81E-04	2.21E-03	5.86E-04
10:15	2.57E-03	6.81E-04	2.21E-03	5.86E-04
10:30	2.57E-03	6.81E-04	2.21E-03	5.86E-04
10:45	2.57E-03	6.81E-04	2.21E-03	5.86E-04
11:00	5.25E-02	4.11E-01	4.52E-02	3.54E-01
11:15	2.52E-02	1.70E+01	2.17E-02	1.46E+01
11:30	6.30E-01	4.24E+02	5.42E-01	3.64E+02
11:45	6.30E-01	4.24E+02	5.42E-01	3.64E+02
12:00	6.30E-01	4.24E+02	5.42E-01	3.64E+02
12:15	6.30E-01	4.24E+02	5.42E-01	3.64E+02
12:30	3.15E-01	2.12E+02	2.71E-01	1.82E+02
12:45	3.15E-01	2.12E+02	2.71E-01	1.82E+02
13:00	3.15E-01	2.12E+02	2.71E-01	1.82E+02
13:15	3.15E-01	2.12E+02	2.71E-01	1.82E+02
13:30	3.15E-02	2.12E+01	2.71E-02	1.82E+01
13:45	3.15E-02	2.12E+01	2.71E-02	1.82E+01
14:00	3.15E-02	2.12E+01	2.71E-02	1.82E+01
14:15	3.15E-02	2.12E+01	2.71E-02	1.82E+01
14:30	3.15E-03	2.12E+00	2.71E-03	1.82E+00
14:45	3.15E-03	2.12E+00	2.71E-03	1.82E+00
15:00	3.15E-03	2.12E+00	2.71E-03	1.82E+00
15:15	3.15E-03	2.12E+00	2.71E-03	1.82E+00
15:30	3.17E-04	2.12E-01	2.73E-04	1.83E-01
15:45	3.17E-04	2.12E-01	2.73E-04	1.83E-01
16:00	3.17E-04	2.12E-01	2.73E-04	1.83E-01

Offsite Field Data

Field Data DOSE RATES	0.5 MILE		1 MILE		2 MILES		3 MILES	
	cntrline		out edge		cntrline		out edge	
	TIME	mR/hr	mR/hr	mR/hr	mR/hr	mR/hr	mR/hr	mR/hr
5:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
5:15	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00
5:30	0.03	0.01	0.01	0.00	0.00	0.00	0.00	0.00
5:45	0.03	0.01	0.01	0.00	0.00	0.00	0.00	0.00
6:00	0.03	0.01	0.01	0.00	0.00	0.00	0.00	0.00
6:15	0.03	0.01	0.01	0.00	0.00	0.00	0.00	0.00
6:30	0.03	0.01	0.01	0.00	0.00	0.00	0.00	0.00
6:45	0.03	0.01	0.01	0.00	0.00	0.00	0.00	0.00
7:00	0.03	0.01	0.01	0.00	0.00	0.00	0.00	0.00
7:15	0.03	0.01	0.01	0.00	0.00	0.00	0.00	0.00
7:30	0.03	0.01	0.01	0.00	0.00	0.00	0.00	0.00
7:45	0.03	0.01	0.01	0.00	0.00	0.00	0.00	0.00
8:00	0.03	0.01	0.01	0.00	0.00	0.00	0.00	0.00
8:15	0.03	0.01	0.01	0.00	0.00	0.00	0.00	0.00
8:30	0.03	0.01	0.01	0.00	0.00	0.00	0.00	0.00
8:45	0.03	0.01	0.01	0.00	0.00	0.00	0.00	0.00
9:00	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.00
9:15	4	2	1.47	0.74	0.50	0.25	0.70	0.35
9:30	4	2	1.47	0.74	0.50	0.25	0.70	0.35
9:45	2	1	0.72	0.36	0.25	0.12	0.34	0.17
10:00	2	1	0.72	0.36	0.25	0.12	0.34	0.17
10:15	2	1	0.72	0.36	0.25	0.12	0.34	0.17
10:30	2	1	0.72	0.36	0.25	0.12	0.34	0.17
10:45	2	1	0.72	0.36	0.25	0.12	0.34	0.17
11:00	40	20	15	7	5	3	7	4
11:15	19	10	7	4	2.42	1.21	3.38	1.69
11:30	479	239	176	88	60	30.24	84	42
11:45	479	239	176	88	60	30.24	84	42
12:00	479	239	176	88	60	30.24	84	42
12:15	479	239	176	88	60	30.24	84	42
12:30	239	120	88	44	30	15.12	42	21
12:45	239	120	88	44	30	15.12	42	21
13:00	239	120	88	44	30	15.12	42	21
13:15	239	120	88	44	30	15.12	42	21
13:30	24	12	9	4.41	3	1.51	4.22	2.11
13:45	24	12	9	4.41	3	1.51	4.22	2.11
14:00	24	12	9	4.41	3	1.51	4.22	2.11
14:15	24	12	9	4.41	3	1.51	4.22	2.11
14:30	2.40	1.20	0.68	0.44	0.30	0.15	0.42	0.21
14:45	2.40	1.20	0.68	0.44	0.30	0.15	0.42	0.21
15:00	2.40	1.20	0.68	0.44	0.30	0.15	0.42	0.21
15:15	2.40	1.20	0.68	0.44	0.30	0.15	0.42	0.21
15:30	0.24	0.12	0.09	0.04	0.03	0.02	0.04	0.02
15:45	0.24	0.12	0.09	0.04	0.03	0.02	0.04	0.02
16:00	0.24	0.12	0.09	0.04	0.03	0.02	0.04	0.02

The plume has not yet reached the shaded areas - do not give out this data.

Offsite Field Data

TIME	4 MILES		5 MILES		6 MILES		7 MILES	
	cntrline mR/hr	out edge mR/hr						
5:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
5:15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
5:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
5:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6:15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7:15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8:15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8:30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8:45	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
9:00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
9:15	0.18	0.09	0.13	0.06	0.10	0.05	0.08	0.04
9:30	0.18	0.09	0.13	0.06	0.10	0.05	0.08	0.04
9:45	0.09	0.04	0.06	0.03	0.05	0.02	0.04	0.02
10:00	0.09	0.04	0.06	0.03	0.05	0.02	0.04	0.02
10:15	0.09	0.04	0.06	0.03	0.05	0.02	0.04	0.02
10:30	0.09	0.04	0.06	0.03	0.05	0.02	0.04	0.02
10:45	0.09	0.04	0.06	0.03	0.05	0.02	0.04	0.02
11:00	1.79	0.89	1.26	0.63	0.97	0.48	0.77	0.38
11:15	0.86	0.43	0.60	0.30	0.46	0.23	0.37	0.18
11:30	21	11	15	8	12	6	9	5
11:45	21	11	15	8	12	6	9	5
12:00	21	11	15	8	12	6	9	5
12:15	21	11	15	8	12	6	9	5
12:30	11	5	8	4	6	3	5	2
12:45	11	5	8	4	6	3	5	2.30
13:00	11	5	8	4	6	3	5	2.30
13:15	11	5	8	4	6	3	5	2.30
13:30	1	0.54	0.76	0.38	0.58	0.29	0.46	0.23
13:45	1	0.54	0.76	0.38	0.58	0.29	0.46	0.23
14:00	1	0.54	0.76	0.38	0.58	0.29	0.46	0.23
14:15	1	0.54	0.76	0.38	0.58	0.29	0.46	0.23
14:30	0.11	0.05	0.08	0.04	0.06	0.03	0.05	0.02
14:45	0.11	0.05	0.08	0.04	0.06	0.03	0.05	0.02
15:00	0.11	0.05	0.08	0.04	0.06	0.03	0.05	0.02
15:15	0.11	0.05	0.08	0.04	0.06	0.03	0.05	0.02
15:30	0.01	0.01	0.01	0.00	0.01	0.00	0.00	0.00
15:45	0.01	0.01	0.01	0.00	0.01	0.00	0.00	0.00
16:00	0.01	0.01	0.01	0.00	0.01	0.00	0.00	0.00

The plume has not yet reached the shaded areas - do not give out this data.

### Offsite Field Data

TIME	8 MILES		9 MILES		10 MILES		
	cntrline	outer edge	cntrline	outer edge	cntrline	outer edge	
	mR/hr	mR/hr	mR/hr	mR/hr	mR/hr	mR/hr	
5:00	0.00	0.00	0.00	0.00	0.00	0.00	
5:15	0.00	0.00	0.00	0.00	0.00	0.00	
5:30	0.00	0.00	0.00	0.00	0.00	0.00	
5:45	0.00	0.00	0.00	0.00	0.00	0.00	
6:00	0.00	0.00	0.00	0.00	0.00	0.00	
6:15	0.00	0.00	0.00	0.00	0.00	0.00	
6:30	0.00	0.00	0.00	0.00	0.00	0.00	
6:45	0.00	0.00	0.00	0.00	0.00	0.00	
7:00	0.00	0.00	0.00	0.00	0.00	0.00	
7:15	0.00	0.00	0.00	0.00	0.00	0.00	
7:30	0.00	0.00	0.00	0.00	0.00	0.00	
7:45	0.00	0.00	0.00	0.00	0.00	0.00	
8:00	0.00	0.00	0.00	0.00	0.00	0.00	
8:15	0.00	0.00	0.00	0.00	0.00	0.00	
8:30	0.00	0.00	0.00	0.00	0.00	0.00	
8:45	0.00	0.00	0.00	0.00	0.00	0.00	
9:00	0.00	0.00	0.00	0.00	0.00	0.00	
9:15	0.06	0.03	0.05	*	0.03	0.05	0.02
9:30	0.06	0.03	0.05	0.03	0.05	0.05	0.02
9:45	0.03	0.02	0.03	0.01	0.02	0.02	0.01
10:00	0.03	0.02	0.03	0.01	0.02	0.02	0.01
10:15	0.03	0.02	0.03	0.01	0.02	0.02	0.01
10:30	0.03	0.02	0.03	0.01	0.02	0.02	0.01
10:45	0.03	0.02	0.03	0.01	0.02	0.02	0.01
11:00	0.63	0.32	0.53	0.26	0.45	0.23	
11:15	0.30	0.15	0.25	0.13	0.22	0.11	
11:30	8	3.78	6	3.15	5.42	2.71	
11:45	8	3.78	6	3.15	5.42	2.71	
12:00	8	3.78	6	3.15	5.42	2.71	
12:15	8	3.78	6	3.15	5.42	2.71	
12:30	4	1.89	3	1.58	2.71	1.35	
12:45	4	1.89	3	1.58	2.71	1.35	
13:00	4	1.89	3	1.58	2.71	1.35	
13:15	4	1.89	3	1.58	2.71	1.35	
13:30	0.38	0.19	0.32	0.16	0.27	0.14	
13:45	0.38	0.19	0.32	0.16	0.27	0.14	
14:00	0.38	0.19	0.32	0.16	0.27	0.14	
14:15	0.38	0.19	0.32	0.16	0.27	0.14	
14:30	0.04	0.02	0.03	0.02	0.03	0.01	
14:45	0.04	0.02	0.03	0.02	0.03	0.01	
15:00	0.04	0.02	0.03	0.02	0.03	0.01	
15:15	0.04	0.02	0.03	0.02	0.03	0.01	
15:30	0.00	0.00	0.00	0.00	0.00	0.00	
15:45	0.00	0.00	0.00	0.00	0.00	0.00	
16:00	0.00	0.00	0.00	0.00	0.00	0.00	

The plume has not yet reached the shaded areas - do not give out this data.

### Offsite Field Data

Field Data DOSE RATES ME	0.5 MILE		1 MILE		2 MILES		3 MILES	
	centerline	outer edge						
	uR/hr							
5:00	2	1	1	0	0	0	0	0
5:15	6	3	2	1	1	0	1	1
5:30	25	13	9	5	3	2	4	2
5:45	26	13	10	5	3	2	5	2
6:00	27	13	10	5	3	2	5	2
6:15	27	13	10	5	3	2	5	2
6:30	27	13	10	5	3	2	5	2
6:45	27	13	10	5	3	2	5	2
7:00	27	13	10	5	3	2	5	2
7:15	27	13	10	5	3	2	5	2
7:30	27	13	10	5	3	2	5	2
7:45	27	13	10	5	3	2	5	2
8:00	27	13	10	5	3	2	5	2
8:15	27	13	10	5	3	2	5	2
8:30	27	13	10	5	3	2	5	2
8:45	27	13	10	5	3	2	5	2
9:00	14	7	5	3	2	1	3	1
9:15	3992	1996	1471	735	504	252	704	352
9:30	3992	1996	1471	735	504	252	704	352
9:45	1955	978	720	360	247	123	345	172
10:00	1955	978	720	360	247	123	345	172
:15	1955	978	720	360	247	123	345	172
10:30	1955	978	720	360	247	123	345	172
10:45	1955	978	720	360	247	123	345	172
11:00	39902	19951	14701	7350	5040	2520	7035	3518
11:15	19154	9577	7057	3528	2419	1210	3377	1689
11:30	478802	239401	176401	88200	60480	30240	84420	42210
11:45	478802	239401	176401	88200	60480	30240	84420	42210
12:00	478802	239401	176401	88200	60480	30240	84420	42210
12:15	478802	239401	176401	88200	60480	30240	84420	42210
12:30	239402	119701	88201	44100	30240	15120	42210	21105
12:45	239402	119701	88201	44100	30240	15120	42210	21105
13:00	239402	119701	88201	44100	30240	15120	42210	21105
13:15	239402	119701	88201	44100	30240	15120	42210	21105
13:30	23942	11971	8821	4410	3024	1512	4221	2111
13:45	23942	11971	8821	4410	3024	1512	4221	2111
14:00	23942	11971	8821	4410	3024	1512	4221	2111
14:15	23942	11971	8821	4410	3024	1512	4221	2111
14:30	2396	1198	883	441	303	151	422	211
14:45	2396	1198	883	441	303	151	422	211
15:00	2396	1198	883	441	303	151	422	211
15:15	2396	1198	883	441	303	151	422	211
15:30	241	121	89	44	30	15	43	21
15:45	241	121	89	44	30	15	43	21
16:00	241	121	89	44	30	15	43	21

The plume has not yet reached the shaded areas - do not give out this data.

Micro-R meter offscale High

Offsite Field Data

FIELD DATA		4 MILES		5 MILES		6 MILES		7 MILES	
RATES	centerline	outer edge							
TIME	uR/hr								
5:00	0	0	0	0	0	0	0	0	
5:15	0	0	0	0	0	0	0	0	
5:30	1	1	1	0	1	0	0	0	
5:45	1	1	1	0	1	0	1	0	
6:00	1	1	1	0	1	0	1	0	
6:15	1	1	1	0	1	0	1	0	
6:30	1	1	1	0	1	0	1	0	
6:45	1	1	1	0	1	0	1	0	
7:00	1	1	1	0	1	0	1	0	
7:15	1	1	1	0	1	0	1	0	
7:30	1	1	1	0	1	0	1	0	
7:45	1	1	1	0	1	0	1	0	
8:00	1	1	1	0	1	0	1	0	
8:15	1	1	1	0	1	0	1	0	
8:30	1	1	1	0	1	0	1	0	
8:45	1	1	1	0	1	0	1	0	
9:00	1	0	0	0	0	0	0	0	
9:15	179	89	126	63	97	48	77	38	
9:30	179	89	126	63	97	48	77	38	
9:45	87	44	62	31	47	24	38	19	
10:00	87	44	62	31	47	24	38	19	
10:15	87	44	62	31	47	24	38	19	
10:30	87	44	62	31	47	24	38	19	
10:45	87	44	62	31	47	24	38	19	
11:00	1785	893	1260	630	966	483	767	383	
11:15	857	428	603	302	484	232	368	184	
11:30	21420	10710	15120	7560	11592	5796	9198	4599	
11:45	21420	10710	15120	7560	11592	5796	9198	4599	
12:00	21420	10710	15120	7560	11592	5796	9190	4599	
12:15	21420	10710	15120	7560	11592	5796	9198	4599	
12:30	10710	5355	7560	3780	5796	2898	4599	2300	
12:45	10710	5355	7560	3780	5796	2898	4599	2300	
13:00	10710	5355	7560	3780	5796	2898	4599	2300	
13:15	10710	5355	7560	3780	5796	2898	4599	2300	
13:30	1071	536	756	378	580	290	460	230	
13:45	1071	536	756	378	580	290	460	230	
14:00	1071	536	756	378	580	290	460	230	
14:15	1071	536	756	378	580	290	460	230	
14:30	107	54	76	38	58	29	46	23	
14:45	107	54	76	38	58	29	46	23	
15:00	107	54	76	38	58	29	46	23	
15:15	107	54	76	38	58	29	46	23	
15:30	11	5	8	4	6	3	5	2	
15:45	11	5	8	4	6	3	5	2	
16:00	11	5	8	4	6	3	5	2	

The plume has not yet reached the shaded areas - do not give out this data.

Micro-R meter offscale High

Offsite Field Data

FIELD DATA DOSE RATES	8 MILES		9 MILES		10 MILES	
	centerline uR/hr	outer edge uR/hr	centerline uR/hr	outer edge uR/hr	centerline uR/hr	outer edge uR/hr
TIME						
5:00	0	0	0	0	0	0
5:15	0	0	0	0	0	0
5:30	0	0	0	0	0	0
5:45	0	0	0	0	0	0
6:00	0	0	0	0	0	0
6:15	0	0	0	0	0	0
6:30	0	0	0	0	0	0
6:45	0	0	0	0	0	0
7:00	0	0	0	0	0	0
7:15	0	0	0	0	0	0
7:30	0	0	0	0	0	0
7:45	0	0	0	0	0	0
8:00	0	0	0	0	0	0
8:15	0	0	0	0	0	0
8:30	0	0	0	0	0	0
8:45	0	0	0	0	0	0
9:00	0	0	0	0	0	0
9:15	63	32	53	26	45	23
9:30	63	32	53	26	45	23
9:45	31	15	26	13	22	11
10:00	31	15	26	13	22	11
10:15	31	15	26	13	22	11
10:30	31	15	26	13	22	11
10:45	31	15	26	13	22	11
11:00	630	315	525	263	452	226
11:15	302	151	252	126	217	108
11:30	7560	3780	6300	3150	5418	2709
11:45	7560	3780	6300	3150	5418	2709
12:00	7560	3780	6300	3150	5418	2709
12:15	7560	3780	6300	3150	5418	2709
12:30	3780	1890	3150	1575	2709	1355
12:45	3780	1890	3150	1575	2709	1355
13:00	3780	1890	3150	1575	2709	1355
13:15	3780	1890	3150	1575	2709	1355
13:30	378	189	315	158	271	135
13:45	378	189	315	158	271	135
14:00	378	189	315	158	271	135
14:15	378	189	315	158	271	135
14:30	38	19	32	16	27	14
14:45	38	19	32	16	27	14
15:00	38	19	32	16	27	14
15:15	18	19	32	16	27	14
15:30	4	2	3	2	3	1
15:45	4	2	3	2	3	1
16:00	4	2	3	2	3	1

The plume has not yet reached the shaded areas - do not give out this data.

Offsite    id    Data

The plume has not yet reached the shaded areas - do not give out this data.

	Volume =	ml	count	time=	5 minutes
	2.03E+05	ml			

## Offsite Field Data

	Eff. Factor=	5.88		Bkg (cpm)		120		
ESP-2	MILES (centerline)	1 MILES (centerline)		2 MILES (centerline)		3 MILES (centerline)		
DATA	Iodine-131 conc.	Iodine-131 conc.		Iodine-131 conc.		Iodine-131 conc.		
TIME	uCi/ml	Cnts/ Min	uCi/ml	Cnts/ Min	uCi/ml	Cnts/ Min	uCi/ml	Cnts/ Min
5:00 AM	1.21E-12	1.20E+02	4.46E-13	1.20E+02	1.53E-13	1.20E+02	2.13E-13	1.20E+02
5:15	4.03E-12	1.20E+02	1.49E-12	1.20E+02	5.09E-13	1.20E+02	7.11E-13	1.20E+02
5:30	1.75E-11	1.22E+02	6.44E-12	1.21E+02	2.21E-12	1.20E+02	3.08E-12	1.20E+02
5:45	1.81E-11	1.22E+02	6.68E-12	1.21E+02	2.29E-12	1.20E+02	3.20E-12	1.20E+02
6:00	1.83E-11	1.22E+02	6.73E-12	1.21E+02	2.31E-12	1.20E+02	3.22E-12	1.20E+02
6:15	1.83E-11	1.22E+02	6.73E-12	1.21E+02	2.31E-12	1.20E+02	3.22E-12	1.20E+02
6:30	1.83E-11	1.22E+02	6.73E-12	1.21E+02	2.31E-12	1.20E+02	3.22E-12	1.20E+02
6:45	1.83E-11	1.22E+02	6.73E-12	1.21E+02	2.31E-12	1.20E+02	3.22E-12	1.20E+02
7:00	1.83E-11	1.22E+02	6.73E-12	1.21E+02	2.31E-12	1.20E+02	3.22E-12	1.20E+02
7:15	1.83E-11	1.22E+02	6.73E-12	1.21E+02	2.31E-12	1.20E+02	3.22E-12	1.20E+02
7:30	1.83E-11	1.22E+02	6.73E-12	1.21E+02	2.31E-12	1.20E+02	3.22E-12	1.20E+02
7:45	1.83E-11	1.22E+02	6.73E-12	1.21E+02	2.31E-12	1.20E+02	3.22E-12	1.20E+02
8:00	1.83E-11	1.22E+02	6.73E-12	1.21E+02	2.31E-12	1.20E+02	3.22E-12	1.20E+02
8:15	1.83E-11	1.22E+02	6.73E-12	1.21E+02	2.31E-12	1.20E+02	3.22E-12	1.20E+02
8:30	1.83E-11	1.22E+02	6.73E-12	1.21E+02	2.31E-12	1.20E+02	3.22E-12	1.20E+02
8:45	1.83E-11	1.22E+02	6.73E-12	1.21E+02	2.31E-12	1.20E+02	3.22E-12	1.20E+02
9:00	1.72E-11	1.22E+02	6.34E-12	1.21E+02	2.17E-12	1.20E+02	1.94E-12	1.20E+02
9:15	1.54E-10	1.37E+02	5.68E-13	1.20E+02	1.95E-11	1.22E+02	2.72E-11	1.23E+02
9:30	2.99E-11	1.23E+02	1.10E-11	1.21E+02	3.78E-12	1.20E+02	5.28E-12	1.21E+02
9:45	2.29E-11	1.22E+02	8.44E-12	1.21E+02	2.89E-12	1.20E+02	4.04E-12	1.20E+02
10:00	2.29E-11	1.22E+02	8.44E-12	1.21E+02	2.89E-12	1.20E+02	4.04E-12	1.20E+02
10:15	2.29E-11	1.22E+02	8.44E-12	1.21E+02	2.89E-12	1.20E+02	4.04E-12	1.20E+02
10:30	2.29E-11	1.22E+02	8.44E-12	1.21E+02	2.89E-12	1.20E+02	4.04E-12	1.20E+02
10:45	2.29E-11	1.22E+02	8.44E-12	1.21E+02	2.89E-12	1.20E+02	4.04E-12	1.20E+02
11:00	1.38E-08	1.60E+03	5.10E-09	5.62E+02	1.75E-09	3.07E+02	7.44E-09	3.81E+02
11:15	5.70E-07	6.11E+04	2.10E-07	2.26E+04	7.20E-08	7.83E+03	1.01E-07	1.09E+04
11:30	1.43E-05	1.52E+06	5.25E-06	5.62E+05	1.80E-06	1.93E+05	2.51E-06	2.69E+05
11:45	1.43E-05	1.52E+06	5.25E-06	5.62E+05	1.80E-06	1.93E+05	2.51E-06	2.69E+05

The plume has not yet reached the shaded areas - do not give out this data.

## Offsite Radiiodine Data

	4 MILES (centerline)		5 MILES (centerline)		6 MILES (centerline)	
	Iodine-131 conc.		Iodine-131 conc.		Iodine-131 conc.	
	uCi/ml	Cnts/ Min	uCi/ml	Cnts/ Min	uCi/ml	Cnts/ Min
5:00 AM	5.41E-14	1.20E+02	3.82E-14	1.20E+02	2.93E-14	1.20E+02
5:15	1.80E-13	1.20E+02	1.27E-13	1.20E+02	9.76E-14	1.20E+02
5:30	7.82E-13	1.20E+02	5.52E-13	1.20E+02	4.23E-13	1.20E+02
5:45	8.12E-13	1.20E+02	5.73E-13	1.20E+02	4.39E-13	1.20E+02
6:00	8.18E-13	1.20E+02	5.77E-13	1.20E+02	4.43E-13	1.20E+02
6:15	8.18E-13	1.20E+02	5.77E-13	1.20E+02	4.43E-13	1.20E+02
6:30	8.18E-13	1.20E+02	5.77E-13	1.20E+02	4.43E-13	1.20E+02
6:45	8.18E-13	1.20E+02	5.77E-13	1.20E+02	4.43E-13	1.20E+02
7:00	8.18E-13	1.20E+02	5.77E-13	1.20E+02	4.43E-13	1.20E+02
7:15	8.18E-13	1.20E+02	5.77E-13	1.20E+02	4.43E-13	1.20E+02
7:30	8.18E-13	1.20E+02	5.77E-13	1.20E+02	4.43E-13	1.20E+02
7:45	8.18E-13	1.20E+02	5.77E-13	1.20E+02	4.43E-13	1.20E+02
8:00	8.18E-13	1.20E+02	5.77E-13	1.20E+02	4.43E-13	1.20E+02
8:15	8.18E-13	1.20E+02	5.77E-13	1.20E+02	4.43E-13	1.20E+02
8:30	8.18E-13	1.20E+02	5.77E-13	1.20E+02	4.43E-13	1.20E+02
8:45	8.18E-13	1.20E+02	5.77E-13	1.20E+02	4.43E-13	1.20E+02
9:00	7.70E-13	1.20E+02	5.44E-13	1.20E+02	4.17E-13	1.20E+02
9:15	6.90E-12	1.21E+02	4.87E-12	1.21E+02	3.74E-12	1.20E+02
9:30	1.34E-12	1.20E+02	9.46E-13	1.20E+02	7.25E-13	1.20E+02
9:45	1.02E-12	1.20E+02	7.23E-13	1.20E+02	5.54E-13	1.20E+02
10:00	1.02E-12	1.20E+02	7.23E-13	1.20E+02	5.54E-13	1.20E+02
10:15	1.02E-12	1.20E+02	7.23E-13	1.20E+02	5.54E-13	1.20E+02
10:30	1.02E-12	1.20E+02	7.23E-13	1.20E+02	5.54E-13	1.20E+02
10:45	1.02E-12	1.20E+02	7.23E-13	1.20E+02	5.54E-13	1.20E+02
11:00	6.19E-10	1.86E+02	4.37E-10	1.67E+02	3.35E-10	1.56E+02
11:15	2.55E-08	2.85E+03	1.80E-08	2.05E+03	1.38E-08	1.60E+03
11:30	6.38E-07	6.83E+04	4.50E-07	4.82E+04	3.45E-07	3.70E+04
11:45	6.38E-07	6.83E+04	4.50E-07	4.82E+04	3.45E-07	3.70E+04

## Offsite iodine Data

7 MILES (centerline)		8 MILES (centerline)		9 MILES (centerline)		10 MILES (centerline)		
	Iodine-131 conc.		Iodine-131 conc.		Iodine-131 conc.		Iodine-131 conc.	
	uCi/ml	Cnts/ Min	uCi/ml	Cnts/ Min	uCi/ml	Cnts/ Min	uCi/ml	Cnts/ Min
5:00 AM	2.32E-14	1.20E+02	1.91E-14	1.20E+02	1.59E-14	1.20E+02	1.37E-14	1.20E+02
5:15	7.75E-14	1.20E+02	6.37E-14	1.20E+02	5.31E-14	1.20E+02	4.56E-14	1.20E+02
5:30	3.36E-13	1.20E+02	2.76E-13	1.20E+02	2.30E-13	1.20E+02	1.98E-13	1.20E+02
5:45	3.49E-13	1.20E+02	2.86E-13	1.20E+02	2.39E-13	1.20E+02	2.05E-13	1.20E+02
6:00	3.51E-13	1.20E+02	2.89E-13	1.20E+02	2.41E-13	1.20E+02	2.07E-13	1.20E+02
6:15	3.51E-13	1.20E+02	2.89E-13	1.20E+02	2.41E-13	1.20E+02	2.07E-13	1.20E+02
6:30	3.51E-13	1.20E+02	2.89E-13	1.20E+02	2.41E-13	1.20E+02	2.07E-13	1.20E+02
6:45	3.51E-13	1.20E+02	2.89E-13	1.20E+02	2.41E-13	1.20E+02	2.07E-13	1.20E+02
7:00	3.51E-13	1.20E+02	2.89E-13	1.20E+02	2.41E-13	1.20E+02	2.07E-13	1.20E+02
7:15	3.51E-13	1.20E+02	2.89E-13	1.20E+02	2.41E-13	1.20E+02	2.07E-13	1.20E+02
7:30	3.51E-13	1.20E+02	2.89E-13	1.20E+02	2.41E-13	1.20E+02	2.07E-13	1.20E+02
7:45	3.51E-13	1.20E+02	2.89E-13	1.20E+02	2.41E-13	1.20E+02	2.07E-13	1.20E+02
8:00	3.51E-13	1.20E+02	2.89E-13	1.20E+02	2.41E-13	1.20E+02	2.07E-13	1.20E+02
8:15	3.51E-13	1.20E+02	2.89E-13	1.20E+02	2.41E-13	1.20E+02	2.07E-13	1.20E+02
8:30	3.51E-13	1.20E+02	2.89E-13	1.20E+02	2.41E-13	1.20E+02	2.07E-13	1.20E+02
8:45	3.51E-13	1.20E+02	2.89E-13	1.20E+02	2.41E-13	1.20E+02	2.07E-13	1.20E+02
9:00	3.31E-13	1.20E+02	2.72E-13	1.20E+02	2.27E-13	1.20E+02	1.95E-13	1.20E+02
9:15	2.96E-12	1.20E+02	2.44E-12	1.20E+02	2.03E-12	1.20E+02	1.75E-12	1.20E+02
9:30	5.75E-13	1.20E+02	4.73E-13	1.20E+02	3.94E-13	1.20E+02	3.39E-13	1.20E+02
9:45	6.40E-13	1.20E+02	3.62E-13	1.20E+02	3.01E-13	1.20E+02	2.59E-13	1.20E+02
10:00	4.40E-13	1.20E+02	3.62E-13	1.20E+02	3.01E-13	1.20E+02	2.59E-13	1.20E+02
10:15	4.40E-13	1.20E+02	3.62E-13	1.20E+02	3.01E-13	1.20E+02	2.59E-13	1.20E+02
10:30	4.40E-13	1.20E+02	3.62E-13	1.20E+02	3.01E-13	1.20E+02	2.59E-13	1.20E+02
10:45	4.40E-13	1.20E+02	3.62E-13	1.20E+02	3.01E-13	1.20E+02	2.59E-13	1.20E+02
11:00	2.66E-10	1.48E+02	2.18E-10	1.43E+02	1.82E-10	1.39E+02	1.57E-10	1.37E+02
11:15	1.10E-08	1.29E+03	9.00E-09	1.08E+03	7.50E-09	9.22E+02	6.45E-09	8.10E+02
11:30	2.74E-07	2.94E+04	2.25E-07	2.42E+04	1.88E-07	2.02E+04	1.61E-07	1.74E+04
11:45	2.74E-07	2.94E+04	2.25E-07	2.42E+04	1.88E-07	2.02E+04	1.61E-07	1.74E+04

## Offsite Iodine Data

The plume has not yet reached the shaded areas - do not give out this data.								
ESP-2	0.5 MILES (centerline)		1 MILES (centerline)		2 MILES (centerline)		3 MILES (centerline)	
DATA	Iodine-131 conc.		Iodine-131 conc.		Iodine-131 conc.		Iodine-131 conc.	
TIME	uCi/ml	Cnts/ Min	uCi/ml	Cnts/ Min	uCi/ml	Cnts/ Min	uCi/ml	Cnts/ Min
12:00	1.43E-05	1.52E+06	5.25E-06	5.62E+05	1.80E-06	1.93E+05	2.51E-06	2.69E+05
12:15	1.43E-05	1.52E+06	5.25E-06	5.62E+05	1.80E-06	1.93E+05	2.51E-06	2.69E+05
12:30	7.13E-06	7.62E+05	2.63E-06	2.81E+05	9.00E-07	9.64E+04	1.26E-06	1.34E+05
12:45	7.13E-06	7.62E+05	2.63E-06	2.81E+05	9.00E-07	9.64E+04	1.26E-06	1.34E+05
13:00	7.13E-06	7.62E+05	2.63E-06	2.81E+05	9.00E-07	9.64E+04	1.26E-06	1.34E+05
13:15	7.13E-06	7.62E+05	2.63E-06	2.81E+05	9.00E-07	9.64E+04	1.26E-06	1.34E+05
13:30	7.13E-07	7.63E+04	2.63E-07	2.82E+04	9.00E-08	9.75E+03	1.26E-07	1.36E+04
13:45	7.13E-07	7.63E+04	2.63E-07	2.82E+04	9.00E-08	9.75E+03	1.26E-07	1.36E+04
14:00	7.13E-07	7.63E+04	2.63E-07	2.82E+04	9.00E-08	9.75E+03	1.26E-07	1.36E+04
14:15	7.13E-07	7.63E+04	2.63E-07	2.82E+04	9.00E-08	9.75E+03	1.26E-07	1.36E+04
14:30	7.13E-08	7.74E+03	2.63E-08	2.93E+03	9.00E-09	1.08E+03	1.26E-08	1.46E+03
14:45	7.13E-08	7.74E+03	2.63E-08	2.93E+03	9.00E-09	1.08E+03	1.26E-08	1.46E+03
15:00	7.13E-08	7.74E+03	2.63E-08	2.93E+03	9.00E-09	1.08E+03	1.26E-08	1.46E+03
15:15	7.13E-08	7.74E+03	2.63E-08	2.93E+03	9.00E-09	1.08E+03	1.26E-08	1.46E+03
15:30	7.14E-09	8.84E+02	2.63E-09	4.01E+02	9.02E-10	2.16E+02	1.26E-09	2.55E+02
15:45	7.14E-09	8.84E+02	2.63E-09	4.01E+02	9.02E-10	2.16E+02	1.26E-09	2.55E+02
16:00	7.14E-09	8.84E+02	2.63E-09	4.01E+02	9.02E-10	2.16E+02	1.26E-09	2.55E+02

The plume has not yet reached the shaded areas - do not give out this data.

## Offsite Radiological Data

	4 MILES (centerline)		5 MILES (centerline)		6 MILES (centerline)	
	Iodine-131 conc.		Iodine-131 conc.		Iodine-131 conc.	
	uCi/ml	Cnts/ Min	uCi/ml	Cnts/ Min	uCi/ml	Cnts/ Min
12:00	6.38E-07	6.83E+04	6.30E-07	4.82E+04	3.49E-07	3.70E+04
12:15	6.38E-07	6.83E+04	4.50E-07	4.82E+04	3.49E-07	3.70E+04
12:30	3.19E-07	3.42E+04	2.25E-07	2.42E+04	1.73E-07	1.86E+04
12:45	3.19E-07	3.42E+04	2.25E-07	2.42E+04	1.73E-07	1.86E+04
13:00	3.19E-07	3.42E+04	2.25E-07	2.42E+04	1.73E-07	1.86E+04
13:15	3.19E-07	3.42E+04	2.25E-07	2.42E+04	1.73E-07	1.86E+04
13:30	3.19E-08	3.53E+03	2.25E-08	2.53E+03	1.73E-08	1.96E+03
13:45	3.19E-08	3.53E+03	2.25E-08	2.53E+03	1.73E-08	1.96E+03
14:00	3.19E-08	3.53E+03	2.25E-08	2.53E+03	1.73E-08	1.96E+03
14:15	3.19E-08	3.53E+03	2.25E-08	2.53E+03	1.73E-08	1.96E+03
14:30	3.19E-09	4.61E+02	2.25E-09	3.61E+02	1.73E-09	3.05E+02
14:45	3.19E-09	4.61E+02	2.25E-09	3.61E+02	1.73E-09	3.05E+02
15:00	3.19E-09	4.61E+02	2.25E-09	3.61E+02	1.73E-09	3.05E+02
15:15	3.19E-09	4.61E+02	2.25E-09	3.61E+02	1.73E-09	3.05E+02
15:30	3.19E-10	1.54E+02	2.26E-10	1.44E+02	1.73E-10	1.38E+02
15:45	3.19E-10	1.54E+02	2.26E-10	1.44E+02	1.73E-10	1.38E+02
16:00	3.19E-10	1.54E+02	2.26E-10	1.44E+02	1.73E-10	1.38E+02

The plume has not yet reached the shaded areas - do not give out this data.

Offsite ~~1~~ id Data

ESP-2	7 MILES (centerline)		8 MILES (centerline)		9 MILES (centerline)		10 MILES (centerline)	
	Iodine-131 conc.		Iodine-131 conc.		Iodine-131 conc.		Iodine-131 conc.	
	uCi/ml	Cnts/ Min	uCi/ml	Cnts/ Min	uCi/ml	Cnts/ Min	uCi/ml	Cnts/ Min
12:00	2.74E-07	2.94E+04	2.25E-07	2.42E+04	1.98E-07	2.02E+04	1.51E-07	1.74E+04
12:15	2.74E-07	2.94E+04	2.25E-07	2.42E+04	1.98E-07	2.02E+04	1.51E-07	1.74E+04
12:30	1.37E-07	1.48E+04	1.13E-07	1.22E+04	9.38E-08	1.01E+04	8.06E-08	8.74E+03
12:45	1.37E-07	1.48E+04	1.13E-07	1.22E+04	9.38E-08	1.01E+04	8.06E-08	8.74E+03
13:00	1.37E-07	1.48E+04	1.13E-07	1.22E+04	9.38E-08	1.01E+04	8.06E-08	8.74E+03
13:15	1.37E-07	1.48E+04	1.13E-07	1.22E+04	9.38E-08	1.01E+04	8.06E-08	8.74E+03
13:30	1.37E-08	1.58E+03	1.13E-08	1.32E+03	9.38E-09	1.12E+03	8.06E-09	9.82E+02
13:45	1.37E-08	1.58E+03	1.13E-08	1.32E+03	9.38E-09	1.12E+03	8.06E-09	9.82E+02
14:00	1.37E-08	1.58E+03	1.13E-08	1.32E+03	9.38E-09	1.12E+03	8.06E-09	9.82E+02
14:15	1.37E-08	1.58E+03	1.13E-08	1.32E+03	9.38E-09	1.12E+03	8.06E-09	9.82E+02
14:30	1.37E-09	2.66E+02	1.13E-09	2.40E+02	9.38E-10	2.20E+02	8.06E-10	2.06E+02
14:45	1.37E-09	2.66E+02	1.13E-09	2.40E+02	9.38E-10	2.20E+02	8.06E-10	2.06E+02
15:00	1.37E-09	2.66E+02	1.13E-09	2.40E+02	9.38E-10	2.20E+02	8.06E-10	2.06E+02
15:15	1.37E-09	2.66E+02	1.13E-09	2.40E+02	9.38E-10	2.20E+02	8.06E-10	2.06E+02
15:30	1.37E-10	1.35E+02	1.13E-10	1.32E+02	9.40E-11	1.30E+02	8.08E-11	1.29E+02
15:45	1.37E-10	1.35E+02	1.13E-10	1.32E+02	9.40E-11	1.30E+02	8.08E-11	1.29E+02
16:00	1.37E-10	1.35E+02	1.13E-10	1.32E+02	9.40E-11	1.30E+02	8.08E-11	1.29E+02

The plume has not yet reached the shaded areas - do not give out this data.

Review with Emergency Coordinator the recommended Emergency Classification  
(based on Dose Projections only) :

Recommend Alert

**Recommended Protective Actions (based on Dose Projections only)**

EVACUATE

SHELTER IN-PLACE

OTHER

\*\*\*

Note

\*\*\* - Compare these recommendations with other groups' recommendations  
that the Emergency Coordinator/Recovery Manager reviews.

Projection based on data on 10/20/93 915 Time since trip 0.25 hrs

**Meteorology Assessment**

Temperature Gradient -0.5

Distance	X/Q	Ch	Distance	X/Q	Ch
mile	sec/m3	mph-sec/m3	mile	sec/m3	mph-sec/m3
.5	1.85E-04	3.80E-04	2	2.39E-05	4.90E-05
1	6.83E-05	1.40E-04	4	8.29E-06	1.70E-05
3	1.32E-05	2.70E-05	6	4.49E-06	9.20E-06
5	5.85E-06	1.20E-05	8	2.93E-06	6.00E-06
7	3.56E-06	7.30E-06	10	2.10E-06	4.30E-06
9	2.44E-06	5.00E-06			
mile 0 - 2   2 - 5   5 - 10					
PAZ L B M C N A D O R	G H I J K P				

**Source Term Assessment**

Steam Relief Valves	Containment	Unit Vent
Ci/sec	Ci/sec	Ci/sec
0.00E-01	2.72E-06	2.91E-01 - Noble Gas
0.00E-01	8.55E-09	9.15E-06 - Iodine

Source Term based on LOCA(charcoal)

**Dose Assessment**

Noble Gas - Adult Whole Body

Dose Rate	Dose(rem)		
mile	rem/hr	2.5E-01hr	2hr
.5	1.81E-03	4.5E-04	3.6E-03
1	6.68E-04	1.7E-04	1.3E-03
2	2.34E-04	5.8E-05	4.7E-04
3	1.29E-04	3.2E-05	2.6E-04
4	8.11E-05	2.0E-05	1.6E-04
5	5.72E-05	1.4E-05	1.1E-04
6	4.39E-05	1.1E-05	8.8E-05
7	3.48E-05	8.7E-06	7.0E-05
8	2.86E-05	7.2E-06	5.7E-05
9	2.38E-05	6.0E-06	4.8E-05
10	2.05E-05	5.1E-06	4.1E-05

Iodine - Child Thyroid

Dose Rate	Dose(rem)	ETA		
mile	rem/hr	2.5E-01hr	2hr	hr
.5	3.84E-03	9.6E-04	7.7E-03	0.24
1	1.41E-03	3.5E-04	2.8E-03	0.49
2	4.95E-04	1.2E-04	9.9E-04	0.98
3	2.73E-04	6.8E-05	5.5E-04	1.46
4	1.72E-04	4.3E-05	3.4E-04	1.95
5	1.21E-04	3.0E-05	2.4E-04	2.44
6	9.29E-05	2.3E-05	1.9E-04	2.93
7	7.37E-05	1.8E-05	1.5E-04	3.41
8	6.06E-05	1.5E-05	1.2E-04	3.90
9	5.05E-05	1.3E-05	1.0E-04	4.39
10	4.34E-05	1.1E-05	8.7E-05	4.88

Integrated WB	L	4.53E-04	B	4.53E-04	M	4.53E-04	C	4.53E-04	N	5.84E-05
Dose*	TH	9.59E-04		9.59E-04		9.59E-04		9.59E-04		1.24E-04
(rem)	WB A	5.84E-05	D	5.84E-05	O	5.84E-05	R	5.84E-05	E	0.00E-01
	TH	1.24E-04		1.24E-04		1.24E-04		1.24E-04		0.00E-01
	WB F	0.00E-01	F	1.43E-05	H	1.43E-05	I	1.43E-05	J	1.43E-05
	TH	0.00E-01		3.03E-05		3.03E-05		3.03E-05		3.03E-05
	WB K	1.43E-05	P	1.43E-05	Q	0.00E-01	S	0.00E-01		
	TH	3.03E-05		3.03E-05		0.00E-01		0.00E-01		

\* This dose is after the release and adjusted for any wind shifts

- Dose projections based on data below

Containment

39 H 1.55E+04 cpm  
I-131/Xe-133 Ratio 3.14E-03  
psig 1.80E-01  
Leak Rate 3.16E+03 ml/hr  
Leak rate based on Realistic Leak Rate  
Percent bypass leakage 7  
Correction Factor 5.56E-14

Unit Vent

EMF 36 L 5.06E+05 cpm  
I-131/Xe-133 Ratio 3.14E-05  
Flow Rate 5.30E+04 cfm  
Correction Factor 1.08E-11

Review with Emergency Coordinator the recommended Emergency Classification  
(based on Dose Projections only) :

Recommend Alert

Recommended Protective Actions (based on Dose Projections only)

EVACUATE

SHELTER IN-PLACE

OTHER

\*\*\*

Note

\*\*\* - Compare these recommendations with other groups' recommendations  
that the Emergency Coordinator/Recovery Manager reviews.

Projection based on data on 10/20/93 930 Time since trip 0.50 hrs

Meteorology Assessment

Temperature Gradient -0.3

Distance	X/Q	Ch	Distance	X/Q	Ch
mile	sec/m3	mph-sec/m3	mile	sec/m3	mph-sec/m3
.5	1.24E-04	3.80E-04	2	1.60E-05	4.90E-05
1	4.58E-05	1.40E-04	4	5.56E-06	1.70E-05
3	8.82E-06	2.70E-05	6	3.01E-06	9.20E-06
5	3.92E-06	1.20E-05	8	1.96E-06	6.00E-06
7	2.39E-06	7.30E-06	10	1.41E-06	4.30E-06
9	1.63E-06	5.00E-06			
mile 0 - 2   2 - 5   5 - 10					
PAZ L B M C N A D O R	I J K P				

Source Term Assessment

Steam Relief Valves	Containment	Unit Vent
Ci/sec	Ci/sec	Ci/sec
0.00E-01	4.40E-06	1.25E-01 - Noble Gas
0.00E-01	1.43E-08	4.06E-06 - Iodine

Source Term based on LOCA(charcoal)

Dose Assessment

Noble Gas - Adult Whole Body

Distance	Dose Rate		Dose(rem)
mile	rem/hr	2.5E-01hr	2hr
.5	5.21E-04	1.3E-04	1.0E-03
1	1.92E-04	4.8E-05	3.8E-04
2	6.71E-05	1.7E-05	1.3E-04
3	3.70E-05	9.2E-06	7.4E-05
4	2.33E-05	5.8E-06	4.7E-05
5	1.64E-05	4.1E-06	3.3E-05
6	1.26E-05	3.2E-06	2.5E-05
7	1.00E-05	2.5E-06	2.0E-05
8	8.22E-06	2.1E-06	1.6E-05
9	6.85E-06	1.7E-06	1.4E-05
10	5.89E-06	1.5E-06	1.2E-05

Integrated	WB	L	B	5.83E-04	M	5.83E-04	C	5.83E-04	N	7.52E-05
Dose*	TH			1.25E-03		1.25E-03		1.25E-03		1.61E-04
(rem)	WB	A		7.52E-05	D	7.52E-05	O	7.52E-05	R	7.52E-05
	TH			1.61E-04		1.61E-04		1.61E-04		0.00E-01
	WB	F		0.00E-01	F	1.43E-05	H	1.43E-05	I	1.84E-05
	TH			0.00E-01		3.03E-05		3.03E-05		3.93E-05
	WB	K		1.84E-05	P	1.84E-05	Q	0.00E-01	S	0.00E-01
	TH			3.93E-05		3.93E-05		0.00E-01		0.00E-01

\* This dose is after the release and adjusted for any wind shifts

- Dose projections based on data below

Containment

39 H 2.51E+04 cpm  
I-131/Xe-133 Ratio 3.25E-03  
psig 1.80E-01  
Leak Rate 3.16E+03 ml/hr  
Leak rate based on Realistic Leak Rate  
Percent bypass leakage 7  
Correction Factor 5.56E-14

Unit Vent

EMF 36 L 2.17E+05 cpm  
I-131/Xe-133 Ratio 3.25E-05  
Flow Rate 5.30E+04 cfm  
Correction Factor 1.08E-11

This is a hypothetical projection. Projection is not stored.

Review with Emergency Coordinator the recommended Emergency Classification  
(based on Dose Projections only) :

Recommend General Emergency

Recommended Protective Actions (based on Dose Projections only)

EVACUATE	L	B	M	C	N	A	D	O	R	E	F	G	H	I	J	K	P	Q	S
SHELTER IN-PLACE																			
OTHER					N	A	D	O	R										

\*\*\*

Note

\*\*\* - Compare these recommendations with other groups' recommendations  
that the Emergency Coordinator/Recovery Manager reviews.

Projection based on data on 10/20/93 1115 Time since trip 2.25 hrs

Meteorology Assessment

Temperature Gradient 0.8

Distance	X/Q	Ch	Distance	X/Q	Ch
mile	sec/m3	mph-sec/m3	mile	sec/m3	mph-sec/m3
.5	2.64E-04	1.10E-03	2	4.81E-05	2.00E-04
1	1.23E-04	5.10E-04	4	1.97E-05	8.20E-05
3	2.88E-05	1.20E-04	6	1.23E-05	5.10E-05
5	1.51E-05	6.30E-05	8	9.13E-06	3.80E-05
7	1.03E-05	4.30E-05	10	7.21E-06	3.00E-05
9	7.93E-06	3.30E-05			
mile	2   2 - 5	5 - 10			
PAZ	M C N A D O R	G H I J K P			

Source Term Assessment

Steam Relief Valves	Containment	Unit Vent
Ci/sec	Ci/sec	Ci/sec
0.00E-01	3.36E-05	3.93E+00 - Noble Gas
0.00E-01	3.63E-07	4.24E-02 - Iodine

Source Term based on Melted Core

Dose Assessment

Noble Gas - Adult Whole Body

Distance	Dose Rate	Dose(rem)	Time	Rate	Dose(rem)
mile	rem/hr	2.5E-01hr	2hr	2.5E-01hr	2hr
.5	3.50E-02	8.7E-03	7.0E-02	.5	2.54E+01
1	1.62E-02	4.1E-03	3.2E-02	1	1.18E+01
2	6.36E-03	1.6E-03	1.3E-02	2	4.61E+00
3	3.81E-03	9.5E-04	7.6E-03	3*	2.77E+00
4	2.61E-03	6.5E-04	5.2E-03	4	1.89E+00
5	2.00E-03	5.0E-04	4.0E-03	5	1.45E+00
6	1.62E-03	4.1E-04	3.2E-03	6	1.18E+00
7	1.37E-03	3.4E-04	2.7E-03	7	9.92E-01
8	1.21E-03	3.0E-04	2.4E-03	8	8.76E-01
9	1.05E-03	2.6E-04	2.1E-03	9	7.61E-01
10	9.53E-04	2.4E-04	1.9E-03	10	6.92E-01

Iodine - Child Thyroid

Distance	Dose Rate	Dose(rem)	Time	Rate	Dose(rem)	ETA
mile	rem/hr	2.5E-01hr	2hr	2.5E-01hr	2hr	hr
.5	2.54E+01	6.3E+00	5.1E+01	.5	2.54E+01	0.12
1	1.18E+01	2.9E+00	2.4E+01	1	1.18E+01	0.24
2	4.61E+00	1.2E+00	9.2E+00	2	4.61E+00	0.48
3*	2.77E+00	6.9E-01	5.5E+00	3*	2.77E+00	0.72
4	1.89E+00	4.7E-01	3.8E+00	4	1.89E+00	0.96
5	1.45E+00	3.6E-01	2.9E+00	5	1.45E+00	1.20
6	1.18E+00	2.9E-01	2.4E+00	6	1.18E+00	1.44
7	9.92E-01	2.5E-01	2.0E+00	7	9.92E-01	1.68
8	8.76E-01	2.2E-01	1.8E+00	8	8.76E-01	1.92
9	7.61E-01	1.9E-01	1.5E+00	9	7.61E-01	2.16
10	6.92E-01	1.7E-01	1.4E+00	10	6.92E-01	2.40

Integrated	WB L	9.19E-03	B	9.19E-03	M	9.19E-03	C	9.19E-03	N	1.65E-03
Dose*	TH	6.34E+00		6.34E+00		6.34E+00		6.34E+00		1.15E+00
(rem)	WB A	1.65E-03	D	1.65E-03	O	1.65E-03	R	1.65E-03	E	0.00E-01
	TH	1.15E+00		1.15E+00		1.15E+00		1.15E+00		0.00E-01
	WB F	0.00E-01	F	5.15E-04	H	5.15E-04	I	5.15E-04	J	5.15E-04
	TH	0.00E-01		3.63E-01		3.63E-01		3.63E-01		3.63E-01
	WB K	5.15E-04	P	5.15E-04	Q	0.00E-01	S	0.00E-01		
	TH	3.63E-01		3.63E-01		0.00E-01		0.00E-01		

\* This dose is after the release and adjusted for any wind shifts

- Dose projections based on data below

Containment

39 H 1.02E+05 cpm  
I-131/Xe-133 Ratio 1.08E-02  
psig 1.80E-01  
Leak Rate 3.16E+03 ml/hr  
Leak rate based on Realistic Leak Rate  
Percent bypass leakage 7  
Correction Factor 1.04E-13

Unit Vent


EMF 36 L 1.04E+06 cpm  
I-131/Xe-133 Ratio 1.08E-02  
Flow Rate 5.30E+04 cfm  
Correction Factor 7.14E-11

This is a hypothetical projection. Projection is not stored.

PROJ. DATE = 10/20/93

PROJ. TIME = 11:15:00

## CHI/Q\* DIFFUSION FACTORS



## CURRENT EFFLUENT

RATE = .0 uCi/s

## CURRENT MET

SPEED = 4.1 MPH

DIR = 181 DEG

STABILITY = F

## CENTERLINE VALUES

LOCAT	DEG	sec/m <sup>3</sup>
SB	1	2.64E-04
CL2	1	4.81E-05
CL5	1	1.51E-05
CL10	1	7.21E-06

## LEGEND

White	0.0-1.0E-12
Dark Gray	1.0E-12-1.0E-9
Black	1.0E-9-1.0E-6
Hatched	1.0E-6+ s/m <sup>3</sup>

MODE = A DECAY = OFF DEPOSITION = OFF ETA = 2.4 HRS

RELEASE HT. = 3.3 ft. RELEASE PT. = Simultaneous

Review with Emergency Coordinator the recommended Emergency Classification  
(based on Dose Projections only) :

Recommend Site Area Emergency

Recommended Protective Actions (based on Dose Projections only)

EVACUATE

SHELTER IN-PLACE

OTHER

\*\*\*

Note

\*\*\* - Compare these recommendations with other groups' recommendations  
that the Emergency Coordinator/Recovery Manager reviews.

Projection based on data on 10/20/93 1130 Time since trip 2.50 hrs

Meteorology Assessment

Temperature Gradient -0.9

Distance	X/Q	Ch	Distance	X/Q	Ch
mile	sec/m3	mph-sec/m3	mile	sec/m3	mph-sec/m3
.5	2.79E-06	1.40E-05	2	1.18E-07	5.90E-07
1	2.40E-07	1.20E-06	4	6.39E-08	3.20E-07
3	8.18E-08	4.10E-07	6	3.99E-08	2.00E-07
5	4.99E-08	2.50E-07	8	3.59E-08	1.80E-07
7	3.79E-08	1.90E-07	10	2.99E-08	1.50E-07
9	3.19E-08	1.60E-07			
mile 0 - 2   2 - 5   5 - 10					
PAZ L B M C N A			I J K P		

Source Term Assessment

Containment	Unit Vent
Containment	Unit Vent
Ci/sec	Ci/sec
0.00E-01	2.92E+01 - Noble Gas
0.00E-01	3.37E-01 - Iodine

Source Term based on Melted Core

Dose Assessment

Noble Gas - Adult Whole Body

Dose Rate	Dose(rem)		
mile	rem/hr	2.5E-01hr	2hr
.5	2.74E-03	6.9E-04	5.5E-03
1	2.35E-04	5.9E-05	4.7E-04
2	1.16E-04	2.9E-05	2.3E-04
3	8.03E-05	2.0E-05	1.6E-04
4	6.27E-05	1.6E-05	1.3E-04
5	4.90E-05	1.2E-05	9.8E-05
6	3.92E-05	9.8E-06	7.8E-05
7	3.72E-05	9.3E-06	7.4E-05
8	3.53E-05	8.8E-06	7.1E-05
9	3.14E-05	7.8E-06	6.3E-05
10	2.94E-05	7.3E-06	5.9E-05

Iodine - Child Thyroid

Dose Rate	Dose(rem)	ETA		
mile	rem/hr	2.5E-01hr	2hr	hr
.5	2.13E+00	5.3E-01	4.3E+00	0.10
1	1.82E-01	4.6E-02	3.6E-01	0.20
2	8.97E-02	2.2E-02	1.8E-01	0.40
3	6.23E-02	1.6E-02	1.2E-01	0.60
4	4.86E-02	1.2E-02	9.7E-02	0.80
5	3.80E-02	9.5E-03	7.6E-02	1.00
6	3.04E-02	7.6E-03	6.1E-02	1.20
7	2.89E-02	7.2E-03	5.8E-02	1.40
8	2.74E-02	6.8E-03	5.5E-02	1.60
9	2.43E-02	6.1E-03	4.9E-02	1.80
10	2.28E-02	5.7E-03	4.6E-02	2.00

Integrated WB L	1.14E-03	B	1.14E-03	M	1.14E-03	C	1.14E-03	N	8.73E-05
Dose*	TH	5.33E-01	5.33E-01		5.33E-01		5.33E-01		2.25E-02
(rem)	WB A	8.73E-05	D	5.84E-05	O	5.84E-05	R	5.84E-05	E 0.00E-01
	TH	2.25E-02		1.24E-04		1.24E-04		1.24E-04	0.00E-01
	WB F	0.00E-01	F	1.43E-05	H	1.43E-05	I	2.66E-05	J 2.66E-05
	TH	0.00E-01		3.03E-05		3.03E-05		9.53E-03	9.53E-03
	WB K	2.66E-05	P	2.66E-05	Q	0.00E-01	S	0.00E-01	
	TH	9.53E-03		9.53E-03		0.00E-01		0.00E-01	

\* This dose is after the release and adjusted for any wind shifts

- Dose projections based on data below

Unit Vent

36 H 3.00E+03 cpm  
I-131/Xe-133 Ratio 1.15E-02  
Flow Rate 5.30E+04 cfm  
Correction Factor 1.84E-07

This is a hypothetical projection. Projection is not stored.

Review with Emergency Coordinator the recommended Emergency Classification  
(based on Dose Projections only) :

Recommend Site Area Emergency

Recommended Protective Actions (based on Dose Projections only)

EVACUATE  
SHELTER IN-PLACE  
OTHER

\*\*\*

Note

\*\*\* - Compare these recommendations with other groups' recommendations  
that the Emergency Coordinator/Recovery Manager reviews.

Projection based on data on 10/20/93 1130 Time since trip 2.50 hrs

Meteorology Assessment

Temperature Gradient -0.9

Distance	X/Q	Ch	Distance	X/Q	Ch
mile	sec/m3	mph-sec/m3	mile	sec/m3	mph-sec/m3
.5	2.79E-06	1.40E-05	2	1.18E-07	5.90E-07
1	2.40E-07	1.20E-06	4	6.39E-08	3.20E-07
3	8.18E-08	4.10E-07	6	3.99E-08	2.00E-07
5	4.99E-08	2.50E-07	8	3.59E-08	1.80E-07
7	3.79E-08	1.90E-07	10	2.99E-08	1.50E-07
9	3.19E-08	1.60E-07			
mile 0 - 2   2 - 5   5 - 10					
PAZ L B M C N A			I J K P		

Source Term Assessment

Steam Relief Valves	Containment	Unit Vent
Ci/sec	Ci/sec	Ci/sec
0.00E-01	0.00E-01	2.92E+01 - Noble Gas
0.00E-01	0.00E-01	3.37E-01 - Iodine

Source Term based on Melted Core

Dose Assessment

Noble Gas - Adult Whole Body

Distance	Dose Rate	Dose(rem)
mile	rem/hr	2.5E-01hr 2hr
.5	2.74E-03	6.9E-04 5.5E-03
1	2.35E-04	5.9E-05 4.7E-04
2	1.16E-04	2.9E-05 2.3E-04
3	8.03E-05	2.0E-05 1.6E-04
4	6.27E-05	1.6E-05 1.3E-04
5	4.90E-05	1.2E-05 9.8E-05
6	3.92E-05	9.8E-06 7.8E-05
7	3.72E-05	9.3E-06 7.4E-05
8	3.53E-05	8.8E-06 7.1E-05
9	3.14E-05	7.8E-06 6.3E-05
10	2.94E-05	7.3E-06 5.9E-05

Iodine - Child Thyroid

Distance	Dose Rate	Dose(rem)	ETA
mile	rem/hr	2.5E-01hr 2hr	hr
.5	2.13E+00	5.3E-01 4.3E+00	0.10
1.	1.82E-01	4.6E-02 3.6E-01	0.20
2	8.97E-02	2.2E-02 1.8E-01	0.40
3	6.23E-02	1.6E-02 1.2E-01	0.60
4	4.86E-02	1.2E-02 9.7E-02	0.80
5	3.80E-02	9.5E-03 7.6E-02	1.00
6	3.04E-02	7.6E-03 6.1E-02	1.20
7	2.89E-02	7.2E-03 5.8E-02	1.40
8	2.74E-02	6.8E-03 5.5E-02	1.60
9	2.43E-02	6.1E-03 4.9E-02	1.80
10	2.28E-02	5.7E-03 4.6E-02	2.00

Integrated WB L 1.14E-03 B 1.14E-03 M 1.14E-03 C 1.14E-03 N 8.73E-05

Dose*	TH	WB A	WB F	WB K	WB P	TH	WB F	WB H	WB I	WB Q	TH	WB S
(rem)	5.33E-01	8.73E-05	0.00E-01	2.66E-05	2.66E-05	5.33E-01	5.84E-05	1.43E-05	1.43E-05	0.00E-01	9.53E-03	0.00E-01
	TH	2.25E-02	1.24E-04	1.24E-04	1.24E-04	5.33E-01	5.84E-05	1.43E-05	1.43E-05	1.24E-04	0.00E-01	9.53E-03
	WB A	8.73E-05	D 5.84E-05	O 5.84E-05	R 5.84E-05	5.33E-01	5.84E-05	E 0.00E-01	J 2.66E-05	2.66E-05	0.00E-01	9.53E-03
	TH	2.25E-02	1.24E-04	1.24E-04	1.24E-04	5.33E-01	5.84E-05	1.43E-05	1.43E-05	1.24E-04	0.00E-01	9.53E-03
	WB F	0.00E-01	F 1.43E-05	H 1.43E-05	I 1.43E-05	5.33E-01	5.84E-05	1.43E-05	1.43E-05	1.24E-04	0.00E-01	9.53E-03
	TH	0.00E-01	3.03E-05	3.03E-05	3.03E-05	5.33E-01	5.84E-05	1.43E-05	1.43E-05	1.24E-04	0.00E-01	9.53E-03
	WB K	2.66E-05	P 2.66E-05	Q 0.00E-01	S 0.00E-01	5.33E-01	5.84E-05	1.43E-05	1.43E-05	1.24E-04	0.00E-01	9.53E-03
	TH	9.53E-03	9.53E-03	0.00E-01	0.00E-01	5.33E-01	5.84E-05	1.43E-05	1.43E-05	1.24E-04	0.00E-01	9.53E-03

\* This dose is after the release and adjusted for any wind shifts

- Dose projections based on data below \*

Unit Vent

? 36 H 3.00E+03 cpm  
I-131/Xe-133 Ratio 1.15E-02  
Flow Rate 5.30E+04 cfm  
Correction Factor 1.84E-07

This is a hypothetical projection. Projection is not stored.

Review with Emergency Coordinator the recommended Emergency Classification  
 (based on Dose Projections only) :  
 Recommend Site Area Emergency

Recommended Protective Actions (based on Dose Projections only)

EVACUATE

SHELTER IN-PLACE	L	B	M	C	N	A	D	O	R	E	F	G	H	I	J	K	P	Q	S
OTHER		L	B	M	C														

\*\*\*

Note

\*\*\* - Compare these recommendations with other groups' recommendations  
 that the Emergency Coordinator/Recovery Manager reviews.

Projection based on data on 10/20/93 1200 Time since trip 3.00 hrs

Meteorology Assessment

Temperature Gradient -0.9

Distance	X/Q	Ch	Distance	X/Q	Ch
mile	sec/m3	mph-sec/m3	mile	sec/m3	mph-sec/m3
.5	2.99E-06	1.40E-05	2	1.26E-07	5.90E-07
1	2.56E-07	1.20E-06	4	6.84E-08	3.20E-07
3	8.76E-08	4.10E-07	6	4.27E-08	2.00E-07
5	5.34E-08	2.50E-07	8	3.85E-08	1.80E-07
7	4.06E-08	1.90E-07	10	3.21E-08	1.50E-07
9	3.42E-08	1.60E-07			
mile 0 - 2   2 - 5   5 - 10					
PAZ L B M C N A D O R			I J K P		

Source Term Assessment

Steam Relief Valves	Containment	Unit Vent
Ci/sec	Ci/sec	Ci/sec
0.00E-01	4.74E-05	3.09E+01 - Noble Gas
0.00E-01	6.17E-07	4.03E-01 - Iodine

Source Term based on Melted Core

Dose Assessment

Noble Gas - Adult Whole Body

Distance	Dose Rate	Dose(rem)
mile	rem/hr	2.5E-01hr 2hr
.5	3.11E-03	7.8E-04 6.2E-03
1	2.67E-04	6.7E-05 5.3E-04
2	1.31E-04	3.3E-05 2.6E-04
3	9.11E-05	2.3E-05 1.8E-04
4	7.11E-05	1.8E-05 1.4E-04
5	5.55E-05	1.4E-05 1.1E-04
6	4.44E-05	1.1E-05 8.9E-05
7	4.22E-05	1.1E-05 8.4E-05
8	4.00E-05	1.0E-05 8.0E-05
9	3.55E-05	8.9E-06 7.1E-05
10	3.33E-05	8.3E-06 6.7E-05

Iodine - Child Thyroid

Distance	Dose Rate	Dose(rem)	ETA
mile	rem/hr	2.5E-01hr 2hr	hr
.5	2.72E+00	6.8E-01 5.4E+00	0.11
1	2.33E-01	5.8E-02 4.7E-01	0.21
2	1.15E-01	2.9E-02 2.3E-01	0.43
3	7.98E-02	2.0E-02 1.6E-01	0.64
4	6.22E-02	1.6E-02 1.2E-01	0.85
5	4.86E-02	1.2E-02 9.7E-02	1.07
6	3.89E-02	9.7E-03 7.8E-02	1.28
7	3.70E-02	9.2E-03 7.4E-02	1.50
8	3.50E-02	8.8E-03 7.0E-02	1.71
9	3.11E-02	7.8E-03 6.2E-02	1.92
10	2.92E-02	7.3E-03 5.8E-02	2.14

Integrated WB L	1.23E-03	B	1.23E-03	M	1.23E-03	C	1.23E-03	N	9.12E-05
Dose*	TH	6.82E-01	6.82E-01	6.82E-01	6.82E-01		6.82E-01		2.88E-02
(rem)	WB A	9.12E-05	D	9.12E-05	O	9.12E-05	R	9.12E-05	E 0.00E-01
	TH	2.88E-02		2.88E-02		2.88E-02		2.88E-02	0.00E-01
	WB F	0.00E-01	F	1.43E-05	H	1.43E-05	I	2.82E-05	J 2.82E-05
	TH	0.00E-01		3.03E-05		3.03E-05		1.22E-02	1.22E-02
	WB K	2.82E-05	P	2.82E-05	Q	0.00E-01	S	0.00E-01	
	TH	1.22E-02		1.22E-02		0.00E-01		0.00E-01	

\* This dose is after the release and adjusted for any wind shifts

- Dose projections based on data below

Containment

? 39 H 1.31E+05 cpm  
I-131/Xe-133 Ratio 1.30E-02  
psig 1.80E-01  
Leak Rate 3.16E+03 ml/hr  
Leak rate based on Realistic Leak Rate  
Percent bypass leakage 7  
Correction Factor 1.15E-13

Unit Vent

EMF 36 H 3.00E+03 cpm  
I-131/Xe-133 Ratio 1.30E-02  
Flow Rate 5.30E+04 cfm  
Correction Factor 1.95E-07

Review with Emergency Coordinator the recommended Emergency Classification  
(based on Dose Projections only) :

Recommend Site Area Emergency

Recommended Protective Actions (based on Dose Projections only)

EVACUATE

SHELTER IN-PLACE	L	B	M	C	N	A	D	O	R	E	F	G	H	I	J	K	P	Q	S
OTHER		L	B	M	C														

\*\*\*

Note

\*\*\* - Compare these recommendations with other groups' recommendations  
that the Emergency Coordinator/Recovery Manager reviews.

Projection based on data on 10/20/93 1215 Time since trip 3.25 hrs

Meteorology Assessment

Temperature Gradient -0.8

Distance	X/Q	Ch	Distance	X/Q	Ch
mile	sec/m3	mph-sec/m3	mile	sec/m3	mph-sec/m3
.5	2.67E-06	1.40E-05	2	1.13E-07	5.90E-07
1	2.29E-07	1.20E-06	4	6.11E-08	3.20E-07
3	7.82E-08	4.10E-07	6	3.82E-08	2.00E-07
5	4.77E-08	2.50E-07	8	3.44E-08	1.80E-07
7	3.63E-08	1.90E-07	10	2.86E-08	1.50E-07
9	3.05E-08	1.60E-07			
mile 0 - 2   2 - 5   5 - 10					
PAZ L B M C N A			I J K P		

Source Term Assessment

Steam Relief Valves	Containment	Unit Vent
Ci/sec	Ci/sec	Ci/sec
0.00E-01	5.22E-05	3.17E+01 - Noble Gas
0.00E-01	7.18E-07	4.36E-01 - Iodine

Source Term based on Melted Core

Dose Assessment

Noble Gas - Adult Whole Body

Dose Rate	Dose(rem)		
mile	rem/hr	2.5E-01hr	2hr
.5	2.84E-03	7.1E-04	5.7E-03
1	2.44E-04	6.1E-05	4.9E-04
2	1.20E-04	3.0E-05	2.4E-04
3	8.32E-05	2.1E-05	1.7E-04
4	6.50E-05	1.6E-05	1.3E-04
5	5.08E-05	1.3E-05	1.0E-04
6	4.06E-05	1.0E-05	8.1E-05
7	3.86E-05	9.6E-06	7.7E-05
8	3.65E-05	9.1E-06	7.3E-05
9	3.25E-05	8.1E-06	6.5E-05
10	3.05E-05	7.6E-06	6.1E-05

Iodine - Child Thyroid

Dose Rate	Dose(rem)	ETA		
mile	rem/hr	2.5E-01hr	2hr	hr
.5	2.63E+00	6.6E-01	5.3E+00	0.10
1	2.25E-01	5.6E-02	4.5E-01	0.19
2	1.11E-01	2.8E-02	2.2E-01	0.38
3	7.70E-02	1.9E-02	1.5E-01	0.57
4	6.01E-02	1.5E-02	1.2E-01	0.76
5	4.70E-02	1.2E-02	9.4E-02	0.95
6	3.76E-02	9.4E-03	7.5E-02	1.15
7	3.57E-02	8.9E-03	7.1E-02	1.34
8	3.38E-02	8.5E-03	6.8E-02	1.53
9	3.01E-02	7.5E-03	6.0E-02	1.72
10	2.82E-02	7.0E-03	5.6E-02	1.91

Integrated	WB L	1.94E-03	B	1.94E-03	M	1.94E-03	C	1.94E-03	N	1.21E-04
Dose*	TH	1.34E+00		1.34E+00		1.34E+00		1.34E+00		5.65E-02
(rem)	WB A	1.21E-04	D	9.12E-05	O	9.12E-05	R	9.12E-05	E	0.00E-01
	TH	5.65E-02		2.88E-02		2.88E-02		2.88E-02		0.00E-01
	WB F	0.00E-01	F	1.43E-05	H	1.43E-05	I	4.09E-05	J	4.09E-05
	TH	0.00E-01		3.03E-05		3.03E-05		2.39E-02		2.39E-02
	WB K	4.09E-05	P	4.09E-05	Q	0.00E-01	S	0.00E-01		
	TH	2.39E-02		2.39E-02		0.00E-01		0.00E-01		

\* This dose is after the release and adjusted for any wind shifts

- Dose projections based on data below

Containment

39 H 1.41E+05 cpm  
I-131/Xe-133 Ratio 1.38E-02  
psig 1.80E-01  
Leak Rate 3.16E+03 ml/hr  
Leak rate based on Realistic Leak Rate  
Percent bypass leakage 7  
Correction Factor 1.17E-13


Unit Vent

EMF 36 H 3.00E+03 cpm  
I-131/Xe-133 Ratio 1.38E-02  
Flow Rate 5.30E+04 cfm  
Correction Factor 1.99E-07

PROJ. DATE = 10/20/93

PROJ. TIME = 12:15:00

## THYROID DOSE RATE



## CURRENT EFFLUENT

RATE = .0 uCi/s

## CURRENT MET

SPEED = 5.1 MPH

DIR = 180 DEG

STABILITY = A

## CENTERLINE VALUES

LOCAT	DEG	mrem/hr
SB	0	2.63E+03
CL2	0	1.11E+02
CL5	0	4.70E+01
CL10	0	2.82E+01

## LEGEND

0 - 10
10 - 2500
2500 - 12500
12500+ mR/hr

MODE = A DECAY = OFF DEPOSITION = OFF ETA = 2.0 HRS

RELEASE HT. = 3.3 ft. RELEASE PT. = Simultaneous

# EMERGENCY NOTIFICATION

1. THIS IS A(N) DRILL	INITIAL	FOLLOW-UP*	MESSAGE NUMBER _____																																																	
2. SITE: McGuire	UNIT: 1	REPORTED BY: _____																																																		
TRANSMITTAL TIME/DATE: _____ / _____ / _____ (Eastern) mm dd yy		CONFIRMATION PHONE NUMBER: _____																																																		
4. AUTHENTICATION: _____ (Number) _____ (Codeword)																																																				
5. EMERGENCY CLASSIFICATION: A- NOTIFICATION OF UNUSUAL EVENT      B- ALERT      C- SITE AREA EMERGENCY      D- GENERAL EMERGENCY																																																				
6. A- Emergency Declaration At: B- Termination At: TIME/DATE: _____ / _____ / _____ (If B, go to item 16.) (Eastern) mm dd yy																																																				
7. EMERGENCY DESCRIPTION/REMARKS: _____ _____ _____																																																				
8. PLANT CONDITION: A- IMPROVING      B- STABLE      C- DEGRADING																																																				
9. REACTOR STATUS: A- SHUTDOWN: TIME/DATE: 900 10/20/93 (Eastern) mm dd yy      B- _____ %POWER																																																				
10. EMERGENCY RELEASE(S): A- NONE(Go to item 14.)      B- POTENTIAL(Go to item 14.)      C- IS OCCURRING      D- HAS OCCURRED																																																				
**11. TYPE OF RELEASE: GROUND LEVEL AIRBORNE      Started: _____ / _____ / _____ Time(Eastern)      Date      Stopped: _____ / _____ / _____ Time(Eastern)      Date B- LIQUID      Started: _____ / _____ / _____ Time(Eastern)      Date      Stopped: _____ / _____ / _____ Time(Eastern)      Date																																																				
**12. RELEASE MAGNITUDE: CURIES PER SEC.		NORMAL OPERATING LIMITS: ABOVE A- NOBLE GASES 3.27E+01      B- IODINES 2.36E-01 C- IODINE/NOBLE GAS RATIO(If available) _____      D- OTHER _____																																																		
**13. ESTIMATE OF PROJECTED OFFSITE DOSE: NEW UNCHANGED ESTIMATED DURATION: 1.00 HRS. <table border="0" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Wholebody</th> <th>Child Thyroid</th> <th></th> <th>Wholebody</th> <th>Child Thyroid</th> <th></th> </tr> <tr> <th></th> <th>DOSE RATE</th> <th>DOSE RATE</th> <th></th> <th>DOSE</th> <th>DOSE</th> <th></th> </tr> </thead> <tbody> <tr> <td>Distance</td> <td>mrem/hr</td> <td>mrem/hr</td> <td></td> <td>mrem</td> <td>mrem</td> <td></td> </tr> <tr> <td>Site Boundary</td> <td>3.12E+00</td> <td>1.52E+03</td> <td></td> <td>2.72E+00</td> <td>1.72E+03</td> <td></td> </tr> <tr> <td>2 miles</td> <td>1.32E-01</td> <td>6.41E+01</td> <td></td> <td>1.54E-01</td> <td>7.25E+01</td> <td></td> </tr> <tr> <td>5 miles</td> <td>5.58E-02</td> <td>2.71E+01</td> <td></td> <td>5.48E-02</td> <td>3.07E+01</td> <td></td> </tr> <tr> <td>10 miles</td> <td>3.35E-02</td> <td>1.63E+01</td> <td></td> <td>2.94E-02</td> <td>1.84E+01</td> <td></td> </tr> </tbody> </table>					Wholebody	Child Thyroid		Wholebody	Child Thyroid			DOSE RATE	DOSE RATE		DOSE	DOSE		Distance	mrem/hr	mrem/hr		mrem	mrem		Site Boundary	3.12E+00	1.52E+03		2.72E+00	1.72E+03		2 miles	1.32E-01	6.41E+01		1.54E-01	7.25E+01		5 miles	5.58E-02	2.71E+01		5.48E-02	3.07E+01		10 miles	3.35E-02	1.63E+01		2.94E-02	1.84E+01	
	Wholebody	Child Thyroid		Wholebody	Child Thyroid																																															
	DOSE RATE	DOSE RATE		DOSE	DOSE																																															
Distance	mrem/hr	mrem/hr		mrem	mrem																																															
Site Boundary	3.12E+00	1.52E+03		2.72E+00	1.72E+03																																															
2 miles	1.32E-01	6.41E+01		1.54E-01	7.25E+01																																															
5 miles	5.58E-02	2.71E+01		5.48E-02	3.07E+01																																															
10 miles	3.35E-02	1.63E+01		2.94E-02	1.84E+01																																															
**14. METEOROLOGICAL DATA: A- WIND DIRECTION(from) 181.0 degrees      B- WIND SPEED(mph) 4.9 C- STABILITY CLASS      A      D- PRECIPITATION(type) _____																																																				
15. RECOMMENDED PROTECTIVE ACTIONS: A- NO RECOMMENDED PROTECTIVE ACTIONS B- EVACUATE _____ C- SHELTER IN-PLACE _____ D- OTHER _____																																																				
16. APPROVED BY: _____		TIME/DATE: _____ / _____ / _____ (Name)      (Title)      (Eastern) mm dd yy																																																		

\* If items 8-14 have not changed, only items 1-7 and 15-16 are required to be completed.

\*\*Information may not be available on initial notifications.

Review with Emergency Coordinator the recommended Emergency Classification  
 (based on Dose Projections only) :  
 Recommend Site Area Emergency

Recommended Protective Actions (based on Dose Projections only)

EVACUATE

SHELTER IN-PLACE	L	B	M	C	N	A	D	O	R	E	F	G	H	I	J	K	P	Q	S
OTHER		L	B	M	C														

\*\*\*

Note

\*\*\* - Compare these recommendations with other groups' recommendations  
 that the Emergency Coordinator/Recovery Manager reviews.

Projection based on data on 10/20/93 1230 Time since trip 3.50 hrs

Meteorology Assessment

Temperature Gradient -0.9

Distance	X/Q	Ch	Distance	X/Q	Ch
mile	sec/m3	mph-sec/m3	mile	sec/m3	mph-sec/m3
.5	2.85E-06	1.40E-05	2	1.20E-07	5.90E-07
1	2.44E-07	1.20E-06	4	6.50E-08	3.20E-07
3	8.33E-08	4.10E-07	6	4.07E-08	2.00E-07
5	5.08E-08	2.50E-07	8	3.66E-08	1.80E-07
7	3.86E-08	1.90E-07	10	3.05E-08	1.50E-07
9	3.25E-08	1.60E-07			
mile 0 - 2   2 - 5   5 - 10					
PAZ L B M C N A D O R			G H I J K P		

Source Term Assessment

Steam Relief Valves	Containment	Unit Vent
Ci/sec	Ci/sec	Ci/sec
1.65E+01	0.00E-01	1.61E+01 - Noble Gas
2.40E-03	0.00E-01	2.34E-01 - Iodine

Source Term based on Melted Core

Dose Assessment

Noble Gas - Adult Whole Body

Dose Rate	Dose(rem)		
mile	rem/hr	2.5E-01hr	2hr
.5	3.12E-03	7.8E-04	6.2E-03
1	2.68E-04	6.7E-05	5.4E-04
2	1.32E-04	3.3E-05	2.6E-04
3	9.15E-05	2.3E-05	1.8E-04
4	7.14E-05	1.8E-05	1.4E-04
5	5.58E-05	1.4E-05	1.1E-04
6	4.46E-05	1.1E-05	8.9E-05
7	4.24E-05	1.1E-05	8.5E-05
8	4.02E-05	1.0E-05	8.0E-05
9	3.57E-05	8.9E-06	7.1E-05
10	3.35E-05	8.4E-06	6.7E-05

Iodine - Child Thyroid

Dose Rate	Dose(rem)	ETA		
mile	rem/hr	2.5E-01hr	2hr	hr
.5	1.52E+00	3.8E-01	3.0E+00	0.10
1	1.30E-01	3.3E-02	2.6E-01	0.20
2	6.41E-02	1.6E-02	1.3E-01	0.41
3	4.45E-02	1.1E-02	8.9E-02	0.61
4	3.47E-02	8.7E-03	6.9E-02	0.81
5	2.71E-02	6.8E-03	5.4E-02	1.02
6	2.17E-02	5.4E-03	4.3E-02	1.22
7	2.06E-02	5.2E-03	4.1E-02	1.42
8	1.95E-02	4.9E-03	3.9E-02	1.63
9	1.74E-02	4.3E-03	3.5E-02	1.83
10	1.63E-02	4.1E-03	3.3E-02	2.03

Integrated	WB	L	2.72E-03	B	2.72E-03	M	2.72E-03	C	2.72E-03	N	1.54E-04
Dose*	TH		1.72E+00		1.72E+00		1.72E+00		1.72E+00		7.25E-02
(rem)	WB	A	1.54E-04	D	1.24E-04	O	1.24E-04	R	1.24E-04	E	0.00E-01
	TH		7.25E-02		4.48E-02		4.48E-02		4.48E-02		0.00E-01
	WB	F	0.00E-01	F	2.83E-05	H	2.83E-05	I	5.48E-05	J	5.48E-05
	TH		0.00E-01		6.82E-03		6.82E-03		3.07E-02		3.07E-02
	WB	K	5.48E-05	P	5.48E-05	Q	0.00E-01	S	0.00E-01		
	TH		3.07E-02		3.07E-02		0.00E-01		0.00E-01		

\* This dose is after the release and adjusted for any wind shifts

- Dose projections based on data below

Unit Vent

F 36 H 1.50E+03 cpm  
I-131/Xe-133 Ratio 1.45E-02  
Flow Rate 5.30E+04 cfm  
Correction Factor 2.03E-07

# EMERGENCY NOTIFICATION

1. THIS IS \*(N) DRILL      INITIAL      FOLLOW-UP\*      MESSAGE NUMBER \_\_\_\_\_

2. SITE: McGuire      UNIT: 1      REPORTED BY: \_\_\_\_\_

TRANSMITTAL TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 (Eastern)      mm dd yy      CONFIRMATION PHONE NUMBER: \_\_\_\_\_

4. AUTHENTICATION: \_\_\_\_\_  
 (Number)      (Codeword)

5. EMERGENCY CLASSIFICATION:

A- NOTIFICATION OF UNUSUAL EVENT      B- ALERT      C- SITE AREA EMERGENCY      D- GENERAL EMERGENCY

6. A- Emergency Declaration At: B- Termination At: TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ (if B, go to item 15.)  
 (Eastern)      mm dd yy

7. EMERGENCY DESCRIPTION/REMARKS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

8. PLANT CONDITION: A- IMPROVING      B- STABLE      C- DEGRADING

9. REACTOR STATUS: A- SHUTDOWN: TIME/DATE: 900 10/20/93      B- \_\_\_\_\_ %POWER  
 (Eastern)      mm dd yy

10. EMERGENCY RELEASE(S):

A- NONE(Go to item 14.)      B- POTENTIAL(Go to item 14.)      C- IS OCCURRING      D- HAS OCCURRED

\*\*11. TYPE OF RELEASE: GROUND LEVEL

AIRBORNE	Started: _____ / _____ / _____ Time(Eastern)      Date	Stopped: _____ / _____ / _____ Time(Eastern)      Date
B- LIQUID	Started: _____ / _____ / _____ Time(Eastern)      Date	Stopped: _____ / _____ / _____ Time(Eastern)      Date

\*\*12. RELEASE MAGNITUDE: CURIES PER SEC.

A- NOBLE GASES 1.64E+01	B- IODINES 2.50E-01
C- IODINE/NOBLE GAS RATIO(if available) _____	D- OTHER _____

\*\*13. ESTIMATE OF PROJECTED OFFSITE DOSE: NEW UNCHANGED ESTIMATED DURATION: 1.25 HRS.

	Wholebody	Child Thyroid	Wholebody	Child Thyroid
DOSE RATE	DOSE RATE	DOSE	DOSE	
Distance	mrem/hr	mrem/hr	mrem	mrem
Site boundary	2.06E+00	2.11E+03	3.24E+00	2.25E+03
2 miles	8.67E-02	8.89E+01	1.76E-01	9.48E+01
5 miles	3.67E-02	3.77E+01	6.40E-02	4.01E+01
10 miles	2.20E-02	2.26E+01	3.49E-02	2.41E+01

\*\*14. METEOROLOGICAL DATA:

A- WIND DIRECTION(from) 183.0 degrees	B- WIND SPEED(mph) 3.7
C- STABILITY CLASS A	D- PRECIPITATION(type) _____

15. RECOMMENDED PROTECTIVE ACTIONS:

A- NO RECOMMENDED PROTECTIVE ACTIONS	
B- EVACUATE _____	
C- SHELTER IN-PLACE _____	
D- OTHER _____	

16. APPROVED BY: \_\_\_\_\_ TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 (Name)      (Title)      (Eastern)      mm dd yy

\* If items 8-14 have not changed, only items 1-7 and 15-16 are required to be completed.

\*\*Information may not be available on initial notifications.

Review with Emergency Coordinator the recommended Emergency Classification  
 (based on Dose Projections only) :

Recommend Site Area Emergency

Recommended Protective Actions (based on Dose Projections only)

EVACUATE

SHELTER IN-PLACE	L	B	M	C	N	A	D	O	R	E	F	G	H	I	J	K	P	Q	S
OTHER		L	B	M	C														

\*\*\*

Note

\*\*\* - Compare these recommendations with other groups' recommendations  
 that the Emergency Coordinator/Recovery Manager reviews.

Projection based or data on 10/20/93 1245 Time since trip 3.75 hrs

Meteorology Assessment

Temperature Gradient -0.9

Distance	X/Q	Ch	Distance	X/Q	Ch
mile	sec/m3	mph-sec/m3	mile	sec/m3	mph-sec/m3
.5	3.73E-06	1.40E-05	2	1.57E-07	5.90E-07
1	3.20E-07	1.20E-06	4	8.53E-08	3.20E-07
3	1.09E-07	4.10E-07	6	5.33E-08	2.00E-07
5	6.67E-08	2.50E-07	8	4.80E-08	1.80E-07
7	5.07E-08	1.90E-07	10	4.00E-08	1.50E-07
9	4.27E-08	1.60E-07			
mile 0 - 2   2 - 5   5 - 10					
PAZ L B M C N A D O R			G H I J K P		

Source Term Assessment

Steam Relief Valves	Containment	Unit Vent
Ci/sec	Ci/sec	Ci/sec
0.00E-01	0.00E-01	1.64E+01 - Noble Gas
0.00E-01	0.00E-01	2.50E-01 - Iodine

Source Term based on Melted Core

Dose Assessment

Noble Gas - Adult Whole Body

Dose Rate	Dose(rem)		
mile	rem/hr	2.5E-01hr	2hr
.5	2.06E-03	5.1E-04	4.1E-03
1	1.76E-04	4.4E-05	3.5E-04
2	8.67E-05	2.2E-05	1.7E-04
3	6.02E-05	1.5E-05	1.2E-04
4	4.70E-05	1.2E-05	9.4E-05
5	3.67E-05	9.2E-06	7.3E-05
6	2.94E-05	7.3E-06	5.9E-05
7	2.79E-05	7.0E-06	5.6E-05
8	2.64E-05	6.6E-06	5.3E-05
9	2.35E-05	5.9E-06	4.7E-05
10	2.20E-05	5.5E-06	4.4E-05

Iodine - Child Thyroid

Dose Rate	Dose(rem)	ETA		
mile	rem/hr	2.5E-01hr	2hr	hr
.5	2.11E+00	5.3E-01	4.2E+00	0.13
1	1.81E-01	4.5E-02	3.6E-01	0.27
2	8.89E-02	2.2E-02	1.8E-01	0.53
3	6.18E-02	1.5E-02	1.2E-01	0.80
4	4.82E-02	1.2E-02	9.6E-02	1.07
5	3.77E-02	9.4E-03	7.5E-02	1.33
6	3.01E-02	7.5E-03	6.0E-02	1.60
7*	2.86E-02	7.2E-03	5.7E-02	1.87
8	2.71E-02	6.8E-03	5.4E-02	2.13
9	2.41E-02	6.0E-03	4.8E-02	2.40
10	2.26E-02	5.6E-03	4.5E-02	2.67

Integrated WB L 3.24E-03 B 3.24E-03 M 3.24E-03 C 3.24E-03 N 1.76E-04

Dose\* TH 2.25E+00 2.25E+00 2.25E+00 2.25E+00 9.48E-02

(rem) WB A 1.76E-04 D 1.46E-04 O 1.46E-04 R 1.46E-04 E 0.00E-01

TH 9.48E-02 6.70E-02 6.70E-02 6.70E-02 0.00E-01

WB F 0.00E-01 F 3.74E-05 H 3.74E-05 I 6.40E-05 J 6.40E-05

TH 0.00E-01 1.62E-02 1.62E-02 4.01E-02 4.01E-02

WB K 6.40E-05 P 6.40E-05 Q 0.00E-01 S 0.00E-01

TH 4.01E-02 4.01E-02 0.00E-01 0.00E-01

\* This dose is after the release and adjusted for any wind shifts

- Dose projections based on data below

Containment

? 39 H 1.60E+05 cpm  
I-131/Xe-133 Ratio 1.52E-02  
psig 1.80E-01  
Leak Rate 3.16E+03 ml/hr  
Leak rate based on Realistic Leak Rate  
Percent bypass leakage 7  
Correction Factor 1.21E-13

Unit Vent

EMF 36 H 1.50E+03 cpm  
I-131/Xe-133 Ratio 1.52E-02  
Flow Rate 5.30E+04 cfm  
Correction Factor 2.06E-07

# EMERGENCY NOTIFICATION

1. THIS IS A(N) DRILL       INITIAL       FOLLOW-UP\*      MESSAGE NUMBER \_\_\_\_\_

2. SITE: McGuire      UNIT: 1      REPORTED BY: \_\_\_\_\_

TRANSMITTAL TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ CONFIRMATION PHONE NUMBER: \_\_\_\_\_  
 (Eastern)      mm dd yy

4. AUTHENTICATION: \_\_\_\_\_  
 (Number)      (Codeword)

5. EMERGENCY CLASSIFICATION:  
 A- NOTIFICATION OF UNUSUAL EVENT      B- ALERT      C- SITE AREA EMERGENCY      D- GENERAL EMERGENCY

6. A- Emergency Declaration At: B- Termination At: TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ (If B, go to item 16.)  
 (Eastern)      mm dd yy

7. EMERGENCY DESCRIPTION/REMARKS:  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

8. PLANT CONDITION:      A- IMPROVING      B- STABLE      C- DEGRADING

9. REACTOR STATUS:      A- SHUTDOWN: TIME/DATE: 900      10/20/93      B- \_\_\_\_\_ %POWER  
 (Eastern)      mm dd yy

10. EMERGENCY RELEASE(S):  
 A- NONE(Go to item 14.)      B- POTENTIAL(Go to item 14.)      C- IS OCCURRING      D- HAS OCCURRED

\*\*11. TYPE OF RELEASE: GROUND LEVEL

AIRBORNE	Started: _____ / _____ / _____ Time(Eastern)      Date	* Stopped: _____ / _____ / _____ Time(Eastern)      Date
B- LIQUID	Started: _____ / _____ / _____ Time(Eastern)      Date	Stopped: _____ / _____ / _____ Time(Eastern)      Date

\*\*12. RELEASE MAGNITUDE: CURIES PER SEC.

NORMAL OPERATING LIMITS: ABOVE

A- NOBLE GASES 1.66E+01      B- IODINES 2.66E-01

C- IODINE/NOBLE GAS RATIO(If available)      D- OTHER \_\_\_\_\_

\*\*13. ESTIMATE OF PROJECTED OFF-SITE DOSE:      NEW      UNCHANGED      ESTIMATED DURATION: 1.50 HRS.

	Wholebody	Child Thyroid	Wholebody	Child Thyroid
	DOSE RATE	DOSE RATE	DOSE	DOSE
Distance	mrem/hr	mrem/hr	mrem	mrem
Site Boundary	2.06E+00	2.22E+03	3.75E+00	2.80E+03
2 miles	8.69E-02	9.34E+01	1.97E-01	1.18E+02
5 miles	3.68E-02	3.96E+01	7.32E-02	5.00E+01
10 miles	2.21E-02	2.38E+01	4.05E-02	3.00E+01

\*\*14. METEOROLOGICAL DATA:

A- WIND DIRECTION(from) 176.0 degrees      B- WIND SPEED(mph) 3.8  
 C- STABILITY CLASS      A      D- PRECIPITATION(type) \_\_\_\_\_

15. RECOMMENDED PROTECTIVE ACTIONS:

- A- NO RECOMMENDED PROTECTIVE ACTIONS
- B- EVACUATE \_\_\_\_\_
- C- SHELTER IN-PLACE \_\_\_\_\_
- D- OTHER \_\_\_\_\_

16. APPROVED BY: \_\_\_\_\_ TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 (Name)      (Title)      (Eastern)      mm dd yy

\* If items 8-14 have not changed, only items 1-7 and 15-16 are required to be completed.

\*\*Information may not be available on initial notifications.

Review with Emergency Coordinator the recommended Emergency Classification  
 (based on Dose Projections only) :  
 Recommend Site Area Emergency

Recommended Protective Actions (based on Dose Projections only)

EVACUATE

SHELTER IN-PLACE	L	B	M	C	N	A	D	O	R	E	F	G	H	I	J	K	P	Q	S
OTHER		L	B	M	C														

\*\*\*

Note

\*\*\* - Compare these recommendations with other groups' recommendations  
 that the Emergency Coordinator/Recovery Manager reviews.

Projection based on data on 10/20/93 1300 Time since trip 4.00 hrs

Meteorology Assessment

Temperature Gradient -0.9

Distance	X/Q	Ch	Distance	X/Q	Ch
mile	sec/m3	mph-sec/m3	mile	sec/m3	mph-sec/m3
.5	3.69E-06	1.40E-05	2	1.56E-07	5.90E-07
1	3.17E-07	1.20E-06	4	8.44E-08	3.20E-07
3	1.08E-07	4.10E-07	6	5.28E-08	2.00E-07
5	6.60E-08	2.50E-07	8	4.75E-08	1.80E-07
7	5.01E-08	1.90E-07	10	3.96E-08	1.50E-07
9	4.22E-08	1.60E-07			
mile 0 - 2   2 - 5   5 - 10					
PAZ L B M C N A D O R			I J K P		

Source Term Assessment

Steam Relief Valves	Containment	Unit Vent
Ci/sec	Ci/sec	Ci/sec
0.00E-01	1.09E-04	1.66E+01 - Noble Gas
0.00E-01	1.75E-06	2.66E-01 - Iodine

Source Term based on Melted Core

Dose Assessment

Noble Gas - Adult Whole Body

Dose Rate	Dose(rem)		
mile	rem/hr	2.5E-01hr	2hr
.5	2.06E-03	5.2E-04	4.1E-03
1	1.77E-04	4.4E-05	3.5E-04
2	8.69E-05	2.2E-05	1.7E-04
3	6.04E-05	1.5E-05	1.2E-04
4	4.71E-05	1.2E-05	9.4E-05
5	3.68E-05	9.2E-06	7.4E-05
6	2.95E-05	7.4E-06	5.9E-05
7	2.80E-05	7.0E-06	5.6E-05
8	2.65E-05	6.6E-06	5.3E-05
9	2.36E-05	5.9E-06	4.7E-05
10	2.21E-05	5.5E-06	4.4E-05

Iodine - Child Thyroid

Dose Rate	Dose(rem)	ETA		
mile	rem/hr	2.5E-01hr	2hr	hr
.5	2.22E+00	5.5E-01	4.4E+00	0.13
1	1.90E-01	4.8E-02	3.8E-01	0.26
2	9.34E-02	2.3E-02	1.9E-01	0.53
3	6.49E-02	1.6E-02	1.3E-01	0.79
4	5.07E-02	1.3E-02	1.0E-01	1.06
5	3.96E-02	9.9E-03	7.9E-02	1.32
6	3.17E-02	7.9E-03	6.3E-02	1.58
7	3.01E-02	7.5E-03	6.0E-02	1.85
8	2.85E-02	7.1E-03	5.7E-02	2.11
9	2.53E-02	6.3E-03	5.1E-02	2.37
10	2.38E-02	5.9E-03	4.8E-02	2.64

Integrated WB L	3.75E-03	B	3.75E-03	M	3.75E-03	C	3.75E-03	N	1.97E-04
Dose*	TH	2.80E+00	2.80E+00	O	2.80E+00	2.80E+00	2.80E+00	P	1.18E-01
(rem)	WB A	1.97E-04	D	1.67E-04	O	1.67E-04	R	1.67E-04	E
	TH	1.18E-01		9.04E-02		9.04E-02		9.04E-02	0.00E-01
	WB F	0.00E-01	F	3.74E-05	H	3.74E-05	I	7.32E-05	J
	TH	0.00E-01		1.62E-02		1.62E-02		5.00E-02	5.00E-02
	WB K	7.32E-05	P	7.32E-05	Q	0.00E-01	S	0.00E-01	
	TH	5.00E-02		5.00E-02		0.00E-01		0.00E-01	

\* This dose is after the release and adjusted for any wind shifts

- Dose projections based on data below

Containment

• 39 H 1.70E+05 cpm  
I-131/Xe-133 Ratio 1.60E-02  
psig 3.00E-01  
Leak Rate 5.23E+03 ml/hr  
Leak rate based on Realistic Leak Rate  
Percent bypass leakage 7  
Correction Factor 1.23E-13


Unit Vent

EMF 36 H 1.50E+03 cpm  
I-131/Xe-133 Ratio 1.60E-02  
Flow Rate 5.30E+04 cfm  
Correction Factor 2.09E-07

PROJ. DATE = 10/20/93

PROJ. TIME = 13:00:00

## THYROID DOSE RATE



## CURRENT EFFLUENT

RATE = .0 uCi/s

## CURRENT MET

SPEED = 3.7 MPH

DIR = 176 DEG

STABILITY = A

## CENTERLINE VALUES

LOCAT	DEG	mrem/hr
SB	356	2.22E+03
CL2	356	9.34E+01
CL5	356	3.96E+01
CL10	356	2.38E+01

## LEGEND

0 - 10
10 - 2500
2500 - 12500
12500+ mR/hr


MODE = A DECAY = OFF DEPOSITION = OFF ETA = 2.7 HRS

RELEASE HT. = 3.3 ft. RELEASE PT. = Simultaneous

PROJ. DATE = 10/20/93

PROJ. TIME = 13:00:00

## CHI/Q\* DIFFUSION FACTORS



## CURRENT EFFLUENT

RATE = .0 uCi/s

## CURRENT MET

SPEED = 3.7 MPH

DIR = 176 DEG

STABILITY = A

## CENTERLINE VALUES

LOCAT	DEG	sec/m <sup>3</sup>
SB	356	3.69E-06
CL2	356	1.56E-07
CL5	356	6.60E-08
CL10	356	3.96E-08

## LEGEND

0.0-1.0E-12
1.0E-12-1.0E-9
1.0E-9-1.0E-6
1.0E-6+ s/m <sup>3</sup>

MODE = A DECAY = OFF DEPOSITION = OFF ETA = 2.7 HRS

RELEASE HT. = 3.3 ft. RELEASE PT. = Simultaneous

# EMERGENCY NOTIFICATION

1. THIS IS A(N) DRILL	INITIAL	FOLLOW-UP*	MESSAGE NUMBER _____																																										
2. SITE: McGuire	UNIT: 1	REPORTED BY: _____																																											
TRANSMITTAL TIME/DATE: _____ / _____ / _____ (Eastern) mm dd yy		CONFIRMATION PHONE NUMBER: _____																																											
4. AUTHENTICATION: _____ (Number)		(Codeword) _____																																											
5. EMERGENCY CLASSIFICATION: A- NOTIFICATION OF UNUSUAL EVENT      B- ALERT      C- SITE AREA EMERGENCY      D- GENERAL EMERGENCY																																													
6. A- Emergency Declaration At: TIME/DATE: _____ / _____ / _____ (If B, go to item 16.) (Eastern) mm dd yy																																													
7. EMERGENCY DESCRIPTION/REMARKS: _____ _____																																													
8. PLANT CONDITION:      A- IMPROVING      B- STABLE      C- DEGRADING																																													
9. REACTOR STATUS:      A- SHUTDOWN: TIME/DATE: 900 10/20/93      B- _____ %POWER (Eastern) mm dd yy																																													
10. EMERGENCY RELEASE(S): A- NONE(Go to item 14.)      B- POTENTIAL(Go to item 14.)      C- IS OCCURRING      D- HAS OCCURRED																																													
**11. TYPE OF RELEASE: GROUND LEVEL <table border="0" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 25%;">AIRBORNE</td> <td style="width: 25%;">Started: _____ / _____ / _____ Time(Eastern)</td> <td style="width: 25%;">Date</td> <td style="width: 25%;">Stopped: _____ / _____ / _____ Time(Eastern)</td> </tr> <tr> <td>B- LIQUID</td> <td>Started: _____ / _____ / _____ Time(Eastern)</td> <td>Date</td> <td>Stopped: _____ / _____ / _____ Time(Eastern)</td> </tr> </table>				AIRBORNE	Started: _____ / _____ / _____ Time(Eastern)	Date	Stopped: _____ / _____ / _____ Time(Eastern)	B- LIQUID	Started: _____ / _____ / _____ Time(Eastern)	Date	Stopped: _____ / _____ / _____ Time(Eastern)																																		
AIRBORNE	Started: _____ / _____ / _____ Time(Eastern)	Date	Stopped: _____ / _____ / _____ Time(Eastern)																																										
B- LIQUID	Started: _____ / _____ / _____ Time(Eastern)	Date	Stopped: _____ / _____ / _____ Time(Eastern)																																										
**12. RELEASE MAGNITUDE: CURIES PER SEC.		NORMAL OPERATING LIMITS: ABOVE A- NOBLE GASES 1.71E+00      B- IODINES 3.24E-02 C- IODINE/NOBLE GAS RATIO(IF available) _____      D- OTHER _____																																											
**13. ESTIMATE OF PROJECTED OFFSITE DOSE: NEW UNCHANGED ESTIMATED DURATION: 1.75 HRS. <table border="0" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>Wholebody</th> <th>Child Thyroid</th> <th></th> <th>Wholebody</th> <th>Child Thyroid</th> </tr> <tr> <th></th> <th>DOSE RATE</th> <th>DOSE RATE</th> <th></th> <th>DOSE</th> <th>DOSE</th> </tr> </thead> <tbody> <tr> <td>Distance</td> <td>mrem/hr</td> <td>mrem/hr</td> <td></td> <td>mrem</td> <td>mrem</td> </tr> <tr> <td>Site Boundary</td> <td>1.62E-01</td> <td>2.06E+02</td> <td></td> <td>5.34E+00</td> <td>4.51E+03</td> </tr> <tr> <td>2 miles</td> <td>6.83E-03</td> <td>8.70E+00</td> <td></td> <td>2.64E-01</td> <td>1.90E+02</td> </tr> <tr> <td>5 miles</td> <td>2.89E-03</td> <td>3.69E+00</td> <td></td> <td>1.02E-01</td> <td>8.06E+01</td> </tr> <tr> <td>10 miles</td> <td>1.74E-03</td> <td>2.21E+00</td> <td></td> <td>5.75E-02</td> <td>4.84E+01</td> </tr> </tbody> </table>					Wholebody	Child Thyroid		Wholebody	Child Thyroid		DOSE RATE	DOSE RATE		DOSE	DOSE	Distance	mrem/hr	mrem/hr		mrem	mrem	Site Boundary	1.62E-01	2.06E+02		5.34E+00	4.51E+03	2 miles	6.83E-03	8.70E+00		2.64E-01	1.90E+02	5 miles	2.89E-03	3.69E+00		1.02E-01	8.06E+01	10 miles	1.74E-03	2.21E+00		5.75E-02	4.84E+01
	Wholebody	Child Thyroid		Wholebody	Child Thyroid																																								
	DOSE RATE	DOSE RATE		DOSE	DOSE																																								
Distance	mrem/hr	mrem/hr		mrem	mrem																																								
Site Boundary	1.62E-01	2.06E+02		5.34E+00	4.51E+03																																								
2 miles	6.83E-03	8.70E+00		2.64E-01	1.90E+02																																								
5 miles	2.89E-03	3.69E+00		1.02E-01	8.06E+01																																								
10 miles	1.74E-03	2.21E+00		5.75E-02	4.84E+01																																								
**14. METEOROLOGICAL DATA: A- WIND DIRECTION(from) 185.0 degrees      B- WIND SPEED(mph) 570 C- STABILITY CLASS A      D- PRECIPITATION(type) _____																																													
15. RECOMMENDED PROTECTIVE ACTIONS: A- NO RECOMMENDED PROTECTIVE ACTIONS B- EVACUATE _____ C- SHELTER IN-PLACE _____ D- OTHER _____																																													
16. APPROVED BY: _____ (Name) _____		TIME/DATE: _____ / _____ / _____ (Eastern) mm dd yy																																											

\* If items 8-14 have not changed, only items 1-7 and 15-16 are required to be completed.

\*\*Information may not be available on initial notifications.

Review with Emergency Coordinator the recommended Emergency Classification  
(based on Dose Projections only) :

None

Recommended Protective Actions (based on Dose Projections only)

EVACUATE

SHELTER IN-PLACE	L	B	M	C	N	A	D	O	R	E	F	G	H	I	J	K	P	Q	S
OTHER			L	B	M	C													

\*\*\*

Note

\*\*\* - Compare these recommendations with other groups' recommendations  
that the Emergency Coordinator/Recovery Manager reviews.

Projection based on data on 10/20/93 1400 Time since trip 5.00 hrs

Meteorology Assessment

Temperature Gradient -1.0

Distance	X/Q	Ch	Distance	X/Q	Ch
mile	sec/m3	mph-sec/m3	mile	sec/m3	mph-sec/m3
.5	2.82E-06	1.40E-05	2	1.19E-07	5.90E-07
1	2.42E-07	1.20E-06	4	6.45E-08	3.20E-07
3	8.27E-08	4.10E-07	6	4.03E-08	2.00E-07
5	5.04E-08	2.50E-07	8	3.63E-08	1.80E-07
7	3.83E-08	1.90E-07	10	3.02E-08	1.50E-07
9	3.23E-08	1.60E-07			
mile 0 - 2   2 - 5   5 - 10					
PAZ L B M C N A D O R			G H I J K P		

Source Term Assessment

Steam Relief Valves	Containment	Unit Vent
Ci/sec	Ci/sec	Ci/sec
0.00E-01	1.38E-04	1.71E+00 - Noble Gas
0.00E-01	2.61E-06	3.24E-02 - Iodine

Source Term based on Melted Core

Dose Assessment

Noble Gas - Adult Whole Body

Distance	Dose Rate	Dose(rem)
mile	rem/hr	2.5E-01hr
.5	1.62E-04	4.0E-05
1	1.39E-05	3.5E-06
2	6.83E-06	1.7E-06
3	4.74E-06	1.2E-06
4	3.70E-06	9.3E-07
5	2.89E-06	7.2E-07
6	2.31E-06	5.8E-07
7	2.20E-06	5.5E-07
8	2.08E-06	5.2E-07
9	1.85E-06	4.6E-07
10	1.74E-06	4.3E-07

Integrated WB	L	5.34E-03	B	5.34E-03	M	5.34E-03	C	5.34E-03	N	2.64E-04
Dose*	TH	4.51E+00		4.51E+00		4.51E+00		4.51E+00		1.90E-01
(rem)	WB A	2.64E-04	D	2.34E-04	O	2.34E-04	R	2.34E-04	E	0.00E-01
	TH	1.90E-01		1.63E-01		1.63E-01		1.63E-01		0.00E-01
	WB F	0.00E-01	F	3.82E-05	H	3.82E-05	I	1.02E-04	J	1.02E-04
	TH	0.00E-01		1.72E-02		1.72E-02		8.06E-02		8.06E-02
	WB K	1.02E-04	P	1.02E-04	Q	0.00E-01	S	0.00E-01		
	TH	8.06E-02		8.06E-02		0.00E-01		0.00E-01		

\* This dose is after the release and adjusted for any wind shifts

Iodine - Child Thyroid

Distance	Dose Rate	Dose(rem)	ETA
mile	rem/hr	2.5E-01hr	hr
.5	2.06E-01	5.2E-02	0.10
1	1.77E-02	4.4E-03	0.20
2	8.70E-03	2.2E-03	0.40
3	6.05E-03	1.5E-03	0.60
4	4.72E-03	1.2E-03	0.81
5	3.69E-03	9.2E-04	1.01
6	2.95E-03	7.4E-04	1.21
7	2.80E-03	7.0E-04	1.41
8	2.65E-03	6.6E-04	1.61
9	2.36E-03	5.9E-04	1.81
10	2.21E-03	5.5E-04	2.02

- Dose projections based on data below -

Containment

• 39 H 2.08E+05 cpm  
I-131/Xe-133 Ratio 1.90E-02  
psig 3.00E-01  
Leak Rate 5.23E+03 ml/hr  
Leak rate based on Realistic Leak Rate  
Percent bypass leakage 7  
Correction Factor 1.27E-13

Unit Vent

EMF s. H 1.50E+02 cpm  
I-131/Xe-133 Ratio 1.90E-02  
Flow Rate 5.30E+04 cfm  
Correction Factor 2.15E-07

PROJ. DATE = 10/20/93

PROJ. TIME = 14:00:00

## CURRENT EFFLUENT

RATE = .0 uCi/s

## CURRENT MET

SPEED = 5.0 MPH



DIR = 185 DEG

STABILITY = A

## CENTERLINE VALUES

LOCAT	DEG	mrem/hr
SB	5	2.06E+02
CL2	5	8.70E+00
CL5	5	3.69E+00
CL10	5	2.21E+00

## LEGEND




MODE = A DECAY = OFF DEPOSITION = OFF ETA = 2.0 HRS

RELEASE HT. = 3.3 ft. RELEASE PT. = Simultaneous

PROJ. DATE = 10/20/93

PROJ. TIME = 14:00:00

## CHI/Q\* DIFFUSION FACTORS



## CURRENT EFFLUENT

RATE = .0 uCi/s

## CURRENT MET

SPEED = 5.0 MPH

DIR = 185 DEG

STABILITY = A

## CENTERLINE VALUES

LOCAT	DEG	sec/m³
SB	5	2.82E-06
CL2	5	1.19E-07
CL5	5	5.04E-08
CL10	5	3.02E-08

## LEGEND

0.0-1.0E-12
1.0E-12-1.0E-9
1.0E-9-1.0E-6
1.0E-6+ s/m³

MODE = A DECAY = OFF DEPOSITION = OFF ETA = 2.0 HRS

RELEASE HT. = 3.3 ft. RELEASE PT. = Simultaneous

# EMERGENCY NOTIFICATION

1. THIS IS A(N) DRILL      INITIAL      FOLLOW-UP\*      MESSAGE NUMBER \_\_\_\_\_

2. SITE: McGuire      UNIT: 1      REPORTED BY: \_\_\_\_\_

ANSMITTAL TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 (Eastern) mm dd yy      CONFIRMATION PHONE NUMBER: \_\_\_\_\_

4. AUTHENTICATION: \_\_\_\_\_  
 (Number)      (Codeword)

5. EMERGENCY CLASSIFICATION:

A- NOTIFICATION OF UNUSUAL EVENT      B- ALERT      C- SITE AREA EMERGENCY      D- GENERAL EMERGENCY

6. A- Emergency Declaration At: B- Termination At: TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ (If B, go to item 16.)  
 (Eastern) mm dd yy

7. EMERGENCY DESCRIPTION/REMARKS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

8. PLANT CONDITION: A- IMPROVING      B- STABLE      C- DEGRADING

9. REACTOR STATUS: A- SHUTDOWN: TIME/DATE: 900 10/20/93  
 (Eastern) mm dd yy      B- \_\_\_\_\_ %POWER

10. EMERGENCY RELEASE(S):

A- NONE(Go to item 14.)      B- POTENTIAL(Go to item 14.)      C- IS OCCURRING      D- HAS OCCURRED

\*\*11. TYPE OF RELEASE: GROUND LEVEL

AIRBORNE	Started: _____ / _____ / _____ Time(Eastern) Date	Stopped: _____ / _____ / _____ Time(Eastern) Date
B- LIQUID	Started: _____ / _____ / _____ Time(Eastern) Date	Stopped: _____ / _____ / _____ Time(Eastern) Date

\*\*12. RELEASE MAGNITUDE: CURIES PER SEC.

A- NOBLE GASES 1.72E-01      B- IODINES 3.77E-03

C- IODINE/NOBLE GAS RATIO(If available) \_\_\_\_\_      D- OTHER \_\_\_\_\_

\*\*13. ESTIMATE OF PROJECTED OFFSITE DOSE: NEW UNCHANGED \* ESTIMATED DURATION: 2.00 HRS.

	Wholebody	Child Thyroid	Wholebody	Child Thyroid
DOSE RATE	DOSE RATE	DOSE	DOSE	
Distance	mrem/hr	mrem/hr	mrem	mrem
Site Boundary	1.69E-02	2.49E+01	5.46E+00	4.66E+03
2 miles	7.13E-04	1.05E+00	2.70E-01	1.97E+02
5 miles	3.02E-04	4.45E-01	1.04E-01	8.35E+01
10 miles	1.81E-04	2.67E-01	5.88E-02	5.01E+01

\*\*14. METEOROLOGICAL DATA:

A- WIND DIRECTION(from) 176.0 degrees      B- WIND SPEED(mph) 4.8  
 C- STABILITY CLASS A      D- PRECIPITATION(type) \_\_\_\_\_

15. RECOMMENDED PROTECTIVE ACTIONS:

A- NO RECOMMENDED PROTECTIVE ACTIONS  
 B- EVACUATE \_\_\_\_\_  
 C- SHELTER IN-PLACE \_\_\_\_\_  
 D- OTHER \_\_\_\_\_

16. APPROVED BY: \_\_\_\_\_ TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 (Name)      (Title)      (Eastern) mm dd yy

\* If items 8-14 have not changed, only items 1-7 and 15-16 are required to be completed.

\*\*Information may not be available on initial notifications.

Review with Emergency Coordinator the recommended Emergency Classification  
(based on Dose Projections only) :

None

Recommended Protective Actions (based on Dose Projections only)

EVACUATE

SHELTER IN-PLACE	L	B	M	C	N	A	D	O	R	E	F	G	H	I	J	K	P	Q	S
OTHER		L	B	M	C														

\*\*\*

Note

\*\*\* - Compare these recommendations with other groups' recommendations  
that the Emergency Coordinator/Recovery Manager reviews.

Projection based on data on 10/20/93 1500, Time since trip 6.00 hrs

Meteorology Assessment

Temperature Gradient -0.8

Distance	X/Q	Ch	Distance	X/Q	Ch
mile	sec/m3	mph-sec/m3	mile	sec/m3	mph-sec/m3
.5	2.93E-06	1.40E-05	2	1.23E-07	5.90E-07
1	2.51E-07	1.20E-06	4	6.69E-08	3.20E-07
3	8.58E-08	4.10E-07	6	4.18E-08	2.00E-07
5	5.23E-08	2.50E-07	8	3.77E-08	1.80E-07
7	3.97E-08	1.90E-07	10	3.14E-08	1.50E-07
9	3.35E-08	1.60E-07			
mile 0 - 2   2 - 5   5 - 10					
PAZ L B M C N A D O R			I J K P		

Source Term Assessment

Steam Relief Valves	Containment	Unit Vent
Ci/sec	Ci/sec	Ci/sec
0.00E-01	1.42E-03	1.70E-01 - Noble Gas
0.00E-01	3.11E-05	3.74E-03 - Iodine

Source Term based on Melted Core

Dose Assessment

Noble Gas - Adult Whole Body

Dose Rate	Dose(rem)		
mile	rem/hr	2.5E-01hr	2hr
.5	1.69E-05	4.2E-06	3.4E-05
1	1.45E-06	3.6E-07	2.9E-06
2	7.13E-07	1.8E-07	1.4E-06
3	4.95E-07	1.2E-07	9.9E-07
4	3.87E-07	9.7E-08	7.7E-07
5	3.02E-07	7.6E-08	6.0E-07
6	2.42E-07	6.0E-08	4.8E-07
7	2.30E-07	5.7E-08	4.6E-07
8	2.17E-07	5.4E-08	4.3E-07
9	1.93E-07	4.8E-08	3.9E-07
10	1.81E-07	4.5E-08	3.6E-07

Iodine - Child Thyroid

Dose Rate	Dose(rem)	ETA		
mile	rem/hr	2.5E-01hr	2hr	hr
.5	2.49E-02	6.2E-03	5.0E-02	0.10
1	2.14E-03	5.3E-04	4.3E-03	0.21
2	1.05E-03	2.6E-04	2.1E-03	0.42
3	7.30E-04	1.8E-04	1.5E-03	0.63
4	5.70E-04	1.4E-04	1.1E-03	0.84
5	4.45E-04	1.1E-04	8.9E-04	1.05
6	3.56E-04	8.9E-05	7.1E-04	1.26
7	3.39E-04	8.5E-05	6.8E-04	1.46
8	3.21E-04	8.0E-05	6.4E-04	1.67
9	2.85E-04	7.1E-05	5.7E-04	1.88
10	2.67E-04	6.7E-05	5.3E-04	2.09

Integrated WB L	5.46E-03	B	5.46E-03	M	5.46E-03	C	5.46E-03	N	2.70E-04
Dose*	TH	4.68E+00	4.68E+00	4.68E+00	4.68E+00		4.68E+00		1.97E-01
(rem)	WB A	2.70E-04	D	2.40E-04	O	2.40E-04	R	2.40E-04	E 0.00E-01
	TH	1.97E-01		1.69E-01		1.69E-01		1.69E-01	0.00E-01
	WB F	0.00E-01	F	4.03E-05	H	4.03E-05	I	1.04E-04	J 1.04E-04
	TH	0.00E-01		1.99E-02		1.99E-02		8.35E-02	8.35E-02
	WB K	1.04E-04	P	1.04E-04	Q	0.00E-01	S	0.00E-01	
	TH	8.35E-02		8.35E-02		0.00E-01		0.00E-01	

\* This dose is after the release and adjusted for any wind shifts

- Dose projections based on data below

Containment

39 H 2.47E+05 cpm  
I-131/Xe-133 Ratio 2.19E-02  
psig 3.00E+00  
Leak Rate 4.54E+04 ml/hr  
Leak rate based on Realistic Leak Rate  
Percent bypass leakage 7  
Correction Factor 1.26E-13


Unit Vent

EMI 36 H 1.50E+01 cpm  
I-131/Xe-133 Ratio 2.19E-02  
Flow Rate 5.30E+04 cfm  
Correction Factor 2.14E-07

PROJ. DATE = 10/20/93

PROJ. TIME = 15:00:00

## CHI/Q\* DIFFUSION FACTORS



## CURRENT EFFLUENT

RATE = .8 uCi/s

## CURRENT MET

SPEED = 4.8 MPH

DIR = 176 DEG

STABILITY = A

## CENTERLINE VALUES

LOCAT	DEG	sec/m3
SB	356	2.93E-06
CL2	356	1.23E-07
CL5	356	5.23E-08
CL10	356	3.14E-08

## LEGEND

White	0.0-1.0E-12
Light Gray	1.0E-12-1.0E-9
Dark Gray	1.0E-9-1.0E-6
Hatched	1.0E-6+ sec/m3

MODE = A DECAY = OFF DEPOSITION = OFF ETA = 2.1 HRS

RELEASE HT. = 3.3 ft. RELEASE PT. = Simultaneous

## EMERGENCY NOTIFICATION

1. THIS IS A(N) DRILL INITIAL FOLLOW-UP \* MESSAGE NUMBER \_\_\_\_\_

2. SITE: McGuire                    UNIT: 1                    REPORTED BY: \_\_\_\_\_

ANSIMMITAL TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ CONFIRMATION PHONE NUMBER: \_\_\_\_\_  
(Eastern) mm dd yy

4. AUTHENTICATION: \_\_\_\_\_  
(Number) \_\_\_\_\_ (Codeword) \_\_\_\_\_

#### 5. EMERGENCY CLASSIFICATION:

A- NOTIFICATION OF UNUSUAL EVENT      B- ALERT      C- SITE AREA EMERGENCY      D- GENERAL EMERGENCY

6. A- Emergency Declaration At: B- Termination At: TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ (If B, go to item 16.)  
(Eastern) mm dd yy

7. EMERGENCY DESCRIPTION/REMARKS: \_\_\_\_\_

8. PLANT CONDITION:      A- IMPROVING      B- STABLE      C- DEGRADING

9. REACTOR STATUS: A- SHUTDOWN: TIME/DATE: 900 10/20/93 B- \_\_\_\_\_ %POWER  
(Eastern) mm dd yy

10. EMERGENCY RELEASE(S):  
A- NONE(Go to item 14.)      B- POTENTIAL(Go to item 14.)      C- IS OCCURRING      D- HAS OCCURRED

411. TYPE OF RELEASE: GROUND LEVEL

AIRBORNE	Started:	_____	/	_____	Stopped:	_____	/	_____
		Time(Eastern)		Date		Time(Eastern)		Date
LIQUID	Started:	_____	/	_____	Stopped:	_____	/	_____
		Time(Eastern)		Date		Time(Eastern)		Date

\*\*12. RELEASE MAGNITUDE: CURIOS PER SEC. NORMAL OPERATING LIMITS: ABOVE

A- NOBLE GASES 1.72E-01 B- IODINEO 3.77E-03

C- IODINE/NOBLE GAS RATIO(if available) \_\_\_\_\_ D- OTHER \_\_\_\_\_

\*\*13. ESTIMATE OF PROJECTED OFFSITE DOSE: NEW UNCHANGED ESTIMATED DURATION: 2.00 HRS.

Wholebody Child Thyroid Wholebody Child Thyroid

DOSE RATE      DOSE RATE      DOSE

Distance	mrem/hr	mrem/hr	mrem	mrem
Site Boundary	1.69E-02	2.49E+01	5.46E+00	4.68E+03
2 miles	7.13E-04	1.05E+00	2.70E-01	1.97E+02
5 miles	3.02E-04	4.45E-01	1.04E-01	8.35E+01
10 miles	1.81E-04	2.67E-01	5.88E-02	5.01E+01

\*\*14. METEOROLOGICAL DATA:

A- WIND DIRECTION(from) 176.0 degrees B- WIND SPEED(mph) 4.8  
C- STABILITY CLASS A D- PRECIPITATION(type)

15. RECOMMENDED PROTECTIVE ACTIONS:

A- NO RECOMMENDED PROTECTIVE ACTIONS

**B - EVACUATE**

C- SHELTER IN-PLACE

D- OTHER

16. APPROVED BY: \_\_\_\_\_ TIME/DATE: \_\_\_\_\_ / /  
(Name) (Title) (Eastern) mm dd yy

\* if items 8-14 have not changed, only items 1-7 and 15-16 are required to be completed.

*\*\*Information may not be available on initial notifications.*

Review with Emergency Coordinator the recommended Emergency Classification  
(based on Dose Projections only) :

None

Recommended Protective Actions (based on Dose Projections only)

EVACUATE

SHELTER IN-PLACE	L	B	M	C	N	A	D	O	R	E	F	G	H	I	J	K	P	Q	S
OTHER		L	B	M	C														

\*\*\*

Note

\*\*\* - Compare these recommendations with other groups' recommendations  
that the Emergency Coordinator/Recovery Manager reviews.

Projection based on data on 10/20/93 1500 Time since trip 6.00 hrs

Meteorology Assessment

Temperature Gradient -0.8

Distance	X/Q	Ch	Distance	X/Q	Ch
mile	sec/m3	mph-sec/m3	mile	sec/m3	mph-sec/m3
.5	2.93E-06	1.40E-05	2	1.23E-07	5.90E-07
1	2.51E-07	1.20E-06	4	6.69E-08	3.20E-07
3	8.58E-08	4.10E-07	6	4.18E-08	2.00E-07
5	5.23E-08	2.50E-07	8	3.77E-08	1.80E-07
7	3.97E-08	1.90E-07	10	3.14E-08	1.50E-07
9	3.35E-08	1.60E-07			
mile 0 - 2   2 - 5   5 - 10					
PAZ L B M C N A D O R			I J K P		

Source Term Assessment

Steam Relief Valves	Containment	Unit Vent
Ci/sec	Ci/sec	Ci/sec
0.00E-01	1.42E-03	1.70E-01 - Noble Gas
0.00E-01	3.11E-05	3.74E-03 - Iodine

Source Term based on Melted Core

Dose Assessment

Noble Gas - Adult Whole Body

Distance	Dose Rate	Dose(rem)
mile	rem/hr	2.5E-01hr 2hr
.5	1.69E-05	4.2E-06 3.4E-05
1	1.45E-06	3.6E-07 2.9E-06
2	7.13E-07	1.8E-07 1.4E-06
3	4.95E-07	1.2E-07 9.9E-07
4	3.87E-07	9.7E-08 7.7E-07
5	3.02E-07	7.6E-08 6.0E-07
6	2.42E-07	6.0E-08 4.8E-07
7	2.30E-07	5.7E-08 4.6E-07
8	2.17E-07	5.4E-08 4.3E-07
9	1.93E-07	4.8E-08 3.9E-07
10	1.81E-07	4.5E-08 3.6E-07

Iodine - Child Thyroid

Distance	Dose Rate	Dose(rem)	ETA
mile	rem/hr	2.5E-01hr 2hr	hr
.5	2.49E-02	6.2E-03 5.0E-02	0.10
1	2.14E-03	5.3E-04 4.3E-03	0.21
2	1.05E-03	2.6E-04 2.1E-03	0.42
3	7.30E-04	1.8E-04 1.5E-03	0.63
4	5.70E-04	1.4E-04 1.1E-03	0.84
5	4.45E-04	1.1E-04 8.9E-04	1.05
6	3.56E-04	8.9E-05 7.1E-04	1.26
7	3.39E-04	8.5E-05 6.8E-04	1.46
8	3.21E-04	8.0E-05 6.4E-04	1.67
9	2.85E-04	7.1E-05 5.7E-04	1.88
10	2.67E-04	6.7E-05 5.3E-04	2.09

Integrated WB L 5.46E-03 B 5.46E-03 M 5.46E-03 C 5.46E-03 N 2.70E-04

Dose\* TH 4.68E+00 4.68E+00 4.68E+00 4.68E+00 1.97E-01

(rem) WB A 2.70E-04 D 2.40E-04 O 2.40E-04 R 2.40E-04 E 0.00E-01

TH 1.97E-01 1.69E-01 1.69E-01 1.69E-01 0.00E-01

WB F 0.00E-01 F 4.03E-05 H 4.03E-05 I 1.04E-04 J 1.04E-04

TH 0.00E-01 1.99E-02 1.99E-02 8.35E-02 8.35E-02

WB K 1.04E-04 P 1.04E-04 Q 0.00E-01 S 0.00E-01

TH 8.35E-02 8.35E-02 0.00E-01 0.00E-01

\* This dose is after the release and adjusted for any wind shifts

- Dose projections based on data below


Containment  
39 H 2.47E+05 cpm  
I-131/Xe-133 Ratio 2.19E-02  
psig 3.00E+00  
Leak Rate 4.54E+04 ml/hr  
Leak rate based on Realistic Leak Rate  
Percent bypass leakage 7  
Correction Factor 1.26E-13

Unit Vent  
EMF 36 H 1.50E+01 cpm  
I-131/Xe-133 Ratio 2.19E-02  
Flow Rate 5.30E+04 cfm  
Correction Factor 2.14E-07

PROJ. DATE = 10/20/93

PROJ. TIME = 15:00:00

## CHI/Q\* DIFFUSION FACTORS



MODE = A DECAY = OFF DEPOSITION = OFF .ETA = 2.1 HRS

RELEASE HT. = 3.3 ft. RELEASE PT. = Simultaneous

## CURRENT EFFLUENT

RATE = .0 uCi/s

## CURRENT MET

SPEED = 4.8 MPH

DIR = 176 DEG

STABILITY = A

## CENTERLINE VALUES

LOCAT	DEG	sec/m <sup>3</sup>
SB	356	2.93E-06
CL2	356	1.23E-07
CL5	356	5.23E-08
CL10	356	3.14E-08

## LEGEND

0.0-1.0E-12
1.0E-12-1.0E-9
1.0E-9-1.0E-6
1.0E-6+ s/m <sup>3</sup>

Review with Emergency Coordinator the recommended Emergency Classification  
(based on Dose Projections only) :

Recommend Alert

Recommended Protective Actions (based on Dose Projections only)

EVACUATE

SHELTER IN-PLACE

OTHER

\*\*\*

Note

\*\*\* - Compare these recommendations with other groups' recommendations  
that the Emergency Coordinator/Recovery Manager reviews.

Projection based on data on 10/20/93 915 Time since trip 0.25 hrs

Meteorology Assessment

Temperature Gradient -0.5

Distance	X/Q	Ch	Distance	X/Q	Ch
mile	sec/m3	mph-sec/m3	mile	sec/m3	mph-sec/m3
.5	1.85E-04	3.80E-04	2	2.39E-05	4.90E-05
1	6.83E-05	1.40E-04	4	8.29E-06	1.70E-05
3	1.32E-05	2.70E-05	6	4.49E-06	9.20E-06
5	5.85E-06	1.20E-05	8	2.93E-06	6.00E-06
7	3.56E-06	7.30E-06	10	2.10E-06	4.30E-06
9	2.44E-06	5.00E-06			
mile 0 - 2   2 - 5   5 - 10					
PAZ L B M C N A D O R	G H I J K P				

Source Term Assessment

Containment	Unit Vent
Ci/sec	Ci/sec
0.00E-01	2.72E-06
0.00E-01	8.55E-09

2.91E-01 - Noble Gas  
9.15E-06 - Iodine

Source Term based on LOCA(charcoal)

Dose Assessment

Noble Gas - Adult Whole Body

Distance		Dose(rem)	
mile	rem/hr	2.5E-01hr	2hr
.5	1.81E-03	4.5E-04	3.6E-03
1	6.68E-04	1.7E-04	1.3E-03
2	2.34E-04	5.8E-05	4.7E-04
3	1.29E-04	3.2E-05	2.6E-04
4	8.11E-05	2.0E-05	1.6E-04
5	5.72E-05	1.4E-05	1.1E-04
6	4.39E-05	1.1E-05	8.8E-05
7	3.48E-05	8.7E-06	7.0E-05
8	2.86E-05	7.2E-06	5.7E-05
9	2.38E-05	6.0E-06	4.8E-05
10	2.05E-05	5.1E-06	4.1E-05

Integrated	WB L	4.53E-04	B	4.53E-0	*	4.53E-04	C	4.53E-04	N	5.84E-05
Dose*	TH	9.59E-04		9.59E-04		9.59E-04		9.59E-04		1.24E-04
(rem)	WB A	5.84E-05	D	5.84E-05	O	5.84E-05	R	5.84E-05	E	0.00E-01
	TH	1.24E-04		1.24E-04		1.24E-04		1.24E-04		0.00E-01
	WB F	0.00E-01	F	1.43E-05	H	1.43E-05	I	1.43E-05	J	1.43E-05
	TH	0.00E-01		3.03E-05		3.03E-05		3.03E-05		3.03E-05
	WB K	1.43E-05	P	1.43E-05	Q	0.00E-01	S	0.00E-01		
	TH	3.03E-05		3.03E-05		0.00E-01		0.00E-01		


\* This dose is after the release and adjusted for any wind shifts

- Dose projections based on data below

Containment  
39 H 1.55E+04 cpm  
I-131/Xe-133 Ratio 3.14E-03  
psig 1.80E-01  
Leak Rate 3.16E+03 ml/hr  
Leak rate based on Realistic Leak Rate  
Percent bypass leakage 7  
Correction Factor 5.56E-14

Unit Vent  
EMF 36 L 5.06E+05 cpm  
I-131/Xe-133 Ratio 3.14E-05  
Flow Rate 5.30E+04 cfm  
Correction Factor 1.08E-11

This is a hypothetical projection. Projection is not stored.



## EMERGENCY NOTIFICATION

115

1. THIS IS A(N) DRILL INITIAL FOLLOW-UP\* MESSAGE NUMBER \_\_\_\_\_

2. SITE: McGuire UNIT: 1 REPORTED BY: \_\_\_\_\_

TRANSMITTAL TIME/DATE: \_\_\_\_/\_\_\_\_/\_\_\_\_ CONFIRMATION PHONE NUMBER: \_\_\_\_\_  
(Eastern) mm dd YY4. AUTHENTICATION: \_\_\_\_\_  
(Number) (Codeword)

## 5. EMERGENCY CLASSIFICATION:

A- NOTIFICATION OF UNUSUAL EVENT B- ALERT C- SITE AREA EMERGENCY D- GENERAL EMERGENCY

6. A- Emergency Declaration At: B- Termination At: TIME/DATE: \_\_\_\_/\_\_\_\_/\_\_\_\_ (If B, go to item 16.)  
(Eastern) mm dd YY7. EMERGENCY DESCRIPTION/REMARKS: \_\_\_\_\_  
\_\_\_\_\_

8. PLANT CONDITION: A- IMPROVING B- STABLE C- DEGRADING

9. REACTOR STATUS: A- SHUTDOWN: TIME/LATE: 900 10/20/93 B- \_\_\_\_\_ %POWER  
(Eastern) mm dd yy

## 10. EMERGENCY RELEASE(S):

A- NONE(Go to item 14.) B- POTENTIAL(Go to item 14.) C- IS OCCURRING D- HAS OCCURRED

## 11. TYPE OF RELEASE: GROUND LEVEL

AIRBORNE	Started: _____	/	/	Stopped: _____	/	/
	Time(Eastern)		Date	Time(Eastern)		Date
B- LIQUID	Started: _____	/	/	Stopped: _____	/	/
	Time(Eastern)		Date	Time(Eastern)		Date

## 12. RELEASE MAGNITUDE: CURIES PER SEC.

\* NORMAL OPERATING LIMITS: ABOVE

A- NOBLE GASES 2.91E-01 B- IODINES 9.16E-06

C- IODINE/NOBLE GAS RATIO(If available) D- OTHER \_\_\_\_\_

## 13. ESTIMATE OF PROJECTED OFFSITE DOSE: NEW UNCHANGED ESTIMATED DURATION: 0.25 HRS.

	Wholebody	Child Thyroid	Wholebody	Child Thyroid
DOSE RATE	DOSE RATE	DOSE	DOSE	
Distance	mrem/hr	mrem/hr	mrem	mrem
Site Boundary	1.81E+00	3.84E+00	4.53E-01	9.59E-01
2 miles	2.34E-01	4.95E-01	5.84E-02	1.24E-01
5 miles	5.72E-02	1.21E-01	1.43E-02	3.03E-02
10 miles	2.05E-02	4.34E-02	5.13E-03	1.09E-02

## 14. METEOROLOGICAL DATA:

A- WIND DIRECTION(from) 181.0 degrees B- WIND SPEED(mph) 2.0  
C- STABILITY CLASS D- PRECIPITATION(type) \_\_\_\_\_

## 15. RECOMMENDED PROTECTIVE ACTIONS:

- A- NO RECOMMENDED PROTECTIVE ACTIONS
- B- EVACUATE \_\_\_\_\_
- C- SHELTER IN-PLACE \_\_\_\_\_
- D- OTHER \_\_\_\_\_

16. APPROVED BY: \_\_\_\_\_ TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
(Name) (Title) (Eastern) mm dd yy

\* If items 8-14 have not changed, only items 1-7 and 15-16 are required to be completed.

\*\*Information may not be available on initial notifications.

## EMERGENCY NOTIFICATION

07/15

1. THIS IS A(N) DRILL INITIAL FOLLOW-UP\* MESSAGE NUMBER \_\_\_\_\_

2. SITE: McGuire UNIT: 1 REPORTED BY: \_\_\_\_\_

TRANSMISSION TIME/DATE: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ CONFIRMATION PHONE NUMBER: \_\_\_\_\_  
(Eastern) mm dd yy4. AUTHENTICATION: \_\_\_\_\_  
(Number) \_\_\_\_\_ (Codeword)5. EMERGENCY CLASSIFICATION:  
A- NOTIFICATION OF UNUSUAL EVENT B- ALERT C- SITE AREA EMERGENCY D- GENERAL EMERGENCY6. A- Emergency Declaration At: B- Termination At: TIME/DATE: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ (If B, go to item 16.)  
(Eastern) mm dd yy7. EMERGENCY DESCRIPTION/REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

8. PLANT CONDITION: A- IMPROVING B- STABLE C- DEGRADING


9. REACTOR STATUS: A- SHUTDOWN: TIME/DATE: 900 10/20/93 B- \_\_\_\_\_ %POWER  
(Eastern) mm dd yy10. EMERGENCY RELEASE(S):  
A- NONE(Go to item 14.) B- POTENTIAL(Go to item 14.) C- IS OCCURRING D- HAS OCCURRED\*\*11. TYPE OF RELEASE: GROUND LEVEL  
AIRBORNE Started: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Stopped: \_\_\_\_ / \_\_\_\_ / \_\_\_\_  
Time(Eastern) Date Time(Eastern) Date  
B- LIQUID Started: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Stopped: \_\_\_\_ / \_\_\_\_ / \_\_\_\_  
Time(Eastern) Date Time(Eastern) Date\*\*12. RELEASE MAGNITUDE: CURIES PER SEC. NORMAL OPERATING LIMITS: ABOVE  
A- NOBLE GASES 2.91E-01 B- IODINES 9.16E-06  
C- IODINE/NOBLE GAS RATIO(If available) D- OTHER \_\_\_\_\_\*\*13. ESTIMATE OF PROJECTED OFFSITE DOSE: NEW UNCHANGED ESTIMATED DURATION: 0.25 HRS.  

	Wholebody	Child Thyroid	Wholebody	Child Thyroid
	DOSE RATE	DOSE RATE	DOSE	DOSE
Distance	mrem/hr	mrem/hr	mrem	mrem
Site Boundary	1.81E+00	3.84E+00	4.53E-01	9.59E-01
2 miles	2.34E-01	4.95E-01	5.84E-02	1.24E-01
5 miles	5.72E-02	1.21E-01	1.43E-02	3.03E-02
10 miles	2.05E-02	4.34E-02	5.13E-03	1.09E-02

\*\*14. METEOROLOGICAL DATA:  
A- WIND DIRECTION(from) 181.0 degrees B- WIND SPEED(mph) 2.0  
C- STABILITY CLASS D- PRECIPITATION(type) \_\_\_\_\_15. RECOMMENDED PROTECTIVE ACTIONS:  
A- NO RECOMMENDED PROTECTIVE ACTIONS  
B- EVACUATE \_\_\_\_\_  
C- SHELTER IN-PLACE \_\_\_\_\_  
D- OTHER \_\_\_\_\_16. APPROVED BY: \_\_\_\_\_ TIME/DATE: \_\_\_\_ / \_\_\_\_ / \_\_\_\_  
(Name) \_\_\_\_\_ (Title) \_\_\_\_\_  
(Eastern) mm dd yy

\* If items 8-14 have not changed, only items 1-7 and 15-16 are required to be completed.

\*\*Information may not be available on initial notifications.



## EMERGENCY NOTIFICATION

0915

1. THIS IS A(N) DRILL INITIAL FOLLOW-UP\* MESSAGE NUMBER \_\_\_\_\_

2. SITE: McGuire UNIT: 1 REPORTED BY: \_\_\_\_\_

TRANSMITTAL TIME/DATE: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ CONFIRMATION PHONE NUMBER: \_\_\_\_\_  
(Eastern) mm dd yy4. AUTHENTICATION: \_\_\_\_\_  
(Number) (Codeword)

## 5. EMERGENCY CLASSIFICATION:

A- NOTIFICATION OF UNUSUAL EVENT B- ALERT C- SITE AREA EMERGENCY D- GENERAL EMERGENCY

6. A- Emergency Declaration At: B- Termination At: TIME/DATE: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ (If B, go to item 16.)  
(Eastern) mm dd yy7. EMERGENCY DESCRIPTION/REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_

8. PLANT CONDITION: A- IMPROVING B- STABLE C- DEGRADING

9. REACTOR STATUS: A- SHUTDOWN: TIME/DATE: 900 10/20/93 B- \_\_\_\_\_ % POWER  
(Eastern) mm dd yy

## 10. EMERGENCY RELEASE(S):

A- NONE(Go to item 14.) B- POTENTIAL(Go to item 14.) C- IS OCCURRING D- HAS OCCURRED

## \*\*11. TYPE OF RELEASE: GROUND LEVEL

AIRBORNE	Started: _____ / _____ / _____ Time(Eastern)	Date	Stopped: _____ / _____ / _____ Time(Eastern)	Date
B- LIQUID	Started: _____ / _____ / _____ Time(Eastern)	Date	Stopped: _____ / _____ / _____ Time(Eastern)	Date

## \*\*12. RELEASE MAGNITUDE: CURIES PER SEC.

NORMAL OPERATING LIMITS: BELOW

A- NOBLE GASES 2.72E-06 B- IODINES 8.55E-09

C- IODINE/NOBLE GAS RATIO(If available) D- OTHER \_\_\_\_\_

## \*\*13. ESTIMATE OF PROJECTED OFFSITE DOSE: NEW UNCHANGED ESTIMATED DURATION: 0.50 HRS.

	Wholebody	Child Thyroid	Wholebody	Child Thyroid
	DOSE RATE	DOSE RATE	DOSE	DOSE
Distance	mrem/hr	mrem/hr	mrem	mrem
Site Boundary	1.69E-05	3.58E-03	4.53E-01	9.60E-01
2 miles	2.18E-06	4.62E-04	5.84E-02	1.24E-01
5 miles	5.35E-07	1.13E-04	1.43E-02	3.03E-02
10 miles	1.92E-07	4.06E-05	5.13E-03	1.09E-02

## \*\*14. METEOROLOGICAL DATA:

A- WIND DIRECTION(from) 181.0 degrees B- WIND SPEED(mph) 2.0

C- STABILITY CLASS D D- PRECIPITATION(type) \_\_\_\_\_

## 15. RECOMMENDED PROTECTIVE ACTIONS:

A- NO RECOMMENDED PROTECTIVE ACTIONS

B- EVACUATE \_\_\_\_\_

C- SHELTER IN PLACE \_\_\_\_\_

D- OTHER \_\_\_\_\_

16. APPROVED BY: \_\_\_\_\_ TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
(Name) (Title) (Eastern) mm dd yy


\* If items 8-14 have not changed, only items 1-7 and 15-16 are required to be completed.

\*\*Information may not be available on initial notifications.

PROJ. DATE = 10/20/93

PROJ. TIME = 09:15:00

CHI/Q\* DIFFUSION FACTORS



CURRENT EFFLUENT

RATE = 3. uCi/s

CURRENT MET

SPEED = 2.0 MPH

DIR = 181 DEG

STABILITY = D

CENTERLINE VALUES

LOCAT	DEG	sec/m3
SB	1	1.85E-04
CL2	1	2.39E-05
CL5	1	5.85E-06
CL10	1	2.10E-06

LEGEND

white	0.0-1.0E-12
dark gray	1.0E-12-1.0E-9
black	1.0E-9-1.0E-6
hatched	1.0E-6+ s/m3

MODE = A DECAY = OFF DEPOSITION = OFF ETA = 5.0 HRS

RELEASE HT. = 6.6 ft. RELEASE PT. = Containment

## EMERGENCY NOTIFICATION

0930

1. THIS IS A(N) DRILL INITIAL FOLLOW-UP\* MESSAGE NUMBER \_\_\_\_\_

2. SITE: McGuire UNIT: 1 REPORTED BY: \_\_\_\_\_

TRANSMITTAL TIME/DATE: \_\_\_\_/\_\_\_\_/\_\_\_\_ CONFIRMATION PHONE NUMBER: \_\_\_\_\_  
(Eastern) mm dd yy4. AUTHENTICATION: \_\_\_\_\_  
(Number) \_\_\_\_\_ (Codeword)

## 5. EMERGENCY CLASSIFICATION:

A- NOTIFICATION OF UNUSUAL EVENT B- ALERT C- SITE AREA EMERGENCY D- GENERAL EMERGENCY

6. A- Emergency Declaration At: B- Termination At: TIME/DATE: \_\_\_\_/\_\_\_\_/\_\_\_\_ (If B, go to item 16.)  
(Eastern) mm dd yy7. EMERGENCY DESCRIPTION/REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_

8. PLANT CONDITION: A- IMPROVING B- STABLE C- DEGRADING

9. REACTOR STATUS: A- SHUTDOWN: TIME/DATE: 900 10/20/93 \* B- \_\_\_\_\_ %POWER  
(Eastern) mm dd yy

## 10. EMERGENCY RELEASE(S):

A- NONE(Go to item 14.) B- POTENTIAL(Go to item 14.) C- IS OCCURRING D- HAS OCCURRED

## \*\*11. TYPE OF RELEASE: GROUND LEVEL

AIRBORNE	Started: _____	/	/	Stopped: _____	/	/
	Time(Eastern)		Date	Time(Eastern)		Date
B- LIQUID	Started: _____	/	/	S	/	/
	Time(Eastern)		Date	n)		Date

## \*\*12. RELEASE MAGNITUDE: CURIES PER SEC.

A- NOBLE GASES 1.25E-01 B- IODINES 4.08E-06  
C- IODINE/NOBLE GAS RATIO(If available) D- OTHER \_\_\_\_\_

## \*\*13. ESTIMATE OF PROJECTED OFFSITE DOSE: NEW UNCHANGED ESTIMATED DURATION: 0.50 HRS.

	Wholebody	Child Thyroid	Wholebody	Child Thyroid
DOSE RATE	DOSE RATE	DOSE	DOSE	
Distance	mrem/hr	mrem/hr	mrem	mrem
Site Boundary	5.21E-01	1.14E+00	5.83E-01	1.25E+00
1 miles	6.71E-02	1.47E-01	7.52E-02	1.61E-01
5 miles	1.64E-02	3.61E-02	1.84E-02	3.93E-02
10 miles	5.89E-03	1.29E-02	6.60E-03	1.41E-02

## \*\*14. METEOROLOGICAL DATA:

A- WIND DIRECTION(from) 179.0 degrees B- WIND SPEED(mph) 3.1  
C- STABILITY CLASS D D- PRECIPITATION(type) \_\_\_\_\_

## 15. RECOMMENDED PROTECTIVE ACTIONS:

A- NO RECOMMENDED PROTECTIVE ACTIONS  
 B- EVACUATE \_\_\_\_\_  
 C- SHELTER IN-PLACE \_\_\_\_\_  
 D- OTHER \_\_\_\_\_

16. APPROVED BY: \_\_\_\_\_ TIME/DATE: \_\_\_\_/\_\_\_\_/\_\_\_\_  
(Name) \_\_\_\_\_ (Title) \_\_\_\_\_ (Eastern) mm dd yy

\* If items 8-14 have not changed, only items 1-7 and 15-16 are required to be completed.

\*\*Information may not be available on initial notifications.

## EMERGENCY NOTIFICATION

1100

1. THIS IS A(N) DRILL INITIAL FOLLOW-UP\* MESSAGE NUMBER \_\_\_\_\_

2. SITE: McGuire UNIT: 1 REPORTED BY: \_\_\_\_\_

TRANSMITTAL TIME/LDATE: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ CONFIRMATION PHONE NUMBER: \_\_\_\_\_  
(Eastern) mm dd yy4. AUTHENTICATION: \_\_\_\_\_  
(Number) (Codeword)5. EMERGENCY CLASSIFICATION:  
A- NOTIFICATION OF UNUSUAL EVENT B- ALERT C- SITE AREA EMERGENCY D- GENERAL EMERGENCY6. A- Emergency Declaration At: B- Termination At: TIME/DATE: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ (If B, go to item 16.)  
(Eastern) mm dd yy7. EMERGENCY DESCRIPTION/REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

8. PLANT CONDITION: A- IMPROVING B- STABLE C- DEGRADING

9. REACTOR STATUS: A- SHUTDOWN: TIME/DATE: 900 10/20/93 B- \_\_\_\_\_ %POWER  
(Eastern) mm dd yy10. EMERGENCY RELEASE(S):  
A- NONE(Go to item 14.) B- POTENTIAL(Go to item 14.) C- IS OCCURRING D- HAS OCCURRED\*\*11. TYPE OF RELEASE: GROUND LEVEL  
AIRBORNE Started: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Stopped: \_\_\_\_ / \_\_\_\_ / \_\_\_\_  
Time(Eastern) Date Time(Eastern) Date  
B- LIQUID Started: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ Stopped: \_\_\_\_ / \_\_\_\_ / \_\_\_\_  
Time(Eastern) Date Time(Eastern) Date\*\*12. RELEASE MAGNITUDE: CURIES PER SEC. NORMAL OPERATING LIMITS: ABOVE  
A- NOBLE GASES 0.68E+00 B- IODINES 8.38E-02  
C- IODINE/NOBLE GAS RATIO(If available) D- OTHER \_\_\_\_\_\*\*13. ESTIMATE OF PROJECTED OFFSITE DOSE: NEW UNCHANGED ESTIMATED DURATION: 0.50 HRS.  

	Wholebody	Child Thyroid	Wholebody	Child Thyroid
	DOSE RATE	DOSE RATE	DOSE	DOSE
Distance	mrem/hr	mrem/hr	mrem	mrem
Site Boundary	1.20E+01	7.79E+03	3.45E+00	1.95E+03
2 miles	1.04E+00	6.75E+02	3.18E-01	1.69E+02
5 miles	2.16E-01	1.40E+02	6.82E-02	3.51E+01
10 miles	6.23E-02	4.05E+01	2.07E-02	1.01E+01

\*\*14. METEOROLOGICAL DATA:  
A- WIND DIRECTION(from) 177.0 degrees B- WIND SPEED(mph) 3.6  
C- STABILITY CLASS C D- PRECIPITATION(type) \_\_\_\_\_15. RECOMMENDED PROTECTIVE ACTIONS:  
A- NO RECOMMENDED PROTECTIVE ACTIONS  
B- EVACUATE \_\_\_\_\_  
C- SHELTER IN-PLACE \_\_\_\_\_  
D- OTHER \_\_\_\_\_16. APPROVED BY: \_\_\_\_\_ TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
(Name) (Title) \* (Eastern) mm dd yy

\* If items 8-14 have not changed, only items 1-7 and 15-16 are required to be completed.

\*\*Information may not be available on initial notifications.

## EMERGENCY NOTIFICATION

11:15

1. THIS IS A(N) DRILL INITIAL FOLLOW-UP\* MESSAGE NUMBER \_\_\_\_\_

2. SITE McGuire UNIT: 1 REPORTED BY: \_\_\_\_\_

ANSMITTAL TIME/DATE: \_\_\_\_/\_\_\_\_/\_\_\_\_ CONFIRMATION PHONE NUMBER: \_\_\_\_\_  
(Eastern) mm dd yy4. AUTHENTICATION: \_\_\_\_\_  
(Number) \_\_\_\_\_  
(Codeword) \_\_\_\_\_

## 5. EMERGENCY CLASSIFICATION:

A- NOTIFICATION OF UNUSUAL EVENT B- ALERT C- SITE AREA EMERGENCY D- GENERAL EMERGENCY

6. A- Emergency Declaration At: B- Termination At: TIME/DATE: \_\_\_\_/\_\_\_\_/\_\_\_\_ (If B, go to item 16.)  
(Eastern) mm dd yy7. EMERGENCY DESCRIPTION/REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_

8. PLANT CONDITION: A- IMPROVING B- STABLE C- DEGRADING

9. REACTOR STATUS: A- SHUTDOWN: TIME/DATE: 900 10/20/93 B- \_\_\_\_\_ %POWER  
(Eastern) mm dd yy

## 10. EMERGENCY RELEASE(S):

A- NONE(Go to item 14.) B- POTENTIAL(Go to item 14.) C- IS OCCURRING D- HAS OCCURRED

\*

## \*\*11. TYPE OF RELEASE: GROUND LEVEL

AIRBORNE	Started: _____ / _____ / _____ Time(Eastern)	Stopped: _____ / _____ / _____ Time(Eastern)
B- LIQUID	Started: _____ / _____ / _____ Time(Eastern)	Stopped: _____ / _____ / _____ Time(Eastern)

## \*\*12. RELEASE MAGNITUDE: CURIEL PER SEC. NORMAL OPERATING LIMITS: ABOVE

A- NOBLE GASES 3.93E+00 B- IODINES 4.24E-02

C- IODINE/NOBLE GAS RATIO(If available) D- OTHER \_\_\_\_\_

\*

## \*\*13. ESTIMATE OF PROJECTED OFFSITE DOSE: NEW UNCHANGED ESTIMATED DURATION: 0.50 HRS.

	Wholebody	Child Thyroid		Wholebody	Child Thyroid
DOSE RATE	DOSE RATE		DOSE	DOSE	
Distance	mrem/hr	mrem/hr	mrem	mrem	
Site Boundary	3.50E+01	2.54E+04	9.19E+00	6.34E+03	
2 miles	6.36E+00	4.61E+03	1.65E+00	1.15E+03	
5 miles	2.00E+00	1.45E+03	5.15E-01	3.63E+02	
10 miles	9.53E-01	6.92E+02	2.43E-01	1.73E+02	

## \*\*14. METEOROLOGICAL DATA:

A- WIND DIRECTION(from) 181.0 degrees B- WIND SPEED(mph) 4.2  
C- STABILITY CLASS F D- PRECIPITATION(type) \_\_\_\_\_

## 15. RECOMMENDED PROTECTIVE ACTIONS:

A- NO RECOMMENDED PROTECTIVE ACTIONS

B- EVACUATE \_\_\_\_\_

C- SHELTER IN-PLACE \_\_\_\_\_

D- OTHER \_\_\_\_\_

16. APPROVED BY: \_\_\_\_\_ TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
(Name) (Title) (Eastern) mm dd yy

\* If items 8-14 have not changed, only items 1-7 and 15-16 are required to be completed.

\*\*Information may not be available on initial notifications.

## EMERGENCY NOTIFICATION

11:30

1. THIS IS A(N) DRILL INITIAL FOLLOW-UP\* MESSAGE NUMBER \_\_\_\_\_

2. SITE: McGuire UNIT: 1 REPORTED BY: \_\_\_\_\_

TRANSMITTAL TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ CONFIRMATION PHONE NUMBER: \_\_\_\_\_  
(Eastern) mm dd yy4. AUTHENTICATION: \_\_\_\_\_  
(Number) (Codeword)

## 5. EMERGENCY CLASSIFICATION:

A- NOTIFICATION OF UNUSUAL EVENT B- ALERT C- SITE PGEA EMERGENCY D- GENERAL EMERGENCY

6. A- Emergency Declaration At: B- Termination At: TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ (If B, go to item 15.)  
(Eastern) mm dd yy7. EMERGENCY DESCRIPTION/REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_

8. PLANT CONDITION: A- IMPROVING B- STABLE C- DEGRADING

9. REACTOR STATUS: A- SHUTDOWN: TIME/DATE: 900 10/20/93 B- \_\_\_\_\_ %POWER  
(Eastern) mm dd yy10. EMERGENCY RELEASE(S):  
A- NONE(Go to item 14.) B- POTENTIAL(Go to item 14.) C- IS OCCURRING D- HAS OCCURRED

## \*\*11. TYPE OF RELEASE: GROUND LEVEL

AIRBORNE	Started: _____ / _____ / _____ Time(Eastern)	Stopped: _____ / _____ / _____ Time(Eastern)
B- LIQUID	Started: _____ / _____ / _____ Time(Eastern)	Stopped: _____ / _____ / _____ Time(Eastern)

## \*\*12. RELEASE MAGNITUDE: CURIES PER SEC.

\* NORMAL OPERATING LIMITS: ABOVE

A- NOBLE GASES 2.92E+01 B- IODINES 3.37E-01  
C- IODINE/NOBLE GAS RATIO(If available) \_\_\_\_\_ D- OTHER \_\_\_\_\_

## \*\*13. ESTIMATE OF PROJECTED OFFSITE DOSE: NEW UNCHANGED ESTIMATED DURATION: 0.50 HRS.

	Wholebody	Child Thyroid	Wholebody	Child Thyroid
	DOSE RATE	DOSE RATE	DOSE	DOSE
Distance	mrem/hr	mrem/hr	mrem	mrem
Site Boundary	2.74E+00	2.13E+03	1.14E+00	5.33E+02
2 miles	1.16E-01	8.97E+01	8.73E-02	2.25E+01
5 miles	4.90E-02	3.80E+01	2.66E-02	9.53E+00
10 miles	2.94E-02	2.26E+01	1.25E-02	5.71E+00

## \*\*14. METEOROLOGICAL DATA:

A- WIND DIRECTION(from) 180.0 degrees B- WIND SPKT^(mph) 5.0  
C- STABILITY CLASS A D- PRECIPITATION(type) \_\_\_\_\_

## 15. RECOMMENDED PROTECTIVE ACTIONS:

- A- NO RECOMMENDED PROTECTIVE ACTIONS  
 B- EVACUATE \_\_\_\_\_  
 C- SHELTER IN-PLACE \_\_\_\_\_  
 D- OTHER \_\_\_\_\_

16. APPROVED BY: \_\_\_\_\_ TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
(Name) (Title) (Eastern) mm dd yy

\* If items 8-14 have not changed, only items 1-7 and 15-16 are required to be completed.

\*\*Information may not be available on initial notifications.

## EMERGENCY NOTIFICATION

11:30

1. THIS IS A(N) DRILL INITIAL FOLLOW-UP\* MESSAGE NUMBER \_\_\_\_\_

2. SITE: McGuire UNIT: 1 REPORTED BY: \_\_\_\_\_

TRANSMITTAL TIME/DATE: \_\_\_\_/\_\_\_\_/\_\_\_\_ CONFIRMATION PHONE NUMBER: \_\_\_\_\_  
(Eastern) mm dd yy4. AUTHENTICATION: \_\_\_\_\_  
(Number) (Codeword)

## 5. EMERGENCY CLASSIFICATION:

A- NOTIFICATION OF UNUSUAL EVENT B- ALERT C- SITE AREA EMERGENCY D- GENERAL EMERGENCY

6. A- Emergency Declaration At: B- Termination At: TIME/DATE: \_\_\_\_/\_\_\_\_/\_\_\_\_ (If B, go to item 16.)  
(Eastern) mm dd yy7. EMERGENCY DESCRIPTION/REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_

8. PLANT CONDITION: A- IMPROVING E- STABLE C- DEGRADING

9. REACTOR STATUS: A- SHUTDOWN: TIME/DATE: 900 10/20/93 B- \_\_\_\_\_ %POWER  
(Eastern) mm dd yy

## 10. EMERGENCY RELEASE(S):

A- NONE(Go to item 14.) B- POTENTIAL(Go to item 14.) C- IS OCCURRING D- HAS OCCURRED

## \*\*11. TYPE OF RELEASE: GROUND LEVEL

AIRBORNE	Started: _____	/	/	Stopped: _____	/	/
	Time(Eastern)		Date	Time(Eastern)		Date
B- LIQUID	Started: _____	/	/	Stopped: _____	/	/
	Time(Eastern)		Date	Time(Eastern)		Date

## \*\*12. RELEASE MAGNITUDE: CURIES PER SEC. NORMAL OPERATING LIMITS: ABOVE

A- NOBLE GAS RS 2.92E+01 B- IODINES 3.37E-01

C- IODINE/NOBLE GAS RATIO(IF available) D- OTHER \_\_\_\_\_

## \*\*13. ESTIMATE OF PROJECTED OFFSITE DOSE: NEW UNCHANGED ESTIMATED DURATION: 0.50 HRS.

	Wholebody	Child Thyroid	Wholebody	Child Thyroid
	DOSE RATE	DOSE RATE	DOSE	DOSE
Distance	mrem/hr	mrem/hr	mrem	mrem
Site Boundary	2.74E+00	2.13E+03	1.14E+00	5.33E+02
2 miles	1.16E-01	8.97E+01	8.73E-02	2.25E+01
5 miles	4.90E-02	3.80E+01	2.56E-02	9.53E+00
10 miles	2.94E-02	2.28E+01	1.25E-02	5.71E+00

## \*\*14. METEOROLOGICAL DATA:

A- WIND DIRECTION(from) 180.0 degrees B- WIND SPEED(mph) 5.0  
C- STABILITY CLASS A D- PRECIPITATION(type) \_\_\_\_\_

## 15. RECOMMENDED PROTECTIVE ACTIONS:

- A- NO RECOMMENDED PROTECTIVE ACTIONS
- B- EVACUATE \_\_\_\_\_
- C- SHELTER IN-PLACE \_\_\_\_\_
- D- OTHER \_\_\_\_\_

16. APPROVED BY: \_\_\_\_\_ TIME/DATE: \_\_\_\_\_  
(Name) (Title) (Eastern) mm dd yy

\* If items 8-14 have not changed, only items 1-7 and 15-16 are required to be completed.

\*\*Information may not be available on initial notifications.

## EMERGENCY NOTIFICATION

12:00

1. THIS IS A(N) DRILL INITIAL FOLLOW-UP\* MESSAGE NUMBER \_\_\_\_\_

2. SITE: McGuire UNIT: 1 REPORTED BY: \_\_\_\_\_

TRANSMITTAL TIME/DATE: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ CONFIRMATION PHONE NUMBER: \_\_\_\_\_  
(Eastern) mm dd yy4. AUTHENTICATION: \_\_\_\_\_  
(Number) \_\_\_\_\_ (Codeword)5. EMERGENCY CLASSIFICATION:  
A- NOTIFICATION OF UNUSUAL EVENT B- ALERT C- SITE AREA EMERGENCY D- GENERAL EMERGENCY6. A- Emergency Declaration At: B- Termination At: TIME/DATE: \_\_\_\_ / \_\_\_\_ / \_\_\_\_ (If B, go to item 16.)  
(Eastern) mm dd yy7. EMERGENCY DESCRIPTION/REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_

8. PLANT CONDITION: A- IMPROVING B- STABLE C- DEGRADING

9. REACTOR STATUS: A- SHUTDOWN: TIME/DATE: 900 10/20/93 B- \_\_\_\_ %POWER  
(Eastern) mm dd yy10. EMERGENCY RELEASE(S):  
A- NONE(Go to item 14.) B- POTENTIAL(Go to item 14.) C- IS OCCURRING D- HAS OCCURRED

\*\*11. TYPE OF RELEASE: GROUND LEVEL

AIRBORNE	Started: _____ / ____ / ____ Time(Eastern)	Stopped: _____ / ____ / ____ Time(Eastern)
B- LIQUID	Started: _____ / ____ / ____ Time(Eastern)	Stopped: _____ / ____ / ____ Time(Eastern)

\*\*12. RELEASE MAGNITUDE: CURIES PER SEC. NORMAL OPERATING LIMITS: ABOVE

A- NOBLE GASES 3.09E+01	B- IODINES 4.03E-01
C- IODINE/NOBLE GAS RATIO(If available) _____	D- OTHER _____

\*\*13. ESTIMATE OF PROJECTED OFFSITE DOSE: NEW UNCHANGED ESTIMATED DURATION: 0.50 HRS.

	Wholebody	Child Thyroid	Wholebody	Child Thyroid
DOSE RATE	DOSE RATE	DOSE	DOSE	
Distance	mrem/hr	mrem/hr	mrem	mrem
Site Boundary	3.11E+00	2.72E+03	1.23E+00	6.82E+02
2 miles	1.31E-01	1.15E+02	9.12E-02	2.88E+01
5 miles	5.55E-02	4.86E+01	2.82E-02	1.22E+01
10 miles	3.33E-02	2.92E+01	1.35E-02	7.31E+00

\*\*14. METEOROLOGICAL DATA:

A- WIND DIRECTION(from) 178.0 degrees	B- WIND SPEED(mph) 4.7
C- STABILITY CLASS A	D- PRECIPITATION(type) _____

15. RECOMMENDED PROTECTIVE ACTIONS:

A- NO RECOMMENDED PROTECTIVE ACTIONS	
B- EVACUATE _____	
C- SHELTER IN PLACE _____	
D- OTHER _____	

16. APPROVED BY: \_\_\_\_\_ TIME/DATE: \_\_\_\_\_ / \_\_\_\_ / \_\_\_\_  
(Name) \_\_\_\_\_ (Title) \_\_\_\_\_ (Eastern) mm dd yy

\* If items 8-14 have not changed, only items 1-7 and 15-16 are required to be completed.

\*\*Information may not be available on initial notifications.

## EMERGENCY NOTIFICATION

12:15

1. THIS IS A(N) DRILL INITIAL FOLLOW-UP\* MESSAGE NUMBER \_\_\_\_\_

2. SITE: McGuire UNIT: 1 REPORTED BY: \_\_\_\_\_

ANSMITTAL TIME/DATE: \_\_\_\_/\_\_\_\_/\_\_\_\_ CONFIRMATION PHONE NUMBER: \_\_\_\_\_  
(Eastern) mm dd yy4. AUTHENTICATION: \_\_\_\_\_  
(Number) \_\_\_\_\_ (Codeword)

## 5. EMERGENCY CLASSIFICATION:

A- NOTIFICATION OF UNUSUAL EVENT B- ALERT C- SITE AREA EMERGENCY D- GENERAL EMERGENCY

6. A- Emergency Declaration At: B- Termination At: TIME/DATE: \_\_\_\_/\_\_\_\_/\_\_\_\_ (If B, go to item 16.)  
(Eastern) mm dd yy7. EMERGENCY DESCRIPTION/REMARKS: \_\_\_\_\_  
\_\_\_\_\_

8. PLANT CONDITION: A- IMPROVING B- STABLE C- DEGRADING \*

9. REACTOR STATUS: A- SHUTDOWN: TIME/DATE: 900 10/20/93 B- \_\_\_\_\_ \*POWER  
(Eastern) mm dd yy

## 10. EMERGENCY RELEASE(S):

A- NONE(Go to item 14.) B- POTENTIAL(Go to item 14.) C- IS OCCURRING D- HAS OCCURRED

## \*\*11. TYPE OF RELEASE: GROUND LEVEL

AIRBORNE	Started: _____ / _____ / _____ Time(Eastern)	Stopped: _____ / _____ / _____ Time(Eastern)
B- LIQUID	Started: _____ / _____ / _____ Time(Eastern)	Stopped: _____ / _____ / _____ Time(Eastern)

## \*\*12. RELEASE MAGNITUDE: CURIES PER SEC.

A- NOBLE GASES 3.17E+01 B- IODINES 4.36E-01

C- IODINE/NOBLE GAS RATIO(If available) \_\_\_\_\_ D- OTHER \_\_\_\_\_

## \*\*13. ESTIMATE OF PROJECTED OFFSITE DOSE: NEW UNCHANGED ESTIMATED DURATION: 0.75 HRS.

	Wholebody	Child Thyroid	Wholebody	Child Thyroid
	DOSE RATE	DOSE RATE	DOSE	DOSE
Distance	mrem/hr	mrem/hr	mrem	mrem
site Boundary	2.84E+00	2.63E+03	1.94E+00	1.34E+03
2 miles	1.20E-01	1.11E+02	1.21E-01	5.65E+01
5 miles	5.08E-02	4.70E+01	4.09E-02	2.39E+01
10 miles	3.05E-02	2.82E+01	2.11E-02	1.44E+01

## \*\*14. METEOROLOGICAL DATA:

A- WIND DIRECTION(from) 180.0 degrees B- WIND SPEED(mph) 5.2

C- STABILITY CLASS A D- PRECIPITATION(type) \_\_\_\_\_

## 15. RECOMMENDED PROTECTIVE ACTIONS:

A- NO RECOMMENDED PROTECTIVE ACTIONS \*

B- EVACUATE \_\_\_\_\_

C- SHELTER IN-PLACE \_\_\_\_\_

D- OTHER \_\_\_\_\_

16. APPROVED BY: \_\_\_\_\_ TIME/DATE: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
(Name) (Title) (Eastern) mm dd yy

\* If items 8-14 have not changed, only items 1-7 and 15-16 are required to be completed.

\*\*Information may now be available on initial notifications.

## McGUIRE SYSTEM ABBREVIATIONS

<u>SYSTEM</u>	<u>NAME</u>	
AD	AUXILIARY DIESEL SYSTEM	AUXILIARY DIESEL
AS	AUXILIARY STEAM SYSTEM	AUXILIARY STEAM
BB	STEAM GENERATOR BLOWDOWN RECYCLE SYSTEM	BOILER BLOWDOWN
BW	STEAM GENERATOR WET LAYUP	BOILER WET LAY-UP
CA	AUXILIARY FEEDWATER SYSTEM	CONDENSATE AUXILIARY
CB	HEATING BOILER FEEDWATER SYSTEM	CONDENSATE BOILER
CP	POLISHING DEMINERALIZER SYSTEM	CONDENSATE POLISHING
CF	FEEDWATER SYSTEM	CONDENSATE FEEDWATER
CL	FDWP CONDENSATE SEAL SYSTEM	CONDENSATE LEAKOFF
CM	CONDENSATE SYSTEM	CONDENSATE MAIN
CS	CONDENSATE STORAGE SYSTEM	CONDENSATE STORAGE
CT	CONDENSATE SAMPLING SYSTEM	CONDENSATE TESTING

### ELECTRICAL SYSTEMS

ESA	525KV SYSTEM
EAA	525KV SWITCHYARD PHYSICAL LAYOUT SYSTEM
EAB	525KV SWITCHYARD CABLE SUPPORT SYSTEM
EAC	525KV SWITCHYARD GROUNDING SYSTEM
EAD	525KV SWITCHYARD PROTECTIVE RELAYING SYSTEM
EAE	525KV SWITCHYARD CONTROL SYSTEM
EAF	525KV SWITCHYARD METERING AND MONITORING SYSTEM
EAG	525KV SWITCHYARD FIRE DETECTION/PROTECTION SYSTEM
EAH	525KV SWITCHYARD 125V DC SYSTEM
EAI	525KV SWITCHYARD 480, 208/120VAC SYS.
EAL	525KV SWITCHYARD LIGHTING SYSTEM

### SWITCHYARD AC SYSTEM

ESC	SWITCHYARD 480 VAC SYSTEM
ESD	SWITCHYARD 208/120VAC SYSTEM
ESO	525/230KV COMMON PHYSICAL LAYOUT SYSTEM
EBI	230KV SWITCHYARD 480, 208/120VAC SYSTEM

McGUIRE SYSTEM ABBREVIATIONS

SYSTEM      NAME

SWITCHYARD DC SYSTEM

ESE    SWITCHYARD 125VDC SYSTEM  
EBH    230KV SWITCHYARD 125VDC SYSTEM

SWITCHYARD CABLE SUPPORT SYSTEM

EBB    230KV SWITCHYARD CABLE SUPPORT SYSTEM  
ESB    525/230KV COMMON CABLE SUPPORT SYSTEM  
ESF    SWITCHYARD RELAY HOUSE CABLE SUPPORT SYSTEM (more commonly, ENGINEERED  
       SAFETY FEATURES)  
ESG    SWITCHYARD TRENCH SYSTEM  
ESH    SWITCHYARD CONTROL SYSTEM  
EBA    230KV SWITCHYARD PHYSICAL LAYOUT SYSTEM  
EBD    230KV SWITCHYARD PROTECTIVE RELAYING SYSTEM  
EBC    230KV SWITCHYARD CONTROL SYSTEM

SWITCHYARD FIRE DETECTION/PROTECTION SYSTEM

EBG    230KV SWITCHYARD FIRE DETECTION/PROTECTION SYSTEM  
ESI    SWITCHYARD RELAY HOUSE FIRE DETECTION SYSTEM

SWITCHYARD GROUNDING SYSTEM

EBC    230KV SWITCHYARD GROUNDING SYSTEM  
ESL    SWITCHYARD RELAY HOUSE GROUNDING SYSTEM

SWITCHYARD LIGHTING SYSTEM

EBL    230KV SWITCHYARD LIGHTING SYSTEM  
EBF    230KV SWITCHYARD METERING & MONITORING SYSTEM  
ESR    SWITCHYARD MICROWAVE SYSTEM

SWITCHYARD MONITORING SYSTEM

EST    SWITCHYARD SUPERVISORY SYSTEM  
ESV    SWITCHYARD EVENT RECORDER SYSTEM

McGUIRE SYSTEM ABBREVIATIONS

SYSTEM      NAME

ESY SWITCHYARD SECURITY SYSTEM  
ERE UNIT MAIN POWER SYSTEM CONTROL SYSTEM  
EEU UNIT GENERATOR VOLTAGE SYSTEM

AUXILIARY POWER SYSTEM

EPA UNIT MAIN POWER SYSTEM (24KV)  
EPB 6.9KV NORMAL AUXILIARY POWER SYSTEM  
EPC 4.16KV ESSENTIAL AUXILIARY POWER SYSTEM  
EPD 600VAC NORMAL AUXILIARY POWER SYSTEM  
EPE 600VAC ESSENTIAL AUXILIARY POWER SYSTEM  
EPF 240/120 VAC AUXILIARY CONTROL POWER SYSTEM  
EPG 240/120 VAC VITAL INSTRUMENTATION & CONTROL POWER SYSTEM  
EPH 208/120 VAC NORMAL AUXILIARY POWER SYSTEM  
EPI 208/120 VAC ESSENTIAL AUXILIARY POWER SYSTEM  
EPJ 250VDC AUXILIARY POWER SYSTEM  
EPK 125VDC AUXILIARY CONTROL POWER SYSTEM  
EPL 125VDC VITAL INSTRUMENT & CONTROL POWER SYSTEM  
EPM 13.8KV NORMAL AUXILIARY POWER SYSTEM  
EPR 240/120VAC NORMAL AUX POWER SYSTEM  
EPQ 125VDC CLASS 1E (ESSENTIAL) DIESEL AUX. POWER SYSTEM  
EPT 24VDC AUXILIARY POWER SYSTEM  
ETE 208/120VAC BLACKOUT AUXILIARY POWER SYSTEM  
ETK 6.9KV BLACKOUT AUXILIARY POWER SYSTEM  
ETL 600/208/120VAC STANDBY SHUTDOWN FACILITY AUXILIARY POWER SYSTEM  
ETM 250VDC/125VDC STANDBY SHUTDOWN FACILITY AUXILIARY POWER SYSTEM

LIGHTING SYSTEM

EHM HYDROGEN MITIGATION SYSTEM  
ELN NORMAL LIGHTING SYSTEM  
ELA EMERGENCY LIGHTING SYSTEM (AC)  
ELD EMERGENCY LIGHTING SYSTEM (DC)

McGUIRE SYSTEM ABBREVIATIONS

SYSTEM      NAME

EHT      TRACE HEATING SYSTEM

PLANT GROUNDING SYSTEM

EVA      STATION GROUNDING SYSTEM

EVB      INSTRUMENT GROUNDING SYSTEM

EVC      COMPUTER GROUNDING SYSTEM

COMMUNICATION SYSTEM

ECB      NORMAL COMMUNICATION SYSTEM (BELL)

ECI      INTERPLANT TELEPHONE SYSTEM

ECP      PUBLIC ADDRESS SYSTEM

ECM      MICROWAVE SYSTEM (INTERFACED WITH INTERPLANT TELEPHONE SYSTEM)

ECD      MICROWAVE (DISPATCH) SYSTEM

ECF      INTERCOMMUNICATION SYSTEM (ADMINISTRATION BUILDING)

ECG      FUEL HANDLING INTERCOM. SYS. (SOUND POWERED TELEPHONE)

ECH      TEST DEPARTMENT INTERCOM. SYS. (SOUND POWERED TELEPHONE)

ECE      COMMUNICATION SYSTEM (EMERGENCY)

ECS      ELECTRICAL - SUPPORT COMPUTERS

ERA      TRANSFORMER STATION PHYSICAL LAYOUT SYSTEM

ERB      TRANSFORMER STATION CABLE SUPPORT SYSTEM

ERC      TRANSFORMER STATION GROUNDING SYSTEM

ERF      UNIT MAIN POWER SYSTEM METERING AND MONITORING SYSTEM

PLANT MONITORING SYSTEM

EMA      ANNUNCIATOR ALARM SYSTEM (STATION/AREA)

EMB      ANNUNCIATOR ALARM SYSTEM (UNIT)

EMC      EVENT RECORDER SYSTEM (PLANT)

EMD      LOOSE PARTS MONITORING SYSTEM (UNIT)

EME      POWER MONITORING SYSTEM (REACTOR COOLANT PUMPS)

EMF      RADIATION MONITORING SYSTEM (UNIT)

EMG      RECORDER SYSTEM

McGUIRE SYSTEM ABBREVIATIONS

SYSTEM      NAME

EMH VIBRATION MONITORING SYS. (REACTOR COOLANT PUMPS)  
EMI VIBRATION MONITORING SYS. (OTHER THAN R.C.P.'s)  
EMJ CLOSED CIRCUIT TELEVISION MONITORING SYSTEM  
EMK EVACUATION ALARM SYSTEM  
EMT CLASS 1E TEMPERATURE MONITORING-SYSTEM EQUIPMENT AREA  
EWM WATER HAMMER MONITORING SYSTEM (WEST.)

PROTECTIVE RELAYING SYSTEM

ERD UNIT MAIN POWER SYSTEM PROTECTIVE RELAYING SYSTEM  
ERN CLASS 1E DIESEL PROTECTIVE RELAYING AND METERING SYSTEM

PLANT CABLE SUPPORT SYSTEM

EWA CABLE SUPPORT SYSTEM  
EWB EQUIPMENT ROOM CABLE SUPPORT SYSTEM  
EWC GENERAL PLANT CABLE SUPPORT SYSTEM  
EOA MAIN CONTROL ROOM BOARD SYSTEM  
EOB HVAC CONTROL PANEL  
EOC SAFE SHUTDOWN CONTROL PANEL SYSTEM  
EZA ELECTRICAL PENETRATIONS  
EDA CONTROL ROD DRIVE POSITION INDICATION SYSTEM

COORDINATED PROCESS CONTROL SYSTEM

EIA NSS PROCESS INSTRUMENTATION & CONTROL SYSTEM - NUCLEAR  
EIB BALANCE OF PLANT PROCESS INSTRUMENTATION AND CONTROL SYSTEM  
EQA DIESEL GENERATOR  
EQB DIESEL LOAD SEQUENCING SYSTEM  
EQC DIESEL CONTROL SYSTEM  
EQD SAFE SHUTDOWN DIESEL CONTROL SYSTEM  
EKA DISPATCH CONTROL SYSTEM  
EEA ENVIRONMENTAL INSTRUMENTATION SYSTEM  
EFA FIRE DETECTION SYSTEM

McGUIRE SYSTEM ABBREVIATIONS

SYSTEM      NAME

EGA GENERATOR COOLING SYSTEM  
EGB GENERATOR EXCITATION SYSTEM  
EGC GENERATOR INSTRUMENT INSTRUMENTATION & CONTROL SYSTEM  
EEB METEOROLOGICAL INSTRUMENTATION SYSTEM  
EET VITAL EQUIPMENT AREA TEMPERATURE MONITORING SYSTEM

NUCLEAR INSTRUMENTATION SYSTEM

ENA IN-CORE INSTRUMENTATION SYSTEM  
ENB OUT-OF-CORE INSTRUMENTATION SYSTEM  
ENC WIDE RANGE NEUTRON FLUX SYSTEM  
EXA PLANT SECURITY SYSTEM  
EXH ELECTRICALLY OPERATED CRANES & HOISTS  
EXS MISCELLANEOUS ELECTRICAL  
EYA TEST SYSTEMS - ELECTRICAL  
EUC CATHODIC PROTECTION SYSTEM

FUEL HANDLING SYSTEM

FB	HEATING BOILER FUEL GAS SYSTEM (OIL LIGHTING)	FUEL BOILER
FC	NUCLEAR FUEL HANDLING SYSTEM	FUEL CARRYING
FD	DIESEL GENERATOR ENGINE FUEL OIL SYSTEM	FUEL DIESEL
FG	UNLEADED GAS FOR VEHICLES	FUEL UNLEADED GAS
FS	AUXILIARY FUEL OIL SYSTEM	FUEL SECONDARY
FW	REFUELING WATER SYSTEM	FUELING WATER

COMPRESSED GAS SYSTEM

GB	HYDROGEN BLANKET SYSTEM	GAS BLANKET
GH	GENERATOR HYDROGEN SYSTEM	GAS HYDROGEN
GL	LABORATORY LP GAS SYSTEM	GAS LABORATORY
GN	NITROGEN SYSTEM	GAS NITROGEN
GO	OXYGEN SYSTEM	GAS OXYGEN
GP	CO <sub>2</sub> GENERATOR PURGE SYSTEM	GAS PURGE

McGUIRE SYSTEM ABBREVIATIONS

SYSTEM      NAME

GS      HYDROGEN BULK STORAGE SYSTEM      GAS STORAGE

HEATER SYSTEM

HA	BLEED STEAM TO "A" HEATERS	HEATER "A"
HB	BLEED STEAM TO "B" HEATERS	HEATER "B"
HC	BLEED STEAM TO "C" HEATERS	HEATER "C"
HD	BLEED STEAM TO "D" HEATERS	HEATER "D"
HE	BLEED STEAM TO "E" HEATERS	HEATER "E"
HF	BLEED STEAM TO "F" HEATERS	HEATER "F"
HG	BLEED STEAM TO "G" HEATERS	HEATER "G"
HM	MOISTURE SEPARATOR-REHEATER BLEED SYSTEM	HEATER MOISTURE-SEPARATOR
HR	HEATER RELIEF VALVE SYSTEM	HEATER RELIEF
HS	MOISTURE SEPARATOR-REHEATER DRAIN SYSTEM	HEATER MOISTURE-SEPARATOR
HV	HEATER VENT SYSTEM	HEATER VENT
HW	HEATER DRAIN SYSTEM	HEATER DRAIN WATER

INSTRUMENTATION & CONTROL ELECTRO-MECHANICAL SYSTEMS

IAE	CONTAINMENT PERSONNEL AIR LOCK SYSTEM	INSTRUMENTATION AIR LOCK
ICE	CONTAINMENT LEAK TESTING SYSTEM	INSTRUMENTATION CONTAINMENT
IDE	STEAM DUMP CONTROL SYSTEM	INSTRUMENTATION DUMP
IEE	SEISMIC (EARTHQUAKE) MONITORING SYSTEM	INSTRUMENTATION EARTHQUAKE
IFE	FEEDWATER CONTROL SYSTEM	INSTRUMENTATION FEEDWATER
IKE	OPERATOR AID COMPUTER SYSTEM	INSTRUMENTATION COMPUTER
ILE	PRESSURIZER PRESSURE & LEVEL CONTROL SYSTEM	INSTRUMENTATION LEVEL
INE	AUXILIARY SHUTDOWN SYSTEM	
IPE	REACTOR PROTECTION SYSTEM	INSTRUMENTATION PROTECTION
IRE	ROD CONTROL SYSTEM	INSTRUMENTATION ROD
ISE	ENGINEERED SAFETY FEATURES ACTUATION SYSTEM	INSTRUMENTATION SAFETY
ITE	MAIN TURBINE INSTRUMENTATION AND CONTROL SYSTEM & SUPERVISORY SYSTEM	INSTRUMENTATION TURBINE
IWE	FEEDWATER PUMP TURBINE SUPERVISORY SYSTEM	INSTRUMENTATION FEEDWATER

McGUIRE SYSTEM ABBREVIATIONS

SYSTEM      NAME

COOLING RECIRCULATED

KC	COMPONENT COOLING SYSTEM	COOLING COMPONENT
KD	DIESEL GENERATOR ENGINE COOLING WATER SYSTEM	COOLING DIESEL
KF	SPENT FUEL COOLING SYSTEM	COOLING FUEL
KG	GENERATOR STATOR COOLING WATER SYSTEM	COOLING GENERATOR
KR	RECIRCULATED COOLING WATER SYSTEM	COOLING RECIRCULATED

HYDRAULIC & LUBRICATING OIL SYSTEMS

LC	CIRCUIT BREAKER TRANSFER OIL SYSTEM	LUBE CIRCUIT BREAKER
LD	DIESEL GENERATOR ENGINE LUBE OIL SYSTEM (CLASS 1E)	LUBE DRAFT FAN (DIESEL)
LE	TRANSFORMER TRANSFER OIL SYSTEM	LUBE ELECTRICAL
LF	FWP TURBINE LUBE OIL SYSTEM	LUBE FEED PUMP
LG	GENERATOR SEAL OIL SYSTEM (IRON HORSE)	LUBE GENERATOR
LH	MAIN TURBINE HYDRAULIC OIL SYSTEM	LUBE HYDRAULIC
LP	FWP TURBINE HYDRAULIC OIL SYSTEM	LUBE PUMP
LT	MAIN TURBINE LUBE OIL AND PURIFICATION SYSTEM	LUBE TURBINE

MISCELLANEOUS SYSTEMS

MD	MISCELLANEOUS DRAINS & VENTS	MISCELLANEOUS DRAINS
ME	MISCELLANEOUS EMBEDDED PIPING	MISCELLANEOUS EMBEDDED
MF	MISCELLANEOUS FIELD ROUTED PIPING	MISCELLANEOUS FIELD
MH	MECHANICALLY OPERATED HOISTS	MECHANICAL HOISTS
MI	MISCELLANEOUS STATION INSTRUMENTATION	MISCELLANEOUS INST.
MR	MISCELLANEOUS SAFETY & RELIEF VALVE DISCHARGE	MISCELLANEOUS RELIEF
MT	MISCELLANEOUS TRANSFERS	MISCELLANEOUS TRANSFERS
MV	MISCELLANEOUS VALVES	MISCELLANEOUS VALVES

REACTOR SUPPORT & NUCLEAR ASSOCIATED SYSTEMS

NB	BORON RECYCLE SYSTEM	NUCLEAR BORON RECYCLE
NC	REACTOR COOLANT SYSTEM	NUCLEAR COOLANT

McGUIRE SYSTEM ABBREVIATIONS

SYSTEM      NAME

ND	RESIDUAL HEAT REMOVAL	NUCLEAR DECAY HEAT REMOVAL
NF	ICE CONDENSER REFRIGERATION SYSTEM	NUCLEAR ICE CONDENSER
NI	SAFETY INJECTION SYSTEM	NUCLEAR INJECTION
NM	NUCLEAR SAMPLING SYSTEM	NUCLEAR MONITORING
NR	BORON THERMAL REGENERATION	NUCLEAR REGENERATION
NS	CONTAINMENT SPRAY SYSTEM	NUCLEAR SPRAY
NV	CHEMICAL & VOLUME CONTROL SYSTEM	NUCLEAR VOLUME CONTROL

RAW WATER SYSTEMS

RA	CONDENSER CLEANING SYSTEM	RAW WATER AMERTAP
RC	CONDENSER CIRCULATING WATER SYSTEMS (INCLUDES RAW WATER CONDENSER LOW LEVEL INTAKE COOLING WATER)	
RF	FIRE PROTECTION SYSTEM	RAW WATER FIRE
RL	CONVENTIONAL LOW PRESSURE SERVICE WATER SYS.	RAW WATER LOW PRESSURE
RN	NUCLEAR SERVICE WATER SYSTEM	RAW WATER NUCLEAR
RQ	ENVIRONMENTAL WATER QUALITY MONITORING SYS.	RAW WATER QUALITY
RS	CCW INTAKE SCREEN BACKWASH SYSTEM	RAW WATER SCREEN
RV	CONTAINMENT VENTILATION COOLING WATER SYSTEM	RAW WATER VENTILATION
RY	EXTERIOR FIRE PROTECTION SYSTEM	RAW WATER YARD

STEAM LEAD SYSTEM

SM	MAIN STEAM	STEAM MAIN
SP	MAIN STEAM SUPPLY TO FDWP TURBINE	STEAM PUMP TURBINE
SV	MAIN STEAM VENT TO ATMOSPHERE	STEAM VENT
SW	SEAL WATER SYSTEM	SEAL WATER

TURBINE CYCLE SERVICES SYSTEM

TE	TURBINE EXHAUST	TURBINE EXHAUST
TF	FDWP TURBINE STEAM SEAL SYSTEM	TURBINE FEED PUMP
TL	MAIN TURBINE LEAKOFF & STEAM SEAL SYSTEM	TURBINE LEAKOFFS

McGUIRE SYSTEM ABBREVIATIONS

SYSTEM      NAME

VENTILATION & COMPRESSED AIR SYSTEMS

VA	AUX BLDG VENTILATION SYSTEM	VENTILATION AUX BLDG
VB	BREATHING AIR SYSTEM	VENTILATION BREATHING AIR
VC	CONTROL AREA HVAC SYSTEM	VENTILATION CONTROL AREA
VD	DIESEL BUILDING VENTILATION SYSTEM	VENTILATION DIESEL
VE	ANNULUS VENTILATION SYSTEM	VENTILATION EVACUATION
VF	FUEL POOL VENTILATION SYSTEM	VENTILATION FUEL POOL
VG	DIESEL GENERATOR ENGINE STARTING AIR SYSTEM	VENTILATION DIESEL GENERATOR
VH	TECHNICAL SUPPORT CENTER VENTILATION SYSTEM	VENTILATION HOT MACHINE SHOP
VI	INSTRUMENT AIR SYSTEM	VENTILATION INSTRUMENT AIR
VS	STATION AIR SYSTEM	VENTILATION STATION AIR

WASTE REMOVAL SYSTEM

WC	CONVENTIONAL WASTE WATER TREATMENT	WASTE WATER TREATMENT
WD	ROOF DRAINS	WASTE ROOF DRAINS
WE	EQUIPMENT DECONTAMINATION SYSTEM	WASTE EQUIPMENT
WF	FLOOR DRAIN AND EQUIPMENT DRAINS SYSTEM	WASTE FLOOR DRAINS
WG	GASEOUS WASTE MANAGEMENT SYSTEM	WASTE GAS
WL	LIQUID WASTE RECYCLE SYSTEM	WASTE LIQUID
WM	LIQUID WASTE MONITOR & DISPOSAL SYSTEM	WASTE MONITORING
WN	DIESEL GENERATOR ROOM SUMP PUMP SYSTEM	WASTE DIESEL GENERATOR
WO	WASTE OIL SYSTEM	WASTE OIL
WP	TURBINE ROOM SUMP PUMP SYSTEM	WASTE POWERHOUSE
WS	NUCLEAR SOLID WASTE DISPOSAL SYSTEM	WASTE SOLID
WT	SANITATION AND WASTE TREATMENT SYSTEM (PLUMBING)	WASTE TREATMENT
WU	UNWATERING SYSTEM	WASTE UNWATERING
WY	YARD DRAINS	WASTE YARD
WZ	GROUNDWATER DRAINAGE SYSTEM	WASTE Z

McGUIRE SYSTEM ABBREVIATIONS

SYSTEM      NAME

TREATED WATER SYSTEMS

YA	CONVENTIONAL CHEMICAL ADDITION SYSTEM	Y ADDITION
YC	CHILLED WATER SYSTEM	Y CHILLED
YD	DRINKING WATER SYSTEM	Y DRINKING
YF	FILTERED WATER SYSTEM	Y FILTERED
YH	HEATING WATER SYSTEM	Y HEATING
YM	MAKEUP DEMINERALIZER WATER SYSTEM	Y MAKEUP

VACUUM SYSTEMS

ZD	DIESEL GENERATOR ENGINE CRANKCASE VACUUM SYS.	Z DIESEL
ZJ	CONDENSER STEAM AIR EJECTOR SYSTEM	Z EJECTOR
ZM	MAIN VACUUM SYSTEM	Z MAIN
ZP	VACUUM PRIMING SYSTEM	Z PRIMING

CONFIDENTIAL

McGUIRE NUCLEAR STATION  
ANNUAL EXERCISE  
MEDICAL DRILL  
OCTOBER 20, 1993

The annual Emergency Medical Drill will be conducted on October 20, 1993 at approximately 6:45 A.M. as part of the Annual Exercise Scenario. The purpose of the drill is to evaluate the McGuire Nuclear Station's Medical Emergency Response Team (MERT), the local Emergency Medical Services (Mecklenburg County Emergency Medical Service ( MEDIC and North Meck Rescue ) and the Carolina's Medical Center. These organizations support McGuire during contaminated medical emergencies.

OBJECTIVES

The objectives of the drill are to:

- Evaluate the readiness of the station's MERT Team
- Assess the coordination between the MERT team, Radiation Protection and the Operations groups.
- Provide adequate pre-hospital emergency medical treatment and care of injured contaminated personnel.
- Test the effectiveness of Emergency Medical Services (EMS) in handling and transporting contaminated individuals.
- Evaluate the ability of the Carolina's Medical Center staff to prepare for and receive contaminated injuries.

OVERVIEW

The station groups that have involvement in the drill are Operations, Radiation Protection and Security. Operations has the responsibility for informing the Emergency Coordinator of the incident. Security personnel (MERT) will be responsible for initial victim assessment (including the need for off-site personnel) and primary treatment since this drill is mainly to determine the ability of off-site Emergency Medical System personnel to handle and transport contaminated injuries.

Radiation protection and contamination control measures will be handled by station Radiation Protection personnel. Radiation Protection personnel will accompany EMS personnel to the hospital for radiation control at that location. Security personnel shall follow security procedures for Emergency Medical Service personnel

CONFIDENTIAL

access to the McGuire Protected Area. All on scene drill related activities will stop and time will be on hold during the time it takes for Emergency Medical Service personnel to be processed for on site activities.

Victims will be stabilized on site and transported to Carolina's Medical Center for further care.

PREDICTED RESPONSE

- MERT Team Arrival Activities
  - Triage
  - Initial patient assessment
  - Medical treatment
- Notification Process
  - Radiation Protection Group
  - Operations Group
  - EMS
- Stabilize and package injured individuals
- Effective patient turnover to EMS personnel
- Transport to Carolina's Medical Center

SCENARIO

INITIAL CONDITION:

Two (2) employees were working on the Auxiliary Building 760' elevation, in the Waste Shipping Area, packaging waste.

The work area is in a RCZ, so both employees are wearing Anti-C's. The radiation level in the general area is 3mr/HR Beta-Gamma. The surface removable contamination level on the floor is 5300 dpm/cmsq.

Employee "A" is standing on the floor level operating a banding tool.

Employee "B" is standing on the third (3rd) rung of a ladder making sure the band is straight.

As Employee "A" tightens the band around the crate, the band breaks striking Employee "B". When struck by the broken band, Employee "B" trying to avoid the band causes the ladder to fall and causes the ladder to land on top of Employee "A".

CONFIDENTIAL

INJURIES

Employee "A": Complaining of pain and bruising of the left leg in the area of the shin.

Employee "B" Has a laceration to the inside of the right thigh and an open fracture of the left arm.

VITAL SIGNS

EMPLOYEE "A" (UPON ARRIVAL OF MERT)

PULSE -----	ACTUAL
RESPIRATIONS -----	ACTUAL
BLOOD PRESSURE -----	ACTUAL
PUPILS -----	ACTUAL
LEVEL OF CONSCIOUSNESS -----	ACTUAL
NEUROLOGICAL FUNCTION -----	PAIN UPON MOVEMENT OF LEG
DISTAL PULSE ON LEFT LEG -----	PRESENT

EMPLOYEE "B" (UPON ARRIVAL OF MERT)

PULSE -----	ACTUAL
RESPIRATIONS -----	ACTUAL
BLOOD PRESSURE -----	ACTUAL
PUPILS -----	ACTUAL
LEVEL OF CONSCIOUSNESS -----	ACTUAL
NEUROLOGICAL FUNCTION -----	PAIN UPON MOVEMENT OF ARM
DISTAL PULSE ON LEFT ARM -----	PRESENT

Employee "A": Patient condition and vital signs remain actual throughout the event.

Employee "B": Patient condition will remain stable as time passes. The controller/evaluator will be allowed to interject vital signs if necessary to indicate a worsening condition. The vital signs will be given only when actually monitored by medical responders.

CONFIDENTIAL

CONTAMINATION LEVEL

Employee "A":

Left Arm at Elbow ----- 500 CCPM  
Clothing ----- 900 CCPM

When clothing is removed and the arm is decontaminated the patient will be transported as a non-contaminated patient.

Employee "B":

Left arm at fracture ----- 600 CCPM  
After 1st decon ----- 450 CCPM  
After 2nd decon ----- Background  
Clothing ----- 850 CCPM

NOTE

- The only personnel allowed to question or speak to emergency responders are the drill controllers and evaluators. This will assist in reducing the confusion of the drill participants at the accident scene.
- Vital signs may be changed by controllers to reflect changes in the victims condition.
- The Safety and Health Services Section shall provide the drill controllers at the station. A Nuclear Generation Department Emergency Planning Consultant will serve as the controller/evaluator at Carolina's Medical Center.

CONFIDENTIAL

McGuire Nuclear Station  
Annual Exercise  
Fire Drill  
October 20, 1993

The annual Fire Drill will be conducted on October 20, 1993 during and as part of the Annual Exercise. The purpose of the drill is to evaluate the McGuire Nuclear Station Fire Brigade, Gilead and Cornelius Fire Departments. These organizations support McGuire during a fire emergency.

OBJECTIVES

The overall objective of the drill is to evaluate the capability of the offsite fire agencies (Gilead and Cornelius Fire Departments) utilizing a simulated fire emergency at the McGuire Site.

Specific objectives are:

- Test the resources for all organizations available for a fire emergency response at the site.
- Reflect response times of these resources.
- Evaluate the interface between site representatives and responding offsite fire agencies and the ability to work together.
- Point out any future training needs.

INITIAL CONDITIONS

The location of the drill will be the McGuire Central Waste Storage Facility, located inside the Protected Area Fence east of the Unit Two (2) Turbine Building.

The fire will be simulated burning of hazardous materials and hazardous waste. The smoke will be created by a non-toxic chemical smoke generator.

A fire involving this type material will require a response from the offsite fire agencies because of the type and quantity of materials and the limited personnel available.

Normal access to the station through the Vehicle Access Portal (VAP) will be blocked preventing normal access to the fire scene.

CONFIDENTIAL

SEQUENCE OF EVENTS

The fire is discovered and reported to the Simulator Control Room by an employee in the Environmental Management trailer. The Simulator Control Room will notify Mecklenburg County and the McGuire Technical Support Center.

The Operations Support Center Should dispatch the Station Fire Brigade or at the minimum a Fire Brigade leader to the scene for initial fire suppression and/or to interface with the offsite fire agencies.

Offsite fire agencies (Gilead and Cornelius Fire Departments) should respond with appropriate personnel and equipment.

The drill will be terminated when the offsite agencies have connected to the McGuire fire hydrant system and charged an attack line, donned protective clothing and advanced to extinguish the fire.

OVERVIEW

A station Fire Brigade Leader and the offsite fire agencies will be the primary players in the drill. The Fire Protection Unit of the Safety and Health Services Section will serve as controllers and evaluators.

The Simulator Control Room will have the responsibility of notifying the offsite fire agencies. The station Fire Brigade Leader will have overall control of the site fire suppression operations and serve as Incident Commander to offsite responding agencies.

NOTE

The ability and technique of the offsite agencies to suppress a fire is not being tested. The objective is to verify a timely response with the proper equipment and personnel and verify communications between the Station Fire Brigade Leader and the offsite agency.