



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555-0001

POWER AUTHORITY OF THE STATE OF NEW YORK

DOCKET NO. 50-333

JAMES A. FITZPATRICK NUCLEAR POWER PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 208  
License No. DPR-5:

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Power Authority of the State of New York (the licensee) dated January 11, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-59 is hereby amended to read as follows:

9403250181 940318  
PDR ADOCK 05000333  
P PDR

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 208, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

*Robert A. Capra*

Robert A. Capra, Director  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: March 18, 1994

ATTACHMENT TO LICENSE AMENDMENT NO. 208

FACILITY OPERATING LICENSE NO. DPR-59

DOCKET NO. 50-333

Revise Appendix A as follows:

Remove Page  
174

Insert Page  
174

JAFNPP

4.7 (cont'd)

(5) Type C test.

Type C tests shall be performed during each reactor shutdown for refueling but in no case at intervals greater than two years. \*\*

(6) Other leak rate tests specified in Section 4.7.d shall be performed during each reactor shutdown for refueling but in no case at intervals greater than two years.

f. Containment modification\*

Any major modification, replacement of a component which is part of the primary reactor containment boundary, or resealing a seal-welded door, performed after the preoperational leakage rate test shall be followed by either a Type A, Type B, or Type C test, as applicable, for the area affected by the modification. The measured leakage from this test shall be included in the test report. The acceptance criteria as appropriate, shall be met. Minor modifications, replacements, or resealing of seal-welded doors, performed directly prior to the conduct of a scheduled Type A test do not require a separate test.

\* In accordance with an exemption from 10 CFR 50 Appendix J, a Type A, B, or C test is not required for the replacement of piping and welds which constitute the Core Spray System minimum flow lines (3"-W23-152-7A, B) during the 1993 maintenance outage.

\*\* In accordance with an exemption from 10 CFR 50 Appendix J, the Type C test of the shutdown cooling isolation valves (10MOV-17 and 10MOV-18) may be deferred until refueling outage Reload 11/ Cycle 12.