



**GPU Nuclear Corporation**  
Post Office Box 480  
Route 441 South  
Middletown, Pennsylvania 17057  
717 944-7621  
TELEX 84-2386  
Writer's Direct Dial Number:

February 9, 1983  
5211-83-037

Office of Nuclear Reactor Regulation  
Attn: John F. Stolz  
Operating Reactors Branch No. 4  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Sir:

Three Mile Island Nuclear Station, Unit 1 (TMI-1)  
Operating License No. DPR-50  
Docket No. 50-289  
Status of TMI-1 Technical Specification Change Requests (TSCR)

Attached is a table that indicates the status of the TSCR's that are pending action (i.e. submitted by GPUN but not approved by NRC). This table is provided to facilitate our mutual understanding of the status of each change so that appropriate action can be taken as needed.

You should specifically note that by this letter, GPUN is withdrawing several TSCR's. Also it should be noted that five of our pending TSCR's are needed for restart.

Sincerely,

H. D. Hukill  
Director, TMI-1

HDH:CWS:vjf  
Attachment  
cc: R. Conte  
J. Van Vliet

8302150368 830209  
PDR ADDCK 05000289  
P PDR

*Aool*

OUTSTANDING TSCR's

<u>TSCR #</u>	<u>Subject</u>	<u>Action</u>
26	MPC <sub>w</sub> to Xenon	Withdrawn
38	Fuel Cask Drop	NRC Approval Requested
42	RCS Leakage Interpretation	Withdrawn
66	Relief Valve Capacity	Withdrawn
78	Station ETS	Withdrawn
81	STS Conversion	Withdrawn
82	Small Break LOCA Procedures	Withdrawn
83	Fire Protection	Withdrawn (See TSCR 97)
94	OTSG Tube Inspection	Withdrawn
95/95A	Definition of Operable	Withdrawn
96	Fire Barriers	Withdrawn (See TSCR 97)
97	Fire Protection	NRC approval requested
99	Administrative Changes	NRC Approval Requested
100A	TS Appendix B changes	Withdrawn by TSCR 118
104	RV Surveillance Capsule Utilization Factor	GPUN to further revise to reflect the extended TMI-1 shutdown
105	Snubber Surveillance	NRC Approval Requested
107	RB Spray System	NRC Approval Needed for <u>Restart</u>
108	Natural Circulation Testing	NRC Approval Needed for <u>Restart</u>
109	H <sub>2</sub> Recombiner	NRC Approval Requested
113	Appendix J Testing	NRC Approval Requested
114	High Range Radiation Monitors	NRC Approval Requested
116	RB Purge Valve Testing*	GPUN to further revise pending NRC approval of GPUN Proposal on Purging (5211-82-307)
118	Deletion of Appendix B	NRC approval was requested by 12/1/82
119	Aircraft Movement Reporting	NRC Approval Requested
120	ES Bypass Setpoint	NRC Approval Needed for <u>Restart</u>
121	Waste Gas System Monitoring/Limits	NRC Approval Requested by 3/15/83
122	Audit Frequency Changes	NRC Approval Requested
123	SG Tube Repair Admin. Change	NRC Approval Required for <u>Heatup</u>

\*The portion of TSCR No. 116 which permits reduced reactor building purge exhaust flow rate and testing frequency to accommodate 30° purge valve opening limitation needs NRC approval for Restart.