



PECO ENERGY

PECO Energy Company
Nuclear Group Headquarters
965 Chesterbrook Boulevard
Wayne, PA 19087-5891

March 18, 1994

Docket No. 50-277
License No DPR-44

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: Peach Bottom Atomic Power Station, Unit 2
Issuance of the Core Operating Limits Report
for Reload 9, Cycle 10 (Rev. 2)

Dear Sir:

Enclosed is a copy of the Core Operating Limits Report (COLR) for Peach Bottom Atomic Power Station (PBAPS), Unit 2, Reload 9, Cycle 10 (Rev. 2).

This report provides the cycle-specific parameter limits for: Maximum Average Planar Linear Heat Generation Rate (MAPLHGR); Minimum Critical Power Ratio (MCPD); Flow Adjustment Factor (K_f) Linear Heat Generation Rate (LHGR); and Rod Block Monitor (RBM) flow biased upscale setpoints. These values have been determined using NRC-approved methodology and are established such that all applicable limits of the plant safety analysis are met.

This report is being submitted to the NRC in accordance with the PBAPS Unit 2 Technical Specifications Section 6.9.1.e.

If you have any questions concerning this submittal, please contact us.

Sincerely,

G. A. Hunger, Jr., Director
Licensing Section

Enclosure

cc: T. T. Martin, Administrator, Region I, USNRC
W. L. Schmidt, Senior Resident Inspector, USNRC, PBAPS

9403280014 940318
PDR ADOCK 05000277
P PDR

Adol
1/1