

APPENDIX A
NOTICE OF VIOLATION

Florida Power and Light Company
Turkey Point Units 3 & 4

Docket Nos. 50-250 and 50-251
License Nos. DPR-31 and DPR-41

As a result of the inspection conducted on November 29 - December 3, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified.

10 CFR 20.203(b) requires that each radiation area be conspicuously posted with a sign or signs bearing the radiation caution symbol and the words CAUTION - RADIATION AREA. 10 CFR 20.202(b)(2) defines a radiation area as any area accessible to personnel, in which there exist radiation at such levels that a major portion of the body could receive in any one hour a dose in excess of 5 millirem or in any 5 consecutive days a dose in excess of 100 millirem.

Contrary to the above, the requirement to conspicuously post radiation areas was not met in that accessible areas in the auxiliary building, where the radiation levels exceeded 5 millirems per hour, were not posted.

This is a Severity Level V Violation (Supplement IV).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Date: December 22, 1982