

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

LICENSEE CODE: GA E I H 2; LICENSE NUMBER: 00-000000-00; LICENSE TYPE: 41111; CAT 58: 4

REPORT SOURCE: L; DOCKET NUMBER: 05000366; EVENT DATE: 090281; REPORT DATE: 020383

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES: An operator observed that the "A" Post-Accident Monitoring torus water level indicator was reading higher than the "B" indicator. The "A" indicator was declared inoperable and a 30-day LCO initiated as per Tech Specs. 3.3.6.4, ACTION a. Tech. Specs. table 3.3.6.4-1(3) requires both instruments to be operable; the "B" instrument remained operable. The health and safety of the public were not affected by this repetitive event as last reported on LER 50-366/1981-077.

SYSTEM CODE: SB; CAUSE CODE: E; CAUSE SUBCODE: B; COMPONENT CODE: VALVE; COMP. SUBCODE: X; VALVE SUBCODE: X; LER/RO REPORT NUMBER: 81; SEQUENTIAL REPORT NO.: 083; OCCURRENCE CODE: 03; REPORT TYPE: X; REVISION NO.: 1; ACTION TAKEN: A; FUTURE ACTION: Z; EFFECT ON PLANT: Z; SHUTDOWN METHOD: Z; HOURS: 0000; ATTACHMENT SUBMITTED: N; NPRD-4 FORM SUB.: N; PRIME COMP. SUPPLIER: A; COMPONENT MANUFACTURER: D232

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS: The cause of this event was attributed to a leaking equalizing valve which resulted in the draining of the reference leg for the "A" torus water transmitter. The valve stem for the equalizing valve was replaced, and the reference leg was backfilled. The "A" Post-Accident Monitoring torus water level instrument was then returned to normal operable status.

FACILITY STATUS: E; % POWER: 087; OTHER STATUS: NA; METHOD OF DISCOVERY: A; DISCOVERY DESCRIPTION: Operator observation

ACTIVITY CONTENT RELEASED OF RELEASE: Z; AMOUNT OF ACTIVITY: NA; LOCATION OF RELEASE: NA

PERSONNEL EXPOSURES: NUMBER: 000; TYPE: Z; DESCRIPTION: NA

PERSONNEL INJURIES: NUMBER: 000; DESCRIPTION: NA

LOSS OF OR DAMAGE TO FACILITY: TYPE: Z; DESCRIPTION: NA

PUBLICITY ISSUED: N; DESCRIPTION: NA

8302150490 830203 PDR ADOCK 05000366 PDR S

NRC USE ONLY