



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

Serving The Best Location in the Nation

MURRAY R. EDELMAN
VICE PRESIDENT
NUCLEAR

February 8, 1983

PY-CEI/NRR-0014 L

Mr. B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
SER Confirmatory Issue No. 37
Communication Fire Protection Features

Dear Mr. Youngblood:

This letter documents our commitment to provide fire protection features for the portable communication system fixed repeaters.

The emergency/communications repeater and the security repeater are located at the 603'-6" elevation in the Service Building. To ensure that one repeater will be free of fire damage in the event of an exposure fire, the repeaters are separated and a Halon fire suppression system is provided.

This design will be documented in the next revision of the Fire Protection Evaluation Report. If you have any questions, please let me know.

Very truly yours,

Murray R. Edelman
Vice President
Nuclear Group

MRE:kh

cc: Jay Silberg, Esq.
John Stefano
Max Gildner
J. Steng
R. Pender

8302150509 830208
PDR ADOCK 05000440
E PDR