CONTROL BLOCK: [| | | | |] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

036683

Line	Field	Value
0 1	Licensee Code (2)	M E M Y P 1
	License Number (3)	0 0 - 0 0 0 0 0 - 0 0
	License Type (4)	4 1 1 1 1
	CAT (5)	
0 1 (CON'T)	Report Source (6)	L
	Docket Number (7)	0 5 0 0 0 3 0 9
	Event Date (8)	0 3 1 8 8 1
	Report Date (9)	0 4 1 4 8 1

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During conduct of routine quarterly surveillance procedure #3.1.20, SA-A-138,

0 3 the service air isolation to containment failed to operate as required. Redundant

0 4 equipment remained available during the event and there was no effect on public

0 5 health or safety.

0 6

0 7

0 8

Line	System Code (11)	Cause Code (12)	Cause Subcode (13)	Component Code (14)	Comp. Subcode (15)	Valve Subcode (16)
0 9	S D	B	B	V A L V E X	F	H

(17) LER/RO REPORT NUMBER

Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
8 1	—	0 0 2	/	0 3	L	—	0

Action Taken (18)	Future Action (19)	Effect on Plant (20)	Shutdown Method (21)	Hours (22)	Attachment Submitted (23)	NPRD-4 Form Sub. (24)	Prime Comp. Supplier (25)	Component Manufacturer (26)
E	Z	Z	Z	0 0 0 0	N	Y	A	W 0 3 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Failure of the valve to close was caused by inadequate lubrication. A lubrication

1 1 material was applied to the valve linkage and the valve was cycled again and

1 2 operated satisfactorily. No additional action was required.

1 3

1 4

Line	Facility Status (28)	% Power (29)	Other Status (30)	Method of Discovery (31)	Discovery Description (32)
1 5	E	0 9 7	NA	B	Routine Surveillance Testing

Line	Activity Released (33)	Content of Release (34)	Amount of Activity (35)	Location of Release (36)
1 6	Z	Z	NA	NA

PERSONNEL EXPOSURES

Line	Number (37)	Type (38)	Description (39)
1 7	0 0 0	A	NA

PERSONNEL INJURIES

Line	Number (40)	Description (41)
1 8	0 0 0	NA

LOSS OF OR DAMAGE TO FACILITY (43)

Line	Type (42)	Description
1 9	Z	NA

8208260555 810414
PDR ADOCK 05000309
S PDR

PUBLICITY

Line	Issued (44)	Description (45)	NRC USE ONLY
2 0	N		

NAME OF PREPARER James E. Brinkler PHONE: 207-882-6321