

THE CINCINNATI GAS & ELECTRIC COMPANY

WM. H. ZIMMER NUCLEAR POWER STATION, UNIT 1
P.O. BOX 201, MOSCOW, OH 45153



CINCINNATI, OHIO 45201

January 31, 1983
QA-2224

E. A. BORGMANN
SENIOR VICE PRESIDENT

U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Attention: Mr. J. G. Keppler
Regional Administrator

RE: WM. H. ZIMMER NUCLEAR POWER STATION UNIT 1
10CFR50.55(e) ITEM E-35 ELECTRICAL EQUIPMENT
FOUNDATION WELDING DOCKET NO. 50-358
CONSTRUCTION PERMIT NO. CPPR-88, W.O. 57300,
JOB E-5590, FILE NO. NRC-7, E-35

Gentlemen:

This letter constitutes the initial written report concerning the subject condition initially reported to the Commission under the requirements of 10CFR50.55(e) on January 4, 1983 as a potentially reportable deficiency.

Some Electrical Equipment panels have not been mounted as prescribed by the mounting arrangement drawings. This condition has been identified in the control room and switchgear rooms.

Henry J. Kaiser and Cincinnati Gas & Electric are evaluating the panel mounting welds to imbed plates and the as-built mounting arrangements. All other electrical equipment panels are being examined to identify if additional panels do not conform to the mounting requirements. To date, ten (10) panels have been identified that are not in conformance with design requirements. Each panel not found in conformance with the design requirements is being documented on nonconformance reports for evaluation or rework as required. Examination of all panels is expected to be completed by March 31, 1983, at which time a final report will be submitted.

(Continued)

8302150529 830131
PDR ADOCK 05000358
S PDR

1427


FEB 7 1983

Mr. J. G. Keppler
QA-2224
January 31, 1983
Page 3

We trust the above will be found acceptable as an interim report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By 

E. A. BORGMANN
SENIOR VICE PRESIDENT

GNW:jas
cc: NRC Office of Inspection and Enforcement
Washington, D.C. 20555
NRC Senior Resident Inspector
Attn: W. F. Christianson
Zimmer Project Inspector
Region III